



National Load Despatch Centre
राष्ट्रीय भार प्रेषण केंद्र
GRID CONTROLLER OF INDIA LIMITED
ग्रिड कंट्रोलर ऑफ इंडिया लिमिटेड

(Government of India Enterprise/ भारत सरकार का उद्यम)
B-9, QUTUB INSTITUTIONAL AREA, KATWARIA SARAI, NEW DELHI -110016
बी-9, कुतुब इन्स्टीट्यूशनल एरिया, कटवारिया सराये, न्यू दिल्ली-110016

Ref: POSOCO/NLDC/SO/Daily PSP Report

दिनांक: 07.08.2024

To,

- कार्यकारी निदेशक, पू.क्षे.भा.प्रे.के., 14, गोल्फ क्लब रोड, कोलकाता - 700033
Executive Director, ERLDC, 14 Golf Club Road, Tollygunge, Kolkata, 700033
- कार्यकारी निदेशक, ऊ.क्षे.भा.प्रे.के., 18/ए, शाहीद जीत सिंह सनसनवाल मार्ग, नई दिल्ली - 110016
Executive Director, NRLDC, 18-A, Shaheed Jeet Singh Marg, Katwaria Sarai, New Delhi - 110016
- कार्यकारी निदेशक, प.क्षे.भा.प्रे.के., एफ3, एम आई डी सी क्षेत्र, अंधेरी, मुंबई - 400093
Executive Director, WRLDC, F-3, M.I.D.C. Area, Marol, Andheri (East), Mumbai-400093
- कार्यकारी निदेशक, ऊ.पू.क्षे.भा.प्रे.के., डोंगतेह, लोअर नोंग्रह, लापलंग, शिलोंग - 793006
Executive Director, NERLDC, Dongteih, Lower Nongrah, Lapalang, Shillong - 793006, Meghalaya
- कार्यकारी निदेशक, द.क्षे.भा.प्रे.के., 29, रेस कोर्स क्रॉस रोड, बंगलुरु - 560009
Executive Director, SRLDC, 29, Race Course Cross Road, Bangalore-560009

Sub: Daily PSP Report for the date 06.08.2024.

महोदय/Dear Sir,

आईईजीसी-2010 की धारा स.-5.5.1 के प्रावधान के अनुसार, दिनांक 6-अगस्त-2024 की अखिल भारतीय प्रणाली की दैनिक ग्रिड निष्पादन रिपोर्ट रांभांप्रेके की वेबसाइट पर उपलब्ध है।

As per article 5.5.1 of the Indian Electricity Grid Code, the daily report pertaining power supply position of All India Power System for the date 06.08.2024, is available at the NLDC website.

धन्यवाद,
Thanks

Report for previous day

PROVISIONAL
Date of Reporting: 07-Aug-2024

A. Power Supply Position at All India and Regional level

	NR	WR	SR	ER	NER	TOTAL
Demand Met during Evening Peak hrs(MW) (at 20:00 hrs; from RLDCs)	73847	55504	45422	26146	3462	204381
Peak Shortage (MW)	0	0	0	96	0	96
Energy Met (MU)	1696	1276	1153	561	64	4750
Hydro Gen (MU)	383	92	180	83	39	776
Wind Gen (MU)	52	196	124	-	-	372
Solar Gen (MU)*	63.42	59.57	100.66	1.71	0.85	226
Energy Shortage (MU)	0.38	0.00	0.00	0.18	0.00	0.56
Maximum Demand Met During the Day (MW) (From NLDC SCADA)	77171	56750	54514	26956	3483	206522
Time Of Maximum Demand Met	22:46	19:24	10:27	00:00	19:28	19:54

B. Frequency Profile (%)

Region	FVI	< 49.7	49.7 - 49.8	49.8 - 49.9	< 49.9	49.9 - 50.05	> 50.05
All India	0.034	0.07	0.37	5.49	5.93	75.30	18.77

C. Power Supply Position in States

Region	States	Max.Demand Met during the day (MW)	Shortage during maximum Demand (MW)	Energy Met (MU)	Drawal Schedule (MU)	OD(+)/UD(-) (MU)	Max OD (MW)	Energy Shortage (MU)
NR	Punjab	15046	0	348.5	231.4	1.1	303	0.00
	Haryana	12505	0	267.4	201.0	-1.6	263	0.00
	Rajasthan	10098	0	224.0	42.9	-6.5	607	0.00
	Delhi	6577	0	134.8	124.5	-1.4	246	0.00
	UP	27966	0	574.4	287.9	-2.9	306	0.00
	Uttarakhand	2365	0	51.8	28.8	0.6	193	0.00
	HP	1693	0	36.1	4.5	-0.8	85	0.00
	J&K(UT) & Ladakh(UT)	2479	0	49.2	25.7	-1.2	1452	0.38
	Chandigarh	418	0	8.1	8.1	-0.1	62	0.00
WR	Railways_NR ISTS	199	0	1.9	3.9	-2.0	40	0.00
	Chhattisgarh	4102	0	91.1	52.4	0.3	315	0.00
	Gujarat	16883	0	382.3	113.8	-5.7	383	0.00
	MP	10881	0	228.8	91.5	-2.6	759	0.00
	Maharashtra	22728	0	499.9	177.1	-5.9	939	0.00
	Goa	616	0	13.4	10.9	2.2	86	0.00
	DNHDDPDCL	1295	0	29.8	29.8	0.0	158	0.00
	AMNSIL	827	0	18.3	7.5	0.0	8	0.00
	BALCO	525	0	12.5	12.7	-0.1	3	0.00
SR	Andhra Pradesh	10543	0	220.9	60.6	0.0	970	0.00
	Telangana	13315	0	267.7	156.5	-0.6	899	0.00
	Karnataka	12215	0	224.4	21.7	-4.2	460	0.00
	Kerala	4025	0	79.1	37.0	1.2	516	0.00
	Tamil Nadu	16422	0	351.3	173.4	-5.1	981	0.00
	Puducherry	435	0	10.0	9.7	-0.4	57	0.00
	Railways_SR ISTS	11	0	0.1	0.1	0.0	4	0.00
ER	Bihar	7210	0	134.4	127.3	-2.7	354	0.18
	DVC	3208	0	68.3	-46.0	-1.0	344	0.00
	Jharkhand	1952	0	40.1	29.4	-1.4	178	0.00
	Odisha	5146	0	109.6	40.7	-4.0	444	0.00
	West Bengal	9519	0	207.4	81.2	-2.1	304	0.00
	Sikkim	86	0	1.4	1.4	0.0	27	0.00
	Railways_ER ISTS	11	0	0.1	0.1	0.0	4	0.00
NER	Arunachal Pradesh	171	0	2.9	2.8	-0.5	18	0.00
	Assam	2239	0	41.9	35.3	-0.5	114	0.00
	Manipur	186	0	2.7	2.7	-0.1	20	0.00
	Meghalaya	318	0	5.7	0.4	-0.2	78	0.00
	Mizoram	121	0	2.1	1.0	-0.4	2	0.00
	Nagaland	158	0	3.0	2.8	0.0	19	0.00
	Tripura	330	0	5.6	5.3	-0.4	43	0.00

D. Transnational Exchanges (MU) - Import(+ve)/Export(-ve)

	Bhutan	Nepal	Bangladesh	Godda -> Bangladesh
Actual (MU)	42.4	14.8	-24.2	-24.7
Day Peak (MW)	1970.1	733.9	-1023.0	-1226.3

E. Import/Export by Regions (in MU) - Import(+ve)/Export(-ve); OD(+)/UD(-)

	NR	WR	SR	ER	NER	TOTAL
Schedule(MU)	432.0	-396.0	117.5	-151.7	-1.8	0.0
Actual(MU)	433.4	-406.4	87.2	-118.7	-2.8	-7.3
O/D/U/D(MU)	1.4	-10.4	-30.3	33.0	-1.0	-7.3

F. Generation Outage(MW)

	NR	WR	SR	ER	NER	TOTAL	% Share
Central Sector	3515	12555	5788	4376	597	26831	47
State Sector	7012	12981	7800	2144	131	30067	53
Total	10527	25536	13588	6520	728	56898	100

G. Sourcewise generation (Gross) (MU)

	NR	WR	SR	ER	NER	All India	% Share
Coal	791	1322	573	672	13	3372	66
Lignite	26	12	45	0	0	82	2
Hydro	383	92	180	83	39	776	15
Nuclear	34	68	75	0	0	178	3
Gas, Naptha & Diesel	12	38	5	0	21	77	2
RES (Wind, Solar, Biomass & Others)	121	257	255	4	1	636	12
Total	1368	1788	1133	759	74	5121	100

Share of RES in total generation (%)	8.82	14.35	22.47	0.48	1.15	12.43
Share of Non-fossil fuel (Hydro,Nuclear and RES) in total generation(%)	39.35	23.28	44.98	11.40	53.79	31.05

H. All India Demand Diversity Factor

Based on Regional Max Demands	1.059
Based on State Max Demands	1.088

I. All India Peak Demand and shortage at Solar and Non-Solar Hour

	Max Demand Met(MW)	Time	Shortage(MW)
Solar hr	205976	11:35	0
Non-Solar hr	206522	19:54	0

Diversity factor = Sum of regional or state maximum demands / All India maximum demand

**Note: All generation MU figures are gross

***Godda (Jharkhand) -> Bangladesh power exchange is through the radial connection (isolated from Indian Grid)

Solar Hours -> 07:00 to 17:00hrs and rest are Non-Solar Hours

*Source: RLDCs for solar connected to ISTS; SLDCs for embedded solar. Limited visibility of embedded solar data.

Executive Director-NLDC

INTER-REGIONAL EXCHANGES

Import=(+ve) /Export =(-ve) for NET (MU)

Date of Reporting: 07-Aug-2024

Sl No	Voltage Level	Line Details	No. of Circuit	Max Import (MW)	Max Export (MW)	Import (MU)	Export (MU)	NET (MU)
Import/Export of ER (With NR)								
1	HVDC	ALIPURDUAR-AGRA	2	0	751	0.0	17.0	-17.0
2	HVDC	PUSAULI B/B	-	0	95	0.0	2.4	-2.4
3	765 kV	GAYA-VARANASI	2	249	760	0.0	9.6	-9.6
4	765 kV	SASARAM-FATEHPUR	1	38	429	0.0	5.5	-5.5
5	765 kV	GAYA-BALIA	1	0	757	0.0	13.0	-13.0
6	400 kV	PUSAULI-VARANASI	1	4	57	0.0	0.7	-0.7
7	400 kV	PUSAULI -ALLAHABAD	1	0	101	0.0	1.7	-1.7
8	400 kV	MUZAFFARPUR-GORAKHPUR	2	0	821	0.0	14.4	-14.4
9	400 kV	PATNA-BALIA	2	0	695	0.0	12.7	-12.7
10	400 kV	NAUBATPUR-BALIA	2	4	203	0.0	3.3	-3.3
11	400 kV	BIHARSHARIFF-BALIA	2	109	154	0.0	1.6	-1.6
12	400 kV	MOTIHARI-GORAKHPUR	2	0	530	0.0	9.4	-9.4
13	400 kV	BIHARSHARIFF-VARANASI	2	0	314	0.0	5.4	-5.4
14	220 kV	SAHUPURI-KARAMNASA	1	0	67	0.0	0.7	-0.7
15	132 kV	NAGAR UNTARI-RIHAND	1	0	0	0.1	0.0	0.1
16	132 kV	GARWAH-RIHAND	1	30	0	0.3	0.0	0.3
17	132 kV	KARMANASA-SAHUPURI	1	0	0	0.0	0.0	0.0
18	132 kV	KARMANASA-CHANDAULI	1	0	0	0.0	0.0	0.0
ER-NR						0.4	97.1	-96.7
Import/Export of ER (With WR)								
1	765 kV	JHARSUGUDA-DHARAMJAIGARH	4	920	550	3.2	0.0	3.2
2	765 kV	NEW RANCHI-DHARAMJAIGARH	2	1667	244	22.2	0.0	22.2
3	765 kV	JHARSUGUDA-DURG	2	16	597	0.0	5.5	-5.5
4	400 kV	JHARSUGUDA-RAIGARH	4	149	249	0.0	1.6	-1.6
5	400 kV	RANCHI-SIPAT	2	407	153	4.2	0.0	4.2
6	220 kV	BUDHIPADAR-RAIGARH	1	30	61	0.0	0.6	-0.6
7	220 kV	BUDHIPADAR-KORBA	2	14	128	0.0	1.3	-1.3
ER-WR						29.5	8.9	20.7
Import/Export of ER (With SR)								
1	HVDC	JEYPORE-GAZUWAKA B/B	2	0	312	0.0	7.3	-7.3
2	HVDC	TALCHER-KOLAR BIPOLE	2	0	1491	0.0	29.5	-29.5
3	765 kV	ANGUL-SRIKAKULAM	2	0	2707	0.0	38.8	-38.8
4	400 kV	TALCHER-I/C	2	302	228	0.4	0.0	0.4
5	220 kV	BALIMELA-UPPER-SILERRU	1	0	0	0.0	0.0	0.0
ER-SR						0.0	75.6	-75.6
Import/Export of ER (With NER)								
1	400 kV	BINAGURI-BONGAIGAON	2	76	218	0.2	1.7	-1.5
2	400 kV	ALIPURDUAR-BONGAIGAON	2	164	280	0.0	1.1	-1.1
3	220 kV	ALIPURDUAR-SALAKATI	2	13	81	0.0	0.6	-0.6
ER-NER						0.2	3.4	-3.2
Import/Export of NER (With NR)								
1	HVDC	BISWANATH CHARIALI-AGRA	2	0	307	0.0	7.3	-7.3
NER-NR						0.0	7.3	-7.3
Import/Export of WR (With NR)								
1	HVDC	CHAMPA-KURUKSHETRA	2	0	3013	0.0	73.2	-73.2
2	HVDC	VINDHYACHAL B/B	-	102	0	2.4	0.0	2.4
3	HVDC	MUNDRA-MOHINDERGARH	2	0	1911	0.0	48.3	-48.3
4	765 kV	GWALIOR-AGRA	2	0	2814	0.0	51.0	-51.0
5	765 kV	GWALIOR-PHAGI	2	353	1341	0.3	17.1	-16.9
6	765 kV	JABALPUR-ORAI	2	0	1339	0.0	46.3	-46.3
7	765 kV	GWALIOR-ORAI	1	529	0	8.0	0.0	8.0
8	765 kV	SATNA-ORAI	1	0	1138	0.0	24.0	-24.0
9	765 kV	BANASKANTHA-CHITORGARH	2	0	1873	0.0	25.3	-25.3
10	765 kV	VINDHYACHAL-VARANASI	2	0	3820	0.0	70.2	-70.2
11	400 kV	ZERDA-KANKROLI	1	73	299	0.2	2.6	-2.4
12	400 kV	ZERDA -BHINMAL	1	51	207	0.1	1.8	-1.7
13	400 kV	VINDHYACHAL -RIHAND	1	961	0	20.7	0.0	20.7
14	400 kV	RAPP-SHUJALPUR	2	122	549	0.1	5.6	-5.5
15	400 kV	NEEMUCH-Chittorgarh	2	46	498	0.0	6.5	-6.5
16	220 kV	BHANPURA-RANPUR	1	0	100	0.0	1.8	-1.8
17	220 kV	BHANPURA-MORAK	1	0	30	0.0	1.3	-1.3
18	220 kV	MEHGAON-AURAIYA	1	67	38	0.2	0.3	-0.1
19	220 kV	MALANPUR-AURAIYA	1	38	53	0.1	0.6	-0.5
20	132 kV	GWALIOR-SAWAI MADHOPUR	1	0	0	0.0	0.0	0.0
21	132 kV	RAJGHAT-LALITPUR	2	0	0	0.0	0.0	0.0
WR-NR						32.1	375.8	-343.7
Import/Export of WR (With SR)								
1	HVDC	BHADRAWATI B/B	-	301	0	7.2	0.0	7.2
2	HVDC	RAIGARH-PUGALUR	2	0	801	0.0	10.0	-10.0
3	765 kV	SOLAPUR-RAICHUR	2	1176	1771	8.2	3.8	4.4
4	765 kV	WARDHA-NIZAMABAD	2	0	3570	0.0	40.1	-40.1
5	765 kV	WARORA-WARANGAL(NEW)	2	0	3142	0.0	32.7	-32.7
6	400 kV	KOLHAPUR-KUDGI	2	1712	0	27.6	0.0	27.6
7	220 kV	KOLHAPUR-CHIKODI	2	0	0	0.0	0.0	0.0
8	220 kV	PONDA-AMBEWADI	1	0	0	0.0	0.0	0.0
9	220 kV	XELDEM-AMBEWADI	1	0	86	1.6	0.0	1.6
WR-SR						44.6	86.6	-42.0

INTERNATIONAL EXCHANGES					Import(+ve)/Export(-ve)		
State	Region	Line Name	Max (MW)	Min (MW)	Avg (MW)	Energy Exchange (MU)	
BHUTAN	ER	400kV MANGDECHHU-ALIPURDUAR 1,2&3 i.e. ALIPURDUAR RECEIPT (from MANGDECHU HEP 4*180MW)	829	723	763	18.32	
	ER	400kV TALA-BINAGURI 1,2,4 (& 400kV MALBASE - BINAGURI) i.e. BINAGURI RECEIPT (from TALA HEP 6*170MW)	1005	877	893	21.42	
	ER	220kV CHUKHA-BIRPARA 1&2 (& 220kV MALBASE - BIRPARA) i.e. BIRPARA RECEIPT (from CHUKHA HEP 4*84MW)	86	0	53	1.26	
	NER	132kV GELEPHU-SALAKATI	36	10	15	0.37	
	NER	132kV MOTANGA-RANGIA	67	14	44	1.05	
NEPAL	NR	NEPAL IMPORT (FROM UP)	0	0	0	0.00	
	NR	132kV MAHENDRANAGAR-TANAKPUR(NHPC)	72	0	58	1.39	
	ER	NEPAL IMPORT (FROM BIHAR)	0	0	0	0.00	
	ER	400kV DHALKEBAR-MUZAFFARPUR 1&2	662	404	560	13.43	
BANGLADESH	ER	BHERAMARA B/B HVDC (B'DESH)	-937	-934	-934	-22.42	
	ER (Isolated from Indian Grid)	400kV GODDA_TPS-RAHANPUR (B'DESH) D/C	-1226	-809	-1029	-24.70	
	NER	132kV COMILLA-SURAJMANI NAGAR 1&2	-86	0	-75	-1.79	

Export From India (in MU)

Country	GNA (ISGS/PPA)	T-GNA							TOTAL
		BILATERAL TOTAL	COLLECTIVE						
			IDAM			RTM			
			IEX	PXIL	HPX	IEX	PXIL	HPX	
Bhutan	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Nepal	0.19	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.19
Bangladesh	22.34	0.00	0.00	0.00	0.00	0.00	0.00	0.00	22.34
Myanmar	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total Export	22.53	0.00	0.00	0.00	0.00	0.00	0.00	0.00	22.53

Import by India(in MU)

Country	GNA (ISGA/PPA)	T-GNA							TOTAL
		BILATERAL TOTAL	COLLECTIVE						
			IDAM			RTM			
			IEX	PXIL	HPX	IEX	PXIL	HPX	
Bhutan	38.57	0.00	1.18	0.00	0.00	0.00	0.00	0.00	39.75
Nepal	2.63	0.00	12.39	0.00	0.00	0.00	0.00	0.00	15.02
Bangladesh	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Myanmar	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total Import	41.20	0.00	13.57	0.00	0.00	0.00	0.00	0.00	54.77

Net from India(in MU)

-ve : Export / +ve : Import

Country	GNA (ISGS/PPA)	T-GNA							TOTAL
		BILATERAL TOTAL	COLLECTIVE						
			IDAM			RTM			
			IEX	PXIL	HPX	IEX	PXIL	HPX	
Bhutan	38.57	0.00	1.18	0.00	0.00	0.00	0.00	0.00	39.75
Nepal	2.44	0.00	12.39	0.00	0.00	0.00	0.00	0.00	14.83
Bangladesh	-22.34	0.00	0.00	0.00	0.00	0.00	0.00	0.00	-22.34
Myanmar	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total Net	18.67	0.00	13.57	0.00	0.00	0.00	0.00	0.00	32.24