



National Load Despatch Centre
राष्ट्रीय भार प्रेषण केंद्र
GRID CONTROLLER OF INDIA LIMITED
ग्रिड कंट्रोलर ऑफ इंडिया लिमिटेड

(Government of India Enterprise/ भारत सरकार का उद्यम)
B-9, QUTUB INSTITUTIONAL AREA, KATWARIA SARAI, NEW DELHI -110016
बी-9, कुतुब इन्स्टीट्यूशनल एरिया, कटवारिया सराये, न्यू दिल्ली-110016

Ref: GRID-INDIA/NLDC/SO/Daily PSP Report

दिनांक: 05.09.2025

To,

- कार्यकारी निदेशक, पू.क्षे.भा.प्रे.के., 14, गोल्फ क्लब रोड, कोलकाता - 700033
Executive Director, ERLDC, 14 Golf Club Road, Tollygunge, Kolkata, 700033
- कार्यकारी निदेशक, ऊ.क्षे.भा.प्रे.के., 18/ए, शाहीद जीत सिंह सनसनवाल मार्ग, नई दिल्ली - 110016
Executive Director, NRLDC, 18-A, Shaheed Jeet Singh Marg, Katwaria Sarai, New Delhi - 110016
- कार्यकारी निदेशक, प.क्षे.भा.प्रे.के., एफ3, एम आई डी सी क्षेत्र, अंधेरी, मुंबई - 400093
Executive Director, WRLDC, F-3, M.I.D.C. Area, Marol, Andheri (East), Mumbai-400093
- कार्यकारी निदेशक, ऊ.पू.क्षे.भा.प्रे.के., डोंगतेह, लोअर नोंग्रह, लापालंग, शिलोंग - 793006
Executive Director, NERLDC, Dongteih, Lower Nongrah, Lapalang, Shillong - 793006, Meghalaya
- कार्यकारी निदेशक, द.क्षे.भा.प्रे.के., 29, रेस कोर्स क्रॉस रोड, बंगलुरु - 560009
Executive Director, SRLDC, 29, Race Course Cross Road, Bangalore-560009

Sub: Daily PSP Report for the date 04.09.2025.

महोदय/Sir,

आईईजीसी-2023 की धारा स.-38(1) के प्रावधान के अनुसार, दिनांक 4-सितंबर-2025 की अखिल भारतीय प्रणाली की दैनिक ग्रिड निष्पादन रिपोर्ट रांभांप्रेके की वेबसाइट पर उपलब्ध है।

As per article 38(1) of the Indian Electricity Grid Code, the daily report pertaining power supply position of All India Power System for the date 04.09.2025, is available at the NLDC website.

धन्यवाद,
Thanks

Report for previous day

Date of Reporting: 05-Sep-2025

A. Power Supply Position at All India and Regional level

	NR	WR	SR	ER	NER	TOTAL
Demand Met during Evening Peak hrs(MW) (at 20:00 hrs; from RLDCs)	60577	57533	50062	28267	3856	200295
Peak Shortage (MW)	0	0	0	0	0	0
Energy Met (MU)	1290	1375	1189	618	74	4547
Hydro Gen (MU)	343	114	204	103	37	801
Wind Gen (MU)	12	164	274	-	-	451
Solar Gen (MU)*	170.77	96.62	148.82	4.15	1.04	421
Energy Shortage (MU)	0.00	0.00	0.00	0.00	0.00	0.00
Maximum Demand Met During the Day (MW) (From NLDC SCADA)	62544	60277	54458	29347	3920	205628
Time Of Maximum Demand Met	19:33	19:18	16:00	19:21	20:03	19:24

B. Frequency Profile (%)

Region	FVI	< 49.7	49.7 - 49.8	49.8 - 49.9	< 49.9	49.9 - 50.05	> 50.05
All India	0.030	0.00	0.65	3.95	4.59	81.72	13.69

C. Power Supply Position in States

Region	States	Max.Demand Met during the day (MW)	Shortage during maximum Demand (MW)	Energy Met (MU)	Drawal Schedule (MU)	OD(+)/UD(-) (MU)	Max OD (MW)	Energy Shortage (MU)
NR	Punjab	7533	0	166.4	79.6	-0.7	316	0.00
	Haryana	8440	0	175.1	138.8	-1.3	325	0.00
	Rajasthan	11120	0	249.0	108.9	-7.1	691	0.00
	Delhi	5656	0	114.4	109.6	-0.5	175	0.00
	UP	23126	0	456.0	202.6	-0.2	641	0.00
	Uttarakhand	2175	0	46.3	29.7	0.7	148	0.00
	HP	1682	0	33.3	11.7	0.5	220	0.00
	J&K(UT) & Ladakh(UT)	2135	0	40.8	16.1	1.3	226	0.00
	Chandigarh	252	0	5.0	4.9	0.1	20	0.00
	Railways_NR ISTS	203	0	4.2	3.9	0.3	39	0.00
WR	Chhattisgarh	5044	0	112.8	66.2	0.3	282	0.00
	Gujarat	20497	0	433.9	198.9	-0.7	3348	0.00
	MP	10781	0	230.2	104.5	-1.5	745	0.00
	Maharashtra	24009	0	514.3	171.8	-6.7	637	0.00
	Goa	677	0	15.6	11.5	4.1	64	0.00
	DNHDDPDCL	1354	0	31.3	31.0	0.3	72	0.00
	AMNSIL	832	0	18.2	10.6	0.0	298	0.00
	BALCO	536	0	12.8	12.7	0.1	7	0.00
	RIL JAMNAGAR	249	0	6.0	6.0	0.0	0	0.00
	Andhra Pradesh	10368	0	222.5	35.8	-4.1	583	0.00
SR	Telangana	13339	0	263.8	117.8	0.8	744	0.00
	Karnataka	11903	0	226.9	26.1	-1.4	1037	0.00
	Kerala	3877	0	77.2	36.7	-0.4	317	0.00
	Tamil Nadu	18325	0	389.2	121.7	-5.6	481	0.00
	Puducherry	456	0	9.2	9.0	-0.4	114	0.00
ER	Bihar	8099	0	165.0	153.4	-1.8	344	0.00
	DVC	3083	0	67.3	-17.0	-0.6	369	0.00
	Jharkhand	2138	0	43.6	34.1	0.0	153	0.00
	Odisha	6053	0	120.8	64.5	-2.4	516	0.00
	West Bengal	10332	0	220.5	102.6	-1.2	314	0.00
	Sikkim	84	0	1.2	1.4	-0.2	13	0.00
NER	Railways_ER ISTS	19	0	0.0	0.1	-0.1	0	0.00
	Arunachal Pradesh	199	0	4.0	3.5	0.1	27	0.00
	Assam	2620	0	49.4	43.0	0.3	128	0.00
	Manipur	238	0	3.3	3.2	0.1	62	0.00
	Meghalaya	335	0	5.8	3.2	0.1	35	0.00
	Mizoram	155	0	2.2	0.7	-0.1	33	0.00
	Nagaland	165	0	3.2	2.9	-0.2	16	0.00
	Tripura	368	0	6.5	5.9	0.1	44	0.00

D. Transnational Exchanges (MU) - Import(+ve)/Export(-ve)

	Bhutan	Nepal	Bangladesh	Godda -> Bangladesh
Actual (MU)	48.5	18.9	-24.6	-32.6
Day Peak (MW)	2320.3	923.1	-1164.0	-1466.0

E. Import/Export by Regions (in MU) - Import(+ve)/Export(-ve); OD(+)/UD(-)

	NR	WR	SR	ER	NER	TOTAL
Schedule(MU)	183.8	-203.3	35.6	-24.5	8.4	0.0
Actual(MU)	191.5	-193.8	20.8	-35.2	8.3	-8.3
O/D/U/D(MU)	7.7	9.5	-14.8	-10.7	-0.1	-8.3

F. Generation Outage(MW)

	NR	WR	SR	ER	NER	TOTAL	% Share
Central Sector	8929	12216	12372	3020	85	36621	49
State Sector	12984	13546	8298	3429	199	38456	51
Total	21913	25762	20670	6449	284	75077	100

G. Sourcewise generation (Gross) (MU)

	NR	WR	SR	ER	NER	All India	% Share
Coal	573	1198	493	607	12	2883	59
Lignite	20	13	39	0	0	72	1
Hydro	343	114	204	103	37	801	16
Nuclear	41	50	41	0	0	132	3
Gas, Naptha & Diesel	6	36	7	0	21	70	1
RES (Wind, Solar, Biomass & Others)	189	263	452	7	1	911	19
Total	1172	1674	1236	717	71	4869	100

Share of RES in total generation (%)	16.11	15.71	36.55	0.92	1.50	18.71
Share of Non-fossil fuel (Hydro,Nuclear and RES) in total generation(%)	48.93	25.51	56.38	15.27	53.52	37.88

H. All India Demand Diversity Factor

Based on Regional Max Demands	1.023
Based on State Max Demands	1.062

I. All India Peak Demand and shortage at Solar and Non-Solar Hour

	Max Demand Met(MW)	Time	Shortage(MW)
Solar hr	195677	9:50	0
Non-Solar hr	205628	19:24	0

Diversity factor = Sum of regional or state maximum demands / All India maximum demand

**Note: All generation MU figures are gross

***Godda (Jharkhand) -> Bangladesh power exchange is through the radial connection (isolated from Indian Grid)

Solar Hours -> 06:00 to 18:00hrs and rest are Non-Solar Hours

*Source: RLDCs for solar connected to ISTS; SLDCs for embedded solar. Limited visibility of embedded solar data.

Executive Director-NLDC

INTER-REGIONAL EXCHANGES

Import=(+ve) /Export =(-ve) for NET (MU)
Date of Reporting: 05-Sep-2025

Sl No	Voltage Level	Line Details	No. of Circuit	Max Import (MW)	Max Export (MW)	Import (MU)	Export (MU)	NET (MU)
Import/Export of ER (With NR)								
1	HVDC	ALIPURDUAR-AGRA	2	0	401	0.0	9.1	-9.1
2	HVDC	PUSAULI B/B	-	0	47	0.0	2.3	-2.3
3	765 kV	GAYA-VARANASI	2	1123	476	5.7	0.0	5.7
4	765 kV	SASARAM-FATEHPUR	1	499	251	2.4	0.0	2.4
5	765 kV	GAYA-BALIA	1	0	777	0.0	10.8	-10.8
6	400 kV	PUSAULI-VARANASI	1	0	155	0.0	2.4	-2.4
7	400 kV	PUSAULI-ALLAHABAD	1	57	54	0.2	0.0	0.2
8	400 kV	MUZAFFARPUR-GORAKHPUR	2	364	565	0.0	5.3	-5.3
9	400 kV	PATNA-BALIA	2	76	884	0.0	11.5	-11.5
10	400 kV	NAUBATPUR-BALIA	2	74	363	0.0	3.2	-3.2
11	400 kV	BIHARSHARIFF-BALIA	2	354	264	0.3	0.0	0.3
12	400 kV	MOTIHARI-GORAKHPUR	2	210	394	0.0	3.3	-3.3
13	400 kV	BIHARSARIFF-SAHUPURI	2	616	196	3.0	0.0	3.0
14	220 kV	SAHUPURI-KARMANASA	1	0	49	0.0	0.4	-0.4
15	132 kV	NAGAR UNTARI-RIHAND	1	0	0	0.0	0.0	0.0
16	132 kV	GARWAH-RIHAND	1	30	0	0.5	0.0	0.5
17	132 kV	KARMANASA-SAHUPURI	1	0	0	0.0	0.5	-0.5
18	132 kV	KARMANASA-CHANDAULI	1	0	0	0.0	0.0	0.0
ER-NR						12.2	48.8	-36.5
Import/Export of ER (With WR)								
1	765 kV	JHARSUGUDA-DHARAMJAIGARH	4	1361	100	11.2	0.0	11.2
2	765 kV	NEW RANCHI-DHARAMJAIGARH	2	1947	0	33.7	0.0	33.7
3	765 kV	JHARSUGUDA-DURG	2	275	467	0.0	2.0	-2.0
4	400 kV	JHARSUGUDA-RAIGARH	4	421	320	1.4	0.0	1.4
5	400 kV	RANCHI-SIPAT	2	481	101	6.5	0.0	6.5
6	400 kV	JEYPORE-JACDALPUR	2	584	0	6.8	0.0	6.8
7	220 kV	BUDHIPADAR-RAIGARH	1	84	89	0.0	0.3	-0.3
8	220 kV	BUDHIPADAR-KORBA	2	177	74	0.9	0.0	0.9
ER-WR						60.5	2.3	58.2
Import/Export of ER (With SR)								
1	HVDC	JEYPORE-GAZUWAKA B/B	2	0	529	0.0	12.6	-12.6
2	HVDC	TALCHER-KOLAR BIPOLE	2	0	1479	0.0	32.0	-32.0
3	765 kV	ANGUL-SRIKAKULAM	2	0	2204	0.0	27.5	-27.5
4	400 kV	TALCHER/UC	2	227	652	0.0	3.5	-3.5
5	220 kV	BALIMELA-UPPER-SILERRU	1	0	0	0.0	0.0	0.0
ER-SR						0.0	72.0	-72.0
Import/Export of ER (With NER)								
1	400 kV	BINAGURI-BONGAIGAON	2	131	335	0.2	3.4	-3.2
2	400 kV	ALIPURDUAR-BONGAIGAON	2	0	670	0.0	9.2	-9.2
3	220 kV	ALIPURDUAR-SALAKATI	2	0	129	0.0	2.0	-2.0
ER-NER						0.2	14.6	-14.4
Import/Export of NER (With NR)								
1	HVDC	BISWANATH CHARIALI-AGRA	2	0	304	0.0	7.3	-7.3
NER-NR						0.0	7.3	-7.3
Import/Export of WR (With NR)								
1	HVDC	CHAMPA-KURUKSHETRA	2	0	2003	0.0	46.6	-46.6
2	HVDC	VINDHYACHAL B/B	-	489	256	6.3	2.4	4.0
3	HVDC	MUNDRA-MOHINDERGARH	2	0	981	0.0	24.2	-24.2
4	765 kV	GWALIOR-AGRA	2	172	2182	0.2	21.1	-21.0
5	765 kV	GWALIOR-PHAGI	2	1320	1582	8.2	16.7	-8.5
6	765 kV	JABALPUR-ORAI	2	187	1112	0.0	21.8	-21.8
7	765 kV	GWALIOR-ORAI	1	989	53	12.5	0.0	12.5
8	765 kV	SATNA-ORAI	1	0	907	0.0	11.8	-11.8
9	765 kV	BANASKANTHA-CHITORGARH	2	1637	612	12.0	0.9	11.1
10	765 kV	VINDHYACHAL-VARANASI	2	0	3066	0.0	52.4	-52.4
11	400 kV	ZERDA-KANKROLI	1	357	57	4.1	0.0	4.1
12	400 kV	ZERDA -BHINMAL	1	246	40	2.8	0.0	2.8
13	400 kV	VINDHYACHAL -RIHAND	1	0	1	0.0	0.0	0.0
14	400 kV	RAPP-SHUJALPUR	2	721	384	5.7	2.3	3.4
15	400 kV	NEEMUCH-Chittorgarh	2	438	474	2.8	3.8	-1.1
16	220 kV	BHANPURA-RANPUR	1	0	136	0.0	2.5	-2.5
17	220 kV	BHANPURA-MORAK	1	0	30	0.0	2.1	-2.1
18	220 kV	MEHGAON-AURAIYA	1	78	31	0.5	0.1	0.4
19	220 kV	MALANPUR-AURAIYA	1	54	43	0.1	0.3	-0.1
20	132 kV	RAIGHAT-LALITPUR	2	0	0	0.0	0.0	0.0
WR-NR						55.1	209.2	-154.1
Import/Export of WR (With SR)								
1	HVDC	BHADRAWATI B/B	-	573	0	12.0	0.0	12.0
2	HVDC	RAIGARH-PUGALUR	2	0	2001	0.0	20.9	-20.9
3	765 kV	SOLAPUR-RAICHUR	2	1794	0	25.7	0.0	25.7
4	765 kV	WARDHA-NIZAMABAD	2	1	1968	0.0	17.1	-17.1
5	765 kV	WARORA-WARANGAL(NEW)	2	114	1939	0.0	15.6	-15.5
6	400 kV	KOLHAPUR-KUDGI	2	1979	0	33.0	0.0	33.0
7	220 kV	KOLHAPUR-CHIKODI	2	0	0	0.0	0.0	0.0
8	220 kV	PONDA-AMBEWADI	1	0	0	0.0	0.0	0.0
9	220 kV	XELDEM-AMBEWADI	1	0	111	2.1	0.0	2.1
WR-SR						72.9	53.5	19.4

INTERNATIONAL EXCHANGES					Import(+ve)/Export(-ve)		
State	Region	Line Name	Max (MW)	Min (MW)	Avg (MW)	Energy Exchange (MU)	
BHUTAN	ER	400kV MANGDECHHU-ALIPURDUAR 1,2&3 I.e. ALIPURDUAR RECEIPT (from MANGDECHU HEP 4*180MW)	1308	957	1046	25.11	
	ER	400kV TALA-BINAGURI 1,2,4 (& 400kV MALBASE - BINAGURI) I.e. BINAGURI RECEIPT (from TALA HEP 6*170MW)	1063	807	849	20.38	
	ER	220kV CHUKHA-BIRPARA 1&2 (& 220kV MALBASE - BIRPARA) I.e. BIRPARA RECEIPT (from CHUKHA HEP 4*84MW)	149	0	78	1.88	
	NER	132kV GELEPHU-SALAKATI	14	-8	1	0.03	
	NER	132kV MOTANGA-RANGIA	63	0	48	1.14	
NEPAL	NR	NEPAL IMPORT (FROM UP)	-43	0	0	0.00	
	NR	132kV MAHENDRANAGAR-TANAKPUR(NHPC)	68	0	48	1.15	
	ER	NEPAL IMPORT (FROM BIHAR)	175	124	155	3.73	
	ER	400kV DHALKEBAR-MUZAFFARPUR 1&2	648	540	584	14.02	
BANGLADESH	ER	BHERAMARA B/B HVDC (B'DESH)	-991	-912	-979	-23.49	
	ER (Isolated from Indian Grid)	400kV GODDA_TPS-RAHANPUR (B'DESH) D/C	-1466	-1002	-1359	-32.62	
	NER	132kV COMILLA-SURAJMANI NAGAR 1&2	-54	0	-46	-1.10	

CROSS BORDER EXCHANGE SCHEDULE

Date of Reporting: 05-Sep-2025

Export From India (in MU)

Country	GNA (ISGS/PPA)	T-GNA							TOTAL
		BILATERAL TOTAL	COLLECTIVE						
			IDAM			RTM			
			IEX	PXIL	HPX	IEX	PXIL	HPX	
Bhutan	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Nepal	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Bangladesh	24.16	0.14	0.00	0.00	0.00	0.00	0.00	0.00	24.30
Myanmar	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total Export	24.16	0.14	0.00	0.00	0.00	0.00	0.00	0.00	24.30

Import by India(in MU)

Country	GNA (ISGA/PPA)	T-GNA							TOTAL
		BILATERAL TOTAL	COLLECTIVE						
			IDAM			RTM			
			IEX	PXIL	HPX	IEX	PXIL	HPX	
Bhutan	48.70	0.00	1.47	0.00	0.00	0.07	0.00	0.00	50.24
Nepal	9.15	4.75	0.00	0.00	0.00	5.12	0.00	0.00	19.02
Bangladesh	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Myanmar	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total Import	57.85	4.75	1.47	0.00	0.00	5.19	0.00	0.00	69.26

Net from India(in MU)

-ve : Export / +ve : Import

Country	GNA (ISGS/PPA)	T-GNA							TOTAL
		BILATERAL TOTAL	COLLECTIVE						
			IDAM			RTM			
			IEX	PXIL	HPX	IEX	PXIL	HPX	
Bhutan	48.70	0.00	1.47	0.00	0.00	0.07	0.00	0.00	50.24
Nepal	9.15	4.75	0.00	0.00	0.00	5.12	0.00	0.00	19.02
Bangladesh	-24.16	-0.14	0.00	0.00	0.00	0.00	0.00	0.00	-24.30
Myanmar	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total Net	33.69	4.61	1.47	0.00	0.00	5.19	0.00	0.00	44.96

