



National Load Despatch Centre
राष्ट्रीय भार प्रेषण केंद्र
GRID CONTROLLER OF INDIA LIMITED
ग्रिड कंट्रोलर ऑफ इंडिया लिमिटेड

(Government of India Enterprise/ भारत सरकार का उद्यम)
B-9, QUTUB INSTITUTIONAL AREA, KATWARIA SARAI, NEW DELHI -110016
बी-9, कुतुब इन्स्टीट्यूशनल एरिया, कटवारिया सराये, न्यू दिल्ली-110016

Ref: GRID-INDIA/NLDC/SO/Daily PSP Report

दिनांक: 25.12.2025

To,

- कार्यकारी निदेशक, पू.क्षे.भा.प्रे.के., 14, गोल्फ क्लब रोड, कोलकाता - 700033
Executive Director, ERLDC, 14 Golf Club Road, Tollygunge, Kolkata, 700033
- कार्यकारी निदेशक, ऊ.क्षे.भा.प्रे.के., 18/ए, शाहीद जीत सिंह सनसनवाल मार्ग, नई दिल्ली - 110016
Executive Director, NRLDC, 18-A, Shaheed Jeet Singh Marg, Katwaria Sarai, New Delhi - 110016
- कार्यकारी निदेशक, प.क्षे.भा.प्रे.के., एफ3, एम आई डी सी क्षेत्र, अंधेरी, मुंबई - 400093
Executive Director, WRLDC, F-3, M.I.D.C. Area, Marol, Andheri (East), Mumbai-400093
- कार्यकारी निदेशक, ऊ.पू.क्षे.भा.प्रे.के., डोंगतेह, लोअर नोंग्रह, लापालंग, शिलोंग - 793006
Executive Director, NERLDC, Dongteih, Lower Nongrah, Lapalang, Shillong - 793006, Meghalaya
- कार्यकारी निदेशक, द.क्षे.भा.प्रे.के., 29, रेस कोर्स क्रॉस रोड, बंगलुरु - 560009
Executive Director, SRLDC, 29, Race Course Cross Road, Bangalore-560009

Sub: Daily PSP Report for the date 24.12.2025.

महोदय/Sir,

आईईजीसी-2023 की धारा स.-38(1) के प्रावधान के अनुसार, दिनांक 24-दिसंबर-2025 की अखिल भारतीय प्रणाली की दैनिक ग्रिड निष्पादन रिपोर्ट रांभांप्रेके की वेबसाइट पर उपलब्ध है।

As per article 38(1) of the Indian Electricity Grid Code, the daily report pertaining power supply position of All India Power System for the date 24.12.2025, is available at the NLDC website.

धन्यवाद,
Thanks

Report for previous day

Date of Reporting: 25-Dec-2025

A. Power Supply Position at All India and Regional level

	NR	WR	SR	ER	NER	TOTAL
Demand Met during Evening Peak hrs(MW) (at 19:00 hrs; from RLDCs)	61023	67574	49206	23675	2795	204273
Peak Shortage (MW)	0	107	0	142	0	249
Energy Met (MU)	1311	1570	1202	488	52	4623
Hydro Gen (MU)	125	54	88	24	15	306
Wind Gen (MU)	4	103	50	-	-	156
Solar Gen (MU)*	175.86	161.19	152.41	2.43	0.61	493
Energy Shortage (MU)	0.27	0.77	0.00	0.28	0.00	1.32
Maximum Demand Met During the Day (MW) (From NLDC SCADA)	71642	79568	61666	24425	2937	236096
Time Of Maximum Demand Met	10:41	10:56	09:30	17:37	17:35	10:36

B. Frequency Profile (%)

Region	FV1	< 49.7	49.7 - 49.8	49.8 - 49.9	< 49.9	49.9 - 50.05	> 50.05
All India	0.053	0.10	0.46	9.35	9.92	69.95	20.14

C. Power Supply Position in States

Region	States	Max.Demand Met during the day (MW)	Shortage during maximum Demand (MW)	Energy Met (MU)	Drawal Schedule (MU)	OD(+)/UD(-) (MU)	Max OD (MW)	Energy Shortage (MU)
NR	Punjab	9225	0	164.6	82.3	-1.1	924	0.00
	Haryana	9211	0	172.3	110.4	-0.4	327	0.00
	Rajasthan	17902	0	336.3	121.1	-0.9	1109	0.00
	Delhi	4994	0	84.4	79.0	-0.6	454	0.00
	UP	22248	0	393.4	69.2	-0.7	507	0.00
	Uttarakhand	2494	0	46.6	35.7	0.2	141	0.27
	HP	2196	0	39.4	31.9	-0.4	96	0.00
	J&K(UT) & Ladakh(UT)	3170	0	65.5	61.1	-1.7	127	0.00
	Chandigarh	260	0	4.2	4.2	0.0	13	0.00
	Railways_NR ISTS	214	0	3.8	3.7	0.2	61	0.00
WR	Chhattisgarh	5280	0	107.6	40.6	0.3	233	0.00
	Gujarat	23544	0	445.3	167.9	-2.5	860	0.00
	MP	19572	0	351.5	246.4	0.0	1102	0.77
	Maharashtra	28164	0	581.9	168.8	-9.7	1025	0.00
	Goa	707	0	13.6	10.9	2.2	57	0.00
	DNHDDPDCL	1364	0	31.0	31.0	0.0	74	0.00
	AMNSIL	859	0	19.1	12.1	-0.1	245	0.00
	BALCO	596	0	14.2	14.3	-0.1	19	0.00
	RIL JAMNAGAR	265	0	5.8	5.9	-0.1	0	0.00
	Andhra Pradesh	11220	0	213.5	61.0	1.3	592	0.00
SR	Telangana	14213	0	253.9	99.3	1.1	742	0.00
	Karnataka	16745	0	296.3	124.4	-0.7	753	0.00
	Kerala	4379	0	79.0	58.0	0.4	458	0.00
	Tamil Nadu	17141	0	350.2	215.8	0.2	1399	0.00
	Puducherry	411	0	8.9	8.5	-0.2	31	0.00
	Bihar	6001	0	109.9	104.2	-0.3	396	0.00
ER	DVC	3198	0	65.6	-31.4	-2.9	450	0.00
	Jharkhand	2165	0	41.9	30.0	1.7	387	0.28
	Odisha	5608	0	108.8	17.8	-0.4	509	0.00
	West Bengal	7940	0	159.6	23.2	-1.0	270	0.00
	Sikkim	124	0	1.9	1.9	0.0	20	0.00
	Railways_ER ISTS	16	0	0.1	0.2	0.0	0	0.00
NER	Arunachal Pradesh	175	0	3.4	3.4	-0.1	18	0.00
	Assam	1610	0	28.7	23.2	0.2	128	0.00
	Manipur	254	0	3.9	4.0	-0.1	32	0.00
	Meghalaya	357	0	6.6	5.4	0.0	69	0.00
	Mizoram	164	0	2.4	2.3	-0.2	15	0.00
	Nagaland	157	0	2.8	2.8	-0.1	10	0.00
	Tripura	234	0	4.1	5.0	0.0	39	0.00

D. Transnational Exchanges (MU) - Import(+ve)/Export(-ve)

	Bhutan	Nepal	Bangladesh	Godda -> Bangladesh
Actual (MU)	-11.1	-1.2	-21.4	-23.8
Day Peak (MW)	-887.9	-393.6	-1030.4	-1350.0

E. Import/Export by Regions (in MU) - Import(+ve)/Export(-ve); OD(+)/UD(-)

	NR	WR	SR	ER	NER	TOTAL
Schedule(MU)	201.5	-213.4	192.4	-188.5	8.0	0.0
Actual(MU)	192.5	-219.4	189.6	-185.8	11.5	-11.6
O/D/U/D(MU)	-9.0	-6.0	-2.8	2.7	3.5	-11.6

F. Generation Outage(MW)

	NR	WR	SR	ER	NER	TOTAL	% Share
Central Sector	6181	13717	7118	4185	114	31315	49
State Sector	7224	11435	9674	3437	205	31974	51
Total	13405	25152	16792	7622	319	63289	100

G. Sourcewise generation (Gross) (MU)

	NR	WR	SR	ER	NER	All India	% Share
Coal	812	1474	650	741	14	3690	73
Lignite	24	16	58	0	0	98	2
Hydro	125	54	88	24	15	306	6
Nuclear	32	53	46	0	0	131	3
Gas, Naptha & Diesel	14	45	11	0	22	92	2
RES (Wind, Solar, Biomass & Others)	205	268	242	6	1	722	14
Total	1213	1909	1094	771	51	5039	100

Share of RES in total generation (%)	16.93	14.02	22.10	0.82	1.19	14.32
Share of Non-fossil fuel (Hydro,Nuclear and RES) in total generation(%)	29.90	19.58	34.40	3.96	30.33	23.00

H. All India Demand Diversity Factor

Based on Regional Max Demands	1.017
Based on State Max Demands	1.035

I. All India Peak Demand and shortage at Solar and Non-Solar Hour

	Max Demand Met(MW)	Time	Shortage(MW)
Solar hr	236096	10:36	0
Non-Solar hr	211597	18:22	282

Diversity factor = Sum of regional or state maximum demands / All India maximum demand

**Note: All generation MU figures are gross

***Godda (Jharkhand) -> Bangladesh power exchange is through the radial connection (isolated from Indian Grid)

Solar Hours -> 06:00 to 18:00hrs and rest are Non-Solar Hours

*Source: RLDCs for solar connected to ISTS; SLDCs for embedded solar. Limited visibility of embedded solar data.

Executive Director-NLDC

INTER-REGIONAL EXCHANGES

Import=(+ve)/Export =(-ve) for NET (MU)
Date of Reporting: 25-Dec-2025

Sl No	Voltage Level	Line Details	No. of Circuit	Max Import (MW)	Max Export (MW)	Import (MU)	Export (MU)	NET (MU)
Import/Export of ER (With NR)								
1	HVDC	ALIPURDUAR-AGRA	2	0	0	0.0	0.0	0.0
2	HVDC	PUSAULI B/B	-	0	47	0.0	2.6	-2.6
3	765 kV	GAYA-VARANASI	2	85	1286	0.0	17.6	-17.6
4	765 kV	SASARAM-FATEHPUR	1	72	684	0.0	9.0	-9.0
5	765 kV	GAYA-BALIA	1	0	693	0.0	9.8	-9.8
6	400 kV	PUSAULI-VARANASI	1	29	100	0.0	1.1	-1.1
7	400 kV	PUSAULI-ALLAHABAD	1	0	126	0.0	1.1	-1.1
8	400 kV	MUZAFFARPUR-GORAKHPUR	2	368	706	0.0	4.8	-4.8
9	400 kV	PATNA-BALIA	2	0	1203	0.0	14.5	-14.5
10	400 kV	NAUBATPUR-BALIA	2	0	515	0.0	6.8	-6.8
11	400 kV	BIHARSHARIFF-BALIA	2	390	421	0.0	1.2	-1.2
12	400 kV	MOTIHARI-GORAKHPUR	2	122	602	0.0	6.0	-6.0
13	400 kV	BIHARSARIFF-SAHUPURI	2	72	519	0.0	6.4	-6.4
14	220 kV	SAHUPURI-KARMANASA	1	0	42	0.0	1.0	-1.0
15	132 kV	NAGAR UNTARI-RIHAND	1	0	0	0.1	0.0	0.1
16	132 kV	GARWAH-RIHAND	1	30	0	0.7	0.0	0.7
17	132 kV	KARMANASA-SAHUPURI	1	0	31	0.0	0.0	0.0
18	132 kV	KARMANASA-CHANDAULI	1	0	20	0.0	0.8	-0.8
ER-NR						0.8	82.6	-81.8
Import/Export of ER (With WR)								
1	765 kV	JHARSUGUDA-DHARAMJAIGARH	4	0	1056	0.0	12.1	-12.1
2	765 kV	NEW RANCHI-DHARAMJAIGARH	2	443	1526	0.0	13.3	-13.3
3	765 kV	JHARSUGUDA-DURG	2	0	1292	0.0	23.0	-23.0
4	400 kV	JHARSUGUDA-RAIGARH	4	248	208	0.8	0.0	0.8
5	400 kV	RANCHI-SIPAT	2	116	448	0.0	3.6	-3.6
6	400 kV	JEYPORE-JACDALPUR	2	278	284	0.0	1.0	-1.0
7	220 kV	BUDHIPADAR-RAIGARH	1	0	149	0.0	2.1	-2.1
8	220 kV	BUDHIPADAR-KORBA	2	94	94	0.3	0.0	0.3
ER-WR						2.1	54.1	-52.0
Import/Export of ER (With SR)								
1	HVDC	JEYPORE-GAZUWAKA B/B	2	0	522	0.0	5.9	-5.9
2	HVDC	TALCHER-KOLAR BIPOLE	2	0	1620	0.0	48.2	-48.2
3	765 kV	ANGUL-SRIKAKULAM	2	0	2950	0.0	49.7	-49.7
4	400 kV	TALCHER I/C	2	0	541	0.0	5.0	-5.0
5	220 kV	BALIMELA-UPPER-SILERRU	1	0	23	0.0	0.0	0.0
ER-SR						0.0	103.8	-103.8
Import/Export of ER (With NER)								
1	400 kV	BINAGURI-BONGAIGAON	2	361	220	0.4	1.2	-0.9
2	400 kV	ALIPURDUAR-BONGAIGAON	2	658	179	3.6	0.0	3.6
3	220 kV	ALIPURDUAR-SALAKATI	2	131	12	1.3	0.0	1.3
ER-NER						5.3	1.2	4.0
Import/Export of NER (With NR)								
1	HVDC	BISWANATH CHARIALI-AGRA	2	656	0	18.8	0.0	18.8
NER-NR						18.8	0.0	18.8
Import/Export of WR (With NR)								
1	HVDC	CHAMPA-KURUKSHETRA	2	0	4031	0.0	71.7	-71.7
2	HVDC	VINDHYACHAL B/B	-	1048	0	11.3	0.0	11.3
3	HVDC	MUNDRA-MOHINDERGARH	2	0	987	0.0	24.3	-24.3
4	765 kV	GWALIOR-AGRA	2	813	1883	1.2	15.2	-14.0
5	765 kV	GWALIOR-PHAGI	2	668	1940	1.1	24.3	-23.2
6	765 kV	JABALPUR-ORAI	2	48	956	0.0	21.1	-21.1
7	765 kV	GWALIOR-ORAI	1	1084	0	17.4	0.0	17.4
8	765 kV	SATNA-ORAI	1	0	1275	0.0	21.2	-21.2
9	765 kV	BANASKANTHA-CHITORGARH	2	1774	113	15.7	0.0	15.7
10	765 kV	VINDHYACHAL-VARANASI	2	256	2216	0.0	28.2	-28.2
11	400 kV	ZERDA-KANKROLI	1	263	0	2.9	0.0	2.9
12	400 kV	ZERDA -BHINMAL	1	181	0	2.0	0.0	2.0
13	400 kV	VINDHYACHAL -RIHAND	1	872	0	10.5	0.0	10.5
14	400 kV	RAPP-SHUJALPUR	2	640	279	4.6	1.2	3.4
15	400 kV	NEEMUCH-Chittorgarh	2	729	303	5.6	1.2	4.4
16	220 kV	BHANPURA-RANPUR	1	0	132	0.0	2.2	-2.2
17	220 kV	BHANPURA-MORAK	1	0	30	0.0	1.6	-1.6
18	220 kV	MEHGAON-AURAIYA	1	175	5	1.6	0.0	1.6
19	220 kV	MALANPUR-AURAIYA	1	139	17	1.0	0.0	1.0
20	132 kV	RAIGHAT-LALITPUR	2	0	0	0.0	0.0	0.0
WR-NR						74.9	212.1	-137.2
Import/Export of WR (With SR)								
1	HVDC	BHADRAWATI B/B	-	0	1010	0.0	20.9	-20.9
2	HVDC	RAIGARH-PUGALUR	2	0	4009	0.0	55.8	-55.8
3	765 kV	SOLAPUR-RAICHUR	2	436	1745	1.4	13.4	-11.9
4	765 kV	WARDHA-NIZAMABAD	2	210	2219	0.1	25.0	-24.9
5	765 kV	WARORA-WARANGAL(NEW)	2	0	2933	0.0	39.4	-39.4
6	400 kV	KOLHAPUR-KUDGI	2	1292	0	17.9	0.0	17.9
7	220 kV	KOLHAPUR-CHIKODI	2	0	0	0.0	0.0	0.0
8	220 kV	PONDA-AMBEWADI	1	0	0	0.0	0.0	0.0
9	220 kV	XELDEM-AMBEWADI	1	0	120	0.0	2.2	-2.2
WR-SR						21.6	154.4	-132.8

INTERNATIONAL EXCHANGES					Import(+ve)/Export(-ve)		
State	Region	Line Name	Max (MW)	Min (MW)	Avg (MW)	Energy Exchange (MU)	
BHUTAN	ER	400kV MANGDECHHU-ALIPURDUAR 1,2&3 I.e. ALIPURDUAR RECEIPT (from MANGDECHU HEP 4*180MW)	-239	26	-72	-1.72	
	ER	400kV TALA-BINAGURI 1,2,4 (& 400kV MALBASE - BINAGURI) I.e. BINAGURI RECEIPT (from TALA HEP 6*170MW)	330	-223	2	0.04	
	ER	220kV CHUKHA-BIRPARA 1&2 (& 220kV MALBASE - BIRPARA) I.e. BIRPARA RECEIPT (from CHUKHA HEP 4*84MW)	-362	-246	-310	-7.44	
	NER	132kV GELEPHU-SALAKATI	-71	0	-58	-1.38	
	NER	132kV MOTANGA-RANGIA	-36	0	-24	-0.58	
NEPAL	NR	NEPAL IMPORT (FROM UP)	-70	0	-12	-0.30	
	NR	132kV MAHENDRANAGAR-TANAKPUR(NHPC)	-70	0	-14	-0.34	
	ER	NEPAL IMPORT (FROM BIHAR)	-73	0	-10	-0.23	
	ER	400kV DHALKEBAR-MUZAFFARPUR 1&2	-208	6	-15	-0.35	
BANGLADESH	ER	BHERAMARA B/B HVDC (B'DESH)	-924	-398	-801	-19.22	
	ER (Isolated from Indian Grid)	400kV GODDA_TPS-RAHANPUR (B'DESH) D/C	-1350	-812	-991	-23.78	
	NER	132kV COMILLA-SURAJMANI NAGAR 1&2	-106	0	-93	-2.22	

CROSS BORDER EXCHANGE SCHEDULE

Date of Reporting: 25-Dec-2025

Export From India (in MU)

Country	GNA (ISGS/PPA)	T-GNA							TOTAL
		BILATERAL TOTAL	COLLECTIVE						
			IDAM			RTM			
			IEX	PXIL	HPX	IEX	PXIL	HPX	
Bhutan	0.00	0.31	12.74	0.00	0.00	0.00	0.00	0.00	13.05
Nepal	0.50	0.00	0.00	0.00	0.00	1.49	0.00	0.00	1.99
Bangladesh	19.92	0.00	0.00	0.00	0.00	0.00	0.00	0.00	19.92
Myanmar	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total Export	20.42	0.31	12.74	0.00	0.00	1.49	0.00	0.00	34.96

Import by India(in MU)

Country	GNA (ISGA/PPA)	T-GNA							TOTAL	
		BILATERAL TOTAL	COLLECTIVE							
			IDAM			RTM				
			IEX	PXIL	HPX	IEX	PXIL	HPX		
Bhutan	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	
Nepal	0.00	0.00	0.00	0.00	0.00	0.00	1.43	0.00	0.00	1.43
Bangladesh	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Myanmar	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total Import	0.00	0.00	0.00	0.00	0.00	0.00	1.43	0.00	0.00	1.43

Net from India(in MU)

-ve : Export / +ve : Import

Country	GNA (ISGS/PPA)	T-GNA							TOTAL
		BILATERAL TOTAL	COLLECTIVE						
			IDAM			RTM			
			IEX	PXIL	HPX	IEX	PXIL	HPX	
Bhutan	0.00	-0.31	-12.74	0.00	0.00	0.00	0.00	0.00	-13.05
Nepal	-0.50	0.00	0.00	0.00	0.00	-0.07	0.00	0.00	-0.57
Bangladesh	-19.92	0.00	0.00	0.00	0.00	0.00	0.00	0.00	-19.92
Myanmar	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total Net	-20.42	-0.31	-12.74	0.00	0.00	-0.07	0.00	0.00	-33.54

15 Min (INSTANTANEOUS) ALL INDIA GRID FREQUENCY, GENERATION & DEMAND MET (SCADA DATA)												
TIME	FREQUENCY (Hz)	DEMAND MET (MW)	NUCLEAR (MW)	WIND (MW)	SOLAR (MW)	HYDRO** (MW)	GAS (MW)	THERMAL (MW)	OTHERS* (MW)	NET DEMAND MET (MW)	TOTAL GENERATION (MW)	NET TRANSNATIONAL EXCHANGE (MW)
		(A)	(B)	(C)	(D)	(E)	(F)	(G)	(H)	(I=A+(C+D))	(J=B+C+D+E+F+G+H)	(K) (+ve) Import, (-ve) Export
0:00	50.04	155816	4837	9350	0	7088	2588	132624	3581	146466	160068	-1577
0:15	49.99	155148	4845	9374	0	7032	2591	131998	3573	145774	159413	-1768
0:30	49.94	154485	4838	9362	0	7086	2607	131324	3561	145123	158778	-1684
0:45	49.94	154004	4837	9357	0	6994	2598	131169	3553	144647	158508	-1544
1:00	49.94	153936	4823	9247	0	6958	2594	130911	3579	144689	158112	-1471
1:15	49.99	152590	4824	9311	0	7019	2550	129648	3555	143279	156907	-1473
1:30	49.94	152034	4838	9300	0	6855	2561	129030	3592	142734	156176	-1450
1:45	49.84	150963	4830	9199	0	6838	2641	128160	3615	141764	155283	-1413
2:00	49.89	150659	4829	9060	0	6726	2585	128153	3549	141599	154902	-1438
2:15	49.89	150768	4841	8906	0	6596	2599	128356	3649	141862	154947	-1444
2:30	49.89	150654	4833	8674	0	6757	2646	128164	3595	141980	154669	-1311
2:45	49.94	150727	4839	8466	0	6710	2634	128480	3553	142261	154682	-1268
3:00	49.99	151097	4841	8416	0	7051	2614	128582	3556	142681	155060	-1210
3:15	49.99	151296	4850	8337	0	6998	2609	128756	3637	142959	155187	-1200
3:30	50.04	151002	4845	8247	0	6590	2606	129244	3527	142755	155059	-1230
3:45	49.99	151506	4847	8134	0	6616	2567	129658	3567	143372	155389	-1210
4:00	50.05	151579	4844	8213	0	6518	2611	129970	3608	143366	155764	-1214
4:15	50.00	154168	4838	8233	0	6618	2868	131969	3575	145935	158101	-1063
4:30	50.05	156124	4821	8196	0	6403	2890	134297	3557	147928	160164	-1125
4:45	50.05	157788	4846	8222	0	6741	2875	135413	3578	149566	161675	-1131
5:00	50.05	159945	4836	8270	6	6907	2975	137611	3605	151669	164210	-1172
5:15	50.05	164890	4840	8294	10	7904	3164	141293	3608	156586	169113	-1181
5:30	50.05	169176	4842	8337	9	9282	3274	144067	3694	160830	173505	-1270
5:45	50.10	173582	4840	8467	26	10638	3700	146592	3635	165089	177898	-1329
6:00	50.10	177648	4839	8612	58	11920	4114	148396	3711	168978	181650	-927
6:15	50.00	183061	4835	8746	111	13801	4147	150946	3611	174204	186197	-588
6:30	50.05	189531	4836	8711	185	17452	4655	153585	3595	180635	193019	-713
6:45	50.00	195453	4851	8766	268	20245	5146	156073	3640	186419	198989	-781
7:00	50.05	201258	4844	8731	694	23021	5304	158433	3660	191833	204687	-821
7:15	49.95	206235	4841	8727	1672	25407	5456	159919	3640	195836	209662	-851
7:30	49.95	210322	4837	8602	3427	26615	5564	160831	3650	198293	213526	-850
7:45	50.05	212439	4863	8551	6380	26501	5414	160225	3702	197508	215636	-913
8:00	50.05	214257	4849	8414	10921	24417	5008	160010	3799	194922	217418	-949
8:15	50.05	217887	4852	8156	16873	23437	5031	158793	3729	192858	220871	-933
8:30	50.10	220648	4851	7764	23469	21282	4750	157470	3706	189415	223292	-947
8:45	50.10	224158	4854	7274	30723	18202	4566	157214	3747	186161	226580	-1013
9:00	50.20	226261	4870	6361	37714	16074	4534	155064	3763	182186	228380	-1044
9:15	50.05	232243	4848	5838	44152	14994	4387	156187	3720	182253	234126	-1074
9:30	50.10	233832	4836	5431	49312	14309	3229	155302	3722	179089	236141	-1166
9:45	50.05	234603	4810	5027	53417	13034	2908	153780	3667	176159	236643	-1300
10:00	50.05	235117	4822	4947	57085	12051	2762	152196	3663	173085	237526	-1662
10:15	49.95	235555	4823	4923	60095	10461	2730	151609	3668	170537	238309	-2165
10:30	49.94	235637	4823	4568	63107	10237	2690	149473	3578	167962	238476	-2166
10:45	49.99	235235	4842	4379	64741	9265	2689	148432	3658	166115	238006	-2222
11:00	49.99	235227	4851	4187	66612	8357	2697	146076	3634	162728	236414	-2197
11:15	49.94	232786	4851	3961	67754	8176	2643	144310	3674	161071	235369	-2151
11:30	49.84	231628	4791	3807	68620	7663	2621	142872	3650	159201	234024	-2219
11:45	49.89	230424	4835	3545	69644	7430	2612	141173	3696	157235	232935	-2215
12:00	49.94	229127	4821	3388	70475	7378	2611	139188	3659	155264	231520	-2190
12:15	49.94	227856	4803	3306	71206	6958	2615	137273	3692	153344	229853	-2022
12:30	50.04	225308	4820	3251	71351	6928	2570	135390	3656	150706	227966	-2216
12:45	49.99	223321	4832	3207	70921	6686	2586	134234	3617	149193	226083	-2258
13:00	50.04	220292	4841	3164	71217	6699	2587	131101	3651	145911	223260	-2247
13:15	50.05	215333	4848	3131	70675	6366	2574	127308	3707	141527	218609	-2263
13:30	50.04	214306	4838	3078	70222	6340	2579	126980	3655	141006	217692	-2253
13:45	49.99	214068	4820	2884	68851	6046	2574	128316	3627	142333	217118	-2271
14:00	50.04	213207	4839	2772	67590	6107	2568	128932	3639	142845	216447	-2236
14:15	49.99	213170	4818	2756	65624	6426	2570	130320	3706	144790	216220	-2248
14:30	49.99	213817	4821	2674	63893	6710	2581	132632	3623	147250	216934	-2232
14:45	49.99	214599	4806	2647	61408	7025	2569	135904	3647	150544	218006	-2201
15:00	50.04	215112	4813	2615	58543	7590	2587	138997	3648	153954	218793	-2195
15:15	49.99	213039	4815	2539	55388	7837	2786	139352	3648	155112	216365	-2193
15:30	49.99	212691	4820	2506	51928	8309	3012	141587	3718	158257	215880	-2249
15:45	50.04	212510	4826	2411	47748	9816	3399	143782	3622	162351	215604	-2190
16:00	50.09	212476	3799	2407	42502	11079	3952	147277	3646	167567	214662	-2186
16:15	50.04	208873	4817	2401	36258	11630	4336	149500	3623	170214	212565	-2116
16:30	50.05	209472	4823	2424	29253	14335	5110	153325	3644	177795	212914	-1462
16:45	50.05	209553	4822	2457	21925	18069	5789	155600	3671	185171	212333	-1014
17:00	50.10	208778	4829	2433	15161	21930	5650	158000	3696	191184	211699	-937
17:15	50.00	204885	4811	2585	9080	24118	5542	158453	3618	193220	208207	-950
17:30	50.00	206885	4815	2858	4788	27967	6501	159753	3617	199239	210299	-954
17:45	49.85	209852	4801	3156	2076	31144	6569	161737	3660	204620	213143	-993
18:00	49.75	210968	4809	3506	804	31855	6600	162755	3644	206658	213973	-997
18:15	49.90	210963	4820	3925	429	32004	6369	162724	3683	206609	213954	-990
18:30	49.95	211194	4814	4353	318	31367	6700	162981	3634	206523	214167	-995
18:45	49.95	211403	4830	4750	273	31395	6608	163044	3649	206380	214549	-947
19:00	50.05	209020	4837	5162	159	29824	6049	162500	3646	203699	212177	-955
19:15	50.05	206113	4821	5615	138	27608	5142	162253	3656	200360	209233	-938
19:30	50.05	204240	4848	6019	0	26238	4729	161733	3695	198221	207262	-946
19:45	50.05	201069	4840	6492	0	24101	3733	161306	3682	194577	204154	-969
20:00	50.05	196307	4841	6954	0	21495	3355	159675	3714	189353	200034	-983
20:15	50.00	193054	4845	7304	0	18572	3094	158976	3711	185750	196502	-1046
20:30	50.00	190438	4838	7641	0	16720	2823	158035	3675	182797	193732	-1039
20:45	50.00	187813	4848	7984	0	15074	2790	156749	3784	179829	191229	-1018
21:00	50.00	184042	4844	8116	0	13395	2788	154594	3724	175926	187461	-987
21:15	49.95	181153	4848	8242	0	12567	2807	152154	3708	172911	184326	-948
21:30	49.95	178041	4844	8115	0	11558	2702	150397	3706	169926	181322	-972
21:45	49.95	175167	4855	7941	0	10484	2617	149081	3698	167226	178676	-1414
22:00	50.05	170750	4854	7792	0	9429	2602	146424	3700	162958	174801	-1647
22:15	49.95	170012	4846	7712	0	9682	2608	145373	3688	162300	173909	-1616
22:30	49.90	169111	4840	7769	0	9627	2609	144548	3713	161342	173106	-1649
22:45	50.00											