



National Load Despatch Centre
राष्ट्रीय भार प्रेषण केंद्र
GRID CONTROLLER OF INDIA LIMITED
ग्रिड कंट्रोलर ऑफ इंडिया लिमिटेड

(Government of India Enterprise/ भारत सरकार का उद्यम)
B-9, QUTUB INSTITUTIONAL AREA, KATWARIA SARAI, NEW DELHI -110016
बी-9, कुतुब इन्स्टीट्यूशनल एरिया, कटवारिया सराये, न्यू दिल्ली-110016

Ref: GRID-INDIA/NLDC/SO/Daily PSP Report

दिनांक: 30.11.2024

To,

- कार्यकारी निदेशक, पू.क्षे.भा.प्रे.के., 14, गोल्फ क्लब रोड, कोलकाता - 700033
Executive Director, ERLDC, 14 Golf Club Road, Tollygunge, Kolkata, 700033
- कार्यकारी निदेशक, ऊ.क्षे.भा.प्रे.के., 18/ए, शाहीद जीत सिंह सनसनवाल मार्ग, नई दिल्ली - 110016
Executive Director, NRLDC, 18-A, Shaheed Jeet Singh Marg, Katwaria Sarai, New Delhi - 110016
- कार्यकारी निदेशक, प.क्षे.भा.प्रे.के., एफ3, एम आई डी सी क्षेत्र, अंधेरी, मुंबई - 400093
Executive Director, WRLDC, F-3, M.I.D.C. Area, Marol, Andheri (East), Mumbai-400093
- कार्यकारी निदेशक, ऊ.पू.क्षे.भा.प्रे.के., डोंगतेह, लोअर नोंग्रह, लापालंग, शिलोंग - 793006
Executive Director, NERLDC, Dongteih, Lower Nongrah, Lapalang, Shillong - 793006, Meghalaya
- कार्यकारी निदेशक, द.क्षे.भा.प्रे.के., 29, रेस कोर्स क्रॉस रोड, बंगलुरु - 560009
Executive Director, SRLDC, 29, Race Course Cross Road, Bangalore-560009

Sub: Daily PSP Report for the date 29.11.2024.

महोदय/Dear Sir,

आईईजीसी-2023 की धारा स.-38(1) के प्रावधान के अनुसार, दिनांक 29-नवंबर-2024 की अखिल भारतीय प्रणाली की दैनिक ग्रिड निष्पादन रिपोर्ट रांभांप्रेके की वेबसाइट पर उपलब्ध है।

As per article 38(1) of the Indian Electricity Grid Code, the daily report pertaining power supply position of All India Power System for the date 29.11.2024, is available at the NLDC website.

धन्यवाद,
Thanks

Report for previous day

Date of Reporting: 30-Nov-2024

A. Power Supply Position at All India and Regional level

	NR	WR	SR	ER	NER	TOTAL
Demand Met during Evening Peak hrs(MW) (at 19:00 hrs; from RLDCs)	53225	60962	42943	21213	2669	181012
Peak Shortage (MW)	0	0	0	0	0	0
Energy Met (MU)	1167	1461	1062	430	45	4164
Hydro Gen (MU)	109	39	110	24	15	298
Wind Gen (MU)	14	81	47	-	-	142
Solar Gen (MU)*	146.74	91.03	87.62	2.84	1.13	329
Energy Shortage (MU)	0.61	0.00	0.00	0.02	0.00	0.63
Maximum Demand Met During the Day (MW) (From NLDC SCADA)	61434	71647	53804	21652	2876	207429
Time Of Maximum Demand Met	10:43	10:22	09:34	18:02	17:04	09:46

B. Frequency Profile (%)

Region	FVI	< 49.7	49.7 - 49.8	49.8 - 49.9	< 49.9	49.9 - 50.05	> 50.05
All India	0.044	0.30	2.30	3.95	6.55	77.85	15.60

C. Power Supply Position in States

Region	States	Max.Demand Met during the day (MW)	Shortage during maximum Demand (MW)	Energy Met (MU)	Drawal Schedule (MU)	OD(+)/UD(-) (MU)	Max OD (MW)	Energy Shortage (MU)
NR	Punjab	8596	0	156.6	71.7	-0.6	454	0.00
	Haryana	7738	0	150.1	111.0	-1.4	146	0.06
	Rajasthan	17194	0	324.8	113.9	-1.7	674	0.00
	Delhi	3984	0	72.1	71.9	-1.0	291	0.00
	UP	17679	0	318.4	109.6	0.4	600	0.06
	Uttarakhand	2227	0	41.6	32.9	0.1	64	0.07
	HP	2107	0	37.7	29.5	-0.4	59	0.00
	J&K(UT) & Ladakh(UT)	2874	0	57.6	50.9	0.4	162	0.42
	Chandigarh	217	0	3.8	3.5	0.3	72	0.00
WR	Railways_NR ISTS	209	0	4.3	3.9	0.4	42	0.00
	Chhattisgarh	4428	0	88.6	34.7	0.0	272	0.00
	Gujarat	21493	0	414.6	200.8	-1.6	496	0.00
	MP	17620	0	334.3	209.3	-3.9	672	0.00
	Maharashtra	26048	0	548.9	187.1	-4.8	504	0.00
	Goa	688	0	13.4	12.6	0.2	44	0.00
	DNHDDPDCL	1298	0	29.8	30.0	-0.2	56	0.00
	AMNSIL	826	0	18.7	9.2	0.4	249	0.00
	BALCO	527	0	12.6	12.7	-0.1	3	0.00
SR	Andhra Pradesh	10035	0	197.8	49.9	1.1	942	0.00
	Telangana	11180	0	207.2	103.4	0.4	605	0.00
	Karnataka	14853	0	254.2	72.6	0.2	581	0.00
	Kerala	4311	0	84.9	64.2	1.4	297	0.00
	Tamil Nadu	15137	0	310.0	190.3	1.4	918	0.00
	Puducherry	373	0	8.2	8.0	-0.3	36	0.00
ER	Bihar	4578	0	83.6	75.5	-0.5	204	0.02
	DVC	3133	0	65.6	-48.9	-0.8	241	0.00
	Jharkhand	1995	0	37.2	28.4	-1.2	148	0.00
	Odisha	5015	0	99.2	23.8	-2.5	313	0.00
	West Bengal	7328	0	142.4	21.9	-2.0	297	0.00
	Sikkim	101	0	1.6	1.7	-0.1	19	0.00
	Railways_ER ISTS	18	0	0.2	0.2	0.0	3	0.00
NER	Arunachal Pradesh	165	0	2.3	2.4	-0.3	46	0.00
	Assam	1655	0	28.1	21.0	0.3	142	0.00
	Manipur	215	0	1.1	3.1	-2.0	34	0.00
	Meghalaya	363	0	6.2	5.3	-0.1	277	0.00
	Mizoram	135	0	1.8	1.8	-0.7	17	0.00
	Nagaland	175	0	1.3	2.4	-1.3	24	0.00
	Tripura	241	0	4.0	4.8	0.0	47	0.00

D. Transnational Exchanges (MU) - Import(+ve)/Export(-ve)

	Bhutan	Nepal	Bangladesh	Godda -> Bangladesh
Actual (MU)	-2.5	1.9	-21.6	-12.1
Day Peak (MW)	-267.8	282.8	-991.0	-715.9

E. Import/Export by Regions (in MU) - Import(+ve)/Export(-ve); OD(+)/UD(-)

	NR	WR	SR	ER	NER	TOTAL
Schedule(MU)	248.1	-184.3	126.1	-193.4	3.4	0.0
Actual(MU)	238.0	-179.0	128.6	-198.4	2.6	-8.2
O/D/U/D(MU)	-10.2	5.3	2.6	-5.1	-0.8	-8.2

F. Generation Outage(MW)

	NR	WR	SR	ER	NER	TOTAL	% Share
Central Sector	5493	10064	6488	4163	655	26863	47
State Sector	9183	10195	8424	2749	332	30882	53
Total	14676	20259	14912	6912	986	57745	100

G. Sourcewise generation (Gross) (MU)

	NR	WR	SR	ER	NER	All India	% Share
Coal	648	1473	600	678	10	3408	75
Lignite	27	15	55	0	0	98	2
Hydro	109	39	110	24	15	298	7
Nuclear	32	53	76	0	0	160	4
Gas, Naptha & Diesel	2	13	6	0	25	45	1
RES (Wind, Solar, Biomass & Others)	187	174	158	6	1	526	12
Total	1005	1767	1004	708	51	4536	100
Share of RES in total generation (%)	18.60	9.86	15.74	0.82	2.22	11.60	
Share of Non-fossil fuel (Hydro,Nuclear and RES) in total generation(%)	32.61	15.07	34.26	4.28	32.63	21.72	

H. All India Demand Diversity Factor

Based on Regional Max Demands	1.019
Based on State Max Demands	1.044

I. All India Peak Demand and shortage at Solar and Non-Solar Hour

	Max Demand Met(MW)	Time	Shortage(MW)
Solar hr	207429	9:46	0
Non-Solar hr	192596	18:21	158

Diversity factor = Sum of regional or state maximum demands / All India maximum demand

**Note: All generation MU figures are gross

***Godda (Jharkhand) -> Bangladesh power exchange is through the radial connection (isolated from Indian Grid)

Solar Hours -> 06:00 to 18:00hrs and rest are Non-Solar Hours

*Source: RLDCs for solar connected to ISTS; SLDCs for embedded solar. Limited visibility of embedded solar data.

Executive Director-NLDC

INTER-REGIONAL EXCHANGES						Import=(+ve) /Export =(-ve) for NET (MU)		
						Date of Reporting: 30-Nov-2024		
Sl No	Voltage Level	Line Details	No. of Circuit	Max Import (MW)	Max Export (MW)	Import (MU)	Export (MU)	NET (MU)
Import/Export of ER (With NR)								
1	HVDC	ALIPURDUAR-AGRA	2	0	301	0.0	7.0	-7.0
2	HVDC	PUSAULI B/B	-	3	248	0.0	1.9	-1.9
3	765 kV	GAYA-VARANASI	2	0	1253	0.0	19.8	-19.8
4	765 kV	SASARAM-FATEHPUR	1	0	546	0.0	9.0	-9.0
5	765 kV	GAYA-BALIA	1	0	676	0.0	8.4	-8.4
6	400 kV	PUSAULI-VARANASI	1	1	192	0.0	1.7	-1.7
7	400 kV	PUSAULI -ALLAHABAD	1	65	108	0.0	0.2	-0.2
8	400 kV	MUZAFFARPUR-GORAKHPUR	2	73	441	0.0	6.1	-6.1
9	400 kV	PATNA-BALIA	2	0	807	0.0	14.8	-14.8
10	400 kV	NAUBATPUR-BALIA	2	0	257	0.0	4.7	-4.7
11	400 kV	BIHARSHARIFF-BALIA	2	101	129	0.0	1.5	-1.5
12	400 kV	MOTIHARI-GORAKHPUR	2	0	442	0.0	7.9	-7.9
13	400 kV	BIHARSHARIFF-VARANASI	2	0	328	0.0	0.0	0.0
14	220 kV	SAHUPURI-KARAMNASA	1	0	103	0.0	0.6	-0.6
15	132 kV	NAGAR UNTARI-RIHAND	1	0	0	0.1	0.0	0.1
16	132 kV	GARWAH-RIHAND	1	30	0	0.5	0.0	0.5
17	132 kV	KARMANASA-SAHUPURI	1	0	0	0.0	0.0	0.0
18	132 kV	KARMANASA-CHANDAUJI	1	0	0	0.0	0.0	0.0
ER-NR						0.6	83.3	-82.7
Import/Export of ER (With WR)								
1	765 kV	JHARSUGUDA-DHARAMJAIGARH	4	0	1000	0.0	13.6	-13.6
2	765 kV	NEW RANCHI-DHARAMJAIGARH	2	353	615	0.0	0.6	-0.6
3	765 kV	JHARSUGUDA-DURG	2	0	706	0.0	14.3	-14.3
4	400 kV	JHARSUGUDA-RAIGARH	4	0	685	0.0	11.1	-11.1
5	400 kV	RANCHI-SIPAT	2	51	313	0.0	2.3	-2.3
6	220 kV	BUDHIPADAR-RAIGARH	1	0	87	0.0	1.4	-1.4
7	220 kV	BUDHIPADAR-KORBA	2	63	85	0.0	0.3	-0.3
ER-WR						0.0	43.4	-43.4
Import/Export of ER (With SR)								
1	HVDC	JEYPORE-GAZUWAKA B/B	2	0	379	0.0	9.0	-9.0
2	HVDC	TALCHER-KOLAR BIPOLE	2	0	1214	0.0	29.0	-29.0
3	765 kV	ANGUL-SRIKAKULAM	2	0	2909	0.0	56.0	-56.0
4	400 kV	TALCHER-I/C	2	676	0	14.6	0.0	14.6
5	220 kV	BALIMELA-UPPER-SILERRU	1	0	0	0.0	0.0	0.0
ER-SR						0.0	94.0	-94.0
Import/Export of ER (With NER)								
1	400 kV	BINAGURI-BONGAIGAON	2	0	547	0.0	8.6	-8.6
2	400 kV	ALIPURDUAR-BONGAIGAON	2	0	614	0.0	8.8	-8.8
3	220 kV	ALIPURDUAR-SALAKATI	2	0	101	0.0	1.2	-1.2
ER-NER						0.0	18.5	-18.5
Import/Export of NER (With NR)								
1	HVDC	BISWANATH CHARIALI-AGRA	2	0	654	0.0	15.7	-15.7
NER-NR						0.0	15.7	-15.7
Import/Export of WR (With NR)								
1	HVDC	CHAMPA-KURUKSHETRA	2	0	1027	0.0	18.8	-18.8
2	HVDC	VINDHYACHAL B/B	-	0	307	0.0	7.2	-7.2
3	HVDC	MUNDRA-MOHINDERGARH	2	0	977	0.0	20.0	-20.0
4	765 kV	GWALIOR-AGRA	2	0	1767	0.0	25.9	-25.9
5	765 kV	GWALIOR-PHAGI	2	389	2000	0.6	28.5	-27.9
6	765 kV	JABALPUR-ORAI	2	0	922	0.0	31.4	-31.4
7	765 kV	GWALIOR-ORAI	1	876	0	14.1	0.0	14.1
8	765 kV	SATNA-ORAI	1	0	1048	0.0	20.9	-20.9
9	765 kV	BANASKANTHA-CHITORGARH	2	1024	288	9.6	0.3	9.3
10	765 kV	VINDHYACHAL-VARANASI	2	0	1997	0.0	35.0	-35.0
11	400 kV	ZERDA-KANKROLI	1	243	69	2.2	0.1	2.1
12	400 kV	ZERDA -BHINMAL	1	167	48	1.5	0.1	1.4
13	400 kV	VINDHYACHAL -RIHAND	1	967	0	21.4	0.0	21.4
14	400 kV	RAPP-SHUJALPUR	2	399	304	2.0	1.9	0.2
15	400 kV	NEEMUCH-Chittorgarh	2	604	368	3.0	2.6	0.4
16	220 kV	BHANPURA-RANPUR	1	0	197	0.0	3.4	-3.4
17	220 kV	BHANPURA-MORAK	1	0	30	0.0	1.9	-1.9
18	220 kV	MEHGAON-AURAIYA	1	108	0	1.4	0.0	1.4
19	220 kV	MALANPUR-AURAIYA	1	76	0	0.9	0.0	0.9
20	132 kV	GWALIOR-SAWAI MADHOPUR	1	0	0	0.0	0.0	0.0
21	132 kV	RAJGHAT-LALITPUR	2	0	0	0.0	0.0	0.0
WR-NR						56.6	197.9	-141.3
Import/Export of WR (With SR)								
1	HVDC	BHADRAWATI B/B	-	0	427	0.0	9.6	-9.6
2	HVDC	RAIGARH-PUGALUR	2	0	607	0.0	14.7	-14.7
3	765 kV	SOLAPUR-RAICHUR	2	153	1178	0.0	12.0	-11.9
4	765 kV	WARDHA-NIZAMABAD	2	0	1873	0.0	31.6	-31.6
5	765 kV	WARORA-WARANGAL(NEW)	2	0	2100	0.0	35.0	-35.0
6	400 kV	KOLHAPUR-KUDGI	2	1110	0	19.7	0.0	19.7
7	220 kV	KOLHAPUR-CHIKODI	2	0	0	0.0	0.0	0.0
8	220 kV	PONDA-AMBEWADI	1	0	0	0.0	0.0	0.0
9	220 kV	XELDEM-AMBEWADI	1	0	120	2.3	0.0	2.3
WR-SR						22.0	102.9	-80.9
INTERNATIONAL EXCHANGES								
State	Region	Line Name	Max (MW)	Min (MW)	Avg (MW)	Energy Exchange (MU)		
BHUTAN	ER	400kV MANGDECHHU-ALIPURDUAR 1,2&3 i.e. ALIPURDUAR RECEIPT (from MANGDECHU HEP 4*180MW)	281	-68	36	0.86		
	ER	400kV TALA-BINAGURI 1,2,4 (& 400kV MALBASE - BINAGURI) i.e. BINAGURI RECEIPT (from TALA HEP 6*170MW)	202	-34	75	1.79		
	ER	220kV CHUKHA-BIRPARA 1&2 (& 220kV MALBASE - BIRPARA) i.e. BIRPARA RECEIPT (from CHUKHA HEP 4*84MW)	-299	-176	-211	-5.05		
	NER	132kV GELEPHU-SALAKATI	-62	0	-5	-0.12		
	NER	132kV MOTANGA-RANGIA	12	0	3	0.07		
NEPAL	NR	NEPAL IMPORT (FROM UP)	-36	0	0	0.00		
	NR	132kV MAHENDRANAGAR-TANAKPUR(NHPC)	-36	0	0	0.00		
	ER	NEPAL IMPORT (FROM BIHAR)	0	0	0	0.00		
	ER	400kV DHALKEBAR-MUZAFFARPUR 1&2	258	5	78	1.88		
BANGLADESH	ER	BHERAMARA B/B HVDC (B'DESH)	-931	-730	-848	-20.36		
	ER (Isolated from Indian Grid)	400kV GODDA_TPS-RAHANPUR (B'DESH) D/C	-716	-399	-504	-12.09		
	NER	132kV COMILLA-SURAJMANI NAGAR 1&2	-60	0	-52	-1.24		

CROSS BORDER EXCHANGE SCHEDULE

Date of Reporting: 30-Nov-2024

Export From India (in MU)

Country	GNA (ISGS/PPA)	T-GNA							TOTAL
		BILATERAL TOTAL	COLLECTIVE						
			IDAM			RTM			
			IEX	PXIL	HPX	IEX	PXIL	HPX	
Bhutan	0.00	0.00	2.25	0.00	0.00	1.26	0.00	0.00	3.51
Nepal	0.00	0.00	0.00	0.00	0.00	0.28	0.00	0.00	0.28
Bangladesh	21.13	0.00	0.00	0.00	0.00	0.00	0.00	0.00	21.13
Myanmar	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total Export	21.13	0.00	2.25	0.00	0.00	1.54	0.00	0.00	24.92

Import by India(in MU)

Country	GNA (ISGA/PPA)	T-GNA							TOTAL
		BILATERAL TOTAL	COLLECTIVE						
			IDAM			RTM			
			IEX	PXIL	HPX	IEX	PXIL	HPX	
Bhutan	0.82	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.82
Nepal	0.00	0.00	0.00	0.00	0.00	2.14	0.00	0.00	2.14
Bangladesh	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Myanmar	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total Import	0.82	0.00	0.00	0.00	0.00	2.14	0.00	0.00	2.96

Net from India(in MU)

-ve : Export / +ve : Import

Country	GNA (ISGS/PPA)	T-GNA							TOTAL
		BILATERAL TOTAL	COLLECTIVE						
			IDAM			RTM			
			IEX	PXIL	HPX	IEX	PXIL	HPX	
Bhutan	0.82	0.00	-2.25	0.00	0.00	-1.26	0.00	0.00	-2.69
Nepal	0.00	0.00	0.00	0.00	0.00	1.87	0.00	0.00	1.87
Bangladesh	-21.13	0.00	0.00	0.00	0.00	0.00	0.00	0.00	-21.13
Myanmar	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total Net	-20.31	0.00	-2.25	0.00	0.00	0.61	0.00	0.00	-21.95

Date of Reporting: 30-Nov-2024												
15 Min (INSTANTANEOUS) ALL INDIA GRID FREQUENCY, GENERATION & DEMAND MET (SCADA DATA)												
TIME	FREQUENCY (Hz)	DEMAND MET (MW)	NUCLEAR (MW)	WIND (MW)	SOLAR (MW)	HYDRO** (MW)	GAS (MW)	THERMAL (MW)	OTHERS* (MW)	NET DEMAND MET (MW)	TOTAL GENERATION (MW)	NET TRANSNATIONAL EXCHANGE (MW) (+ve) Import, (-ve) Export
		(A)	(B)	(C)	(D)	(E)	(F)	(G)	(H)	(I=A-(C+D))	(J=B+C+D+E+F+G+H)	(K)
0:00	50.08	142943	6316	7532	84	8199	1805	119647	2644	135327	146227	-887
0:15	49.93	142447	6312	7575	85	8058	1765	118988	2626	134787	145409	-831
0:30	50.03	141852	6292	7473	87	8600	1795	117841	2715	134292	144803	-815
0:45	49.98	140882	6301	7417	89	8181	1791	117320	2687	133376	143786	-819
1:00	49.98	140269	6316	7505	89	8192	1775	116736	2662	132675	143275	-839
1:15	49.98	139751	6316	7555	90	8534	1787	115719	2674	132106	142675	-848
1:30	49.98	138860	6306	7390	88	8283	1782	115294	2639	131382	141782	-857
1:45	49.98	138377	6307	7574	86	8217	1775	114857	2686	130717	141502	-855
2:00	50.03	136860	6305	7580	81	8174	1780	113448	2653	129199	140021	-838
2:15	49.98	136226	6321	7550	86	7779	1773	113278	2660	128590	139447	-756
2:30	49.98	136264	6334	7674	90	7481	1768	113193	2652	128500	139192	-737
2:45	49.98	135918	6318	7586	88	7188	1782	113234	2651	128244	138847	-654
3:00	50.03	135141	6326	7474	90	7161	1783	112852	2632	127577	138318	-659
3:15	49.98	135612	6309	7439	123	7078	1830	113361	2676	128050	138816	-757
3:30	49.98	135345	6311	7325	131	7155	1835	113281	2628	127889	138666	-795
3:45	49.98	135982	6299	7229	131	7141	1833	113949	2659	128622	139241	-807
4:00	50.03	136102	6316	7084	131	7264	1846	114016	2642	128887	139299	-802
4:15	49.98	138507	6313	7209	132	7673	1861	115992	2613	131166	141793	-817
4:30	49.98	140360	6316	7093	133	7792	1871	117800	2652	133134	143657	-817
4:45	49.98	142441	6313	6992	133	8077	1848	119960	2621	135316	145944	-818
5:00	50.03	145026	6314	6858	132	8584	1857	122303	2663	138036	148711	-869
5:15	50.03	149361	6303	6606	137	9378	1857	126127	2652	142618	153060	-807
5:30	50.03	152581	6317	6578	136	9795	1862	128778	2665	145867	156131	-681
5:45	50.03	157505	6318	6549	137	10834	1846	132702	2679	150819	161065	-728
6:00	50.13	160695	6310	6487	127	12693	1857	134260	2656	154081	164390	-747
6:15	49.93	166573	6305	6411	108	14423	1829	138313	2671	160054	170060	-731
6:30	50.03	173475	6292	6486	216	17122	1866	142757	2633	166773	177372	-736
6:45	49.98	179328	6293	6528	324	19177	1874	146226	2664	172476	183086	-749
7:00	49.98	183837	6319	6442	773	20702	1872	148855	2623	176622	187586	-741
7:15	49.78	187792	6304	6564	1618	21517	1871	150988	2639	179610	191501	-742
7:30	49.93	191022	6313	6688	3039	21788	1884	152344	2663	181295	194719	-740
7:45	49.93	193095	6299	6642	5472	20792	1870	152664	2689	180981	196428	-728
8:00	50.03	194116	6314	6523	8919	19381	1871	151859	2721	178674	197588	-746
8:15	49.93	195884	6315	6056	12901	17620	1856	151446	2848	176927	199042	-734
8:30	49.93	197846	6299	5714	17042	16400	1874	151015	2804	175090	201148	-741
8:45	50.03	200442	6313	5352	21265	14820	1858	151471	2840	173825	203919	-718
9:00	50.03	201149	6297	4887	25112	13340	1850	150151	2793	171150	204430	-751
9:15	49.93	204312	6296	4342	28756	12740	1862	150690	2888	171214	207574	-764
9:30	49.93	206222	6278	3792	32290	12200	1877	150572	2917	170140	209926	-837
9:45	50.03	207220	6282	3433	34932	11504	1867	150032	2921	168855	210971	-889
10:00	50.03	206827	6278	3113	37646	10948	1873	147821	2904	166068	210583	-935
10:15	49.98	205528	6266	2968	40249	10041	1797	145588	2934	162311	209843	-933
10:30	50.03	206204	6304	3008	42473	9459	1801	144532	2939	160723	210516	-1051
10:45	50.03	206709	6297	3092	44054	8894	1674	143555	2986	159563	210552	-1202
11:00	50.03	205907	6302	3181	45854	8979	1665	140947	3008	156872	209936	-1243
11:15	49.98	203767	6285	2989	47063	7875	1662	138817	3000	153715	207691	-1351
11:30	49.98	202726	6282	3024	47772	8060	1673	136809	2985	151930	206605	-1388
11:45	49.98	202365	6287	2930	48383	8239	1690	135813	2986	151052	206328	-1334
12:00	50.00	201063	6282	2861	48448	8263	1665	134248	3030	149754	204797	-1335
12:15	50.02	199358	6286	2777	48290	8007	1704	133147	2982	148291	203193	-1281
12:30	50.02	198227	6277	2715	47661	8136	1680	132547	2995	147851	202011	-1157
12:45	50.02	197159	6271	2737	48282	7901	1691	131104	2992	146140	200978	-1170
13:00	50.07	193919	6286	2752	47934	7527	1672	128851	2999	143233	198021	-1260
13:15	50.07	193036	6287	2746	47472	7165	1652	125703	2988	140088	194013	-1276
13:30	49.97	189511	6284	2792	46706	7259	1672	125894	2991	140013	193598	-1263
13:45	50.06	190072	6286	2933	45593	7364	1667	127136	2983	141546	193962	-1315
14:00	50.11	188920	6298	3052	43817	7372	1675	127580	2977	142051	192771	-1296
14:15	50.01	188466	6275	3252	41615	7269	1671	129394	2968	143599	192444	-1207
14:30	49.96	189608	6283	3305	39371	7539	1684	132285	2960	146932	193427	-1099
14:45	49.96	189599	6276	3365	37134	8028	1702	134084	2966	149100	193555	-1112
15:00	50.01	189427	6261	3468	34437	8508	1734	135932	2913	151522	193253	-1094
15:15	50.01	188998	6265	3641	31747	8873	1816	137562	2906	153610	192810	-1059
15:30	50.06	188849	6280	3637	28706	9427	1826	140015	2913	156506	192804	-1047
15:45	50.01	187668	6265	3603	25313	9677	1849	141832	2905	158752	191444	-1057
16:00	50.01	187108	6258	3610	21707	10850	1882	143615	2858	161791	190780	-981
16:15	50.01	185561	6257	3530	17898	11708	1871	144981	2857	164133	189102	-1064
16:30	50.06	186805	6266	3445	14024	13902	1864	148252	2948	169336	190701	-1061
16:45	49.96	187250	6288	3357	9754	15722	1838	151073	2888	174139	190920	-1002
17:00	49.96	188343	6267	3360	6324	18680	1854	152522	2863	178659	191870	-945
17:15	49.95	188583	6278	3338	3644	20588	1867	153443	2872	181601	192030	-989
17:30	49.85	190066	6269	3310	1541	23445	1876	154044	2944	185215	193429	-1018
17:45	49.75	191440	6271	3502	456	25543	1874	154079	2923	187482	194648	-949
18:00	49.96	191743	6261	3746	157	26021	1871	154033	2799	187840	194888	-931
18:15	50.01	192180	6293	4052	87	27014	1862	153303	2819	188041	195430	-925
18:30	50.05	191800	6280	4305	41	26703	1871	153181	2855	187454	195236	-927
18:45	50.05	191447	6297	4563	45	26763	1812	152630	2840	186839	194950	-912
19:00	50.05	188709	6304	4903	44	24890	1773	151292	2843	183762	192049	-892
19:15	50.05	186069	6307	5293	43	24251	1706	149246	2828	180733	189674	-948
19:30	50.05	183283	6309	5387	46	23155	1665	147332	2837	177850	186731	-934
19:45	50.05	179949	6302	5658	40	21038	1640	145998	2820	174251	183496	-906
20:00	50.05	175219	6294	5879	44	18167	1628	143884	2852	169296	178748	-883
20:15	50.00	171859	6284	6151	34	15967	1743	142398	2843	165674	175420	-865
20:30	50.00	169314	6308	6190	35	15112	1635	140765	2792	163089	172837	-877
20:45	49.95	166934	6308	6362	15	13419	1631	140066	2760	160557	170561	-801
21:00	50.00	163785	6295	6363	32	12285	1640	138028	2822	157390	167465	-750
21:15	50.06	161631	6298	6397	32	12209	1635	135792	2777	155202	165140	-716
21:30	50.06	159465	6313	6587	32	11668	1632	134025	2753	152846	163010	-700
21:45	50.01	156877	6297	6790	32	10666	1631	132266	2809	150055	160491	-775
22:00	50.06	154056	6308	7048	30	9791	1782	130307	2739	146978	158005	-767
22:15	49.95	153537	6314	7106	28	9736	1634	129759	2768	146403	157345	-759
22:30	50.00	153161	6305	7091	30	9949	1635	128980	2787	146040	156777	-779
22:45	50.00											