



National Load Despatch Centre
राष्ट्रीय भार प्रेषण केंद्र
GRID CONTROLLER OF INDIA LIMITED
ग्रिड कंट्रोलर ऑफ इंडिया लिमिटेड

(Government of India Enterprise/ भारत सरकार का उद्यम)
B-9, QUTUB INSTITUTIONAL AREA, KATWARIA SARAI, NEW DELHI -110016
बी-9, कुतुब इन्स्टीट्यूशनल एरिया, कटवारिया सराये, न्यू दिल्ली-110016

Ref: POSOCO/NLDC/SO/Daily PSP Report

दिनांक: 22-May-2024

To,

- कार्यकारी निदेशक, पू.क्षे.भा.प्रे.के., 14, गोल्फ क्लब रोड, कोलकाता - 700033
Executive Director, ERLDC, 14 Golf Club Road, Tollygunge, Kolkata, 700033
- कार्यकारी निदेशक, ऊ.क्षे.भा.प्रे.के., 18/ए, शाहीद जीत सिंह सनसनवाल मार्ग, नई दिल्ली - 110016
Executive Director, NRLDC, 18-A, Shaheed Jeet Singh Marg, Katwaria Sarai, New Delhi - 110016
- कार्यकारी निदेशक, प.क्षे.भा.प्रे.के., एफ3, एम आई डी सी क्षेत्र, अंधेरी, मुंबई - 400093
Executive Director, WRLDC, F-3, M.I.D.C. Area, Marol, Andheri (East), Mumbai-400093
- कार्यकारी निदेशक, ऊ.पू.क्षे.भा.प्रे.के., डोंगतेह, लोअर नोंग्रह, लापालंग, शिलोंग - 793006
Executive Director, NERLDC, Dongteih, Lower Nongrah, Lapalang, Shillong - 793006, Meghalaya
- कार्यकारी निदेशक, द.क्षे.भा.प्रे.के., 29, रेस कोर्स क्रॉस रोड, बंगलुरु - 560009
Executive Director, SRLDC, 29, Race Course Cross Road, Bangalore-560009

Sub: Daily PSP Report for the date 21.05.2024.

महोदय/Dear Sir,

आई०ई०जी०सी०-2010 की धारा स.-5.5.1 के प्रावधान के अनुसार, दिनांक 21-मई-2024 की अखिल भारतीय प्रणाली की दैनिक ग्रिड निष्पादन रिपोर्ट रा०भा०प्रे०के० की वेबसाइट पर उपलब्ध है।

As per article 5.5.1 of the Indian Electricity Grid Code, the daily report pertaining power supply position of All India Power System for the date 21-May-2024, is available at the NLDC website.

धन्यवाद,
Thanks

Report for previous day

Date of Reporting: 22-May-2024

A. Power Supply Position at All India and Regional level

	NR	WR	SR	ER	NER	TOTAL
Demand Met during Evening Peak hrs(MW) (at 20:00 hrs; from RLDCs)	75432	66348	46451	27259	3407	218897
Peak Shortage (MW)	785	0	0	400	0	1185
Energy Met (MU)	1763	1611	1048	589	64	5075
Hydro Gen (MU)	349	63	32	28	18	490
Wind Gen (MU)	9	117	42	-	-	168
Solar Gen (MU)*	175.17	96.21	122.22	3.77	1.17	399
Energy Shortage (MU)	5.78	1.01	0.00	2.68	0.00	9.47
Maximum Demand Met During the Day (MW) (From NLDC SCADA)	82284	74126	48819	28969	3473	233806
Time Of Maximum Demand Met	14:30	14:59	14:43	23:26	18:45	14:59

B. Frequency Profile (%)

Region	FVI	< 49.7	49.7 - 49.8	49.8 - 49.9	< 49.9	49.9 - 50.05	> 50.05
All India	0.026	0.00	0.00	2.58	2.58	80.30	17.12

C. Power Supply Position in States

Region	States	Max.Demand Met during the day (MW)	Shortage during maximum Demand (MW)	Energy Met (MU)	Drawal Schedule (MU)	OD(+)/UD(-) (MU)	Max OD (MW)	Energy Shortage (MU)
NR	Punjab	14186	0	272.0	136.9	1.7	718	0.00
	Haryana	11749	0	248.3	183.4	2.9	482	0.00
	Rajasthan	16673	0	348.4	141.4	1.4	413	5.10
	Delhi	7703	0	158.4	124.8	1.2	424	0.00
	UP	27759	0	574.7	260.0	0.9	229	0.00
	Uttarakhand	2681	0	57.3	27.9	1.0	213	0.00
	HP	1685	0	36.6	1.1	-0.6	49	0.00
	J&K(UT) & Ladakh(UT)	2521	147	54.8	28.9	-0.1	167	0.68
	Chandigarh	413	0	8.0	7.6	0.3	44	0.00
WR	Railways_NR ISTS	220	0	4.3	3.8	0.5	95	0.00
	Chhattisgarh	5028	0	111.9	52.0	0.0	372	0.00
	Gujarat	24728	0	505.0	147.6	-5.0	761	0.00
	MP	13710	0	297.4	162.9	-2.0	548	1.01
	Maharashtra	28035	0	618.5	197.7	-2.4	929	0.00
	Goa	767	0	17.0	14.7	2.1	77	0.00
	DNHDDPDCL	1278	0	29.8	29.6	0.2	83	0.00
	AMNSIL	867	0	19.2	9.1	0.4	287	0.00
	BALCO	522	0	12.5	12.5	0.0	5	0.00
SR	Andhra Pradesh	10331	0	215.2	72.9	0.4	645	0.00
	Telangana	9190	0	192.2	69.7	-0.6	426	0.00
	Karnataka	10648	0	216.3	94.4	-3.3	803	0.00
	Kerala	3924	0	81.0	64.5	0.5	274	0.00
	Tamil Nadu	15549	0	332.9	199.9	-3.3	924	0.00
	Puducherry	431	0	10.0	9.8	-0.4	20	0.00
	Railways_SR ISTS	220	0	4.3	3.8	0.5	95	0.00
ER	Bihar	6613	0	127.8	115.4	1.8	461	0.89
	DVC	3557	0	77.1	-38.4	0.5	338	0.00
	Jharkhand	2179	0	45.3	31.9	0.8	316	1.79
	Odisha	6649	0	122.8	49.9	2.9	1155	0.00
	West Bengal	11199	0	214.6	69.7	-2.0	247	0.00
	Sikkim	97	0	1.5	1.4	0.1	62	0.00
	Railways_ER ISTS	12	0	0.1	0.2	0.0	3	0.00
NER	Arunachal Pradesh	151	0	2.8	2.8	-0.1	27	0.00
	Assam	2269	0	42.2	35.7	-0.2	158	0.00
	Manipur	194	0	2.8	3.0	-0.2	12	0.00
	Meghalaya	320	0	5.6	2.7	-0.1	37	0.00
	Mizoram	122	0	2.0	1.8	-0.2	20	0.00
	Nagaland	173	0	2.7	2.7	0.0	28	0.00
	Tripura	346	0	6.1	6.2	0.0	82	0.00

D. Transnational Exchanges (MU) - Import(+ve)/Export(-ve)

	Bhutan	Nepal	Bangladesh	Godda -> Bangladesh
Actual (MU)	2.5	-9.2	-22.8	-15.4
Day Peak (MW)	334.0	-724.4	-1055.0	-766.0

E. Import/Export by Regions (in MU) - Import(+ve)/Export(-ve); OD(+)/UD(-)

	NR	WR	SR	ER	NER	TOTAL
Schedule(MU)	350.0	-363.5	82.6	-81.8	12.6	0.0
Actual(MU)	353.2	-391.0	80.9	-64.8	13.5	-8.1
O/D/U/D(MU)	3.2	-27.5	-1.7	17.0	0.9	-8.1

F. Generation Outage(MW)

	NR	WR	SR	ER	NER	TOTAL	% Share
Central Sector	1851	5291	3212	2606	501	13461	49
State Sector	4346	3768	4243	1544	109	14008	51
Total	6196	9059	7455	4150	610	27469	100

G. Sourcewise generation (Gross) (MU)

	NR	WR	SR	ER	NER	All India	% Share
Coal	864	1686	694	707	13	3963	72
Lignite	15	14	63	0	0	92	2
Hydro	349	63	32	28	18	490	9
Nuclear	29	60	51	0	0	140	3
Gas, Naptha & Diesel	66	115	13	0	24	217	4
RES (Wind, Solar, Biomass & Others)	192	216	190	5	1	605	11
Total	1515	2153	1043	740	56	5506	100

Share of RES in total generation (%)	12.68	10.03	18.24	0.70	2.09	10.98
Share of Non-fossil fuel (Hydro,Nuclear and RES) in total generation(%)	37.65	15.74	26.16	4.48	34.93	22.42

H. All India Demand Diversity Factor

Based on Regional Max Demands	1.016
Based on State Max Demands	1.045

I. All India Peak Demand and shortage at Solar and Non-Solar Hour

	Max Demand Met(MW)	Time	Shortage(MW)
Solar hr	233806	14:59	45
Non-Solar hr	222211	22:28	2833

Diversity factor = Sum of regional or state maximum demands / All India maximum demand

**Note: All generation MU figures are gross

***Godda (Jharkhand) -> Bangladesh power exchange is through the radial connection (isolated from Indian Grid)

Solar Hours -> 07:00 to 17:00hrs and rest are Non-Solar Hours

*Source: RLDCs for solar connected to ISTS; SLDCs for embedded solar. Limited visibility of embedded solar data.

Executive Director-NLDC

INTER-REGIONAL EXCHANGES

Import=(+ve) /Export =(-ve) for NET (MU)

Date of Reporting: 22-May-2024

Sl No	Voltage Level	Line Details	No. of Circuit	Max Import (MW)	Max Export (MW)	Import (MU)	Export (MU)	NET (MU)
Import/Export of ER (With NR)								
1	HVDC	ALIPURDUAR-AGRA	2	0	0	0.0	0.0	0.0
2	HVDC	PUSAULI B/B	-	2	0	0.0	0.0	0.0
3	765 kV	GAYA-VARANASI	2	691	674	0.0	0.6	-0.6
4	765 kV	SASARAM-FATEHPUR	1	164	536	0.0	4.9	-4.9
5	765 kV	GAYA-BALIA	1	0	668	0.0	11.3	-11.3
6	400 kV	PUSAULI-VARANASI	1	40	62	0.0	0.0	0.0
7	400 kV	PUSAULI -ALLAHABAD	1	61	40	0.0	0.0	0.0
8	400 kV	MUZAFFARPUR-GORAKHPUR	2	186	325	0.0	1.0	-1.0
9	400 kV	PATNA-BALIA	2	25	761	0.0	11.0	-11.0
10	400 kV	NAUBATPUR-BALIA	2	43	412	0.0	3.1	-3.1
11	400 kV	BIHARSHARIFF-BALIA	2	350	18	2.7	0.0	2.7
12	400 kV	MOTIHARI-GORAKHPUR	2	71	398	0.0	5.3	-5.3
13	400 kV	BIHARSHARIFF-VARANASI	2	188	283	0.0	0.0	0.0
14	220 kV	SAHUPURI-KARAMNASA	1	20	87	0.0	0.9	-0.9
15	132 kV	NAGAR UNTARI-RIHAND	1	0	0	0.0	0.0	0.0
16	132 kV	GARWAH-RIHAND	1	30	0	0.7	0.0	0.7
17	132 kV	KARMANASA-SAHUPURI	1	0	0	0.0	0.0	0.0
18	132 kV	KARMANASA-CHANDAULI	1	0	0	0.0	0.0	0.0
ER-NR						3.4	38.0	-34.6
Import/Export of ER (With WR)								
1	765 kV	JHARSUGUDA-DHARAMJAIGARH	4	1017	938	0.0	6.0	-6.0
2	765 kV	NEW RANCHI-DHARAMJAIGARH	2	2016	0	27.5	0.0	27.5
3	765 kV	JHARSUGUDA-DURG	2	100	791	0.0	9.9	-9.9
4	400 kV	JHARSUGUDA-RAIGARH	4	316	217	0.4	0.0	0.4
5	400 kV	RANCHI-SIPAT	2	896	0	10.1	0.0	10.1
6	220 kV	BUDHIPADAR-RAIGARH	1	120	66	0.0	0.0	0.0
7	220 kV	BUDHIPADAR-KORBA	2	344	0	3.3	0.0	3.3
ER-WR						41.3	16.0	25.3
Import/Export of ER (With SR)								
1	HVDC	JEYPORE-GAZUWAKA B/B	2	0	625	0.0	10.9	-10.9
2	HVDC	TALCHER-KOLAR BIPOLE	2	0	1688	0.0	36.2	-36.2
3	765 kV	ANGUL-SRIKAKULAM	2	0	1871	0.0	33.0	-33.0
4	400 kV	TALCHER-I/C	2	344	483	0.0	2.9	-2.9
5	220 kV	BALIMELA-UPPER-SILERRU	1	0	0	0.0	0.0	0.0
ER-SR						0.0	80.1	-80.1
Import/Export of ER (With NER)								
1	400 kV	BINAGURI-BONGAIGAON	2	52	149	0.1	1.7	-1.6
2	400 kV	ALIPURDUAR-BONGAIGAON	2	195	403	0.0	3.7	-3.7
3	220 kV	ALIPURDUAR-SALAKATI	2	33	65	0.0	0.5	-0.5
ER-NER						0.1	5.9	-5.8
Import/Export of NER (With NR)								
1	HVDC	BISWANATH CHARIALI-AGRA	2	315	0	7.4	0.0	7.4
NER-NR						7.4	0.0	7.4
Import/Export of WR (With NR)								
1	HVDC	CHAMPA-KURUKSHETRA	2	0	6061	0.0	108.6	-108.6
2	HVDC	VINDHYACHAL B/B	-	491	52	5.7	1.1	4.6
3	HVDC	MUNDRA-MOHINDERGARH	2	0	1661	0.0	42.4	-42.4
4	765 kV	GWALIOR-AGRA	2	0	2590	0.0	45.1	-45.1
5	765 kV	GWALIOR-PHAGI	2	469	1687	1.1	17.8	-16.7
6	765 kV	JABALPUR-ORAI	2	0	1121	0.0	38.6	-38.6
7	765 kV	GWALIOR-ORAI	1	682	0	10.0	0.0	10.0
8	765 kV	SATNA-ORAI	1	0	1155	0.0	23.6	-23.6
9	765 kV	BANASKANTHA-CHITORGARH	2	78	1419	0.1	9.9	-9.8
10	765 kV	VINDHYACHAL-VARANASI	2	0	3530	0.0	70.2	-70.2
11	400 kV	ZERDA-KANKROLI	1	93	230	0.5	1.0	-0.5
12	400 kV	ZERDA -BHINMAL	1	93	229	0.5	1.0	-0.5
13	400 kV	VINDHYACHAL -RIHAND	1	964	0	20.4	0.0	20.4
14	400 kV	RAPP-SHUJALPUR	2	239	396	1.0	3.8	-2.7
15	400 kV	NEEMUCH-Chittorgarh	2	355	370	2.0	3.2	-1.2
16	220 kV	BHANPURA-RANPUR	1	0	133	0.0	2.6	-2.6
17	220 kV	BHANPURA-MORAK	1	0	30	0.0	2.7	-2.7
18	220 kV	MEHGAON-AURAIYA	1	88	12	0.8	0.0	0.7
19	220 kV	MALANPUR-AURAIYA	1	59	26	0.3	0.1	0.2
20	132 kV	GWALIOR-SAWAI MADHOPUR	1	0	0	0.0	0.0	0.0
21	132 kV	RAJGHAT-LALITPUR	2	0	0	0.0	0.0	0.0
WR-NR						42.2	371.5	-329.3
Import/Export of WR (With SR)								
1	HVDC	BHADRAWATI B/B	-	300	306	3.9	3.2	0.8
2	HVDC	RAIGARH-PUGALUR	2	0	2015	0.0	43.0	-43.0
3	765 kV	SOLAPUR-RAICHUR	2	1856	777	13.7	1.6	12.1
4	765 kV	WARDHA-NIZAMABAD	2	149	1457	0.1	15.7	-15.6
5	765 kV	WARORA-WARANGAL(NEW)	2	80	1481	0.0	17.5	-17.5
6	400 kV	KOLHAPUR-KUDGI	2	1531	0	22.4	0.0	22.4
7	220 kV	KOLHAPUR-CHIKODI	2	0	0	0.0	0.0	0.0
8	220 kV	PONDA-AMBEWADI	1	0	81	1.8	0.0	1.8
9	220 kV	XELDEM-AMBEWADI	1	0	121	2.5	0.0	2.5
WR-SR						44.4	80.8	-36.4

INTERNATIONAL EXCHANGES					Import(+ve)/Export(-ve)		
State	Region	Line Name	Max (MW)	Min (MW)	Avg (MW)	Energy Exchange (MU)	
BHUTAN	ER	400kV MANGDECHHU-ALIPURDUAR 1,2&3 i.e. ALIPURDUAR RECEIPT (from MANGDECHU HEP 4*180MW)	225	110	160	3.84	
	ER	400kV TALA-BINAGURI 1,2,4 (& 400kV MALBASE - BINAGURI) i.e. BINAGURI RECEIPT (from TALA HEP 6*170MW)	111	-32	31	0.73	
	ER	220kV CHUKHA-BIRPARA 1&2 (& 220kV MALBASE - BIRPARA) i.e. BIRPARA RECEIPT (from CHUKHA HEP 4*84MW)	-158	-64	-104	-2.51	
	NER	132kV GELEPHU-SALAKATI	15	0	7	0.16	
	NER	132kV MOTANGA-RANGIA	59	0	10	0.25	
NEPAL	NR	NEPAL IMPORT (FROM UP)	0	0	0	-0.84	
	NR	132kV MAHENDRANAGAR-TANAKPUR(NHPC)	0	0	0	-0.64	
	ER	NEPAL IMPORT (FROM BIHAR)	-318	0	-134	-3.21	
	ER	400kV DHALKEBAR-MUZAFFARPUR 1&2	-406	-23	-187	-4.49	
BANGLADESH	ER	BHERAMARA B/B HVDC (B'DESH)	-943	-655	-857	-20.57	
	ER (Isolated from Indian Grid)	400kV GODDA_TPS-RAHANPUR (B'DESH) D/C	-766	-458	-643	-15.43	
	NER	132kV COMILLA-SURAJMANI NAGAR 1&2	-112	0	-92	-2.21	

Export From India (in MU)

Country	GNA (ISGS/PPA)	T-GNA							TOTAL	
		BILATERAL TOTAL	COLLECTIVE							
			IDAM			RTM				
			IEX	PXIL	HPX	IEX	PXIL	HPX		
Bhutan	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	
Nepal	0.35	0.00	3.87	0.00	0.00	0.00	0.37	0.00	0.00	4.59
Bangladesh	20.62	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	20.62
Myanmar	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total Export	20.97	0.00	3.87	0.00	0.00	0.00	0.37	0.00	0.00	25.21

Import by India(in MU)

Country	GNA (ISGA/PPA)	T-GNA							TOTAL
		BILATERAL TOTAL	COLLECTIVE						
			IDAM			RTM			
			IEX	PXIL	HPX	IEX	PXIL	HPX	
Bhutan	2.38	0.00	0.00	0.00	0.00	0.00	0.00	0.00	2.38
Nepal	0.00	0.00	0.00	0.00	0.00	0.12	0.00	0.00	0.12
Bangladesh	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Myanmar	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total Import	2.38	0.00	0.00	0.00	0.00	0.12	0.00	0.00	2.50

Net from India(in MU)

-ve : Export / +ve : Import

Country	GNA (ISGS/PPA)	T-GNA							TOTAL
		BILATERAL TOTAL	COLLECTIVE						
			IDAM			RTM			
			IEX	PXIL	HPX	IEX	PXIL	HPX	
Bhutan	2.38	0.00	0.00	0.00	0.00	0.00	0.00	0.00	2.38
Nepal	-0.35	0.00	-3.87	0.00	0.00	-0.25	0.00	0.00	-4.47
Bangladesh	-20.62	0.00	0.00	0.00	0.00	0.00	0.00	0.00	-20.62
Myanmar	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total Net	-18.59	0.00	-3.87	0.00	0.00	-0.25	0.00	0.00	-22.71