National Load Despatch Centre
राष्ट्रीय भार प्रेषण केंद्र
GRID CONTROLLER OF INDIA LIMITED
ग्रिड कंट्रोलर ऑफ इंडिया लिमिटेड
(Government of India Enterprise/ भारत सरकार का उद्यम)
B-9, QUTUB INSTITUTIONAL AREA, KATWARIA SARAI, NEW DELHI -110016
बी-9, कुतुब इन्स्टीट्यूशनल एरिया, कटवारिया सराये, न्यू दिल्ली-110016

Ref: GRID-INDIA/NLDC/SO/Daily PSP Report दिनांक: 16.12.2025

To,

1. कार्यकारी निदेशक, पू .क्षे .भा .प्रे .के.,14 , गोल्फ क्लब रोड , कोलकाता - 700033
   Executive Director, ERLDC, 14 Golf Club Road, Tollygunge, Kolkata, 700033
2. कार्यकारी निदेशक, ऊ. क्षे. भा. प्रे. के., 18/ ए , शहीद जीत सिंह सनसनवाल मार्ग, नई दिल्ली – 110016
   Executive Director, NRLDC, 18-A, Shaheed Jeet Singh Marg, Katwaria Sarai, New Delhi – 110016
3. कार्यकारी निदेशक, प .क्षे .भा .प्रे .के., एफ3-, एम आई डी सी क्षेत्र , अंधेरी, मुंबई –400093
   Executive Director, WRLDC, F-3, M.I.D.C. Area, Marol, Andheri (East), Mumbai-400093
4. कार्यकारी निदेशक, ऊ. पू. क्षे. भा. प्रे. के., डोंगतिएह, लोअर नोंग्रह , लापलंग, शिलोंग – 793006
   Executive Director, NERLDC, Dongteih, Lower Nongrah, Lapalang, Shillong - 793006, Meghalaya
5. कार्यकारी निदेशक , द .क्षे .भा .प्रे .के.,29 , रेस कोर्स क्रॉस रोड, बंगलुरु –560009
   Executive Director, SRLDC, 29, Race Course Cross Road, Bangalore-560009

Sub: Daily PSP Report for the date 15.12.2025.

महोदय/Sir,

आई०ई०जी०सी०-2023 की धारा स.-38(1) के प्रावधान के अनुसार, दिनांक 15-दिसंबर-2025 की अखिल भारतीय प्रणाली की दैनिक ग्रिड निष्पादन रिपोर्ट रा०भा०प्रे०के० की वेबसाइट पर उप्लब्ध है |

As per article 38(1) of the Indian Electricity Grid Code, the daily report pertaining power supply position of All India Power System for the date 15.12.2025, is available at the NLDC website.

धन्यवाद,
Thanks

ग्रिड कंट्रोलर ऑफ इंडिया लिमिटेड
राष्ट्रीय भार प्रेषण केंद्र, नई दिल्ली

Report for previous day

Date of Reporting: 16-Dec-2025

A. Power Supply Position at All India and Regional level

	NR	WR	SR	ER	NER	TOTAL
Demand Met during Evening Peak hrs(MW) (at 19:00 hrs; from RLDCs)	58356	65019	48266	22384	2800	196825
Peak Shortage (MW)	0	0	0	0	0	0
Energy Met (MU)	1245	1530	1132	450	50	4407
Hydro Gen (MU)	121	34	99	19	11	284
Wind Gen (MU)	7	95	82	-	-	183
Solar Gen (MU)*	163.65	163.31	155.21	2.98	1.08	486
Energy Shortage (MU)	0.00	0.00	0.00	0.00	0.00	0.00
Maximum Demand Met During the Day (MW) (From NLDC SCADA)	65196	76242	58601	23123	2964	220255
Time Of Maximum Demand Met	10:25	09:52	11:40	17:55	17:23	10:16

B. Frequency Profile (%)

Region	FVI	< 49.7	49.7 - 49.8	49.8 - 49.9	< 49.9	49.9 - 50.05	> 50.05
All India	0.032	0.00	0.50	2.19	2.68	78.95	18.37

C. Power Supply Position in States

Region	States	Max.Demand Met during the day (MW)	Shortage during maximum Demand (MW)	Energy Met (MU)	Drawal Schedule (MU)	OD(+)/UD(-) (MU)	Max OD (MW)	Energy Shortage (MU)
NR	Punjab	8429	0	156.0	69.4	-0.7	374	0.00
	Haryana	8645	0	161.9	113.3	-1.3	462	0.00
	Rajasthan	17670	0	331.8	114.9	-1.3	1380	0.00
	Delhi	4553	0	79.8	73.4	0.6	337	0.00
	UP	20301	0	362.1	87.7	-1.0	365	0.00
	Uttarakhand	2423	0	43.2	32.7	-0.2	112	0.00
	HP	2041	0	36.3	28.4	-0.5	108	0.00
	J&K(UT) & Ladakh(UT)	3160	0	65.8	64.0	-0.8	269	0.00
	Chandigarh	240	0	4.0	3.9	0.0	15	0.00
	Railways_NR ISTS	186	0	4.0	3.8	0.2	34	0.00
WR	Chhattisgarh	5062	0	102.0	33.8	1.4	417	0.00
	Gujarat	22780	0	434.0	185.6	-5.0	949	0.00
	MP	18857	0	344.1	223.3	0.0	344	0.00
	Maharashtra	27288	0	567.1	184.0	-7.8	930	0.00
	Goa	665	0	13.0	10.7	1.8	44	0.00
	DNHDDPDCL	1333	0	29.4	29.4	0.0	63	0.00
	AMNSIL	956	0	20.9	13.3	0.5	300	0.00
	BALCO	576	0	13.7	13.8	-0.1	14	0.00
	RIL JAMNAGAR	265	0	5.9	6.0	-0.1	0	0.00
SR	Andhra Pradesh	10715	0	203.6	54.6	-1.6	528	0.00
	Telangana	13128	0	229.0	108.7	0.0	659	0.00
	Karnataka	16143	0	287.3	101.2	-1.7	586	0.00
	Kerala	4321	0	79.5	59.7	0.0	229	0.00
	Tamil Nadu	16636	0	324.3	186.8	-2.7	793	0.00
	Puducherry	416	0	8.4	8.0	-0.2	27	0.00
ER	Bihar	5409	0	97.3	91.2	-0.5	408	0.00
	DVC	3215	0	67.4	-42.0	0.4	448	0.00
	Jharkhand	2147	0	40.6	29.2	-1.5	302	0.00
	Odisha	4883	0	93.3	11.6	-3.9	253	0.00
	West Bengal	7660	0	149.0	21.9	-2.2	183	0.00
	Sikkim	123	0	1.8	1.7	0.1	38	0.00
	Railways_ER ISTS	15	0	0.2	0.2	0.0	4	0.00
NER	Arunachal Pradesh	176	0	3.1	2.9	0.0	53	0.00
	Assam	1692	0	28.3	21.4	0.6	155	0.00
	Manipur	262	0	3.8	3.9	-0.1	52	0.00
	Meghalaya	343	0	6.2	5.2	-0.1	113	0.00
	Mizoram	150	0	2.2	2.0	-0.4	6	0.00
	Nagaland	172	0	2.9	2.7	0.0	11	0.00
	Tripura	238	0	3.8	4.7	0.0	29	0.00

D. Transnational Exchanges (MU) - Import(+ve)/Export(-ve)

	Bhutan	Nepal	Bangladesh	Godda -> Bangladesh
Actual (MU)	-10.0	3.6	-22.2	-24.7
Day Peak (MW)	-792.7	398.7	-1007.6	-1438.0

E. Import/Export by Regions (in MU) - Import(+ve)/Export(-ve); OD(+)/UD(-)

	NR	WR	SR	ER	NER	TOTAL
Schedule(MU)	227.7	-223.4	143.5	-157.0	9.2	0.0
Actual(MU)	227.7	-224.9	131.2	-158.3	8.1	-16.2
O/D/U/D(MU)	0.0	-1.5	-12.3	-1.3	-1.1	-16.2

F. Generation Outage(MW)

	NR	WR	SR	ER	NER	TOTAL	% Share
Central Sector	6162	11035	6578	5810	30	29615	48
State Sector	10459	10356	8444	2497	205	31960	52
Total	16621	21390	15022	8307	235	61575	100

G. Sourcewise generation (Gross) (MU)

	NR	WR	SR	ER	NER	All India	% Share
Coal	731	1483	620	668	13	3515	73
Lignite	20	17	51	0	0	89	2
Hydro	121	34	99	19	11	284	6
Nuclear	38	53	47	0	0	137	3
Gas, Naptha & Diesel	5	27	4	0	23	59	1
RES (Wind, Solar, Biomass & Others)	197	262	266	7	1	732	15
Total	1111	1875	1087	694	48	4815	100

Share of RES in total generation (%)	17.70	13.95	24.46	1.01	2.25	15.20
Share of Non-fossil fuel (Hydro,Nuclear and RES) in total generation(%)	31.95	18.56	37.85	3.71	25.29	23.93

H. All India Demand Diversity Factor

Based on Regional Max Demands	1.026
Based on State Max Demands	1.059

I. All India Peak Demand and shortage at Solar and Non-Solar Hour

	Max Demand Met(MW)	Time	Shortage(MW)
Solar hr	220255	10:16	0
Non-Solar hr	209358	17:57	0

Diversity factor = Sum of regional or state maximum demands / All India maximum demand

**Note: All generation MU figures are gross

***Godda (Jharkhand) -> Bangladesh power exchange is through the radial connection (isolated from Indian Grid)

Solar Hours -> 06:00 to 18:00hrs and rest are Non-Solar Hours

*Source: RLDCs for solar connected to ISTS; SLDCs for embedded solar. Limited visibility of embedded solar data.

Executive Director-NLDC

INTER-REGIONAL EXCHANGES

Import=(+ve) /Export =(-ve) for NET (MU)
Date of Reporting: 16-Dec-2025

Sl No	Voltage Level	Line Details	No. of Circuit	Max Import (MW)	Max Export (MW)	Import (MU)	Export (MU)	NET (MU)
Import/Export of ER (With NR)								
1	HVDC	ALIPURDUAR-AGRA	2	0	0	0.0	0.0	0.0
2	HVDC	PUSAULI B/B	-	0	47	0.0	0.0	0.0
3	765 kV	GAYA-VARANASI	2	198	1095	0.0	16.8	-16.8
4	765 kV	SASARAM-FATEHPUR	1	32	543	0.0	7.4	-7.4
5	765 kV	GAYA-BALIA	1	0	694	0.0	11.9	-11.9
6	400 kV	PUSAULI-VARANASI	1	94	15	0.8	0.0	0.8
7	400 kV	PUSAULI -ALLAHABAD	1	0	140	0.0	1.8	-1.8
8	400 kV	MUZAFFARPUR-GORAKHPUR	2	361	600	0.0	4.4	-4.4
9	400 kV	PATNA-BALIA	2	1	833	0.0	11.6	-11.6
10	400 kV	NAUBATPUR-BALIA	2	0	391	0.0	3.5	-3.5
11	400 kV	BIHARSHARIFF-BALIA	2	328	250	0.1	0.0	0.1
12	400 kV	MOTIHARI-GORAKHPUR	2	18	509	0.0	6.6	-6.6
13	400 kV	BIHARSARIFF-SAHUPURI	2	34	433	0.0	6.2	-6.2
14	220 kV	SAHUPURI-KARAMNASA	1	0	33	0.0	0.7	-0.7
15	132 kV	NAGAR UNTARI-RIHAND	1	0	0	0.0	0.0	0.0
16	132 kV	GARWAH-RIHAND	1	30	0	0.6	0.0	0.6
17	132 kV	KARMANASA-SAHUPURI	1	0	26	0.0	0.0	0.0
18	132 kV	KARMANASA-CHANDAULI	1	0	0	0.0	0.6	-0.6
					ER-NR	**1.5**	**71.5**	**-70.0**
Import/Export of ER (With WR)								
1	765 kV	JHARSUGUDA-DHARAMJAIGARH	4	614	609	0.0	2.4	-2.4
2	765 kV	NEW RANCHI-DHARAMJAIGARH	2	835	922	0.0	0.3	-0.3
3	765 kV	JHARSUGUDA-DURG	2	0	1387	0.0	25.3	-25.3
4	400 kV	JHARSUGUDA-RAIGARH	4	291	334	0.0	0.8	-0.8
5	400 kV	RANCHI-SIPAT	2	131	313	1.7	0.0	1.7
6	400 kV	JEYPORE-JAGDALPUR	2	314	232	2.4	0.0	2.4
7	220 kV	BUDHIPADAR-RAIGARH	1	0	112	0.0	1.4	-1.4
8	220 kV	BUDHIPADAR-KORBA	2	30	53	0.0	0.0	0.0
					ER-WR	**4.1**	**30.2**	**-26.1**
Import/Export of ER (With SR)								
1	HVDC	JEYPORE-GAZUWAKA B/B	2	0	255	0.0	6.0	-6.0
2	HVDC	TALCHER-KOLAR BIPOLE	2	0	1620	0.0	39.3	-39.3
3	765 kV	ANGUL-SRIKAKULAM	2	0	3113	0.0	50.8	-50.8
4	400 kV	TALCHER-I/C	2	669	257	3.1	0.0	3.1
5	220 kV	BALIMELA-UPPER-SILERRU	1	1	0	0.0	0.0	0.0
					ER-SR	**0.0**	**96.1**	**-96.1**
Import/Export of ER (With NER)								
1	400 kV	BINAGURI-BONGAIGAON	2	139	381	0.2	4.8	-4.6
2	400 kV	ALIPURDUAR-BONGAIGAON	2	309	492	0.0	4.9	-4.9
3	220 kV	ALIPURDUAR-SALAKATI	2	70	87	0.0	0.4	-0.4
					ER-NER	**0.2**	**10.1**	**-9.9**
Import/Export of <null> (With <null>)								
No Records Found								
					NER-NR	**0.0**	**0.0**	**0.0**
Import/Export of WR (With NR)								
1	HVDC	CHAMPA-KURUKSHETRA	2	0	3016	0.0	40.5	-40.5
2	HVDC	VINDHYACHAL B/B	-	0	515	0.0	5.4	-5.4
3	HVDC	MUNDRA-MOHINDERGARH	2	0	1456	0.0	25.1	-25.1
4	765 kV	GWALIOR-AGRA	2	48	2006	0.0	25.3	-25.3
5	765 kV	GWALIOR-PHAGI	2	490	2181	0.5	29.8	-29.3
6	765 kV	JABALPUR-ORAI	2	0	1091	0.0	32.3	-32.3
7	765 kV	GWALIOR-ORAI	1	1131	0	17.4	0.0	17.4
8	765 kV	SATNA-ORAI	1	0	1358	0.0	23.7	-23.7
9	765 kV	BANASKANTHA-CHITORGARH	2	2615	75	19.1	0.0	19.0
10	765 kV	VINDHYACHAL-VARANASI	2	0	2340	0.0	40.1	-40.1
11	400 kV	ZERDA-KANKROLI	1	0	0	0.0	0.0	0.0
12	400 kV	ZERDA -BHINMAL	1	0	0	0.0	0.0	0.0
13	400 kV	VINDHYACHAL -RIHAND	1	962	0	20.2	0.0	20.2
14	400 kV	RAPP-SHUJALPUR	2	648	308	3.2	1.8	1.4
15	400 kV	NEEMUCH-Chittorgarh	2	635	400	3.0	2.4	0.6
16	220 kV	BHANPURA-RANPUR	1	0	140	0.0	2.4	-2.4
17	220 kV	BHANPURA-MORAK	1	0	30	0.0	1.2	-1.2
18	220 kV	MEHGAON-AURAIYA	1	106	4	1.1	0.0	1.1
19	220 kV	MALANPUR-AURAIYA	1	78	18	0.6	0.0	0.5
20	132 kV	RAJGHAT-LALITPUR	2	0	0	0.0	0.0	0.0
					WR-NR	**65.0**	**230.0**	**-165.0**
Import/Export of WR (With SR)								
1	HVDC	BHADRAWATI B/B	-	0	1003	0.0	20.4	-20.4
2	HVDC	RAIGARH-PUGALUR	2	0	2505	0.0	25.9	-25.9
3	765 kV	SOLAPUR-RAICHUR	2	1534	1536	5.1	8.5	-3.5
4	765 kV	WARDHA-NIZAMABAD	2	0	2243	0.0	26.1	-26.1
5	765 kV	WARORA-WARANGAL(NEW)	2	0	2634	0.0	35.8	-35.8
6	400 kV	KOLHAPUR-KUDGI	2	1615	0	24.8	0.0	24.8
7	220 kV	KOLHAPUR-CHIKODI	2	0	0	0.0	0.0	0.0
8	220 kV	PONDA-AMBEWADI	1	2	0	0.0	0.0	0.0
9	220 kV	XELDEM-AMBEWADI	1	0	98	1.9	0.0	1.9
					WR-SR	**31.8**	**116.7**	**-84.9**

INTERNATIONAL EXCHANGES

Import(+ve)/Export(-ve)

State	Region	Line Name	Max (MW)	Min (MW)	Avg (MW)	Energy Exchange (MU)
BHUTAN	ER	400kV MANGDECHHU-ALIPURDUAR 1,2&3 i.e. ALIPURDUAR RECEIPT (from MANGDECHU HEP 4*180MW)	-203	48	-89	-2.14
	ER	400kV TALA-BINAGURI 1,2,4 (& 400kV MALBASE - BINAGURI) i.e. BINAGURI RECEIPT (from TALA HEP 6*170MW)	327	-183	28	0.67
	ER	220kV CHUKHA-BIRPARA 1&2 (& 220kV MALBASE - BIRPARA) i.e. BIRPARA RECEIPT (from CHUKHA HEP 4*84MW)	-340	-243	-296	-7.09
	NER	132kV GELEPHU-SALAKATI	-54	-34	-45	-1.09
	NER	132kV MOTANGA-RANGIA	-19	-6	-13	-0.32
NEPAL	NR	NEPAL IMPORT (FROM UP)	-14	0	0	0.00
	NR	132kV MAHENDRANAGAR-TANAKPUR(NHPC)	41	0	20	0.48
	ER	NEPAL IMPORT (FROM BIHAR)	0	0	0	0.00
	ER	400kV DHALKEBAR-MUZAFFARPUR 1&2	361	0	129	3.10
BANGLADESH	ER	BHERAMARA B/B HVDC (B'DESH)	-892	-607	-822	-19.73
	ER (Isolated from Indian Grid)	400kV GODDA_TPS-RAHANPUR (B'DESH) D/C	-1438	-821	-1030	-24.73
	NER	132kV COMILLA-SURAJMANI NAGAR 1&2	-110	0	-104	-2.49

CROSS BORDER EXCHANGE SCHEDULE **Date of Reporting: 16-Dec-2025**

Export From India (in MU)

Country	GNA (ISGS/PPA)	T-GNA							TOTAL
		BILATERAL TOTAL	COLLECTIVE						
			IDAM			RTM			
			IEX	PXIL	HPX	IEX	PXIL	HPX	
Bhutan	0.00	0.31	9.61	0.00	0.00	0.58	0.00	0.00	10.50
Nepal	0.00	0.00	0.00	0.00	0.00	0.88	0.00	0.00	0.88
Bangladesh	20.51	0.00	0.00	0.00	0.00	0.00	0.00	0.00	20.51
Myanmar	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total Export	20.51	0.31	9.61	0.00	0.00	1.46	0.00	0.00	31.89

Import by India(in MU)

Country	GNA (ISGA/PPA)	T-GNA							TOTAL
		BILATERAL TOTAL	COLLECTIVE						
			IDAM			RTM			
			IEX	PXIL	HPX	IEX	PXIL	HPX	
Bhutan	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Nepal	0.00	0.00	0.00	0.00	0.00	4.39	0.00	0.00	4.39
Bangladesh	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Myanmar	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total Import	0.00	0.00	0.00	0.00	0.00	4.39	0.00	0.00	4.39

Net from India(in MU) **-ve : Export / +ve : Import**

Country	GNA (ISGS/PPA)	T-GNA							TOTAL
		BILATERAL TOTAL	COLLECTIVE						
			IDAM			RTM			
			IEX	PXIL	HPX	IEX	PXIL	HPX	
Bhutan	0.00	-0.31	-9.61	0.00	0.00	-0.58	0.00	0.00	-10.50
Nepal	0.00	0.00	0.00	0.00	0.00	3.51	0.00	0.00	3.51
Bangladesh	-20.51	0.00	0.00	0.00	0.00	0.00	0.00	0.00	-20.51
Myanmar	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total Net	-20.51	-0.31	-9.61	0.00	0.00	2.93	0.00	0.00	-27.50

Date of Reporting: 16-Dec-2025

15 Min (INSTANTANEOUS) ALL INDIA GRID FREQUENCY, GENERATION & DEMAND MET (SCADA DATA)

TIME	FREQUENCY (Hz)	DEMAND MET (MW)	NUCLEAR (MW)	WIND (MW)	SOLAR (MW)	HYDRO** (MW)	GAS (MW)	THERMAL (MW)	OTHERS* (MW)	NET DEMAND MET (MW)	TOTAL GENERATION (MW)	NET TRANSNATIONAL EXCHANGE (MW) (+ve) Import, (-ve) Export
		(A)	(B)	(C)	(D)	(E)	(F)	(G)	(H)	(I=A-(C+D))	(J=B+C+D+E+F+G+H)	(K)
0:00	50.10	143390	5066	9233	0	6433	2182	121473	3233	134157	147620	-1038
0:15	50.05	142944	5078	9358	0	6500	2232	120479	3305	133586	146952	-1082
0:30	50.05	142058	5071	9356	0	6668	2241	119744	3227	132702	146307	-1104
0:45	49.95	142029	5072	9302	0	6713	2237	120040	3234	132727	146598	-1057
1:00	50.00	141972	5072	9271	0	6757	2234	120022	3301	132701	146657	-1022
1:15	49.89	140425	5060	8950	0	6586	2241	119357	3230	131475	145424	-1053
1:30	49.94	140379	5069	8942	0	6560	2232	119063	3232	131437	145098	-1092
1:45	49.95	139740	5063	8923	0	6276	2250	118980	3155	130817	144647	-1120
2:00	50.00	139062	5058	8844	0	6188	2392	118173	3237	130218	143892	-1202
2:15	50.00	139173	5072	8852	0	6207	2233	118422	3231	130321	144017	-1196
2:30	50.00	138470	5072	8890	0	6199	2235	117840	3193	129580	143429	-1222
2:45	49.95	138839	5074	8773	0	6156	2232	118275	3216	130066	143726	-1129
3:00	50.00	138488	5085	8657	0	6122	2236	117801	3285	129831	143186	-1125
3:15	50.00	139055	5095	8586	0	6343	2229	118449	3305	130469	144007	-1145
3:30	50.00	139461	5082	8468	0	6359	2223	119024	3263	130993	144419	-1130
3:45	50.00	139918	5084	8314	0	6251	2224	119905	3194	131604	144972	-1189
4:00	50.05	140044	5091	8237	0	6304	2225	120373	3241	131807	145471	-1216
4:15	50.00	142868	5078	8234	0	6793	2235	122387	3232	134634	147959	-1220
4:30	50.05	143233	5082	8219	0	6790	2065	122979	3235	135014	148370	-1206
4:45	49.99	144969	5076	8079	0	6763	2191	124830	3246	136890	150185	-1242
5:00	50.10	146869	5071	7956	40	7228	2067	126581	3294	138873	152237	-1274
5:15	50.04	151850	5075	7937	4	8179	2119	130792	3228	143909	157334	-1299
5:30	50.05	156320	5082	7873	35	8612	2111	134718	3329	148412	161760	-1288
5:45	49.99	160931	5073	7801	34	9001	2149	138987	3221	153096	166266	-1077
6:00	50.10	165879	5069	7739	27	9835	2152	143049	3230	158113	171101	-571
6:15	50.04	172798	5082	7552	500	12313	2206	147532	3256	164746	178441	-545
6:30	50.09	180004	5072	7444	508	16110	2225	151156	3241	172052	185756	-563
6:45	49.99	186220	5081	7443	661	18086	2224	155236	3254	178116	191985	-662
7:00	49.99	191621	5081	7436	1297	19374	2224	158630	3246	182888	197288	-686
7:15	49.94	197451	5088	7438	2807	21572	2200	160626	3251	187206	202982	-639
7:30	49.99	201752	5076	7564	4484	22645	2205	161725	3343	189704	207042	-656
7:45	50.05	204591	5081	7471	7411	22732	2229	161394	3233	189709	209551	-685
8:00	50.05	205279	5094	7334	11490	19729	2359	160536	3253	186455	209795	-733
8:15	50.00	207767	5090	7074	16600	18248	2207	159773	3276	184093	212268	-705
8:30	50.05	209135	5077	6903	22334	15675	2197	158057	3233	179898	213476	-748
8:45	50.05	210379	5094	6669	27827	13669	2193	155943	3289	175883	214684	-880
9:00	50.05	211797	5078	6401	33517	12521	2190	152561	3315	171879	215583	-875
9:15	50.00	215897	5069	5932	38840	11726	2197	152401	3256	171125	219421	-895
9:30	50.00	217757	5073	5672	43791	10427	2184	150627	3221	168294	220995	-898
9:45	50.05	219689	5046	5286	48509	9817	2197	149041	3259	165894	223155	-875
10:00	50.15	219148	5052	4819	52893	8427	2183	146078	3208	161436	222660	-965
10:15	50.05	219986	5064	4548	56535	7480	2182	145056	3186	158903	224051	-1487
10:30	50.05	220001	5039	4527	60181	7715	2188	141393	3206	155293	224249	-1780
10:45	50.05	219164	5051	4394	63671	7467	2257	137429	3198	151099	223467	-1873
11:00	50.05	218375	5064	4242	66079	7585	2183	134276	3217	148054	222646	-1920
11:15	49.95	217270	5050	4061	67572	6605	2192	132638	3181	145637	221299	-1883
11:30	49.95	217546	5045	3917	68898	6628	2205	131296	3250	144731	221239	-1891
11:45	50.00	216391	5047	3646	69840	6588	2208	129911	3185	142905	220425	-1852
12:00	50.00	214079	5057	3688	70283	6507	2224	126813	3182	140108	217754	-1866
12:15	50.00	212422	5075	3758	70718	6259	2219	124747	3136	137946	215912	-1837
12:30	50.00	211234	5044	3666	70920	6203	2211	123659	3150	136648	214853	-1839
12:45	50.00	210029	5049	3756	71065	6138	2212	122439	3126	135208	213785	-1849
13:00	50.00	207331	5042	3676	70726	6485	2208	119962	3120	132929	211219	-1856
13:15	50.00	204125	5055	3633	69677	6530	2216	117474	3183	130815	207768	-1839
13:30	50.00	203303	5045	3575	68797	6539	2221	117168	3203	130931	206548	-1876
13:45	50.04	204698	5045	3579	67429	6727	2221	120344	3179	133690	208524	-1904
14:00	50.04	204329	5037	3576	65411	6771	2170	122168	3155	135342	208288	-1919
14:15	50.09	205364	5034	3502	63791	6783	2161	124666	3210	138071	209147	-1900
14:30	49.99	206377	5028	3443	61687	6881	2201	127304	3241	141247	209785	-1924
14:45	50.04	205595	5045	3581	59247	7176	2187	129476	3186	142767	209898	-1954
15:00	49.99	206335	5049	3460	55966	7301	2206	133019	3280	146909	210281	-1982
15:15	50.04	205223	5046	3406	53064	8021	2208	134948	3164	148753	209857	-1981
15:30	49.99	206343	5049	3428	49409	8638	2203	139235	3174	153506	211136	-1909
15:45	49.99	206475	5047	3460	45272	9251	2230	142667	3184	157743	211111	-1466
16:00	50.04	206511	5048	3503	40237	10195	2270	146647	3185	162771	211085	-1438
16:15	49.93	203993	5036	3623	34256	10756	2376	150047	3181	166114	209275	-1493
16:30	50.03	204562	5035	3665	27495	12599	2481	155214	3246	173402	209735	-1384
16:45	49.98	204578	5047	3794	20045	14667	2630	159948	3223	180739	209354	-1180
17:00	50.08	204948	5033	3807	13797	18369	2767	162972	3201	187344	209946	-1208
17:15	49.98	203090	5040	3949	7855	20349	2889	163926	3255	191286	207263	-872
17:30	49.93	205271	5035	4187	4026	24261	3082	165735	3230	197058	209556	-860
17:45	49.78	207738	5038	4540	1709	26513	3262	167133	3232	201489	211427	-746
18:00	49.98	208967	5036	5076	867	28419	3267	166790	3275	203024	212730	-756
18:15	49.99	208314	5045	5763	597	28304	3811	165957	3210	201954	212687	-759
18:30	50.04	207403	4979	6567	433	28057	3790	164573	3232	200403	211631	-747
18:45	50.09	205601	4977	7286	309	27383	3553	163064	3187	198006	209759	-755
19:00	50.09	202887	4991	8013	280	26292	2764	161692	3172	194594	207204	-766
19:15	50.03	199955	4996	8574	301	24311	2624	160084	3260	191080	204150	-819
19:30	50.04	197386	4978	9284	0	21465	2639	159784	3301	188102	201451	-786
19:45	50.04	194186	4985	9853	0	19303	2307	158550	3261	184333	198259	-691
20:00	50.04	190293	4989	10286	0	17643	2220	155973	3241	180007	194352	-689
20:15	49.93	186577	4994	10888	0	15487	2217	153633	3283	175689	190502	-657
20:30	49.98	183704	4996	11284	0	14102	2210	152012	3270	172420	187874	-643
20:45	49.98	181457	4994	11578	0	13315	2213	150107	3312	169879	185519	-614
21:00	49.98	178086	4992	11869	0	12427	2209	147386	3235	166217	182118	-599
21:15	50.05	175024	4999	12229	0	12277	2212	144041	3264	162795	179022	-623
21:30	50.05	172158	4989	12509	0	12195	2216	141375	3199	159649	176483	-686
21:45	50.05	168658	4979	12799	0	11187	2280	138722	3210	155859	173177	-961
22:00	50.10	164302	4987	12862	0	10543	2280	135629	3222	151440	169523	-1185
22:15	50.05	164189	4996	12868	0	10239	2453	135241	3256	151321	169053	-1162
22:30	50.00	162536	4990	13084	0	10265	2288	133387	3243	149452	167257	-1093
22:45	50.00	160175	5001	13292	0	8743	2295	132197	3235	146883	164763	-1012
23:00	49.95	157657	4990	13438	0	7744	2294	130524	3251	144219	162241	-1035
23:15	49.95	155991	4995	13495	0	6842	2320	129434	3202	142496	160288	-976
23:30	50.00	153964	4995	13576	0	6612	2318	127556	3155	140388	158212	-991
23:45	50.05	152081	5010	13619	0	6541	2317	125763	3232	138462	156482	-973

*Others include (i) Biomass from Punjab (ii) Some of the state sector IPP & non-conventional generation in SR (small capacity) (iii) Solar generation in Odisha(manually punched).
** Hydro generation is excluding Bhutan hydro.
***Bhutan hydro is accounted for in net transnational exchange.

Disclaimer:
1. The information provided is for general informational purposes only.
2. The data is provided "as is" without any guarantees or warranties.
3. All Data is operational SCADA data telemetered and reporting at NLDC through RLDC/SLDC.
4. Data is subject to errors due to telemetry loss/freeze/garbage value etc.
5. Demand met and RE generation data is incident on transmission system. Resources in distribution system plus behind the meter (BTM) generation excluded.
6. Users are advised to ensure its accuracy, completeness and relevance for their purposes, and, in this respect, GRID-INDIA shall not be responsible for any errors or omissions.