



National Load Despatch Centre
राष्ट्रीय भार प्रेषण केंद्र
GRID CONTROLLER OF INDIA LIMITED
ग्रिड कंट्रोलर ऑफ इंडिया लिमिटेड

(Government of India Enterprise/ भारत सरकार का उद्यम)
B-9, QUTUB INSTITUTIONAL AREA, KATWARIA SARAI, NEW DELHI -110016
बी-9, कुतुब इन्स्टीट्यूशनल एरिया, कटवारिया सराये, न्यू दिल्ली-110016

Ref: GRID-INDIA/NLDC/SO/Daily PSP Report

दिनांक: 19.01.2025

To,

- कार्यकारी निदेशक, पू.क्षे.भा.प्रे.के., 14, गोल्फ क्लब रोड, कोलकाता - 700033
Executive Director, ERLDC, 14 Golf Club Road, Tollygunge, Kolkata, 700033
- कार्यकारी निदेशक, ऊ.क्षे.भा.प्रे.के., 18/ए, शाहीद जीत सिंह सनसनवाल मार्ग, नई दिल्ली - 110016
Executive Director, NRLDC, 18-A, Shaheed Jeet Singh Marg, Katwaria Sarai, New Delhi - 110016
- कार्यकारी निदेशक, प.क्षे.भा.प्रे.के., एफ3, एम आई डी सी क्षेत्र, अंधेरी, मुंबई -400093
Executive Director, WRLDC, F-3, M.I.D.C. Area, Marol, Andheri (East), Mumbai-400093
- कार्यकारी निदेशक, ऊ.पू.क्षे.भा.प्रे.के., डोंगतेह, लोअर नोंग्रह, लापलंग, शिलोंग - 793006
Executive Director, NERLDC, Dongteih, Lower Nongrah, Lapalang, Shillong - 793006, Meghalaya
- कार्यकारी निदेशक, द.क्षे.भा.प्रे.के., 29, रेस कोर्स क्रॉस रोड, बंगलुरु -560009
Executive Director, SRLDC, 29, Race Course Cross Road, Bangalore-560009

Sub: Daily PSP Report for the date 18.01.2025.

महोदय/Dear Sir,

आईईजीसी-2023 की धारा स.-38(1) के प्रावधान के अनुसार, दिनांक 18-जनवरी-2025 की अखिल भारतीय प्रणाली की दैनिक ग्रिड निष्पादन रिपोर्ट रांभांप्रेके की वेबसाइट पर उपलब्ध है।

As per article 38(1) of the Indian Electricity Grid Code, the daily report pertaining power supply position of All India Power System for the date 18.01.2025, is available at the NLDC website.

धन्यवाद,
Thanks

Report for previous day

Date of Reporting: 19-Jan-2025

A. Power Supply Position at All India and Regional level

	NR	WR	SR	ER	NER	TOTAL
Demand Met during Evening Peak hrs(MW) (at 19:00 hrs; from RLDCs)	60733	65313	43574	22681	2703	195004
Peak Shortage (MW)	0	0	0	0	0	0
Energy Met (MU)	1239	1542	1148	462	49	4441
Hydro Gen (MU)	90	47	91	23	11	262
Wind Gen (MU)	20	83	96	-	-	199
Solar Gen (MU)*	148.70	101.39	99.57	2.95	1.13	354
Energy Shortage (MU)	0.42	0.06	0.00	0.00	0.00	0.48
Maximum Demand Met During the Day (MW) (From NLDC SCADA)	65288	78120	59402	23521	2877	225118
Time Of Maximum Demand Met	10:21	10:30	09:58	17:56	17:43	09:58

B. Frequency Profile (%)

Region	FVI	< 49.7	49.7 - 49.8	49.8 - 49.9	< 49.9	49.9 - 50.05	> 50.05
All India	0.026	0.00	0.00	2.43	2.43	82.03	15.54

C. Power Supply Position in States

Region	States	Max.Demand Met during the day (MW)	Shortage during maximum Demand (MW)	Energy Met (MU)	Drawal Schedule (MU)	OD(+)/UD(-) (MU)	Max OD (MW)	Energy Shortage (MU)
NR	Punjab	8449	0	155.1	64.9	-1.1	675	0.00
	Haryana	8024	0	154.4	106.5	-1.7	289	0.00
	Rajasthan	17664	0	323.4	99.6	-3.1	637	0.00
	Delhi	4945	0	84.2	83.8	-1.9	477	0.00
	UP	20292	0	358.5	132.0	-1.1	249	0.05
	Uttarakhand	2527	0	46.6	38.8	-0.5	125	0.00
	HP	2193	0	40.1	34.1	-0.5	193	0.00
	J&K(UT) & Ladakh(UT)	3100	0	68.2	64.6	-0.3	1049	0.37
	Chandigarh	281	0	4.8	4.8	-0.1	58	0.00
WR	Railways_NR ISTS	180	0	3.6	3.8	-0.2	38	0.00
	Chhattisgarh	5415	0	110.1	59.1	-1.1	314	0.00
	Gujarat	23417	0	428.9	210.0	1.0	1425	0.00
	MP	18120	0	332.7	217.3	-2.1	725	0.06
	Maharashtra	28839	0	591.7	202.1	0.8	716	0.00
	Goa	706	0	15.0	14.6	0.4	111	0.00
	DNHDDPDCL	1345	0	30.4	30.5	-0.1	58	0.00
	AMNSIL	761	0	17.0	7.4	0.6	298	0.00
	BALCO	535	0	12.7	12.7	0.0	18	0.00
SR	RIL JAMNAGAR	141	0	3.2	3.2	0.0	0	0.00
	Andhra Pradesh	11294	0	206.2	60.3	-0.2	633	0.00
	Telangana	14145	0	260.9	136.8	-1.5	635	0.00
	Karnataka	16704	0	285.2	87.7	1.0	873	0.00
	Kerala	4187	0	85.0	67.4	0.8	386	0.00
	Tamil Nadu	15080	0	302.9	162.9	3.4	1404	0.00
	Puducherry	352	0	7.8	7.6	-0.3	24	0.00
	Bihar	5378	0	96.9	90.6	-5.5	196	0.00
	DVC	3225	0	70.1	-29.0	-0.6	236	0.00
ER	Jharkhand	2105	0	39.6	27.5	-0.8	187	0.00
	Odisha	5282	0	98.3	28.8	-2.0	378	0.00
	West Bengal	8033	0	155.5	30.3	-1.6	140	0.00
	Sikkim	119	0	1.9	2.0	-0.1	15	0.00
	Railways_ER ISTS	12	0	0.1	0.2	-0.1	10	0.00
	Arunachal Pradesh	183	0	2.8	2.9	-0.2	37	0.00
NER	Assam	1533	0	27.3	20.3	0.3	91	0.00
	Manipur	274	0	3.9	3.9	-0.1	54	0.00
	Meghalaya	375	0	6.5	4.9	-0.1	75	0.00
	Mizoram	151	0	2.5	1.9	0.1	21	0.00
	Nagaland	166	0	2.3	2.5	-0.2	18	0.00
	Tripura	231	0	4.1	3.4	0.0	24	0.00

D. Transnational Exchanges (MU) - Import(+ve)/Export(-ve)

	Bhutan	Nepal	Bangladesh	Godda -> Bangladesh
Actual (MU)	-5.0	-8.7	-21.8	-12.0
Day Peak (MW)	-346.4	-497.0	-1032.0	-768.0

E. Import/Export by Regions (in MU) - Import(+ve)/Export(-ve); OD(+)/UD(-)

	NR	WR	SR	ER	NER	TOTAL
Schedule(MU)	258.3	-240.5	139.2	-161.5	4.5	0.0
Actual(MU)	245.4	-225.8	136.6	-166.6	3.3	-7.1
O/D/U/D(MU)	-12.9	14.7	-2.6	-5.1	-1.2	-7.1

F. Generation Outage(MW)

	NR	WR	SR	ER	NER	TOTAL	% Share
Central Sector	5301	6259	5958	3357	698	21572	40
State Sector	8548	12825	7084	4379	171	33006	60
Total	13849	19083	13042	7735	868	54578	100

G. Sourcewise generation (Gross) (MU)

	NR	WR	SR	ER	NER	All India	% Share
Coal	731	1574	643	690	14	3651	76
Lignite	28	21	43	0	0	91	2
Hydro	90	47	91	23	11	262	5
Nuclear	32	54	61	0	0	147	3
Gas, Naptha & Diesel	3	12	9	0	24	48	1
RES (Wind, Solar, Biomass & Others)	195	187	231	6	1	619	13
Total	1079	1895	1077	718	51	4819	100

Share of RES in total generation (%)	18.07	9.86	21.45	0.79	2.26	12.85
Share of Non-fossil fuel (Hydro,Nuclear and RES) in total generation(%)	29.38	15.22	35.52	3.98	24.51	21.35

H. All India Demand Diversity Factor

Based on Regional Max Demands	1.018
Based on State Max Demands	1.047

I. All India Peak Demand and shortage at Solar and Non-Solar Hour

	Max Demand Met(MW)	Time	Shortage(MW)
Solar hr	225118	9:58	0
Non-Solar hr	201275	18:41	25

Diversity factor = Sum of regional or state maximum demands / All India maximum demand

**Note: All generation MU figures are gross

***Godda (Jharkhand) -> Bangladesh power exchange is through the radial connection (isolated from Indian Grid)

Solar Hours -> 06:00 to 18:00hrs and rest are Non-Solar Hours

*Source: RLDCs for solar connected to ISTS; SLDCs for embedded solar. Limited visibility of embedded solar data.

Executive Director-NLDC

INTER-REGIONAL EXCHANGES								
Import=(+ve) /Export =(-ve) for NET (MU)								
Date of Reporting: 19-Jan-2025								
Sl No	Voltage Level	Line Details	No. of Circuit	Max Import (MW)	Max Export (MW)	Import (MU)	Export (MU)	NET (MU)
Import/Export of ER (With NR)								
1	HVDC	ALIPURDUAR-AGRA	2	0	0	0.0	0.0	0.0
2	HVDC	PUSAULI B/B	-	0	49	0.0	1.2	-1.2
3	765 kV	GAYA-VARANASI	2	0	1066	0.0	15.0	-15.0
4	765 kV	SASARAM-FATEHPUR	1	0	674	0.0	9.9	-9.9
5	765 kV	GAYA-BALIA	1	0	827	0.0	13.6	-13.6
6	400 kV	PUSAULI-VARANASI	1	0	98	0.0	1.2	-1.2
7	400 kV	PUSAULI -ALLAHABAD	1	54	42	0.1	0.0	0.1
8	400 kV	MUZAFFARPUR-GORAKHPUR	2	21	802	0.0	8.3	-8.3
9	400 kV	PATNA-BALIA	2	0	887	0.0	15.9	-15.9
10	400 kV	NAUBATPUR-BALIA	2	0	609	0.0	5.0	-5.0
11	400 kV	BIHARSHARIFF-BALIA	2	2	276	0.0	4.5	-4.5
12	400 kV	MOTIHARI-GORAKHPUR	2	0	608	0.0	9.1	-9.1
13	400 kV	BIHARSHARIFF-VARANASI	2	0	0	0.0	0.0	0.0
14	220 kV	SAHUPURI-KARAMNASA	1	0	76	0.0	0.9	-0.9
15	132 kV	NAGAR UNTARI-RIHAND	1	0	0	0.0	0.0	0.0
16	132 kV	GARWAH-RIHAND	1	0	0	0.5	0.0	0.5
17	132 kV	KARMANASA-SAHUPURI	1	0	0	0.0	0.0	0.0
18	132 kV	KARMANASA-CHANDAUJI	1	0	0	0.0	0.0	0.0
ER-NR						0.6	84.6	-84.0
Import/Export of ER (With WR)								
1	765 kV	JHARSUGUDA-DHARAMJAIGARH	4	422	828	0.0	2.4	-2.4
2	765 kV	NEW RANCHI-DHARAMJAIGARH	2	565	845	0.0	1.2	-1.2
3	765 kV	JHARSUGUDA-DURG	2	0	1186	0.0	21.9	-21.9
4	400 kV	JHARSUGUDA-RAIGARH	4	0	725	0.0	11.5	-11.5
5	400 kV	RANCHI-SIPAT	2	102	334	0.0	1.4	-1.4
6	220 kV	BUDHIPADAR-RAIGARH	1	8	130	0.0	1.6	-1.6
7	220 kV	BUDHIPADAR-KORBA	2	112	100	0.4	0.0	0.4
ER-WR						0.4	40.1	-39.6
Import/Export of ER (With SR)								
1	HVDC	JEYPORE-GAZUWAKA B/B	2	0	214	0.0	5.1	-5.1
2	HVDC	TALCHER-KOLAR BIPOLE	2	0	1252	0.0	21.9	-21.9
3	765 kV	ANGUL-SRIKAKULAM	2	0	2962	0.0	55.4	-55.4
4	400 kV	TALCHER-I/C	2	834	369	10.2	0.0	10.2
5	220 kV	BALIMELA-UPPER-SILERRU	1	0	0	0.0	0.0	0.0
ER-SR						0.0	82.3	-82.3
Import/Export of ER (With NER)								
1	400 kV	BINAGURI-BONGAIGAON	2	253	10	3.6	0.0	3.6
2	400 kV	ALIPURDUAR-BONGAIGAON	2	393	0	6.6	0.0	6.6
3	220 kV	ALIPURDUAR-SALAKATI	2	92	0	1.5	0.0	1.5
ER-NER						11.7	0.0	11.7
Import/Export of NER (With NR)								
1	HVDC	BISWANATH CHARIALI-AGRA	2	661	0	16.2	0.0	16.2
NER-NR						16.2	0.0	16.2
Import/Export of WR (With NR)								
1	HVDC	CHAMPA-KURUKSHETRA	2	0	3020	0.0	50.9	-50.9
2	HVDC	VINDHYACHAL B/B	-	0	312	0.0	7.2	-7.2
3	HVDC	MUNDRA-MOHINDERGARH	2	0	1219	0.0	30.2	-30.2
4	765 kV	GWALIOR-AGRA	2	130	2811	0.1	30.8	-30.7
5	765 kV	GWALIOR-PHAGI	2	127	1998	0.1	24.7	-24.7
6	765 kV	JABALPUR-ORAI	2	23	1384	0.0	30.0	-30.0
7	765 kV	GWALIOR-ORAI	1	844	0	14.5	0.0	14.5
8	765 kV	SATNA-ORAI	1	0	1262	0.0	21.1	-21.1
9	765 kV	BANASKANTHA-CHITORGARH	2	1883	483	15.9	0.8	15.0
10	765 kV	VINDHYACHAL-VARANASI	2	0	2961	0.0	41.4	-41.4
11	400 kV	ZERDA-KANKROLI	1	363	66	3.8	0.1	3.8
12	400 kV	ZERDA -BHINMAL	1	250	46	2.6	0.1	2.6
13	400 kV	VINDHYACHAL -RIHAND	1	970	0	22.3	0.0	22.3
14	400 kV	RAPP-SHUJALPUR	2	672	534	4.4	2.0	2.5
15	400 kV	NEEMUCH-Chittorgarh	2	665	555	4.1	2.0	2.1
16	220 kV	BHANPURA-RANPUR	1	0	180	0.0	3.0	-3.0
17	220 kV	BHANPURA-MORAK	1	0	30	0.0	1.9	-1.9
18	220 kV	MEHGAON-AURAIYA	1	103	12	1.0	0.0	1.0
19	220 kV	MALANPUR-AURAIYA	1	74	30	0.6	0.1	0.5
20	132 kV	GWALIOR-SAWAI MADHOPUR	1	0	0	0.0	0.0	0.0
21	132 kV	RAJGHAT-LALITPUR	2	0	0	0.0	0.0	0.0
WR-NR						69.4	246.2	-176.9
Import/Export of WR (With SR)								
1	HVDC	BHADRAWATI B/B	-	0	511	0.0	12.0	-12.0
2	HVDC	RAIGARH-PUGALUR	2	0	1500	0.0	31.2	-31.2
3	765 kV	SOLAPUR-RAICHUR	2	1131	1206	3.4	9.7	-6.3
4	765 kV	WARDHA-NIZAMABAD	2	352	2198	0.2	31.3	-31.1
5	765 kV	WARORA-WARANGAL(NEW)	2	105	2261	0.0	34.6	-34.5
6	400 kV	KOLHAPUR-KUDGI	2	1507	0	24.8	0.0	24.8
7	220 kV	KOLHAPUR-CHIKODI	2	0	0	0.0	0.0	0.0
8	220 kV	PONDA-AMBEWADI	1	0	0	0.0	0.0	0.0
9	220 kV	XELDEM-AMBEWADI	1	0	89	1.9	0.0	1.9
WR-SR						30.3	118.7	-88.4
INTERNATIONAL EXCHANGES								
State		Region	Line Name	Max (MW)	Min (MW)	Avg (MW)	Import(+ve)/Export(-ve) Energy Exchange (MU)	
BHUTAN		ER	400kV MANGDECHHU-ALIPURDUAR 1,2&3 i.e. ALIPURDUAR RECEIPT (from MANGDECHU HEP 4*180MW)	232	21	65	1.56	
		ER	400kV TALA-BINAGURI 1,2,4 (& 400kV MALBASE - BINAGURI) i.e. BINAGURI RECEIPT (from TALA HEP 6*170MW)	-241	75	-76	-1.81	
		ER	220kV CHUKHA-BIRPARA 1&2 (& 220kV MALBASE - BIRPARA) i.e. BIRPARA RECEIPT (from CHUKHA HEP 4*84MW)	-245	-93	-179	-4.29	
		NER	132kV GELEPHU-SALAKATI	-28	-11	-20	-0.49	
		NER	132kV MOTANGA-RANGIA	-8	7	0	0.00	
NEPAL		NR	NEPAL IMPORT (FROM UP)	-65	0	-45	-1.08	
		NR	132kV MAHENDRANAGAR-TANAKPUR(NHPC)	-65	0	-44	-1.05	
		ER	NEPAL IMPORT (FROM BIHAR)	-163	-40	-87	-2.08	
		ER	400kV DHALKEBAR-MUZAFFARPUR 1&2	-334	-22	-188	-4.50	
BANGLADESH		ER	BHERAMARA B/B HVDC (B'DESH)	-938	-650	-860	-20.65	
		ER (Isolated from Indian Grid)	400kV GODDA_TPS-RAHANPUR (B'DESH) D/C	-768	-394	-499	-11.97	
		NER	132kV COMILLA-SURAJMANI NAGAR 1&2	-94	0	-50	-1.19	

CROSS BORDER EXCHANGE SCHEDULE

Date of Reporting: 19-Jan-2025

Export From India (in MU)

Country	GNA (ISGS/PPA)	T-GNA							TOTAL
		BILATERAL TOTAL	COLLECTIVE						
			IDAM			RTM			
			IEX	PXIL	HPX	IEX	PXIL	HPX	
Bhutan	0.00	0.30	5.61	0.00	0.00	0.18	0.00	0.00	6.09
Nepal	2.15	0.00	3.78	0.00	0.00	1.03	0.00	0.00	6.96
Bangladesh	21.47	0.00	0.00	0.00	0.00	0.00	0.00	0.00	21.47
Myanmar	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total Export	23.62	0.30	9.39	0.00	0.00	1.21	0.00	0.00	34.52

Import by India(in MU)

Country	GNA (ISGA/PPA)	T-GNA							TOTAL
		BILATERAL TOTAL	COLLECTIVE						
			IDAM			RTM			
			IEX	PXIL	HPX	IEX	PXIL	HPX	
Bhutan	0.76	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.76
Nepal	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Bangladesh	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Myanmar	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total Import	0.76	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.76

Net from India(in MU)

-ve : Export / +ve : Import

Country	GNA (ISGS/PPA)	T-GNA							TOTAL
		BILATERAL TOTAL	COLLECTIVE						
			IDAM			RTM			
			IEX	PXIL	HPX	IEX	PXIL	HPX	
Bhutan	0.76	-0.30	-5.61	0.00	0.00	-0.18	0.00	0.00	-5.33
Nepal	-2.15	0.00	-3.78	0.00	0.00	-1.03	0.00	0.00	-6.96
Bangladesh	-21.47	0.00	0.00	0.00	0.00	0.00	0.00	0.00	-21.47
Myanmar	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total Net	-22.86	-0.30	-9.39	0.00	0.00	-1.21	0.00	0.00	-33.76

Date of Reporting: 19-Jan-2025												
15 Min (INSTANTANEOUS) ALL INDIA GRID FREQUENCY, GENERATION & DEMAND MET (SCADA DATA)												
TIME	FREQUENCY (Hz)	DEMAND MET (MW)	NUCLEAR (MW)	WIND (MW)	SOLAR (MW)	HYDRO** (MW)	GAS (MW)	THERMAL (MW)	OTHERS* (MW)	NET DEMAND MET (MW)	TOTAL GENERATION (MW)	NET TRANSNATIONAL EXCHANGE (MW) (+ve) Import, (-ve) Export
		(A)	(B)	(C)	(D)	(E)	(F)	(G)	(H)	(I=A-(C+D))	(J=B+C+D+E+F+G+H)	(K)
0:00	50.08	153283	5846	14565	788	5904	1840	126486	3349	137930	158778	-1401
0:15	50.03	152755	5858	14421	791	6026	1842	125857	3362	137543	158157	-1473
0:30	50.08	152281	5851	14155	795	6423	1852	125078	3374	137331	157528	-1524
0:45	50.03	151283	5835	14151	793	5919	1846	124629	3343	136339	156516	-1512
1:00	50.03	149808	5849	13826	788	5876	1846	123523	3361	135194	155069	-1514
1:15	50.03	149200	5859	13557	782	5887	1841	123109	3427	134861	154462	-1498
1:30	49.98	147911	5862	13399	776	5554	1852	122424	3353	133736	153220	-1484
1:45	49.98	147886	5829	13218	778	5663	1844	122312	3361	133890	153005	-1517
2:00	50.03	146383	5828	13192	777	5570	1984	121162	3375	132414	151888	-1526
2:15	49.98	145856	5859	12902	778	5416	1853	120841	3406	132176	151055	-1401
2:30	49.98	145657	5844	12562	781	5271	1852	121000	3412	132314	150722	-1384
2:45	50.03	144963	5857	12471	776	5251	1848	120489	3392	131716	150084	-1410
3:00	50.03	144657	5855	12287	773	5189	1847	120568	3369	131597	149888	-1395
3:15	49.98	144384	5826	11984	774	5267	1849	120663	3335	131626	149698	-1419
3:30	50.03	144787	5861	11846	769	5450	1846	120905	3362	132172	150039	-1414
3:45	49.98	145175	5823	11526	767	5259	1840	121819	3375	132882	150409	-1434
4:00	50.03	145382	5842	11344	762	5186	1848	122261	3399	133276	150642	-1405
4:15	49.92	146797	5823	11104	765	5048	1838	124081	3348	134928	152007	-1391
4:30	49.98	148303	5848	10916	762	4970	1840	125980	3376	136625	153692	-1379
4:45	49.98	149980	5834	10769	760	5190	1845	127533	3389	138451	155320	-1433
5:00	50.03	151979	5841	10508	759	5529	1849	129306	3363	140712	157155	-1343
5:15	49.98	156093	5861	10115	759	5591	1854	133444	3348	145219	160972	-1164
5:30	49.98	159520	5845	9792	761	5944	1849	137049	3349	148967	164589	-1169
5:45	49.98	163991	5873	9620	762	7508	1849	139940	3382	153609	168934	-1239
6:00	50.08	167046	5850	9347	765	8126	1845	142710	3378	156934	172021	-1109
6:15	50.03	172183	5864	9094	765	8683	1846	147558	3339	162324	177149	-1065
6:30	50.03	179685	5869	8906	919	12098	1949	151634	3332	169860	184707	-1168
6:45	50.03	185842	5886	8860	916	14619	1966	155092	3290	176066	190629	-1156
7:00	50.03	190557	5858	8585	1032	16541	1954	158088	3392	180940	195450	-1276
7:15	49.93	195483	5892	8403	1431	18605	1962	160765	3378	185649	200436	-1172
7:30	49.98	200526	5932	8176	2186	21292	1955	162562	3374	190164	205477	-1185
7:45	49.98	205111	5910	8089	3310	23306	1962	163831	3410	193712	209818	-1107
8:00	50.03	207485	5902	7926	5471	23606	1963	163796	3429	194088	212093	-1109
8:15	49.93	211363	5899	7937	8351	23894	1965	164304	3412	195075	215762	-1052
8:30	50.03	214746	5908	7792	12102	23791	1967	163925	3454	194852	218939	-1018
8:45	50.03	215662	5935	7760	15868	21252	1966	163339	3469	192034	219589	-979
9:00	50.08	217742	5909	7383	20385	20164	1956	161969	3552	189974	221318	-968
9:15	50.03	221415	5912	7236	24569	19364	2198	162656	3571	189610	225506	-1103
9:30	50.08	223667	5916	7056	27858	18810	1963	162300	3572	188753	227475	-1157
9:45	50.03	223777	5887	6785	30657	17345	1975	161503	3591	186335	227743	-1273
10:00	50.08	223957	5898	6511	33386	15612	1971	160791	3628	184060	227797	-1347
10:15	50.03	224447	5886	6162	37196	12527	1963	161010	3584	181089	228328	-1353
10:30	50.03	224395	5882	5975	40221	11123	1958	159658	3569	178199	228386	-1373
10:45	50.03	223338	5837	5684	42214	9466	1870	158424	3595	175440	227090	-1361
11:00	50.03	222354	5849	5376	45515	8285	1867	155683	3571	171463	226146	-1420
11:15	50.03	220192	5881	5324	47976	7695	1866	151411	3628	166892	223781	-1421
11:30	50.03	218666	5869	5141	49300	6985	1864	149549	3605	164225	222313	-1561
11:45	49.98	217116	5842	4991	48879	7162	1871	148744	3610	163246	221099	-1626
12:00	50.03	215689	5834	4919	49356	6795	1864	146997	3636	161414	219401	-1619
12:15	49.98	214095	5813	4843	50992	6548	1867	144142	3584	158260	217789	-1689
12:30	50.03	212880	5824	4884	50984	6631	1880	142871	3577	157012	216651	-1725
12:45	50.03	211460	5807	4938	51413	6430	1877	141129	3600	155109	215194	-1683
13:00	50.03	207789	5803	5059	51155	6173	1876	138039	3566	151575	211671	-1714
13:15	50.03	203674	5823	5228	51101	5437	1864	134243	3581	147345	207277	-1741
13:30	50.08	202524	5829	5210	50630	5083	1873	133831	3581	146684	206037	-1737
13:45	50.03	202207	5828	5060	50270	5080	1871	134096	3576	146877	205781	-1758
14:00	50.03	201041	5826	4949	49529	5179	1867	133887	3533	146563	204770	-1792
14:15	49.98	200213	5835	4821	48185	5282	1875	134219	3537	147207	203754	-1775
14:30	49.98	200781	5824	4724	46598	5503	1872	136333	3536	149459	204390	-1771
14:45	49.93	200702	5830	4647	44671	5717	1869	138266	3520	151384	204520	-1782
15:00	49.97	200443	5824	4546	42334	5962	1941	140235	3475	153563	204317	-1757
15:15	49.87	199289	5809	4413	39474	6092	1960	142157	3504	155402	203409	-1657
15:30	49.92	198715	5800	4400	36435	7140	1952	143783	3530	157880	203040	-1667
15:45	49.92	199011	5814	4371	33152	8482	1951	146102	3520	161488	203392	-1673
16:00	49.97	198727	5823	4463	29231	9254	1939	148566	3498	165033	202774	-1642
16:15	50.03	197079	5845	4501	25273	9114	1975	151379	3495	167305	201582	-1425
16:30	49.93	197376	5851	4225	21077	10278	2052	154579	3546	172074	201608	-1368
16:45	50.03	199151	5844	4345	17048	12316	2119	157984	3483	177758	203139	-1209
17:00	50.08	198477	5870	4461	13038	14845	2110	158541	3514	180978	202379	-1145
17:15	50.08	196460	5878	4672	9108	15834	2134	159178	3496	182680	200300	-1009
17:30	50.08	197516	5877	4676	5925	18782	1948	161012	3468	186915	201688	-1030
17:45	50.03	199038	5881	4836	3464	21130	1870	162463	3365	190738	203009	-1069
18:00	50.03	199749	5895	5028	2038	22551	1867	163087	3461	192683	203927	-1096
18:15	49.98	199303	5899	5295	1286	22523	1969	163289	3424	192722	203685	-1104
18:30	50.03	201263	5914	5541	1152	23485	1973	164234	3427	194570	205726	-1098
18:45	49.98	201095	5894	5835	1069	23425	1969	164016	3442	194191	205650	-1080
19:00	50.03	199944	5948	6296	1081	22066	1970	163672	3424	192567	204457	-1070
19:15	50.03	198918	5943	6703	880	20923	1980	163574	3386	191335	203389	-1029
19:30	50.08	197085	5944	7313	898	19818	1914	162500	3423	188874	201810	-1042
19:45	50.03	194885	5932	7722	878	18669	1868	160884	3411	186285	199364	-1013
20:00	50.08	190527	5920	8023	883	15230	1849	159706	3427	181621	195038	-1017
20:15	49.98	187092	5914	8137	893	11055	1814	160041	3418	178062	191272	-995
20:30	49.98	184555	5903	8377	893	10094	1768	158573	3386	175285	188994	-1014
20:45	50.03	182316	5906	8629	885	9225	1766	156802	3399	172802	186612	-1018
21:00	50.03	179353	5909	8994	852	8738	1764	153977	3388	169507	183622	-1032
21:15	50.03	177064	5892	9152	853	8408	1760	151982	3391	167059	181438	-1260
21:30	49.97	174281	5886	9358	849	8320	1756	149158	3438	164074	178765	-1380
21:45	49.92	171121	5882	9475	844	8216	1748	146358	3405	160802	175928	-1424
22:00	50.07	167395	5865	9481	792	7768	1730	142877	3409	157122	171922	-1456
22:15	49.91	166918	5907	9672	751	7821	1809	142130	3421	156495	171511	-1518
22:30	49.96	165852										