



National Load Despatch Centre
राष्ट्रीय भार प्रेषण केंद्र
GRID CONTROLLER OF INDIA LIMITED
ग्रिड कंट्रोलर ऑफ इंडिया लिमिटेड

(Government of India Enterprise/ भारत सरकार का उद्यम)
B-9, QUTUB INSTITUTIONAL AREA, KATWARIA SARAI, NEW DELHI -110016
बी-9, कुतुब इन्स्टीट्यूशनल एरिया, कटवारिया सराये, न्यू दिल्ली-110016

Ref: GRID-INDIA/NLDC/SO/Daily PSP Report

दिनांक: 08.01.2025

To,

- कार्यकारी निदेशक, पू.क्षे.भा.प्रे.के., 14, गोल्फ क्लब रोड, कोलकाता - 700033
Executive Director, ERLDC, 14 Golf Club Road, Tollygunge, Kolkata, 700033
- कार्यकारी निदेशक, ऊ.क्षे.भा.प्रे.के., 18/ए, शाहीद जीत सिंह सनसनवाल मार्ग, नई दिल्ली - 110016
Executive Director, NRLDC, 18-A, Shaheed Jeet Singh Marg, Katwaria Sarai, New Delhi - 110016
- कार्यकारी निदेशक, प.क्षे.भा.प्रे.के., एफ3, एम आई डी सी क्षेत्र, अंधेरी, मुंबई - 400093
Executive Director, WRLDC, F-3, M.I.D.C. Area, Marol, Andheri (East), Mumbai-400093
- कार्यकारी निदेशक, ऊ.पू.क्षे.भा.प्रे.के., डोंगतेह, लोअर नोंग्रह, लापालंग, शिलोंग - 793006
Executive Director, NERLDC, Dongteih, Lower Nongrah, Lapalang, Shillong - 793006, Meghalaya
- कार्यकारी निदेशक, द.क्षे.भा.प्रे.के., 29, रेस कोर्स क्रॉस रोड, बंगलुरु - 560009
Executive Director, SRLDC, 29, Race Course Cross Road, Bangalore-560009

Sub: Daily PSP Report for the date 07.01.2025.

महोदय/Dear Sir,

आईईजीसी-2023 की धारा स.-38(1) के प्रावधान के अनुसार, दिनांक 7-जनवरी-2025 की अखिल भारतीय प्रणाली की दैनिक ग्रिड निष्पादन रिपोर्ट रांभांप्रेके की वेबसाइट पर उपलब्ध है।

As per article 38(1) of the Indian Electricity Grid Code, the daily report pertaining power supply position of All India Power System for the date 07.01.2025, is available at the NLDC website.

धन्यवाद,
Thanks

Report for previous day

Date of Reporting: 08-Jan-2025

A. Power Supply Position at All India and Regional level

	NR	WR	SR	ER	NER	TOTAL
Demand Met during Evening Peak hrs(MW) (at 19:00 hrs; from RLDCs)	61983	64773	45817	22517	2632	197722
Peak Shortage (MW)	0	0	0	835	0	835
Energy Met (MU)	1286	1505	1193	465	48	4497
Hydro Gen (MU)	92	37	102	18	12	260
Wind Gen (MU)	18	163	45	-	-	227
Solar Gen (MU)*	151.99	100.96	132.91	2.52	0.80	389
Energy Shortage (MU)	0.15	0.00	0.00	2.34	0.00	2.49
Maximum Demand Met During the Day (MW) (From NLDC SCADA)	68022	75968	60527	23461	2731	228072
Time Of Maximum Demand Met	10:24	09:54	09:46	17:49	18:25	09:52

B. Frequency Profile (%)

Region	FVI	< 49.7	49.7 - 49.8	49.8 - 49.9	< 49.9	49.9 - 50.05	> 50.05
All India	0.027	0.00	0.00	1.98	1.98	76.25	21.77

C. Power Supply Position in States

Region	States	Max.Demand Met during the day (MW)	Shortage during maximum Demand (MW)	Energy Met (MU)	Drawal Schedule (MU)	OD(+)/UD(-) (MU)	Max OD (MW)	Energy Shortage (MU)
NR	Punjab	8676	0	154.1	66.2	-1.9	316	0.00
	Haryana	8191	0	159.6	115.7	-1.3	287	0.00
	Rajasthan	18283	0	335.0	112.9	-1.2	649	0.00
	Delhi	5394	0	90.4	81.8	-0.5	492	0.00
	UP	21002	0	387.6	125.0	1.5	440	0.00
	Uttarakhand	2464	0	45.6	37.1	1.0	175	0.15
	HP	2053	0	37.4	30.6	-0.4	216	0.00
	J&K(UT) & Ladakh(UT)	3200	0	68.0	64.5	-0.4	783	0.00
	Chandigarh	278	0	4.7	4.9	-0.2	45	0.00
WR	Railways_NR ISTS	200	0	4.1	3.7	0.4	66	0.00
	Chhattisgarh	5519	0	113.2	61.2	1.6	290	0.00
	Gujarat	22105	0	411.9	148.4	-10.3	887	0.00
	MP	16850	0	310.8	186.8	-3.0	571	0.00
	Maharashtra	28759	0	591.9	192.0	0.1	492	0.00
	Goa	708	0	14.2	13.2	0.4	44	0.00
	DNHDDPDCL	1336	0	30.6	30.6	0.0	34	0.00
	AMNSIL	769	0	16.9	7.3	0.4	255	0.00
	BALCO	531	0	12.7	12.7	0.0	576	0.00
SR	RIL JAMNAGAR	100	0	2.4	2.4	0.0	0	0.00
	Andhra Pradesh	11099	0	203.1	54.7	-1.4	393	0.00
	Telangana	14617	0	268.3	149.6	-0.6	1088	0.00
	Karnataka	16267	0	288.4	95.1	0.9	699	0.00
	Kerala	4303	0	81.8	63.1	1.2	322	0.00
	Tamil Nadu	16607	0	342.4	204.9	0.6	919	0.00
	Puducherry	389	0	8.5	8.2	-0.2	18	0.00
ER	Bihar	5373	0	99.0	91.8	-4.7	463	2.25
	DVC	3475	0	72.1	-42.9	1.5	521	0.00
	Jharkhand	2052	0	38.3	28.1	0.2	295	0.09
	Odisha	5361	0	104.1	35.5	-2.1	445	0.00
	West Bengal	7402	0	149.8	10.9	-1.2	230	0.00
	Sikkim	118	0	1.7	1.9	-0.1	33	0.00
	Railways_ER ISTS	20	0	0.2	0.1	0.1	0	0.00
NER	Arunachal Pradesh	184	0	2.7	2.9	-0.4	52	0.00
	Assam	1492	0	31.0	20.7	4.3	152	0.00
	Manipur	224	0	1.4	3.7	-2.3	40	0.00
	Meghalaya	374	0	5.7	5.1	-0.8	117	0.00
	Mizoram	154	0	1.9	1.8	-0.5	26	0.00
	Nagaland	161	0	2.0	2.3	-0.3	31	0.00
	Tripura	227	0	3.4	3.3	-0.4	33	0.00

D. Transnational Exchanges (MU) - Import(+ve)/Export(-ve)

	Bhutan	Nepal	Bangladesh	Godda -> Bangladesh
Actual (MU)	-5.0	-7.5	-21.0	-13.5
Day Peak (MW)	-400.8	-526.0	-998.0	-761.0

E. Import/Export by Regions (in MU) - Import(+ve)/Export(-ve); OD(+)/UD(-)

	NR	WR	SR	ER	NER	TOTAL
Schedule(MU)	268.2	-324.7	164.0	-116.0	8.5	0.0
Actual(MU)	261.6	-332.6	164.9	-108.5	7.5	-7.2
O/D/U/D(MU)	-6.7	-7.9	0.9	7.4	-1.0	-7.2

F. Generation Outage(MW)

	NR	WR	SR	ER	NER	TOTAL	% Share
Central Sector	5431	6886	4298	5658	728	23001	45
State Sector	6428	10855	7754	2669	191	27896	55
Total	11859	17740	12052	8327	919	50897	100

G. Sourcewise generation (Gross) (MU)

	NR	WR	SR	ER	NER	All India	% Share
Coal	760	1577	626	636	9	3608	74
Lignite	26	17	56	0	0	99	2
Hydro	92	37	102	18	12	260	5
Nuclear	32	54	71	0	0	157	3
Gas, Naptha & Diesel	13	14	12	0	24	63	1
RES (Wind, Solar, Biomass & Others)	196	267	221	6	1	690	14
Total	1119	1966	1087	660	45	4877	100

Share of RES in total generation (%)	17.51	13.57	20.30	0.90	1.76	14.15
Share of Non-fossil fuel (Hydro,Nuclear and RES) in total generation(%)	28.60	18.20	36.17	3.61	27.37	22.70

H. All India Demand Diversity Factor

Based on Regional Max Demands	1.011
Based on State Max Demands	1.036

I. All India Peak Demand and shortage at Solar and Non-Solar Hour

	Max Demand Met(MW)	Time	Shortage(MW)
Solar hr	228072	9:52	0
Non-Solar hr	206115	18:44	1117

Diversity factor = Sum of regional or state maximum demands / All India maximum demand

**Note: All generation MU figures are gross

***Godda (Jharkhand) -> Bangladesh power exchange is through the radial connection (isolated from Indian Grid)

Solar Hours -> 06:00 to 18:00hrs and rest are Non-Solar Hours

*Source: RLDCs for solar connected to ISTS; SLDCs for embedded solar. Limited visibility of embedded solar data.

Executive Director-NLDC

INTER-REGIONAL EXCHANGES

Import=(+ve) /Export =(-ve) for NET (MU)

Date of Reporting: 08-Jan-2025

Sl No	Voltage Level	Line Details	No. of Circuit	Max Import (MW)	Max Export (MW)	Import (MU)	Export (MU)	NET (MU)
Import/Export of ER (With NR)								
1	HVDC	ALIPURDUAR-AGRA	2	0	0	0.0	0.0	0.0
2	HVDC	PUSAULI B/B	-	1	0	0.0	6.1	-6.1
3	765 kV	GAYA-VARANASI	2	297	695	0.0	6.0	-6.0
4	765 kV	SASARAM-FATEHPUR	1	110	449	0.0	5.2	-5.2
5	765 kV	GAYA-BALIA	1	0	834	0.0	13.6	-13.6
6	400 kV	PUSAULI-VARANASI	1	0	247	0.0	6.0	-6.0
7	400 kV	PUSAULI -ALLAHABAD	1	0	109	0.0	0.2	-0.2
8	400 kV	MUZAFFARPUR-GORAKHPUR	2	126	561	0.0	5.2	-5.2
9	400 kV	PATNA-BALIA	2	0	690	0.0	9.2	-9.2
10	400 kV	NAUBATPUR-BALIA	2	9	464	0.0	2.7	-2.7
11	400 kV	BIHARSHARIFF-BALIA	2	77	234	0.0	3.7	-3.7
12	400 kV	MOTIHARI-GORAKHPUR	2	0	439	0.0	5.1	-5.1
13	400 kV	BIHARSHARIFF-VARANASI	2	118	246	0.0	0.0	0.0
14	220 kV	SAHUPURI-KARAMNASA	1	0	95	0.0	2.8	-2.8
15	132 kV	NAGAR UNTARI-RIHAND	1	0	0	0.0	0.0	0.0
16	132 kV	GARWAH-RIHAND	1	30	0	0.5	0.0	0.5
17	132 kV	KARMANASA-SAHUPURI	1	0	0	0.0	0.0	0.0
18	132 kV	KARMANASA-CHANDAUJI	1	0	0	0.0	0.0	0.0
ER-NR						0.5	65.8	-65.3
Import/Export of ER (With WR)								
1	765 kV	JHARSUGUDA-DHARAMJAIGARH	4	1221	397	7.9	0.0	7.9
2	765 kV	NEW RANCHI-DHARAMJAIGARH	2	1052	292	9.1	0.0	9.1
3	765 kV	JHARSUGUDA-DURG	2	0	939	0.0	14.3	-14.3
4	400 kV	JHARSUGUDA-RAIGARH	4	0	568	0.0	8.5	-8.5
5	400 kV	RANCHI-SIPAT	2	254	144	1.8	0.0	1.8
6	220 kV	BUDHIPADAR-RAIGARH	1	0	118	0.0	1.7	-1.7
7	220 kV	BUDHIPADAR-KORBA	2	134	26	1.4	0.0	1.4
ER-WR						20.2	24.5	-4.3
Import/Export of ER (With SR)								
1	HVDC	JEYPORE-GAZUWAKA B/B	2	0	215	0.0	5.1	-5.1
2	HVDC	TALCHER-KOLAR BIPOLE	2	0	2017	0.0	33.3	-33.3
3	765 kV	ANGUL-SRIKAKULAM	2	0	2909	0.0	51.1	-51.1
4	400 kV	TALCHER-I/C	2	646	222	10.0	0.0	10.0
5	220 kV	BALIMELA-UPPER-SILERRU	1	0	0	0.0	0.0	0.0
ER-SR						0.0	89.5	-89.5
Import/Export of ER (With NER)								
1	400 kV	BINAGURI-BONGAIGAON	2	170	114	1.3	0.6	0.6
2	400 kV	ALIPURDUAR-BONGAIGAON	2	317	139	1.8	0.0	1.8
3	220 kV	ALIPURDUAR-SALAKATI	2	81	20	0.7	0.0	0.7
ER-NER						3.8	0.6	3.2
Import/Export of NER (With NR)								
1	HVDC	BISWANATH CHARIALI-AGRA	2	647	0	11.3	0.0	11.3
NER-NR						11.3	0.0	11.3
Import/Export of WR (With NR)								
1	HVDC	CHAMPA-KURUKSHETRA	2	0	3534	0.0	49.5	-49.5
2	HVDC	VINDHYACHAL B/B	-	245	103	0.0	1.2	-1.2
3	HVDC	MUNDRA-MOHINDERGARH	2	0	1455	0.0	25.1	-25.1
4	765 kV	GWALIOR-AGRA	2	0	2572	0.0	33.4	-33.4
5	765 kV	GWALIOR-PHAGI	2	232	1871	0.3	19.9	-19.6
6	765 kV	JABALPUR-ORAI	2	0	1230	0.0	32.6	-32.6
7	765 kV	GWALIOR-ORAI	1	704	0	11.4	0.0	11.4
8	765 kV	SATNA-ORAI	1	0	1147	0.0	19.9	-19.9
9	765 kV	BANASKANTHA-CHITORGARH	2	453	1509	0.7	18.1	-17.4
10	765 kV	VINDHYACHAL-VARANASI	2	0	3158	0.0	48.1	-48.1
11	400 kV	ZERDA-KANKROLI	1	124	251	0.3	2.3	-2.1
12	400 kV	ZERDA -BHINMAL	1	85	173	0.2	1.6	-1.4
13	400 kV	VINDHYACHAL -RIHAND	1	970	0	21.4	0.0	21.4
14	400 kV	RAPP-SHUJALPUR	2	415	367	2.4	2.0	0.5
15	400 kV	NEEMUCH-Chittorgarh	2	473	302	3.3	1.1	2.3
16	220 kV	BHANPURA-RANPUR	1	0	157	0.0	2.8	-2.8
17	220 kV	BHANPURA-MORAK	1	0	30	0.0	1.4	-1.4
18	220 kV	MEHGAON-AURAIYA	1	119	8	1.0	0.0	1.0
19	220 kV	MALANPUR-AURAIYA	1	80	26	0.4	0.1	0.3
20	132 kV	GWALIOR-SAWAI MADHOPUR	1	0	0	0.0	0.0	0.0
21	132 kV	RAJGHAT-LALITPUR	2	0	0	0.0	0.0	0.0
WR-NR						41.3	258.9	-217.6
Import/Export of WR (With SR)								
1	HVDC	BHADRAWATI B/B	-	0	308	0.0	7.2	-7.2
2	HVDC	RAIGARH-PUGALUR	2	0	2502	0.0	32.1	-32.1
3	765 kV	SOLAPUR-RAICHUR	2	783	1720	2.4	15.9	-13.5
4	765 kV	WARDHA-NIZAMABAD	2	0	2997	0.0	46.2	-46.2
5	765 kV	WARORA-WARANGAL(NEW)	2	0	2826	0.0	44.7	-44.7
6	400 kV	KOLHAPUR-KUDGI	2	1479	0	22.4	0.0	22.4
7	220 kV	KOLHAPUR-CHIKODI	2	0	0	0.0	0.0	0.0
8	220 kV	PONDA-AMBEWADI	1	0	0	0.0	0.0	0.0
9	220 kV	XELDEM-AMBEWADI	1	0	106	2.1	0.0	2.1
WR-SR						26.9	146.0	-119.1

INTERNATIONAL EXCHANGES					Import(+ve)/Export(-ve)	
State	Region	Line Name	Max (MW)	Min (MW)	Avg (MW)	Energy Exchange (MU)
BHUTAN	ER	400kV MANGDECHHU-ALIPURDUAR 1,2&3 i.e. ALIPURDUAR RECEIPT (from MANGDECHU HEP 4*180MW)	197	-30	69	1.67
	ER	400kV TALA-BINAGURI 1,2,4 (& 400kV MALBASE - BINAGURI) i.e. BINAGURI RECEIPT (from TALA HEP 6*170MW)	-226	101	-78	-1.88
	ER	220kV CHUKHA-BIRPARA 1&2 (& 220kV MALBASE - BIRPARA) i.e. BIRPARA RECEIPT (from CHUKHA HEP 4*84MW)	-235	-126	-190	-4.56
	NER	132kV GELEPHU-SALAKATI	-22	-8	-16	-0.38
	NER	132kV MOTANGA-RANGIA	14	-8	5	0.13
NEPAL	NR	NEPAL IMPORT (FROM UP)	-71	0	-50	-1.19
	NR	132kV MAHENDRANAGAR-TANAKPUR(NHPC)	-71	0	-45	-1.08
	ER	NEPAL IMPORT (FROM BIHAR)	-199	-28	-82	-1.98
	ER	400kV DHALKEBAR-MUZAFFARPUR 1&2	-327	-15	-136	-3.27
BANGLADESH	ER	BHERAMARA B/B HVDC (B'DESH)	-934	-649	-824	-19.77
	ER (Isolated from Indian Grid)	400kV GODDA_TPS-RAHANPUR (B'DESH) D/C	-761	-406	-563	-13.50
	NER	132kV COMILLA-SURAJMANI NAGAR 1&2	-64	0	-53	-1.26

Export From India (in MU)

Country	GNA (ISGS/PPA)	T-GNA							TOTAL
		BILATERAL TOTAL	COLLECTIVE						
			IDAM			RTM			
			IEX	PXIL	HPX	IEX	PXIL	HPX	
Bhutan	0.00	0.30	6.08	0.00	0.00	0.00	0.00	0.00	6.38
Nepal	2.00	0.00	1.57	0.00	0.00	1.57	0.00	0.00	5.14
Bangladesh	20.36	0.00	0.00	0.00	0.00	0.00	0.00	0.00	20.36
Myanmar	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total Export	22.36	0.30	7.65	0.00	0.00	1.57	0.00	0.00	31.88

Import by India(in MU)

Country	GNA (ISGA/PPA)	T-GNA							TOTAL
		BILATERAL TOTAL	COLLECTIVE						
			IDAM			RTM			
			IEX	PXIL	HPX	IEX	PXIL	HPX	
Bhutan	0.80	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.80
Nepal	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Bangladesh	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Myanmar	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total Import	0.80	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.80

Net from India(in MU)

-ve : Export / +ve : Import

Country	GNA (ISGS/PPA)	T-GNA							TOTAL
		BILATERAL TOTAL	COLLECTIVE						
			IDAM			RTM			
			IEX	PXIL	HPX	IEX	PXIL	HPX	
Bhutan	0.80	-0.30	-6.08	0.00	0.00	0.00	0.00	0.00	-5.58
Nepal	-2.00	0.00	-1.57	0.00	0.00	-1.57	0.00	0.00	-5.14
Bangladesh	-20.36	0.00	0.00	0.00	0.00	0.00	0.00	0.00	-20.36
Myanmar	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total Net	-21.56	-0.30	-7.65	0.00	0.00	-1.57	0.00	0.00	-31.08

15 Min (INSTANTANEOUS) ALL INDIA GRID FREQUENCY, GENERATION & DEMAND MET (SCADA DATA)												Date of Reporting: 08-Jan-2025
TIME	FREQUENCY (Hz)	DEMAND MET (MW)	NUCLEAR (MW)	WIND (MW)	SOLAR (MW)	HYDRO** (MW)	GAS (MW)	THERMAL (MW)	OTHERS* (MW)	NET DEMAND MET (MW)	TOTAL GENERATION (MW)	NET TRANSNATIONAL EXCHANGE (MW)
		(A)	(B)	(C)	(D)	(E)	(F)	(G)	(H)	(I=A-(C+D))	(J=B+C+D+E+F+G+H)	(K)
0:00	50.02	152730	6211	12641	110	6933	2224	124921	3294	139979	156334	-1505
0:15	49.86	151682	6218	12468	4132	6615	2251	124416	3200	135082	159300	-1630
0:30	49.91	150778	6196	12569	104	6486	2248	123646	3209	138105	154458	-1628
0:45	49.96	150275	6209	12514	110	6402	2250	123034	3272	137651	153791	-1483
1:00	50.01	149622	6208	12490	107	6255	2236	122332	3352	137025	152980	-1385
1:15	50.01	148460	6225	12387	93	6286	2251	121470	3307	135980	152019	-1402
1:30	49.96	147683	6209	12208	90	6260	2251	120783	3288	135385	151089	-1387
1:45	49.96	147179	6214	12028	88	6110	2249	120769	3339	135063	150797	-1381
2:00	50.07	146099	6221	12010	92	5718	2255	119940	3341	133997	149577	-1372
2:15	49.97	145406	6242	11899	91	5526	2274	119528	3283	133416	148843	-1416
2:30	49.97	145406	6241	11753	87	5633	2273	119571	3329	133566	148887	-1346
2:45	50.02	145004	6230	11696	88	5645	2172	119215	3341	133220	148387	-1259
3:00	50.01	144393	6219	11807	83	5680	2174	118530	3343	132503	147836	-1303
3:15	49.97	144986	6226	11788	90	5491	2204	119112	3334	133108	148245	-1332
3:30	50.02	144688	6233	11792	89	5790	2221	118928	3295	132807	148348	-1313
3:45	50.02	145157	6226	11765	87	5898	2219	119138	3338	133305	148671	-1302
4:00	50.07	145506	6220	11748	86	6013	2231	119426	3315	133672	149039	-1316
4:15	50.06	147533	6229	11722	83	6344	2248	121042	3310	135728	150978	-1298
4:30	50.06	149088	6224	11803	89	6537	2251	122398	3379	137196	152681	-1327
4:45	50.01	150621	6232	11850	89	6565	2272	123918	3317	138682	154243	-1263
5:00	50.06	153294	6229	11871	92	6511	2292	126552	3294	141331	156841	-1294
5:15	50.01	157266	6239	11908	93	6564	2293	130458	3314	145265	160869	-1350
5:30	49.96	161834	6237	11819	92	7103	2292	133940	3288	149923	164771	-1343
5:45	50.02	166431	6220	11738	92	7792	2285	138122	3326	154601	169575	-1471
6:00	50.07	170455	6224	11721	95	9248	2386	140660	3351	158639	173685	-1521
6:15	50.07	175582	6222	11608	163	10429	2518	144547	3247	163811	178734	-1543
6:30	50.07	182541	6228	11422	169	12232	2890	149164	3249	170950	185354	-1241
6:45	50.07	189761	6230	11293	231	15606	3211	152765	3291	178237	192627	-1196
7:00	50.07	195970	6238	11191	431	18132	3378	155962	3278	184348	198610	-1364
7:15	49.96	201412	6239	11170	1057	20402	3440	158300	3320	189185	203928	-1233
7:30	50.02	205335	6239	11037	2136	21647	3424	159851	3322	192162	207656	-1157
7:45	50.02	208690	6228	10963	3775	21851	3426	161001	3388	193952	210632	-1107
8:00	50.07	211122	6208	10806	6625	22168	3456	160793	3377	193691	213433	-1088
8:15	50.07	215021	6231	10538	10354	21666	3575	161465	3416	194129	217245	-1092
8:30	50.12	217287	6224	10231	14639	21011	3677	160130	3450	192417	219362	-1105
8:45	50.06	219660	6230	9782	19186	19225	3648	160300	3430	190692	221801	-1118
9:00	50.12	220964	6235	9033	23729	17415	3631	159520	3498	188202	223061	-1085
9:15	50.01	225159	6231	8231	28204	16258	3271	160784	3478	188724	226457	-910
9:30	50.01	227238	6219	7486	32413	15651	2536	160858	3440	187339	228603	-812
9:45	50.01	227824	6215	6899	35758	14300	2537	159648	3428	185167	228785	-816
10:00	50.06	227377	6221	6459	38883	12647	2362	158387	3476	182035	228435	-857
10:15	50.06	226852	6216	6276	41933	10677	2518	157295	3421	178643	228336	-1030
10:30	50.06	226836	6217	6178	44848	8804	2356	156005	3588	175810	227996	-1105
10:45	50.06	226376	6226	6039	48198	7901	2362	153492	3532	172139	227750	-1259
11:00	50.01	224585	6227	6096	50592	7218	2481	150268	3548	167897	226430	-1404
11:15	50.01	222796	6225	6082	52824	6291	2433	147247	3514	163890	224616	-1376
11:30	50.01	221506	6220	5978	53929	6248	2426	144988	3583	161599	223372	-1380
11:45	49.96	220354	6214	5778	55056	6438	2408	143104	3609	159520	222607	-1752
12:00	50.01	219091	6215	5647	55683	6626	2380	139271	3561	157761	219383	-1788
12:15	49.91	217934	6226	5542	56004	6683	2359	137871	3549	156388	218234	-1875
12:30	50.01	216563	6214	5371	56172	6579	2372	135645	3599	155020	215952	-1748
12:45	49.96	215185	6204	5375	56431	7002	2388	133956	3595	153379	214951	-1828
13:00	50.06	211764	6211	5290	56217	6975	2370	133360	3625	150257	214048	-1900
13:15	49.96	207798	6207	5267	56140	6049	2382	130412	3562	146391	210019	-1869
13:30	50.01	206024	6204	5333	55612	5874	2352	129783	3594	145079	208752	-1938
13:45	49.91	206615	6198	5407	54977	6283	2361	130374	3682	146231	209282	-1878
14:00	50.07	205438	6198	5334	53991	6656	2352	129976	3564	146113	208071	-1895
14:15	50.02	204861	6209	5225	52733	6068	2347	131552	3567	146903	207701	-1976
14:30	50.02	205697	6169	5277	51241	6396	2351	133388	3560	149179	208382	-1975
14:45	50.02	206466	6182	5244	49174	6464	2346	136345	3527	152048	209282	-1951
15:00	50.02	206158	6179	5175	46748	6511	2351	138494	3582	154235	209040	-1952
15:15	50.02	205644	6160	5218	44152	6605	2354	140181	3496	156274	208166	-1799
15:30	50.02	205877	6190	5342	41358	7142	2358	142727	3452	159177	208569	-1852
15:45	50.07	205009	6213	5414	38108	7471	2405	144683	3426	161487	207720	-1826
16:00	50.07	204640	6198	5576	34119	7743	2586	147730	3407	164945	207359	-1665
16:15	50.01	202550	6211	5722	29772	7430	2853	149845	3409	167056	205242	-1602
16:30	50.02	204488	6178	5885	25101	8685	3398	154392	3399	173556	206984	-1377
16:45	50.02	205478	6204	5766	19926	11228	3509	157687	3435	179786	207755	-1373
17:00	50.07	205884	6191	5784	15002	13991	3517	160353	3426	185098	208264	-1144
17:15	50.02	204005	6208	5772	10070	15825	3520	161433	3345	188163	206173	-962
17:30	50.02	204141	6189	5839	5963	19465	3501	161898	3346	192339	206201	-794
17:45	49.97	204531	6197	5823	3117	21696	3558	163021	3358	195591	206770	-800
18:00	50.02	205306	6187	5824	1437	22272	3688	164299	3355	198045	207062	-855
18:15	50.02	204652	6208	6297	860	22611	3731	163316	3412	197495	206435	-870
18:30	50.07	205612	6194	6714	749	22985	3149	163778	3393	198149	206962	-870
18:45	50.02	206013	6194	7332	658	22828	2690	164673	3421	198023	207796	-820
19:00	50.07	203564	6217	7794	500	20715	2576	164196	3372	195270	205370	-756
19:15	50.02	202895	6204	8348	476	19082	2596	164687	3408	194071	204801	-733
19:30	50.07	201455	6213	8829	480	17808	2590	164005	3362	192146	203287	-727
19:45	50.07	198175	6215	9268	479	15323	2605	162457	3393	188428	199740	-693
20:00	50.12	194426	6233	9698	478	13479	2582	160079	3403	184250	195952	-715
20:15	50.02	191691	6217	10156	104	12802	2554	157543	3425	181431	192801	-886
20:30	50.02	188597	6229	10502	103	11864	2476	155362	3472	177992	190008	-1078
20:45	49.97	186242	6213	10789	67	10980	2404	153876	3418	175386	187747	-1038
21:00	50.02	183042	6226	11011	63	10511	2425	151026	3443	171968	184705	-1194
21:15	50.02	180169	6219	11289	62	9256	2410	149262	3451	168818	181949	-1439
21:30	50.02	177263	6208	11456	61	8766	2414	146923	3353	165746	179181	-1535
21:45	50.07	174792	6229	11661	61	8991	2410	144023	3335	163070	176710	-1553
22:00	50.12	170572	6211	11764	59	8016	2417	141001	3377	158749	172845	-1560
22:15	50.02	169781	6209	11846	60	8281	2422	139959	3347	157875	172124	-1678
22:30	50.01	167493	6233	11842	60	7955	2427	138215	3398	155591	170130	-1631
22:45	49.97	165423	6230	117								