



National Load Despatch Centre
राष्ट्रीय भार प्रेषण केंद्र
GRID CONTROLLER OF INDIA LIMITED
ग्रिड कंट्रोलर ऑफ इंडिया लिमिटेड

(Government of India Enterprise/ भारत सरकार का उद्यम)
B-9, QUTUB INSTITUTIONAL AREA, KATWARIA SARAI, NEW DELHI -110016
बी-9, कुतुब इन्स्टीट्यूशनल एरिया, कटवारिया सराये, न्यू दिल्ली-110016

Ref: GRID-INDIA/NLDC/SO/Daily PSP Report

दिनांक: 28.08.2025

To,

- कार्यकारी निदेशक, पू.क्षे.भा.प्रे.के., 14, गोल्फ क्लब रोड, कोलकाता - 700033
Executive Director, ERLDC, 14 Golf Club Road, Tollygunge, Kolkata, 700033
- कार्यकारी निदेशक, ऊ.क्षे.भा.प्रे.के., 18/ए, शाहीद जीत सिंह सनसनवाल मार्ग, नई दिल्ली - 110016
Executive Director, NRLDC, 18-A, Shaheed Jeet Singh Marg, Katwaria Sarai, New Delhi - 110016
- कार्यकारी निदेशक, प.क्षे.भा.प्रे.के., एफ3, एम आई डी सी क्षेत्र, अंधेरी, मुंबई - 400093
Executive Director, WRLDC, F-3, M.I.D.C. Area, Marol, Andheri (East), Mumbai-400093
- कार्यकारी निदेशक, ऊ.पू.क्षे.भा.प्रे.के., डोंगतेह, लोअर नोंग्रह, लापालंग, शिलोंग - 793006
Executive Director, NERLDC, Dongteih, Lower Nongrah, Lapalang, Shillong - 793006, Meghalaya
- कार्यकारी निदेशक, द.क्षे.भा.प्रे.के., 29, रेस कोर्स क्रॉस रोड, बंगलुरु - 560009
Executive Director, SRLDC, 29, Race Course Cross Road, Bangalore-560009

Sub: Daily PSP Report for the date 27.08.2025.

महोदय/Sir,

आईईजीसी-2023 की धारा स.-38(1) के प्रावधान के अनुसार, दिनांक 27-अगस्त-2025 की अखिल भारतीय प्रणाली की दैनिक ग्रिड निष्पादन रिपोर्ट रांभांप्रेके की वेबसाइट पर उपलब्ध है।

As per article 38(1) of the Indian Electricity Grid Code, the daily report pertaining power supply position of All India Power System for the date 27.08.2025, is available at the NLDC website.

धन्यवाद,
Thanks

Report for previous day

Date of Reporting: 28-Aug-2025

A. Power Supply Position at All India and Regional level

	NR	WR	SR	ER	NER	TOTAL
Demand Met during Evening Peak hrs(MW) (at 20:00 hrs: from RLDCs)	70605	58267	43977	29184	3612	205645
Peak Shortage (MW)	0	0	0	0	0	0
Energy Met (MU)	1462	1353	1094	645	74	4628
Hydro Gen (MU)	297	114	177	101	38	727
Wind Gen (MU)	15	94	258	-	-	367
Solar Gen (MU)*	182.13	115.91	100.64	3.40	1.22	403
Energy Shortage (MU)	0.31	0.00	0.00	0.05	0.00	0.36
Maximum Demand Met During the Day (MW) (From NLDC SCADA)	71390	59083	54278	29786	3710	205572
Time Of Maximum Demand Met	21:25	19:29	09:36	22:51	18:34	19:29

B. Frequency Profile (%)

Region	FV1	< 49.7	49.7 - 49.8	49.8 - 49.9	< 49.9	49.9 - 50.05	> 50.05
All India	0.043	0.22	1.70	7.37	9.29	79.23	11.48

C. Power Supply Position in States

Region	States	Max.Demand Met during the day (MW)	Shortage during maximum Demand (MW)	Energy Met (MU)	Drawal Schedule (MU)	OD(+)/UD(-) (MU)	Max OD (MW)	Energy Shortage (MU)
NR	Punjab	8865	0	187.6	88.6	-0.8	474	0.00
	Haryana	9810	0	198.0	146.7	-2.1	362	0.00
	Rajasthan	12766	0	281.4	110.9	-6.4	354	0.00
	Delhi	5654	0	122.6	118.2	-1.4	211	0.00
	UP	28516	0	541.4	229.7	0.8	604	0.00
	Uttarakhand	2427	0	51.0	31.2	0.2	148	0.16
	HP	1762	0	35.7	10.7	0.2	446	0.00
	J&K(UT) & Ladakh(UT)	1873	0	33.9	30.9	0.4	531	0.15
	Chandigarh	321	0	6.4	6.2	0.2	41	0.00
	Railways NR ISTS	211	0	4.1	3.7	0.4	67	0.00
WR	Chhattisgarh	5525	0	122.1	69.4	-1.2	308	0.00
	Gujarat	18052	0	400.6	178.7	-1.4	868	0.00
	MP	11809	0	260.5	127.2	0.0	541	0.00
	Maharashtra	22421	0	493.0	165.8	-7.5	917	0.00
	Goa	418	0	11.6	9.3	1.8	71	0.00
	DNHDDPDCL	1272	0	28.7	28.5	0.2	96	0.00
	AMNSIL	839	0	18.2	10.9	0.7	304	0.00
	BALCO	534	0	12.7	12.7	0.0	0	0.00
	RIL JAMNAGAR	249	0	5.6	5.6	0.0	0	0.00
	Andhra Pradesh	10361	0	205.5	23.3	-2.4	559	0.00
SR	Telangana	11876	0	222.9	90.8	-3.4	454	0.00
	Karnataka	12484	0	216.7	38.0	-1.9	1347	0.00
	Kerala	4089	0	84.2	44.7	-0.4	346	0.00
	Tamil Nadu	16874	0	354.6	112.0	-2.6	699	0.00
	Puducherry	439	0	9.8	9.3	-0.1	23	0.00
	Bihar	8078	0	168.7	159.0	-1.4	344	0.00
ER	DVC	3202	0	70.9	-25.7	-0.5	494	0.05
	Jharkhand	2156	0	44.6	34.7	1.8	344	0.00
	Odisha	6323	0	133.2	65.4	-4.1	384	0.00
	West Bengal	10501	0	226.6	99.4	-2.1	322	0.00
	Sikkim	94	0	1.3	1.4	-0.1	15	0.00
	Railways ER ISTS	14	0	0.1	0.2	0.0	0	0.00
NER	Arunachal Pradesh	214	0	4.3	3.5	0.3	26	0.00
	Assam	2381	0	48.1	41.2	0.2	204	0.00
	Manipur	228	0	3.2	3.2	0.0	43	0.00
	Meghalaya	329	0	6.1	2.2	-0.1	157	0.00
	Mizoram	120	0	1.9	0.7	-0.2	44	0.00
	Nagaland	183	0	3.3	2.9	-0.1	18	0.00
	Tripura	341	0	6.7	5.8	0.2	65	0.00

D. Transnational Exchanges (MU) - Import(+ve)/Export(-ve)

	Bhutan	Nepal	Bangladesh	Godda -> Bangladesh
Actual (MU)	51.8	17.7	-23.2	-26.7
Day Peak (MW)	2336.1	898.4	-977.2	-1170.0

E. Import/Export by Regions (in MU) - Import(+ve)/Export(-ve); OD(+)/UD(-)

	NR	WR	SR	ER	NER	TOTAL
Schedule(MU)	258.1	-206.2	-53.1	-3.6	4.8	0.0
Actual(MU)	253.4	-196.5	-60.7	-15.5	7.0	-12.4
O/D/U/D(MU)	-4.8	9.7	-7.6	-11.9	2.2	-12.4

F. Generation Outage(MW)

	NR	WR	SR	ER	NER	TOTAL	% Share
Central Sector	6354	13830	9668	4130	158	34140	50
State Sector	8129	13923	7618	3692	199	33561	50
Total	14483	27753	17286	7822	357	67701	100

G. Sourcewise generation (Gross) (MU)

	NR	WR	SR	ER	NER	All India	% Share
Coal	723	1259	584	616	13	3195	64
Lignite	21	11	45	0	0	77	2
Hydro	297	114	177	101	38	727	15
Nuclear	41	57	47	0	0	145	3
Gas, Naptha & Diesel	6	17	2	0	22	48	1
RES (Wind, Solar, Biomass & Others)	204	211	386	5	1	808	16
Total	1293	1670	1240	722	74	5000	100

Share of RES in total generation (%)	15.78	12.66	31.12	0.71	1.66	16.16
Share of Non-fossil fuel (Hydro,Nuclear and RES) in total generation(%)	41.95	22.93	49.14	14.66	52.74	33.60

H. All India Demand Diversity Factor

Based on Regional Max Demands	1.061
Based on State Max Demands	1.087

Diversity factor = Sum of regional or state maximum demands / All India maximum demand

**Note: All generation MU figures are gross

***Godda (Jharkhand) -> Bangladesh power exchange is through the radial connection (isolated from Indian Grid)

Solar Hours -> 06:00 to 18:00hrs and rest are Non-Solar Hours

*Source: RLDCs for solar connected to ISTS; SLDCs for embedded solar. Limited visibility of embedded solar data.

I. All India Peak Demand and shortage at Solar and Non-Solar Hour

	Max Demand Met(MW)	Time	Shortage(MW)
Solar hr	200379	9:40	24
Non-Solar hr	205572	19:29	305

INTER-REGIONAL EXCHANGES

Import=(+ve)/Export=(-ve) for NET (MU)
Date of Reporting: 28-Aug-2025

Sl No	Voltage Level	Line Details	No. of Circuit	Max Import (MW)	Max Export (MW)	Import (MU)	Export (MU)	NET (MU)
Import/Export of ER (With NR)								
1	HVDC	ALIPURDUAR-AGRA	2	0	401	0.0	9.3	-9.3
2	HVDC	PUSAULI B/B	-	0	47	0.0	2.5	-2.5
3	765 kV	GAYAN-ARANASI	2	1125	598	4.0	0.0	4.0
4	765 kV	SASARAM-FATEHPUR	1	546	217	2.1	0.0	2.1
5	765 kV	GAYA-BALIA	1	0	867	0.0	12.8	-12.8
6	400 kV	PUSAULI-VARANASI	1	0	161	0.0	2.4	-2.4
7	400 kV	PUSAULI-ALLAHABAD	1	66	54	0.1	0.0	0.1
8	400 kV	MUZAFFARPUR-GORAKHPUR	2	395	703	0.0	8.3	-8.3
9	400 kV	PATNA-BALIA	2	187	725	0.0	9.3	-9.3
10	400 kV	NAUBATPUR-BALIA	2	94	308	0.0	2.3	-2.3
11	400 kV	BIHARSHARIFF-BALIA	2	300	347	0.0	1.9	-1.9
12	400 kV	MOTIHARI-GORAKHPUR	2	235	332	0.2	0.0	0.2
13	400 kV	BIHARSARIFF-SAHUPURI	2	378	218	0.5	0.0	0.5
14	220 kV	SAHUPURI-KARMANASA	1	0	66	0.0	0.4	-0.4
15	132 kV	NAGAR UNTARI-RIHAND	1	0	0	0.1	0.0	0.1
16	132 kV	GARWAH-RIHAND	1	30	0	0.7	0.0	0.7
17	132 kV	KARMANASA-SAHUPURI	1	0	0	0.0	0.0	0.0
18	132 kV	KARMANASA-CHANDAULI	1	0	0	0.0	0.0	0.0
ER-NR						7.6	49.2	-41.6
Import/Export of ER (With WR)								
1	765 kV	JHARSUGUDA-DHARAMJAIGARH	4	1163	957	6.7	0.0	6.7
2	765 kV	NEW RANCHI-DHARAMJAIGARH	2	2095	0	35.3	0.0	35.3
3	765 kV	JHARSUGUDA-DURG	2	423	734	0.0	4.1	-4.1
4	400 kV	JHARSUGUDA-RAIGARH	4	631	45	7.2	0.0	7.2
5	400 kV	RANCHI-SIPAT	2	529	48	7.6	0.0	7.6
6	400 kV	JEYPORE-JACDALPUR	2	606	141	6.5	0.0	6.5
7	220 kV	BUDHIPADAR-RAIGARH	1	84	112	0.0	0.7	-0.7
8	220 kV	BUDHIPADAR-KORBA	2	142	123	0.0	0.2	-0.2
ER-WR						63.2	5.1	58.2
Import/Export of ER (With SR)								
1	HVDC	JEYPORE-GAZUWAKA B/B	2	0	471	0.0	9.0	-9.0
2	HVDC	TALCHER-KOLAR BIPOLE	2	0	1480	0.0	31.3	-31.3
3	765 kV	ANGUL-SRIKAKULAM	2	414	1507	0.0	9.6	-9.6
4	400 kV	TALCHER-I/C	2	504	765	0.0	1.5	-1.5
5	220 kV	BALIMELA-UPPER-SILERRU	1	0	0	0.0	0.0	0.0
ER-SR						0.0	49.9	-49.9
Import/Export of ER (With NER)								
1	400 kV	BINAGURI-BONGAIGAON	2	192	325	0.0	3.5	-3.5
2	400 kV	ALIPURDUAR-BONGAIGAON	2	116	736	0.0	8.7	-8.7
3	220 kV	ALIPURDUAR-SALAKATI	2	17	138	0.0	1.6	-1.6
ER-NER						0.0	13.8	-13.8
Import/Export of NER (With NR)								
1	HVDC	BISWANATH CHARIAL-AGRA	2	0	303	0.0	7.4	-7.4
NER-NR						0.0	7.4	-7.4
Import/Export of WR (With NR)								
1	HVDC	CHAMPA-KURUKSHETRA	2	0	4556	0.0	57.4	-57.4
2	HVDC	VINDHYACHAL B/B	-	0	509	0.0	6.9	-6.9
3	HVDC	MUNDRA-MOHINDERGARH	2	0	254	0.0	6.2	-6.2
4	765 kV	GWALIOR-AGRA	2	0	2631	0.0	31.4	-31.4
5	765 kV	GWALIOR-PHAGI	2	1386	1841	7.0	20.0	-13.0
6	765 kV	JABALPUR-ORAI	2	18	1377	0.0	32.5	-32.5
7	765 kV	GWALIOR-ORAI	1	630	56	9.1	0.1	9.0
8	765 kV	SATNA-ORAI	1	0	1064	0.0	15.6	-15.6
9	765 kV	BANASKANTHA-CHITORGARH	2	1483	1162	10.6	3.7	6.9
10	765 kV	VINDHYACHAL-VARANASI	2	0	3643	0.0	59.2	-59.2
11	400 kV	ZERDA-KANKROLI	1	274	109	2.1	0.2	1.9
12	400 kV	ZERDA -BHINMAL	1	189	75	1.5	0.2	1.3
13	400 kV	VINDHYACHAL -RIHAND	1	0	1	0.0	0.0	0.0
14	400 kV	RAPP-SHUJALPUR	2	647	563	4.1	4.4	-0.2
15	400 kV	NEEMUCH-Chittorgarh	2	476	722	2.5	7.0	-4.4
16	220 kV	BHANPURA-RANPUR	1	0	142	0.0	2.7	-2.7
17	220 kV	BHANPURA-MORAK	1	0	30	0.0	2.2	-2.2
18	220 kV	MEHGAON-AURAIYA	1	83	26	0.5	0.1	0.4
19	220 kV	MALANPUR-AURAIYA	1	56	43	0.2	0.3	-0.1
20	132 kV	RAIGHAT-LALITPUR	2	0	0	0.0	0.0	0.0
WR-NR						37.7	249.7	-212.1
Import/Export of WR (With SR)								
1	HVDC	BHADRAWATI B/B	-	997	0	12.8	0.0	12.8
2	HVDC	RAIGARH-PUGALUR	2	0	1501	0.0	23.8	-23.8
3	765 kV	SOLAPUR-RAICHUR	2	3104	0	43.7	0.0	43.7
4	765 kV	WARDHA-NIZAMABAD	2	1719	1398	10.2	6.9	3.3
5	765 kV	WARORA-WARANGAL(NEW)	2	1671	1272	10.8	4.7	6.2
6	400 kV	KOLHAPUR-KUDGI	2	1750	0	32.0	0.0	32.0
7	220 kV	KOLHAPUR-CHIKODI	2	0	0	0.0	0.0	0.0
8	220 kV	PONDA-AMBEWADI	1	0	0	0.0	0.0	0.0
9	220 kV	XELDEM-AMBEWADI	1	0	94	1.9	0.0	1.9
WR-SR						111.3	35.4	75.9

INTERNATIONAL EXCHANGES					Import(+ve)/Export(-ve)		
State	Region	Line Name	Max (MW)	Min (MW)	Avg (MW)	Energy Exchange (MU)	
BHUTAN	ER	400kV MANGDECHHU-ALIPURDUAR 1,2&3 I.e. ALIPURDUAR RECEIPT (from MANGDECHU HEP 4*180MW)	1398	1027	1196	28.70	
	ER	400kV TALA-BINAGURI 1,2,4 (& 400kV MALBASE - BINAGURI) I.e. BINAGURI RECEIPT (from TALA HEP 6*170MW)	893	686	832	19.98	
	ER	220kV CHUKHA-BIRPARA 1&2 (& 220kV MALBASE - BIRPARA) I.e. BIRPARA RECEIPT (from CHUKHA HEP 4*84MW)	261	56	104	2.51	
	NER	132kV GELEPHU-SALAKATI	-8	-4	-6	-0.15	
	NER	132kV MOTANGA-RANGIA	67	0	30	0.72	
NEPAL	NR	NEPAL IMPORT (FROM UP)	-16	0	0	0.00	
	NR	132kV MAHENDRANAGAR-TANAKPUR(NHPC)	66	0	42	1.01	
	ER	NEPAL IMPORT (FROM BIHAR)	148	89	125	2.99	
	ER	400kV DHALKEBAR-MUZAFFARPUR 1&2	680	54	573	13.74	
BANGLADESH	ER	BHERAMARA B/B HVDC (B'DESH)	-926	-903	-925	-22.20	
	ER (Isolated from Indian Grid)	400kV GODDA_TPS-RAHANPUR (B'DESH) D/C	-1170	-952	-1114	-26.74	
	NER	132kV COMILLA-SURAJMANI NAGAR 1&2	-51	0	-42	-1.00	

CROSS BORDER EXCHANGE SCHEDULE

Date of Reporting: 28-Aug-2025

Export From India (in MU)

Country	GNA (ISGS/PPA)	T-GNA							TOTAL
		BILATERAL TOTAL	COLLECTIVE						
			IDAM			RTM			
			IEX	PXIL	HPX	IEX	PXIL	HPX	
Bhutan	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Nepal	0.38	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.38
Bangladesh	22.34	0.10	0.00	0.00	0.00	0.00	0.00	0.00	22.44
Myanmar	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total Export	22.72	0.10	0.00	0.00	0.00	0.00	0.00	0.00	22.82

Import by India(in MU)

Country	GNA (ISGA/PPA)	T-GNA							TOTAL
		BILATERAL TOTAL	COLLECTIVE						
			IDAM			RTM			
			IEX	PXIL	HPX	IEX	PXIL	HPX	
Bhutan	51.07	0.00	1.41	0.00	0.00	0.19	0.00	0.00	52.67
Nepal	8.43	4.71	0.00	0.00	0.00	5.07	0.00	0.00	18.21
Bangladesh	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Myanmar	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total Import	59.50	4.71	1.41	0.00	0.00	5.26	0.00	0.00	70.88

Net from India(in MU)

-ve : Export / +ve : Import

Country	GNA (ISGS/PPA)	T-GNA							TOTAL
		BILATERAL TOTAL	COLLECTIVE						
			IDAM			RTM			
			IEX	PXIL	HPX	IEX	PXIL	HPX	
Bhutan	51.07	0.00	1.41	0.00	0.00	0.19	0.00	0.00	52.67
Nepal	8.05	4.71	0.00	0.00	0.00	5.07	0.00	0.00	17.83
Bangladesh	-22.34	-0.10	0.00	0.00	0.00	0.00	0.00	0.00	-22.44
Myanmar	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total Net	36.78	4.61	1.41	0.00	0.00	5.26	0.00	0.00	48.06

