



National Load Despatch Centre
राष्ट्रीय भार प्रेषण केंद्र
GRID CONTROLLER OF INDIA LIMITED
ग्रिड कंट्रोलर ऑफ इंडिया लिमिटेड

(Government of India Enterprise/ भारत सरकार का उद्यम)
B-9, QUTUB INSTITUTIONAL AREA, KATWARIA SARAI, NEW DELHI -110016
बी-9, कुतुब इन्स्टीट्यूशनल एरिया, कटवारिया सराये, न्यू दिल्ली-110016

Ref: GRID-INDIA/NLDC/SO/Daily PSP Report

दिनांक: 08.05.2025

To,

- कार्यकारी निदेशक, पू.क्षे.भा.प्रे.के., 14, गोल्फ क्लब रोड, कोलकाता - 700033
Executive Director, ERLDC, 14 Golf Club Road, Tollygunge, Kolkata, 700033
- कार्यकारी निदेशक, ऊ.क्षे.भा.प्रे.के., 18/ए, शाहीद जीत सिंह सनसनवाल मार्ग, नई दिल्ली - 110016
Executive Director, NRLDC, 18-A, Shaheed Jeet Singh Marg, Katwaria Sarai, New Delhi - 110016
- कार्यकारी निदेशक, प.क्षे.भा.प्रे.के., एफ3, एम आई डी सी क्षेत्र, अंधेरी, मुंबई -400093
Executive Director, WRLDC, F-3, M.I.D.C. Area, Marol, Andheri (East), Mumbai-400093
- कार्यकारी निदेशक, ऊ.पू.क्षे.भा.प्रे.के., डोंगतेह, लोअर नोंग्रह, लापालंग, शिलोंग - 793006
Executive Director, NERLDC, Dongteih, Lower Nongrah, Lapalang, Shillong - 793006, Meghalaya
- कार्यकारी निदेशक, द.क्षे.भा.प्रे.के., 29, रेस कोर्स क्रॉस रोड, बंगलुरु -560009
Executive Director, SRLDC, 29, Race Course Cross Road, Bangalore-560009

Sub: Daily PSP Report for the date 07.05.2025.

महोदय/Sir,

आईईजीसी-2023 की धारा स.-38(1) के प्रावधान के अनुसार, दिनांक 7-मई-2025 की अखिल भारतीय प्रणाली की दैनिक ग्रिड निष्पादन रिपोर्ट रांभांप्रेके की वेबसाइट पर उपलब्ध है।

As per article 38(1) of the Indian Electricity Grid Code, the daily report pertaining power supply position of All India Power System for the date 07.05.2025, is available at the NLDC website.

धन्यवाद,
Thanks

Report for previous day

Date of Reporting: 08-May-2025

A. Power Supply Position at All India and Regional level

	NR	WR	SR	ER	NER	TOTAL
Demand Met during Evening Peak hrs(MW) (at 20:00 hrs; from RLDCs)	61009	58109	50320	27381	3206	200025
Peak Shortage (MW)	0	0	0	0	0	0
Energy Met (MU)	1360	1364	1209	605	59	4598
Hydro Gen (MU)	238	24	82	31	15	390
Wind Gen (MU)	8	106	71	-	-	185
Solar Gen (MU)*	207.24	115.94	140.29	4.04	1.06	469
Energy Shortage (MU)	0.00	0.00	0.00	0.00	0.00	0.00
Maximum Demand Met During the Day (MW) (From NLDC SCADA)	62407	58435	57593	28223	3262	202213
Time Of Maximum Demand Met	22:19	23:32	14:53	23:25	18:47	22:19

B. Frequency Profile (%)

Region	FVI	< 49.7	49.7 - 49.8	49.8 - 49.9	< 49.9	49.9 - 50.05	> 50.05
All India	0.029	0.00	0.00	2.96	2.96	84.06	12.97

C. Power Supply Position in States

Region	States	Max.Demand Met during the day (MW)	Shortage during maximum Demand (MW)	Energy Met (MU)	Drawal Schedule (MU)	OD(+)/UD(-) (MU)	Max OD (MW)	Energy Shortage (MU)
NR	Punjab	8742	0	191.6	100.6	-0.5	403	0.00
	Haryana	8405	0	184.1	133.4	-2.2	258	0.00
	Rajasthan	12576	0	259.9	96.6	-3.1	684	0.00
	Delhi	5342	0	110.1	102.4	-2.4	184	0.00
	UP	24350	0	470.7	166.3	-1.5	818	0.00
	Uttarakhand	2284	0	46.9	31.2	0.6	154	0.00
	HP	1802	0	36.7	12.9	-1.5	264	0.00
	J&K(UT) & Ladakh(UT)	2505	0	50.8	31.9	-3.1	74	0.00
	Chandigarh	256	0	5.0	5.1	-0.1	21	0.00
	Railways_NR ISTS	211	0	4.2	4.0	0.2	43	0.00
WR	Chhattisgarh	5399	0	120.0	62.9	-1.0	309	0.00
	Gujarat	15808	0	350.0	130.3	-10.7	1236	0.00
	MP	11719	0	249.2	144.2	-2.3	563	0.00
	Maharashtra	24903	0	562.7	192.2	-4.1	765	0.00
	Goa	815	0	17.8	17.4	0.3	59	0.00
	DNHDDPDCL	1296	0	29.3	29.5	-0.2	80	0.00
	AMNSIL	873	0	19.7	9.5	0.0	251	0.00
	BALCO	533	0	12.7	12.7	0.0	9	0.00
	RIL JAMNAGAR	180	0	3.0	3.0	0.0	0	0.00
	Andhra Pradesh	10686	0	225.3	67.5	-0.8	530	0.00
SR	Telangana	10251	0	203.0	79.1	0.0	533	0.00
	Karnataka	15353	0	301.6	112.6	-0.3	925	0.00
	Kerala	4900	0	99.2	69.6	0.6	519	0.00
	Tamil Nadu	17753	0	369.8	229.3	-1.9	690	0.00
	Puducherry	503	0	10.3	10.6	-0.4	26	0.00
	Bihar	6889	0	137.6	132.1	-0.6	131	0.00
ER	DVC	3153	0	72.5	-36.8	2.4	300	0.00
	Jharkhand	1984	0	44.1	33.6	1.9	288	0.00
	Odisha	6440	0	130.2	61.4	-0.4	706	0.00
	West Bengal	10796	0	220.0	89.6	-1.7	305	0.00
	Sikkim	58	0	0.8	1.3	-0.4	6	0.00
	Railways_ER ISTS	13	0	0.3	0.2	0.0	0	0.00
	Arunachal Pradesh	172	0	3.0	3.0	-0.2	26	0.00
NER	Assam	2015	0	36.7	29.3	0.5	156	0.00
	Manipur	232	0	3.3	3.2	0.1	31	0.00
	Meghalaya	333	0	5.8	2.3	0.0	188	0.00
	Mizoram	131	0	2.0	1.7	-0.1	24	0.00
	Nagaland	156	0	2.7	2.7	0.0	6	0.00
	Tripura	334	0	5.6	4.6	0.1	45	0.00

D. Transnational Exchanges (MU) - Import(+ve)/Export(-ve)

	Bhutan	Nepal	Bangladesh	Godda -> Bangladesh
Actual (MU)	4.2	-11.3	-23.3	-27.8
Day Peak (MW)	298.0	-764.8	-992.0	-1374.0

E. Import/Export by Regions (in MU) - Import(+ve)/Export(-ve); OD(+)/UD(-)

	NR	WR	SR	ER	NER	TOTAL
Schedule(MU)	183.6	-324.3	152.9	-25.5	13.3	0.0
Actual(MU)	153.6	-309.5	158.9	-19.0	12.1	-3.9
O/D/U/D(MU)	-30.0	14.8	6.0	6.4	-1.1	-3.9

F. Generation Outage(MW)

	NR	WR	SR	ER	NER	TOTAL	% Share
Central Sector	4214	6542	4478	4095	386	19715	44
State Sector	7604	9865	4676	2339	179	24663	56
Total	11818	16407	9154	6434	565	44378	100

G. Sourcewise generation (Gross) (MU)

	NR	WR	SR	ER	NER	All India	% Share
Coal	752	1439	677	674	12	3554	71
Lignite	26	15	37	0	0	79	2
Hydro	238	24	82	31	15	390	8
Nuclear	28	65	71	0	0	165	3
Gas, Naptha & Diesel	15	47	4	0	23	89	2
RES (Wind, Solar, Biomass & Others)	226	224	242	6	1	699	14
Total	1286	1814	1113	710	51	4975	100

Share of RES in total generation (%)	17.58	12.34	21.75	0.82	2.12	14.05
Share of Non-fossil fuel (Hydro,Nuclear and RES) in total generation(%)	38.31	17.26	35.48	5.12	31.64	25.19

H. All India Demand Diversity Factor

Based on Regional Max Demands	1.038
Based on State Max Demands	1.088

I. All India Peak Demand and shortage at Solar and Non-Solar Hour

	Max Demand Met(MW)	Time	Shortage(MW)
Solar hr	200786	14:56	0
Non-Solar hr	202213	22:19	0

Diversity factor = Sum of regional or state maximum demands / All India maximum demand

**Note: All generation MU figures are gross

***Godda (Jharkhand) -> Bangladesh power exchange is through the radial connection (isolated from Indian Grid)

Solar Hours -> 06:00 to 18:00hrs and rest are Non-Solar Hours

*Source: RLDCs for solar connected to ISTS; SLDCs for embedded solar. Limited visibility of embedded solar data.

Executive Director-NLDC

INTER-REGIONAL EXCHANGES								
Import=(+ve) /Export =(-ve) for NET (MU)								
Date of Reporting: 08-May-2025								
Sl No	Voltage Level	Line Details	No. of Circuit	Max Import (MW)	Max Export (MW)	Import (MU)	Export (MU)	NET (MU)
Import/Export of ER (With NR)								
1	HVDC	ALIPURDUAR-AGRA	2	0	0	0.0	0.0	0.0
2	HVDC	PUSAULI B/B	-	0	47	0.0	2.5	-2.5
3	765 kV	GAYA-VARANASI	2	1472	628	5.5	0.0	5.5
4	765 kV	SASARAM-FATEHPUR	1	557	311	0.5	0.0	0.5
5	765 kV	GAYA-BALIA	1	0	622	0.0	7.8	-7.8
6	400 kV	PUSAULI-VARANASI	1	4	147	0.0	2.0	-2.0
7	400 kV	PUSAULI -ALLAHABAD	1	51	101	0.0	0.3	-0.3
8	400 kV	MUZAFFARPUR-GORAKHPUR	2	771	266	2.9	0.0	2.9
9	400 kV	PATNA-BALIA	2	541	512	0.0	3.1	-3.1
10	400 kV	NAUBATPUR-BALIA	2	237	276	0.0	0.1	-0.1
11	400 kV	BIHARSHARIEF-BALIA	2	655	0	7.0	0.0	7.0
12	400 kV	MOTIHARI-GORAKHPUR	2	285	331	0.0	2.3	-2.3
13	400 kV	BIHARSARIEF-SAHUPURI	2	242	108	1.4	0.0	1.4
14	220 kV	SAHUPURI-KARAMNASA	1	13	51	1.0	0.0	1.0
15	132 kV	NAGAR UNTARI-RIHAND	1	0	0	0.0	0.0	0.0
16	132 kV	GARWAH-RIHAND	1	30	0	0.1	0.0	0.1
17	132 kV	KARMANASA-SAHUPURI	1	0	0	0.4	0.0	0.4
18	132 kV	KARMANASA-CHANDAULI	1	0	0	0.0	0.0	0.0
ER-NR						18.7	18.1	0.6
Import/Export of ER (With WR)								
1	765 kV	JHARSUGUDA-DHARAMJAIGARH	4	1095	479	4.7	0.0	4.7
2	765 kV	NEW RANCHI-DHARAMJAIGARH	2	1900	66	23.6	0.0	23.6
3	765 kV	JHARSUGUDA-DURG	2	73	542	0.0	6.8	-6.8
4	400 kV	JHARSUGUDA-RAIGARH	4	328	378	0.0	1.5	-1.5
5	400 kV	RANCHI-SIPAT	2	487	94	4.2	0.0	4.2
6	220 kV	BUDHIPADAR-RAIGARH	1	65	35	0.3	0.0	0.3
7	220 kV	BUDHIPADAR-KORBA	2	188	2	2.0	0.0	2.0
ER-WR						34.8	8.3	26.5
Import/Export of ER (With SR)								
1	HVDC	JEYPORE-GAZUWAKA B/B	2	0	313	0.0	7.4	-7.4
2	HVDC	TALCHER-KOLAR BIPOLE	2	0	1755	0.0	38.2	-38.2
3	765 kV	ANGUL-SRIKAKULAM	2	0	2566	0.0	41.3	-41.3
4	400 kV	TALCHER-I/C	2	646	714	0.8	0.0	0.8
5	220 kV	BALIMELA-UPPER-SILERRU	1	0	0	0.0	0.0	0.0
ER-SR						0.0	86.9	-86.9
Import/Export of ER (With NER)								
1	400 kV	BINAGURI-BONGAIGAON	2	163	152	0.9	0.9	0.0
2	400 kV	ALIPURDUAR-BONGAIGAON	2	234	252	0.0	0.7	-0.7
3	220 kV	ALIPURDUAR-SALAKATI	2	53	28	0.3	0.0	0.3
ER-NER						1.2	1.6	-0.4
Import/Export of NER (With NR)								
1	HVDC	BISWANATH CHARIALI-AGRA	2	472	0	11.1	0.0	11.1
NER-NR						11.1	0.0	11.1
Import/Export of WR (With NR)								
1	HVDC	CHAMPA-KURUKSHETRA	2	0	2015	0.0	47.6	-47.6
2	HVDC	VINDHYACHAL B/B	-	0	105	0.0	2.4	-2.4
3	HVDC	MUNDRA-MOHINDERGARH	2	0	1455	0.0	31.5	-31.5
4	765 kV	GWALIOR-AGRA	2	0	1952	0.0	29.0	-29.0
5	765 kV	GWALIOR-PHAGI	2	1200	1288	6.9	13.2	-6.2
6	765 kV	JABALPUR-ORAI	2	90	894	0.0	22.3	-22.3
7	765 kV	GWALIOR-ORAI	1	627	0	8.6	0.0	8.6
8	765 kV	SATNA-ORAI	1	0	982	0.0	16.9	-16.9
9	765 kV	BANASKANTHA-CHITORGARH	2	690	1051	8.0	0.0	8.0
10	765 kV	VINDHYACHAL-VARANASI	2	0	2785	0.0	49.6	-49.6
11	400 kV	ZERDA-KANKROLI	1	168	111	0.9	0.4	0.4
12	400 kV	ZERDA -BHINMAL	1	197	205	0.2	1.3	-1.1
13	400 kV	VINDHYACHAL -RIHAND	1	965	0	19.1	0.0	19.1
14	400 kV	RAPP-SHUJALPUR	2	549	252	4.4	1.9	2.6
15	400 kV	NEEMUCH-Chittorgarh	2	595	252	4.2	2.3	1.9
16	220 kV	BHANPURA-RANPUR	1	0	135	0.0	2.6	-2.6
17	220 kV	BHANPURA-MORAK	1	0	30	0.0	1.6	-1.6
18	220 kV	MEHGAON-AURAIYA	1	60	11	0.4	0.0	0.4
19	220 kV	MALANPUR-AURAIYA	1	48	7	0.3	0.0	0.3
20	132 kV	GWALIOR-SAWAI MADHOPUR	1	0	0	0.0	0.0	0.0
21	132 kV	RAJGHAT-LALITPUR	2	0	0	0.0	0.0	0.0
WR-NR						53.1	222.6	-169.6
Import/Export of WR (With SR)								
1	HVDC	BHADRAWATI B/B	-	0	1010	0.0	8.6	-8.6
2	HVDC	RAIGARH-PUGALUR	2	0	4005	0.0	76.8	-76.8
3	765 kV	SOLAPUR-RAICHUR	2	1089	1864	4.4	6.6	-2.2
4	765 kV	WARDHA-NIZAMABAD	2	0	2243	0.0	23.2	-23.2
5	765 kV	WARORA-WARANGAL(NEW)	2	0	2454	0.0	28.3	-28.3
6	400 kV	KOLHAPUR-KUDGI	2	1418	0	23.3	0.0	23.3
7	220 kV	KOLHAPUR-CHIKODI	2	0	0	0.0	0.0	0.0
8	220 kV	PONDA-AMBEWADI	1	0	0	0.0	0.0	0.0
9	220 kV	XELDEM-AMBEWADI	1	0	125	2.5	0.0	2.5
WR-SR						30.2	143.5	-113.2
INTERNATIONAL EXCHANGES								
State	Region	Line Name	Max (MW)	Min (MW)	Avg (MW)	Import(+ve)/Export(-ve) Energy Exchange (MU)		
BHUTAN	ER	400kV MANGDECHHU-ALIPURDUAR 1,2&3 i.e. ALIPURDUAR RECEIPT (from MANGDECHU HEP 4*180MW)	390	229	310	7.44		
	ER	400kV TALA-BINAGURI 1,2,4 (& 400kV MALBASE - BINAGURI) i.e. BINAGURI RECEIPT (from TALA HEP 6*170MW)	-65	35	-15	-0.37		
	ER	220kV CHUKHA-BIRPARA 1&2 (& 220kV MALBASE - BIRPARA) i.e. BIRPARA RECEIPT (from CHUKHA HEP 4*84MW)	-158	-102	-133	-3.18		
	NER	132kV GELEPHU-SALAKATI	-11	2	-5	-0.11		
	NER	132kV MOTANGA-RANGIA	27	0	16	0.39		
NEPAL	NR	NEPAL IMPORT (FROM UP)	-73	0	-52	-1.26		
	NR	132kV MAHENDRANAGAR-TANAKPUR(NHPC)	-73	0	-52	-1.25		
	ER	NEPAL IMPORT (FROM BIHAR)	-215	0	-93	-2.24		
	ER	400kV DHALKEBAR-MUZAFFARPUR 1&2	-550	-8	-273	-6.55		
BANGLADESH	ER	BHERAMARA B/B HVDC (B'DESH)	-946	-886	-934	-22.41		
	ER (Isolated from Indian Grid)	400kV GODDA_TPS-RAHANPUR (B'DESH) D/C	-1374	-813	-1158	-27.80		
	NER	132kV COMILLA-SURAJMANI NAGAR 1&2	-46	0	-38	-0.90		

Export From India (in MU)

Country	GNA (ISGS/PPA)	T-GNA							TOTAL
		BILATERAL TOTAL	COLLECTIVE						
			IDAM			RTM			
			IEX	PXIL	HPX	IEX	PXIL	HPX	
Bhutan	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Nepal	2.33	0.00	3.42	0.00	0.00	2.91	0.00	0.00	8.66
Bangladesh	23.20	0.00	0.00	0.00	0.00	0.00	0.00	0.00	23.20
Myanmar	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total Export	25.53	0.00	3.42	0.00	0.00	2.91	0.00	0.00	31.86

Import by India(in MU)

Country	GNA (ISGA/PPA)	T-GNA							TOTAL
		BILATERAL TOTAL	COLLECTIVE						
			IDAM			RTM			
			IEX	PXIL	HPX	IEX	PXIL	HPX	
Bhutan	3.71	0.00	0.00	0.00	0.00	0.00	0.00	0.00	3.71
Nepal	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Bangladesh	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Myanmar	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total Import	3.71	0.00	0.00	0.00	0.00	0.00	0.00	0.00	3.71

Net from India(in MU)

-ve : Export / +ve : Import

Country	GNA (ISGS/PPA)	T-GNA							TOTAL
		BILATERAL TOTAL	COLLECTIVE						
			IDAM			RTM			
			IEX	PXIL	HPX	IEX	PXIL	HPX	
Bhutan	3.71	0.00	0.00	0.00	0.00	0.00	0.00	0.00	3.71
Nepal	-2.33	0.00	-3.42	0.00	0.00	-2.91	0.00	0.00	-8.66
Bangladesh	-23.20	0.00	0.00	0.00	0.00	0.00	0.00	0.00	-23.20
Myanmar	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total Net	-21.82	0.00	-3.42	0.00	0.00	-2.91	0.00	0.00	-28.15

