



National Load Despatch Centre
राष्ट्रीय भार प्रेषण केंद्र
GRID CONTROLLER OF INDIA LIMITED
ग्रिड कंट्रोलर ऑफ इंडिया लिमिटेड

(Government of India Enterprise/ भारत सरकार का उद्यम)
B-9, QUTUB INSTITUTIONAL AREA, KATWARIA SARAI, NEW DELHI -110016
बी-9, कुतुब इन्स्टीट्यूशनल एरिया, कटवारिया सराये, न्यू दिल्ली-110016

Ref: GRID-INDIA/NLDC/SO/Daily PSP Report

दिनांक: 03.01.2025

To,

- कार्यकारी निदेशक, पू.क्षे.भा.प्रे.के., 14, गोल्फ क्लब रोड, कोलकाता - 700033
Executive Director, ERLDC, 14 Golf Club Road, Tollygunge, Kolkata, 700033
- कार्यकारी निदेशक, ऊ.क्षे.भा.प्रे.के., 18/ए, शाहीद जीत सिंह सनसनवाल मार्ग, नई दिल्ली - 110016
Executive Director, NRLDC, 18-A, Shaheed Jeet Singh Marg, Katwaria Sarai, New Delhi - 110016
- कार्यकारी निदेशक, प.क्षे.भा.प्रे.के., एफ3, एम आई डी सी क्षेत्र, अंधेरी, मुंबई - 400093
Executive Director, WRLDC, F-3, M.I.D.C. Area, Marol, Andheri (East), Mumbai-400093
- कार्यकारी निदेशक, ऊ.पू.क्षे.भा.प्रे.के., डोंगतेह, लोअर नोंग्रह, लापालंग, शिलोंग - 793006
Executive Director, NERLDC, Dongteih, Lower Nongrah, Lapalang, Shillong - 793006, Meghalaya
- कार्यकारी निदेशक, द.क्षे.भा.प्रे.के., 29, रेस कोर्स क्रॉस रोड, बंगलुरु - 560009
Executive Director, SRLDC, 29, Race Course Cross Road, Bangalore-560009

Sub: Daily PSP Report for the date 02.01.2025.

महोदय/Dear Sir,

आईईजीसी-2023 की धारा स.-38(1) के प्रावधान के अनुसार, दिनांक 2-जनवरी-2025 की अखिल भारतीय प्रणाली की दैनिक ग्रिड निष्पादन रिपोर्ट रांभांप्रेके की वेबसाइट पर उपलब्ध है।

As per article 38(1) of the Indian Electricity Grid Code, the daily report pertaining power supply position of All India Power System for the date 02.01.2025, is available at the NLDC website.

धन्यवाद,
Thanks

Report for previous day

Date of Reporting: 03-Jan-2025

A. Power Supply Position at All India and Regional level

	NR	WR	SR	ER	NER	TOTAL
Demand Met during Evening Peak hrs(MW) (at 19:00 hrs; from RLDCs)	60809	62928	43914	21862	2658	192171
Peak Shortage (MW)	0	0	0	96	0	96
Energy Met (MU)	1218	1420	1132	436	47	4253
Hydro Gen (MU)	100	30	85	17	13	245
Wind Gen (MU)	10	53	81	-	-	144
Solar Gen (MU)*	130.54	102.67	124.05	3.13	0.93	361
Energy Shortage (MU)	0.00	0.00	0.00	0.38	0.00	0.38
Maximum Demand Met During the Day (MW) (From NLDC SCADA)	64717	70295	57767	23179	2853	215044
Time Of Maximum Demand Met	10:24	10:14	09:50	17:57	17:25	09:48

B. Frequency Profile (%)

Region	FVI	< 49.7	49.7 - 49.8	49.8 - 49.9	< 49.9	49.9 - 50.05	> 50.05
All India	0.050	0.22	2.43	3.29	5.94	74.97	19.10

C. Power Supply Position in States

Region	States	Max.Demand Met during the day (MW)	Shortage during maximum Demand (MW)	Energy Met (MU)	Drawal Schedule (MU)	OD(+)/UD(-) (MU)	Max OD (MW)	Energy Shortage (MU)
NR	Punjab	8414	0	153.7	81.1	0.1	417	0.00
	Haryana	7881	0	146.0	103.0	-0.4	375	0.00
	Rajasthan	17067	0	312.1	118.3	-1.9	450	0.00
	Delhi	5155	0	86.7	85.3	-1.2	368	0.00
	UP	21067	0	360.1	101.0	-0.4	313	0.00
	Uttarakhand	2429	0	45.3	37.1	0.2	111	0.00
	HP	2029	0	37.0	30.9	-1.4	136	0.00
	J&K(UT) & Ladakh(UT)	3110	0	68.6	65.7	-1.3	978	0.00
	Chandigarh	296	0	5.0	5.1	-0.2	35	0.00
WR	Railways_NR ISTS	186	0	3.8	3.8	0.1	39	0.00
	Chhattisgarh	5048	0	104.6	55.6	0.5	317	0.00
	Gujarat	21620	0	405.7	192.3	-0.3	711	0.00
	MP	13852	0	259.7	158.0	-3.2	420	0.00
	Maharashtra	27520	0	576.7	192.9	1.0	860	0.00
	Goa	709	0	14.8	14.2	0.2	64	0.00
	DNHDDPDCL	1310	0	28.2	28.2	0.0	54	0.00
	AMNSIL	773	0	17.4	6.7	1.2	321	0.00
	BALCO	528	0	12.6	12.7	-0.1	5	0.00
SR	RIL JAMNAGAR	0	0	0.0	0.0	0.0	0	0.00
	Andhra Pradesh	10466	0	199.4	57.5	-0.6	382	0.00
	Telangana	14157	0	260.9	159.8	-2.2	706	0.00
	Karnataka	15236	0	264.5	82.5	-0.9	562	0.00
	Kerala	4225	0	82.8	68.4	0.9	442	0.00
	Tamil Nadu	15658	0	316.1	184.8	-0.5	627	0.00
ER	Puducherry	393	0	8.7	8.4	-0.3	17	0.00
	Bihar	5460	0	96.1	86.8	-2.8	440	0.38
	DVC	3407	0	68.9	-37.3	0.2	296	0.00
	Jharkhand	1982	0	37.1	27.4	-1.2	224	0.00
	Odisha	4717	0	90.3	22.6	-4.5	345	0.00
	West Bengal	7444	0	141.4	9.5	-1.7	179	0.00
	Sikkim	109	0	1.7	1.9	-0.2	25	0.00
NER	Railways_ER ISTS	10	0	0.1	0.1	0.0	10	0.00
	Arunachal Pradesh	172	0	2.7	3.0	-0.4	26	0.00
	Assam	1584	0	28.1	19.5	2.2	168	0.00
	Manipur	259	0	3.4	3.9	-0.5	26	0.00
	Meghalaya	359	0	5.5	5.6	-0.9	125	0.00
	Mizoram	120	0	1.6	1.5	-0.6	8	0.00
	Nagaland	160	0	2.1	2.4	-0.4	33	0.00
	Tripura	233	0	3.7	3.3	-0.4	80	0.00

D. Transnational Exchanges (MU) - Import(+ve)/Export(-ve)

	Bhutan	Nepal	Bangladesh	Godda -> Bangladesh
Actual (MU)	-4.9	-6.2	-20.6	-14.4
Day Peak (MW)	-421.0	-446.9	-1003.0	-768.0

E. Import/Export by Regions (in MU) - Import(+ve)/Export(-ve); OD(+)/UD(-)

	NR	WR	SR	ER	NER	TOTAL
Schedule(MU)	272.3	-277.4	164.5	-165.7	6.4	0.0
Actual(MU)	265.6	-275.9	157.4	-161.6	4.7	-9.9
O/D/U/D(MU)	-6.7	1.5	-7.1	4.1	-1.7	-9.9

F. Generation Outage(MW)

	NR	WR	SR	ER	NER	TOTAL	% Share
Central Sector	4721	7351	5308	4323	568	22271	43
State Sector	8103	11348	8149	2039	197	29835	57
Total	12824	18698	13457	6362	764	52106	100

G. Sourcewise generation (Gross) (MU)

	NR	WR	SR	ER	NER	All India	% Share
Coal	714	1544	604	668	9	3539	76
Lignite	22	18	51	0	0	91	2
Hydro	100	30	85	17	13	245	5
Nuclear	32	54	70	0	0	155	3
Gas, Naptha & Diesel	5	15	5	0	24	49	1
RES (Wind, Solar, Biomass & Others)	167	159	233	6	1	567	12
Total	1040	1820	1048	691	47	4646	100

Share of RES in total generation (%)	16.07	8.73	22.27	0.89	1.98	12.20
Share of Non-fossil fuel (Hydro,Nuclear and RES) in total generation(%)	28.73	13.37	37.01	3.32	28.98	20.81

H. All India Demand Diversity Factor

Based on Regional Max Demands	1.017
Based on State Max Demands	1.046

I. All India Peak Demand and shortage at Solar and Non-Solar Hour

	Max Demand Met(MW)	Time	Shortage(MW)
Solar hr	215044	9:48	0
Non-Solar hr	201014	18:40	0

Diversity factor = Sum of regional or state maximum demands / All India maximum demand

**Note: All generation MU figures are gross

***Godda (Jharkhand) -> Bangladesh power exchange is through the radial connection (isolated from Indian Grid)

Solar Hours -> 06:00 to 18:00hrs and rest are Non-Solar Hours

*Source: RLDCs for solar connected to ISTS; SLDCs for embedded solar. Limited visibility of embedded solar data.

Executive Director-NLDC

INTER-REGIONAL EXCHANGES								
Import=(+ve) /Export =(-ve) for NET (MU)								
Date of Reporting: 03-Jan-2025								
Sl No	Voltage Level	Line Details	No. of Circuit	Max Import (MW)	Max Export (MW)	Import (MU)	Export (MU)	NET (MU)
Import/Export of ER (With NR)								
1	HVDC	ALIPURDUAR-AGRA	2	0	0	0.0	0.0	0.0
2	HVDC	PUSAULI B/B	-	1	0	0.0	6.0	-6.0
3	765 kV	GAYA-VARANASI	2	154	810	0.0	11.7	-11.7
4	765 kV	SASARAM-FATEHPUR	1	25	508	0.0	7.0	-7.0
5	765 kV	GAYA-BALIA	1	0	791	0.0	13.2	-13.2
6	400 kV	PUSAULI-VARANASI	1	0	164	0.0	1.8	-1.8
7	400 kV	PUSAULI -ALLAHABAD	1	0	248	0.0	4.2	-4.2
8	400 kV	MUZAFFARPUR-GORAKHPUR	2	0	727	0.0	9.4	-9.4
9	400 kV	PATNA-BALIA	2	0	897	0.0	15.4	-15.4
10	400 kV	NAUBATPUR-BALIA	2	0	287	0.0	4.8	-4.8
11	400 kV	BIHARSHARIFF-BALIA	2	15	291	0.0	5.6	-5.6
12	400 kV	MOTIHARI-GORAKHPUR	2	0	537	0.0	8.0	-8.0
13	400 kV	BIHARSHARIFF-VARANASI	2	0	0	0.0	0.0	0.0
14	220 kV	SAHUPURI-KARAMNASA	1	0	95	0.0	2.6	-2.6
15	132 kV	NAGAR UNTARI-RIHAND	1	0	0	0.1	0.0	0.1
16	132 kV	GARWAH-RIHAND	1	0	0	0.5	0.0	0.5
17	132 kV	KARMANASA-SAHUPURI	1	0	0	0.0	0.0	0.0
18	132 kV	KARMANASA-CHANDAULI	1	0	0	0.0	0.0	0.0
ER-NR						0.6	89.6	-89.0
Import/Export of ER (With WR)								
1	765 kV	JHARSUGUDA-DHARAMJAIGARH	4	578	567	0.0	0.9	-0.9
2	765 kV	NEW RANCHI-DHARAMJAIGARH	2	635	561	2.2	0.0	2.2
3	765 kV	JHARSUGUDA-DURG	2	0	1013	0.0	14.9	-14.9
4	400 kV	JHARSUGUDA-RAIGARH	4	0	620	0.0	10.2	-10.2
5	400 kV	RANCHI-SIPAT	2	123	253	0.0	1.3	-1.3
6	220 kV	BUDHIPADAR-RAIGARH	1	0	128	0.0	2.0	-2.0
7	220 kV	BUDHIPADAR-KORBA	2	43	82	0.0	0.4	-0.4
ER-WR						2.2	29.6	-27.4
Import/Export of ER (With SR)								
1	HVDC	JEYPORE-GAZUWAKA B/B	2	0	215	0.0	5.1	-5.1
2	HVDC	TALCHER-KOLAR BIPOLE	2	0	2002	0.0	41.1	-41.1
3	765 kV	ANGUL-SRIKAKULAM	2	0	2891	0.0	53.7	-53.7
4	400 kV	TALCHER-I/C	2	633	723	0.2	0.0	0.2
5	220 kV	BALIMELA-UPPER-SILERRU	1	0	0	0.0	0.0	0.0
ER-SR						0.0	99.8	-99.8
Import/Export of ER (With NER)								
1	400 kV	BINAGURI-BONGAIGAON	2	353	22	3.1	0.0	3.1
2	400 kV	ALIPURDUAR-BONGAIGAON	2	588	0	6.1	0.0	6.1
3	220 kV	ALIPURDUAR-SALAKATI	2	111	0	1.5	0.0	1.5
ER-NER						10.6	0.0	10.6
Import/Export of NER (With NR)								
1	HVDC	BISWANATH CHARIALI-AGRA	2	659	0	15.6	0.0	15.6
NER-NR						15.6	0.0	15.6
Import/Export of WR (With NR)								
1	HVDC	CHAMPA-KURUKSHETRA	2	0	3019	0.0	47.8	-47.8
2	HVDC	VINDHYACHAL B/B	-	232	104	0.0	1.2	-1.2
3	HVDC	MUNDRA-MOHINDERGARH	2	0	1454	0.0	36.2	-36.2
4	765 kV	GWALIOR-AGRA	2	0	2351	0.0	33.7	-33.7
5	765 kV	GWALIOR-PHAGI	2	6	1916	0.0	27.3	-27.3
6	765 kV	JABALPUR-ORAI	2	0	1245	0.0	32.7	-32.7
7	765 kV	GWALIOR-ORAI	1	913	0	15.7	0.0	15.7
8	765 kV	SATNA-ORAI	1	0	1120	0.0	21.5	-21.5
9	765 kV	BANASKANTHA-CHITORGARH	2	1149	104	9.7	0.1	9.7
10	765 kV	VINDHYACHAL-VARANASI	2	0	2808	0.0	46.5	-46.5
11	400 kV	ZERDA-KANKROLI	1	253	11	2.4	0.0	2.4
12	400 kV	ZERDA -BHINMAL	1	175	8	1.7	0.0	1.7
13	400 kV	VINDHYACHAL -RIHAND	1	971	0	20.7	0.0	20.7
14	400 kV	RAPP-SHUJALPUR	2	384	381	1.7	2.5	-0.7
15	400 kV	NEEMUCH-Chittorgarh	2	344	383	1.5	2.1	-0.6
16	220 kV	BHANPURA-RANPUR	1	0	143	0.0	2.4	-2.4
17	220 kV	BHANPURA-MORAK	1	0	30	0.0	1.3	-1.3
18	220 kV	MEHGAON-AURAIYA	1	127	6	0.9	0.0	0.9
19	220 kV	MALANPUR-AURAIYA	1	96	28	0.5	0.1	0.4
20	132 kV	GWALIOR-SAWAI MADHOPUR	1	0	0	0.0	0.0	0.0
21	132 kV	RAJGHAT-LALITPUR	2	0	0	0.0	0.0	0.0
WR-NR						54.8	255.3	-200.5
Import/Export of WR (With SR)								
1	HVDC	BHADRAWATI B/B	-	0	1012	0.0	22.0	-22.0
2	HVDC	RAIGARH-PUGALUR	2	0	3003	0.0	41.4	-41.4
3	765 kV	SOLAPUR-RAICHUR	2	1465	1147	6.3	7.4	-1.1
4	765 kV	WARDHA-NIZAMABAD	2	118	2302	0.0	33.0	-33.0
5	765 kV	WARORA-WARANGAL(NEW)	2	0	2275	0.0	35.2	-35.2
6	400 kV	KOLHAPUR-KUDGI	2	1748	0	27.7	0.0	27.7
7	220 kV	KOLHAPUR-CHIKODI	2	0	0	0.0	0.0	0.0
8	220 kV	PONDA-AMBEWADI	1	0	0	0.0	0.0	0.0
9	220 kV	XELDEM-AMBEWADI	1	0	127	2.3	0.0	2.3
WR-SR						36.4	138.9	-102.5
INTERNATIONAL EXCHANGES								
State	Region	Line Name	Max (MW)	Min (MW)	Avg (MW)	Import(+ve)/Export(-ve) Energy Exchange (MU)		
BHUTAN	ER	400kV MANGDECHHU-ALIPURDUAR 1,2&3 i.e. ALIPURDUAR RECEIPT (from MANGDECHU HEP 4*180MW)	190	0	86	2.05		
	ER	400kV TALA-BINAGURI 1,2,4 (& 400kV MALBASE - BINAGURI) i.e. BINAGURI RECEIPT (from TALA HEP 6*170MW)	-260	135	-77	-1.84		
	ER	220kV CHUKHA-BIRPARA 1&2 (& 220kV MALBASE - BIRPARA) i.e. BIRPARA RECEIPT (from CHUKHA HEP 4*84MW)	-250	-115	-195	-4.69		
	NER	132kV GELEPHU-SALAKATI	-29	-11	-18	-0.43		
	NER	132kV MOTANGA-RANGIA	-13	14	-1	-0.02		
NEPAL	NR	NEPAL IMPORT (FROM UP)	-62	0	-48	-1.16		
	NR	132kV MAHENDRANAGAR-TANAKPUR(NHPC)	-62	0	-35	-0.84		
	ER	NEPAL IMPORT (FROM BIHAR)	-187	-84	-85	-2.04		
	ER	400kV DHALKEBAR-MUZAFFARPUR 1&2	-260	16	-91	-2.19		
BANGLADESH	ER	BHERAMARA B/B HVDC (B'DESH)	-941	-652	-808	-19.39		
	ER (Isolated from Indian Grid)	400kV GODDA_TPS-RAHANPUR (B'DESH) D/C	-768	-401	-601	-14.42		
	NER	132kV COMILLA-SURAJMANI NAGAR 1&2	-62	0	-50	-1.20		

CROSS BORDER EXCHANGE SCHEDULE

Date of Reporting: 03-Jan-2025

Export From India (in MU)

Country	GNA (ISGS/PPA)	T-GNA							TOTAL
		BILATERAL TOTAL	COLLECTIVE						
			IDAM			RTM			
			IEX	PXIL	HPX	IEX	PXIL	HPX	
Bhutan	0.00	0.00	6.42	0.00	0.00	0.00	0.00	0.00	6.42
Nepal	1.93	0.00	2.15	0.00	0.00	0.23	0.00	0.00	4.31
Bangladesh	20.17	0.00	0.00	0.00	0.00	0.00	0.00	0.00	20.17
Myanmar	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total Export	22.10	0.00	8.57	0.00	0.00	0.23	0.00	0.00	30.90

Import by India(in MU)

Country	GNA (ISGA/PPA)	T-GNA							TOTAL
		BILATERAL TOTAL	COLLECTIVE						
			IDAM			RTM			
			IEX	PXIL	HPX	IEX	PXIL	HPX	
Bhutan	1.09	0.00	0.00	0.00	0.00	0.00	0.00	0.00	1.09
Nepal	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Bangladesh	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Myanmar	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total Import	1.09	0.00	0.00	0.00	0.00	0.00	0.00	0.00	1.09

Net from India(in MU)

-ve : Export / +ve : Import

Country	GNA (ISGS/PPA)	T-GNA							TOTAL
		BILATERAL TOTAL	COLLECTIVE						
			IDAM			RTM			
			IEX	PXIL	HPX	IEX	PXIL	HPX	
Bhutan	1.09	0.00	-6.42	0.00	0.00	0.00	0.00	0.00	-5.33
Nepal	-1.93	0.00	-2.15	0.00	0.00	-0.23	0.00	0.00	-4.31
Bangladesh	-20.17	0.00	0.00	0.00	0.00	0.00	0.00	0.00	-20.17
Myanmar	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total Net	-21.01	0.00	-8.57	0.00	0.00	-0.23	0.00	0.00	-29.81

Date of Reporting: 03-Jan-2025												
15 Min (INSTANTANEOUS) ALL INDIA GRID FREQUENCY, GENERATION & DEMAND MET (SCADA DATA)												
TIME	FREQUENCY (Hz)	DEMAND MET (MW)	NUCLEAR (MW)	WIND (MW)	SOLAR (MW)	HYDRO** (MW)	GAS (MW)	THERMAL (MW)	OTHERS* (MW)	NET DEMAND MET (MW)	TOTAL GENERATION (MW)	NET TRANSNATIONAL EXCHANGE (MW) (+ve) Import, (-ve) Export
		(A)	(B)	(C)	(D)	(E)	(F)	(G)	(H)	(I=A-(C+D))	(J=B+C+D+E+F+G+H)	(K)
0:00	50.03	142463	5828	9097	147	6306	1748	119985	3144	133219	146255	-1381
0:15	50.03	141511	5841	8906	143	6030	1734	119667	3153	132462	145474	-1307
0:30	50.03	140464	5845	8783	140	6285	1751	118640	3158	131541	144602	-1278
0:45	49.98	139448	5838	8604	140	6629	1754	117376	3147	130704	143488	-1312
1:00	50.03	138785	5846	8481	136	6422	1738	116776	3133	130168	142532	-1194
1:15	50.03	137793	5849	8410	133	6394	1747	115910	3140	129250	141583	-1186
1:30	49.98	136847	5864	8268	132	6176	1736	115256	3176	128447	140608	-1185
1:45	49.98	135898	5851	8151	134	5731	1736	114862	3173	127613	139638	-1184
2:00	49.98	135442	5851	8093	136	5693	1929	114526	3147	127213	139375	-1152
2:15	49.98	134753	5861	8050	135	5400	1744	114261	3108	126568	138559	-1191
2:30	50.03	134023	5873	8052	136	5321	1747	113656	3118	125835	137903	-1190
2:45	49.98	133824	5861	8016	138	5339	1736	113423	3137	125670	137650	-1100
3:00	50.03	133476	5867	7960	136	5322	1729	112978	3125	125380	137117	-1078
3:15	49.98	133835	5872	7878	138	5598	1752	113180	3117	125819	137535	-1096
3:30	49.98	134221	5876	7624	135	5661	1744	113886	3118	126462	138044	-1079
3:45	50.03	133696	5875	7342	108	5693	1734	113736	3086	126246	137574	-1092
4:00	50.03	133871	5865	7187	107	5715	1738	114414	3077	126577	138103	-1124
4:15	50.03	136320	5858	6998	105	6612	1751	116028	3093	129217	140445	-1107
4:30	50.03	138027	5860	6718	108	6669	1731	117760	3082	131201	141928	-1059
4:45	49.98	139672	5872	6499	106	7090	1726	119519	3087	133067	143899	-966
5:00	50.03	141350	5876	6235	108	7487	1732	121000	3096	135007	145534	-986
5:15	49.98	144829	5875	5983	108	7687	1765	124459	3152	138738	149029	-990
5:30	50.03	148677	5883	5721	108	7749	1757	128497	3112	142848	152827	-1002
5:45	49.98	152979	5869	5547	109	7866	1751	132764	3122	147323	157028	-1089
6:00	50.03	156916	5882	5329	111	8402	1739	136101	3182	151476	160746	-1147
6:15	49.98	161335	5866	5248	799	9185	1880	139720	3137	155288	165835	-1221
6:30	50.03	167978	5863	5102	954	10719	2158	144604	3173	161922	172573	-1265
6:45	50.03	174614	5877	4939	1020	13678	2450	147952	3173	168655	179089	-1122
7:00	49.98	180386	5882	4888	1385	15669	2536	151151	3187	174113	184698	-1165
7:15	49.93	185981	5882	4912	2143	17337	2795	153973	3251	178926	190293	-1231
7:30	49.98	190649	5887	4863	3355	17976	2929	156401	3211	182431	194622	-1288
7:45	50.03	195163	5879	4848	5293	18949	3030	157866	3234	185022	199099	-1286
8:00	50.08	196972	5900	4756	8432	18434	2985	156892	3303	183784	200702	-1168
8:15	50.08	200350	5891	4663	11592	17199	2962	157942	3310	184095	203559	-1265
8:30	50.03	202993	5896	4495	15440	16196	2964	158072	3248	183058	206311	-1008
8:45	50.08	205442	5889	4380	19775	14352	2904	157907	3309	181287	208516	-868
9:00	50.13	207003	5887	4267	24606	12503	2908	156898	3366	178130	210435	-906
9:15	50.08	212024	5870	4184	28622	12304	2721	158087	3433	179218	215221	-971
9:30	50.03	213258	5871	4269	32571	11365	2132	157002	3369	176418	216579	-1099
9:45	50.03	214655	5861	4373	36013	10190	1736	156332	3411	174269	217916	-1034
10:00	50.08	214457	5874	4538	39693	9480	1731	152936	3391	170226	217643	-1097
10:15	50.03	214558	5875	4621	42763	7962	1715	151214	3432	167174	217582	-1200
10:30	49.98	214346	5866	4681	45426	6985	1715	149515	3370	164239	217558	-1280
10:45	49.98	213346	5883	4607	47010	6588	1726	147056	3417	161729	216287	-1344
11:00	49.98	212854	5873	4649	49777	6907	1709	141604	3402	158428	213921	-1321
11:15	49.98	211137	5862	4608	51188	6501	1718	140375	3371	155341	213623	-1330
11:30	50.03	210073	5868	4427	52885	6288	1699	138679	3377	152761	213223	-1542
11:45	49.88	208776	5870	4279	52485	6410	1718	138364	3405	152012	212531	-1828
12:00	50.03	207375	5839	4165	52096	6550	1684	137682	3368	151114	211384	-1853
12:15	49.72	204344	5875	4055	50231	6276	1687	136471	3411	150058	208006	-1808
12:30	49.98	204164	5876	3995	49400	6855	1693	136591	3382	150769	207792	-1789
12:45	49.98	203093	5875	3880	50161	7079	1712	134579	3373	149052	206659	-1840
13:00	50.08	200433	5871	3823	51521	6894	1712	131367	3343	145089	204531	-1815
13:15	49.98	196226	5895	3674	51548	6312	1681	127331	3393	141004	199834	-1815
13:30	50.03	194625	5890	3647	51923	6275	1711	125833	3381	139055	198660	-1825
13:45	50.08	195063	5869	3561	52253	6076	1704	126202	3413	139249	199078	-1804
14:00	49.98	193599	5876	3632	49959	6137	1730	126812	3346	140008	197492	-1843
14:15	49.93	192747	5881	3673	47417	6024	1705	128615	3360	141657	196675	-1833
14:30	49.93	194148	5859	3728	46601	6151	1708	130659	3355	143819	198061	-1823
14:45	49.88	194308	5844	3721	43097	6499	1713	133863	3327	147490	198064	-1809
15:00	49.93	193992	5948	3806	41644	6487	1710	135037	3333	148542	197965	-1841
15:15	50.08	194164	5942	3770	39819	6595	1712	136949	3296	150575	198083	-1751
15:30	49.98	193743	5959	3861	34461	6881	1852	141039	3370	155421	197423	-1621
15:45	49.93	193206	5975	3848	30809	7483	1707	143606	3266	158549	196694	-1576
16:00	50.03	193377	5959	3859	27525	8116	1730	146323	3245	161993	196757	-1543
16:15	49.98	192265	5980	3992	24582	7695	1707	148649	3274	163691	195879	-1502
16:30	50.03	193380	5974	4089	20130	8850	1725	152998	3287	169161	197053	-1195
16:45	50.03	193996	6002	4155	16478	10039	1637	155896	3280	173363	197487	-1211
17:00	50.08	194691	6004	4129	12369	12669	1729	158285	3273	178193	198458	-1067
17:15	50.03	193661	6011	4095	8477	14838	1652	158589	3182	181089	196844	-876
17:30	50.03	195389	6015	4002	5186	18436	1658	160092	3154	186201	198543	-724
17:45	49.93	196922	6056	4007	2612	21038	1671	161497	3235	190303	200116	-751
18:00	50.03	199169	6047	4111	1272	22814	1675	163209	3269	193786	202397	-754
18:15	49.73	199859	6058	4242	506	23118	1651	164202	3252	195111	203029	-722
18:30	49.99	200868	6066	4436	285	23711	1665	164526	3285	196147	203974	-705
18:45	49.99	200838	6073	4735	293	23675	1667	164058	3364	195810	203865	-663
19:00	50.04	198731	6050	5054	205	21436	1881	164134	3373	193472	202133	-682
19:15	50.04	196452	6070	5304	205	19330	1676	163499	3352	190943	199436	-684
19:30	50.04	193915	5989	5501	193	17327	1674	163005	3336	188221	197025	-675
19:45	50.04	192145	5960	5532	188	15755	1661	162545	3389	186425	195030	-672
20:00	50.09	188150	5961	5654	187	13840	1674	160335	3359	182309	191010	-698
20:15	50.09	184681	5956	5813	200	12825	1673	157830	3352	178668	187649	-860
20:30	50.04	181505	5936	5920	205	12009	1674	155521	3305	175380	184570	-1038
20:45	49.99	178262	5994	6128	108	11093	1676	153018	3283	172026	181300	-1067
21:00	50.04	175500	5968	6271	106	10469	1807	150910	3282	169123	178813	-1095
21:15	49.99	173227	5962	6393	107	10189	1676	148687	3320	166727	176334	-1193
21:30	49.99	169632	5980	6367	103	9997	1784	145803	3325	163162	173359	-1436
21:45	49.99	166817	5984	6467	105	9324	1779	143756	3322	160245	170737	-1560
22:00	50.09	163417	5985	6555	104	8760	1692	140935	3292	156758	167323	-1624
22:15	49.99	162349	5979	6576	108	9042	1661	139375	3283	155665	166024	-1559
22:30	49.99	160379	5923	6610	73	8965	1757					