



National Load Despatch Centre
राष्ट्रीय भार प्रेषण केंद्र
GRID CONTROLLER OF INDIA LIMITED
ग्रिड कंट्रोलर ऑफ इंडिया लिमिटेड

(Government of India Enterprise/ भारत सरकार का उद्यम)
B-9, QUTUB INSTITUTIONAL AREA, KATWARIA SARAI, NEW DELHI -110016
बी-9, कुतुब इंस्टीट्यूशनल एरिया, कटवारिया सराये, न्यू दिल्ली-110016

Ref: POSOCO/NLDC/SO/Daily PSP Report

दिनांक: 13th April 2024

To,

- कार्यकारी निदेशक, पू.क्षे.भा.प्रे.के., 14, गोल्फ क्लब रोड, कोलकाता - 700033
Executive Director, ERLDC, 14 Golf Club Road, Tollygunge, Kolkata, 700033
- कार्यकारी निदेशक, ऊ.क्षे.भा.प्रे.के., 18/ए, शाहीद जीत सिंह सनसनवाल मार्ग, नई दिल्ली - 110016
Executive Director, NRLDC, 18-A, Shaheed Jeet Singh Marg, Katwaria Sarai, New Delhi - 110016
- कार्यकारी निदेशक, प.क्षे.भा.प्रे.के., एफ3, एम आई डी सी क्षेत्र, अंधेरी, मुंबई - 400093
Executive Director, WRLDC, F-3, M.I.D.C. Area, Marol, Andheri (East), Mumbai-400093
- कार्यकारी निदेशक, ऊ.पू.क्षे.भा.प्रे.के., डोंगतेह, लोअर नोंग्रह, लापालंग, शिलोंग - 793006
Executive Director, NERLDC, Dongteih, Lower Nongrah, Lapalang, Shillong - 793006, Meghalaya
- कार्यकारी निदेशक, द.क्षे.भा.प्रे.के., 29, रेस कोर्स क्रॉस रोड, बंगलुरु - 560009
Executive Director, SRLDC, 29, Race Course Cross Road, Bangalore-560009

Sub: Daily PSP Report for the date 12.04.2024.

महोदय/Dear Sir,

आईंईंजींसीं-2010 की धारा स.-5.5.1 के प्रावधान के अनुसार, दिनांक 12-अप्रैल-2024 की अखिल भारतीय प्रणाली की दैनिक ग्रिड निष्पादन रिपोर्ट रांभांप्रेंकें की वेबसाइट पर उपलब्ध है।

As per article 5.5.1 of the Indian Electricity Grid Code, the daily report pertaining power supply position of All India Power System for the date 12th April 2024, is available at the NLDC website.

धन्यवाद,

Report for previous day

Date of Reporting: 13-Apr-2024

A. Power Supply Position at All India and Regional level

	NR	WR	SR	ER	NER	TOTAL
Demand Met during Evening Peak hrs(MW) (at 20:00 hrs; from RLDCs)	57612	59856	50664	25626	2938	196696
Peak Shortage (MW)	0	0	0	0	0	0
Energy Met (MU)	1235	1483	1335	540	58	4651
Hydro Gen (MU)	133	27	40	16	10	226
Wind Gen (MU)	25	66	67	-	-	157
Solar Gen (MU)*	140.71	82.77	118.70	2.62	1.12	346
Energy Shortage (MU)	0.16	0.00	0.00	0.03	0.00	0.19
Maximum Demand Met During the Day (MW) (From NLDC SCADA)	58086	66769	63388	26033	3121	206122
Time Of Maximum Demand Met	19:43	10:43	11:55	19:31	18:20	10:45

B. Frequency Profile (%)

Region	FVI	< 49.7	49.7 - 49.8	49.8 - 49.9	< 49.9	49.9 - 50.05	> 50.05
All India	0.030	0.00	0.36	3.67	4.03	81.47	14.50

C. Power Supply Position in States

Region	States	Max.Demand Met during the day (MW)	Shortage during maximum Demand (MW)	Energy Met (MU)	Drawal Schedule (MU)	OD(+)/UD(-) (MU)	Max OD (MW)	Energy Shortage (MU)
NR	Punjab	8194	0	160.1	45.5	0.2	272	0.00
	Haryana	8318	0	158.1	93.0	-0.4	247	0.00
	Rajasthan	12606	0	264.4	51.2	1.0	393	0.00
	Delhi	4683	0	96.8	87.6	0.8	152	0.00
	UP	21002	0	417.4	141.3	-0.8	813	0.00
	Uttarakhand	2092	0	43.7	26.7	1.0	340	0.00
	HP	1790	0	33.8	21.3	0.3	146	0.00
	J&K(UT) & Ladakh(UT)	2535	0	52.2	40.9	0.2	283	0.16
	Chandigarh	229	0	4.4	4.3	0.1	22	0.00
WR	Railways_NR ISTS	202	0	4.1	3.7	0.4	34	0.00
	Chhattisgarh	5380	0	119.3	59.6	-0.3	340	0.00
	Gujarat	22231	0	467.2	194.2	-2.4	619	0.00
	MP	11217	0	238.7	123.8	-6.7	554	0.00
	Maharashtra	25766	0	583.4	201.2	-7.2	676	0.00
	Goa	768	0	16.4	11.8	4.3	45	0.00
	DNHDDPDCL	1250	0	28.9	29.1	-0.2	36	0.00
	AMNSIL	789	0	16.9	4.5	0.3	262	0.00
	BALCO	520	0	12.4	12.5	-0.1	9	0.00
SR	Andhra Pradesh	12401	0	239.1	69.8	-1.3	361	0.00
	Telangana	11720	0	241.4	128.7	1.1	721	0.00
	Karnataka	16189	0	316.8	151.6	-1.7	695	0.00
	Kerala	4769	0	104.7	87.3	1.7	384	0.00
	Tamil Nadu	19414	0	422.1	279.7	-5.3	804	0.00
	Puducherry	488	0	10.7	10.5	-0.3	56	0.00
	Railways_SR ISTS	11	0	0.1	0.1	0.0	2	0.00
ER	Bihar	6271	0	118.8	108.6	-0.6	377	0.03
	DVC	3285	0	71.7	-41.4	0.0	241	0.00
	Jharkhand	1926	0	38.9	28.8	-2.6	226	0.00
	Odisha	5528	0	116.2	39.4	-2.2	290	0.00
	West Bengal	9305	0	192.7	57.0	-1.8	401	0.00
	Sikkim	100	0	1.6	1.7	-0.1	13	0.00
	Railways_ER ISTS	11	0	0.1	0.1	0.0	2	0.00
NER	Arunachal Pradesh	171	0	2.4	2.6	-0.2	87	0.00
	Assam	1870	0	35.9	29.8	0.3	126	0.00
	Manipur	207	0	3.1	3.1	0.0	90	0.00
	Meghalaya	345	0	5.8	4.9	0.0	63	0.00
	Mizoram	124	0	1.9	1.8	-0.2	17	0.00
	Nagaland	151	0	2.4	2.4	0.0	20	0.00
	Tripura	305	0	6.1	4.8	0.7	52	0.00

D. Transnational Exchanges (MU) - Import(+ve)/Export(-ve)

	Bhutan	Nepal	Bangladesh	Godda -> Bangladesh
Actual (MU)	-6.3	-10.0	-20.0	-20.6
Day Peak (MW)	-548.6	-778.0	-1043.0	-994.0

E. Import/Export by Regions (in MU) - Import(+ve)/Export(-ve); OD(+)/UD(-)

	NR	WR	SR	ER	NER	TOTAL
Schedule(MU)	99.6	-328.3	306.0	-89.5	12.2	0.0
Actual(MU)	111.7	-327.4	311.4	-114.7	12.3	-6.7
O/D/U/D(MU)	12.1	0.9	5.4	-25.2	0.1	-6.7

F. Generation Outage(MW)

	NR	WR	SR	ER	NER	TOTAL	% Share
Central Sector	4348	6095	4168	3636	201	18447	53
State Sector	4736	6442	3110	2162	170	16619	47
Total	9084	12536	7278	5797	371	35066	100

G. Sourcewise generation (Gross) (MU)

	NR	WR	SR	ER	NER	All India	% Share
Coal	826	1652	724	723	16	3941	78
Lignite	27	18	66	0	0	111	2
Hydro	133	27	40	16	10	226	4
Nuclear	29	53	51	0	0	132	3
Gas, Naptha & Diesel	18	44	6	0	24	92	2
RES (Wind, Solar, Biomass & Others)	182	152	219	4	1	558	11
Total	1213	1946	1106	743	51	5060	100

Share of RES in total generation (%)	15.01	7.79	19.81	0.57	2.23	11.03
Share of Non-fossil fuel (Hydro,Nuclear and RES) in total generation(%)	28.31	11.91	28.02	2.70	21.19	18.10

H. All India Demand Diversity Factor

Based on Regional Max Demands	1.054
Based on State Max Demands	1.087

I. All India Peak Demand and shortage at Solar and Non-Solar Hour

	Max Demand Met(MW)	Time	Shortage(MW)
Solar hr	206122	10:45	0
Non-Solar hr	200622	19:27	0

Diversity factor = Sum of regional or state maximum demands / All India maximum demand

**Note: All generation MU figures are gross

***Godda (Jharkhand) -> Bangladesh power exchange is through the radial connection (isolated from Indian Grid)

Solar Hours -> 07:00 to 17:00hrs and rest are Non-Solar Hours

*Source: RLDCs for solar connected to ISTS; SLDCs for embedded solar. Limited visibility of embedded solar data.

Executive Director-NLDC

INTER-REGIONAL EXCHANGES

Import=(+ve) /Export =(-ve) for NET (MU)

Date of Reporting: 13-Apr-2024

Sl No	Voltage Level	Line Details	No. of Circuit	Max Import (MW)	Max Export (MW)	Import (MU)	Export (MU)	NET (MU)
Import/Export of ER (With NR)								
1	HVDC	ALIPURDUAR-AGRA	2	0	0	0.0	0.0	0.0
2	HVDC	PUSAULI B/B	-	0	48	0.0	1.3	-1.3
3	765 kV	GAYA-VARANASI	2	103	688	0.0	10.5	-10.5
4	765 kV	SASARAM-FATEHPUR	1	27	447	0.0	7.5	-7.5
5	765 kV	GAYA-BALIA	1	0	593	0.0	10.1	-10.1
6	400 kV	PUSAULI-VARANASI	1	0	74	0.0	1.0	-1.0
7	400 kV	PUSAULI -ALLAHABAD	1	26	29	0.1	0.0	0.1
8	400 kV	MUZAFFARPUR-GORAKHPUR	2	574	448	0.0	0.5	-0.5
9	400 kV	PATNA-BALIA	2	152	682	0.0	10.2	-10.2
10	400 kV	NAUBATPUR-BALIA	2	86	214	0.0	2.8	-2.8
11	400 kV	BIHARSHARIFF-BALIA	2	424	121	2.6	0.0	2.6
12	400 kV	MOTIHARI-GORAKHPUR	2	285	353	0.0	4.0	-4.0
13	400 kV	BIHARSHARIFF-VARANASI	2	121	144	0.0	0.9	-0.9
14	220 kV	SAHUPURI-KARAMNASA	1	24	70	0.0	0.9	-0.9
15	132 kV	NAGAR UNTARI-RIHAND	1	0	0	0.0	0.0	0.0
16	132 kV	GARWAH-RIHAND	1	30	0	0.7	0.0	0.7
17	132 kV	KARMANASA-SAHUPURI	1	0	0	0.0	0.0	0.0
18	132 kV	KARMANASA-CHANDAULI	1	0	0	0.0	0.0	0.0
ER-NR						3.4	49.6	-46.2
Import/Export of ER (With WR)								
1	765 kV	JHARSUGUDA-DHARAMJAIGARH	4	1402	0	20.7	0.0	20.7
2	765 kV	NEW RANCHI-DHARAMJAIGARH	2	726	816	0.0	3.1	-3.1
3	765 kV	JHARSUGUDA-DURG	2	0	964	0.0	17.0	-17.0
4	400 kV	JHARSUGUDA-RAIGARH	4	11	306	0.0	4.1	-4.1
5	400 kV	RANCHI-SIPAT	2	161	215	0.0	1.4	-1.4
6	220 kV	BUDHIPADAR-RAIGARH	1	56	95	0.0	0.5	-0.5
7	220 kV	BUDHIPADAR-KORBA	2	0	1	0.0	0.0	0.0
ER-WR						20.7	26.0	-5.4
Import/Export of ER (With SR)								
1	HVDC	JEYPORE-GAZUWAKA B/B	2	0	630	0.0	14.5	-14.5
2	HVDC	TALCHER-KOLAR BIPOLE	2	0	1493	0.0	36.1	-36.1
3	765 kV	ANGUL-SRIKAKULAM	2	0	2841	0.0	57.4	-57.4
4	400 kV	TALCHER-I/C	2	426	150	3.4	0.0	3.4
5	220 kV	BALIMELA-UPPER-SILERRU	1	0	0	0.0	0.0	0.0
ER-SR						0.0	108.0	-108.0
Import/Export of ER (With NER)								
1	400 kV	BINAGURI-BONGAIGAON	2	236	172	1.7	1.0	0.8
2	400 kV	ALIPURDUAR-BONGAIGAON	2	463	134	3.5	0.0	3.5
3	220 kV	ALIPURDUAR-SALAKATI	2	33	19	0.1	0.0	0.1
ER-NER						5.4	1.0	4.4
Import/Export of NER (With NR)								
1	HVDC	BISWANATH CHARIALI-AGRA	2	659	0	16.4	0.0	16.4
NER-NR						16.4	0.0	16.4
Import/Export of WR (With NR)								
1	HVDC	CHAMPA-KURUKSHETRA	2	0	2518	0.0	58.4	-58.4
2	HVDC	VINDHYACHAL B/B	-	514	0	9.4	0.0	9.4
3	HVDC	MUNDRA-MOHINDERGARH	2	0	786	0.0	15.7	-15.7
4	765 kV	GWALIOR-AGRA	2	94	1671	0.0	16.9	-16.8
5	765 kV	GWALIOR-PHAGI	2	900	1064	3.5	13.3	-9.7
6	765 kV	JABALPUR-ORAI	2	336	624	0.0	9.7	-9.7
7	765 kV	GWALIOR-ORAI	1	563	0	9.3	0.0	9.3
8	765 kV	SATNA-ORAI	1	0	1028	0.0	20.1	-20.1
9	765 kV	BANASKANTHA-CHITORGARH	2	2217	216	22.7	0.2	22.5
10	765 kV	VINDHYACHAL-VARANASI	2	0	2428	0.0	35.6	-35.6
11	400 kV	ZERDA-KANKROLI	1	454	0	5.6	0.0	5.6
12	400 kV	ZERDA -BHINMAL	1	453	0	5.6	0.0	5.6
13	400 kV	VINDHYACHAL -RIHAND	1	965	0	21.9	0.0	21.9
14	400 kV	RAPP-SHUJALPUR	2	678	248	4.8	0.8	4.0
15	400 kV	NEEMUCH-Chittorgarh	2	693	206	4.7	0.8	3.9
16	220 kV	BHANPURA-RANPUR	1	0	127	0.0	2.3	-2.3
17	220 kV	BHANPURA-MORAK	1	0	30	0.0	1.8	-1.8
18	220 kV	MEHGAON-AURAIYA	1	65	0	1.1	0.0	1.1
19	220 kV	MALANPUR-AURAIYA	1	49	0	0.6	0.0	0.6
20	132 kV	GWALIOR-SAWAI MADHOPUR	1	0	0	0.0	0.0	0.0
21	132 kV	RAJGHAT-LALITPUR	2	0	0	0.0	0.0	0.0
WR-NR						89.2	175.5	-86.3
Import/Export of WR (With SR)								
1	HVDC	BHADRAWATI B/B	-	0	1012	0.0	16.4	-16.4
2	HVDC	RAIGARH-PUGALUR	2	0	6024	0.0	109.9	-109.9
3	765 kV	SOLAPUR-RAICHUR	2	0	2002	0.0	28.1	-28.1
4	765 kV	WARDHA-NIZAMABAD	2	0	2617	0.0	50.9	-50.9
5	765 kV	WARORA-WARANGAL(NEW)	2	0	3004	0.0	59.6	-59.6
6	400 kV	KOLHAPUR-KUDGI	2	1135	0	15.0	0.0	15.0
7	220 kV	KOLHAPUR-CHIKODI	2	0	0	0.0	0.0	0.0
8	220 kV	PONDA-AMBEWADI	1	0	72	1.6	0.0	1.6
9	220 kV	XELDEM-AMBEWADI	1	0	132	2.6	0.0	2.6
WR-SR						19.2	264.9	-245.7

INTERNATIONAL EXCHANGES					Import(+ve)/Export(-ve)	
State	Region	Line Name	Max (MW)	Min (MW)	Avg (MW)	Energy Exchange (MU)
BHUTAN	ER	400kV MANGDECHHU-ALIPURDUAR 1,2&3 i.e. ALIPURDUAR RECEIPT (from MANGDECHU HEP 4*180MW)	-168	145	-36	-0.87
	ER	400kV TALA-BINAGURI 1,2,4 (& 400kV MALBASE - BINAGURI) i.e. BINAGURI RECEIPT (from TALA HEP 6*170MW)	-298	103	-91	-2.18
	ER	220kV CHUKHA-BIRPARA 1&2 (& 220kV MALBASE - BIRPARA) i.e. BIRPARA RECEIPT (from CHUKHA HEP 4*84MW)	-255	-77	-152	-3.64
	NER	132kV GELEPHU-SALAKATI	-13	0	-5	-0.11
	NER	132kV MOTANGA-RANGIA	38	12	19	0.46
NEPAL	NR	NEPAL IMPORT (FROM UP)	0	0	0	1.16
	NR	132kV MAHENDRANAGAR-TANAKPUR(NHPC)	-72	0	-46	-1.10
	ER	NEPAL IMPORT (FROM BIHAR)	-284	-4	-148	-3.54
	ER	400kV DHALKEBAR-MUZAFFARPUR 1&2	-494	-30	-272	-6.53
BANGLADESH	ER	BHERAMARA B/B HVDC (B'DESH)	-943	-649	-750	-17.99
	ER (Isolated from Indian Grid)	400kV GODDA_TPS-RAHANPUR (B'DESH) D/C	-994	-799	-857	-20.56
	NER	132kV COMILLA-SURAJMANI NAGAR 1&2	-100	0	-83	-2.00

Export From India (in MU)

Country	GNA (ISGS/PPA)	T-GNA							TOTAL
		BILATERAL TOTAL	COLLECTIVE						
			IDAM			RTM			
			IEX	PXIL	HPX	IEX	PXIL	HPX	
Bhutan	0.00	0.00	6.41	0.00	0.00	0.83	0.00	0.00	7.24
Nepal	0.23	0.00	6.36	0.00	0.00	0.00	0.00	0.00	6.59
Bangladesh	17.90	0.00	0.00	0.00	0.00	0.00	0.00	0.00	17.90
Myanmar	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total Export	18.13	0.00	12.77	0.00	0.00	0.83	0.00	0.00	31.73

Import by India(in MU)

Country	GNA (ISGA/PPA)	T-GNA							TOTAL
		BILATERAL TOTAL	COLLECTIVE						
			IDAM			RTM			
			IEX	PXIL	HPX	IEX	PXIL	HPX	
Bhutan	0.36	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.36
Nepal	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Bangladesh	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Myanmar	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total Import	0.36	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.36

Net from India(in MU)

-ve : Export / +ve : Import

Country	GNA (ISGS/PPA)	T-GNA							TOTAL
		BILATERAL TOTAL	COLLECTIVE						
			IDAM			RTM			
			IEX	PXIL	HPX	IEX	PXIL	HPX	
Bhutan	0.36	0.00	-6.41	0.00	0.00	-0.83	0.00	0.00	-6.88
Nepal	-0.23	0.00	-6.36	0.00	0.00	0.00	0.00	0.00	-6.59
Bangladesh	-17.90	0.00	0.00	0.00	0.00	0.00	0.00	0.00	-17.90
Myanmar	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total Net	-17.77	0.00	-12.77	0.00	0.00	-0.83	0.00	0.00	-31.37