



National Load Despatch Centre
राष्ट्रीय भार प्रेषण केंद्र
GRID CONTROLLER OF INDIA LIMITED
ग्रिड कंट्रोलर ऑफ इंडिया लिमिटेड

(Government of India Enterprise/ भारत सरकार का उद्यम)
B-9, QUTUB INSTITUTIONAL AREA, KATWARIA SARAI, NEW DELHI -110016
बी-9, कुतुब इन्स्टीट्यूशनल एरिया, कटवारिया सराये, न्यू दिल्ली-110016

Ref: GRID-INDIA/NLDC/SO/Daily PSP Report

दिनांक: 05.12.2024

To,

- कार्यकारी निदेशक, पू.क्षे.भा.प्रे.के., 14, गोल्फ क्लब रोड, कोलकाता - 700033
Executive Director, ERLDC, 14 Golf Club Road, Tollygunge, Kolkata, 700033
- कार्यकारी निदेशक, ऊ.क्षे.भा.प्रे.के., 18/ए, शाहीद जीत सिंह सनसनवाल मार्ग, नई दिल्ली - 110016
Executive Director, NRLDC, 18-A, Shaheed Jeet Singh Marg, Katwaria Sarai, New Delhi - 110016
- कार्यकारी निदेशक, प.क्षे.भा.प्रे.के., एफ3, एम आई डी सी क्षेत्र, अंधेरी, मुंबई -400093
Executive Director, WRLDC, F-3, M.I.D.C. Area, Marol, Andheri (East), Mumbai-400093
- कार्यकारी निदेशक, ऊ.पू.क्षे.भा.प्रे.के., डोंगतेह, लोअर नोंग्रह, लापालंग, शिलोंग - 793006
Executive Director, NERLDC, Dongteih, Lower Nongrah, Lapalang, Shillong - 793006, Meghalaya
- कार्यकारी निदेशक, द.क्षे.भा.प्रे.के., 29, रेस कोर्स क्रॉस रोड, बंगलुरु -560009
Executive Director, SRLDC, 29, Race Course Cross Road, Bangalore-560009

Sub: Daily PSP Report for the date 04.12.2024.

महोदय/Dear Sir,

आईईजीसी-2023 की धारा स.-38(1) के प्रावधान के अनुसार, दिनांक 4-दिसंबर-2024 की अखिल भारतीय प्रणाली की दैनिक ग्रिड निष्पादन रिपोर्ट रांभांप्रेके की वेबसाइट पर उपलब्ध है।

As per article 38(1) of the Indian Electricity Grid Code, the daily report pertaining power supply position of All India Power System for the date 04.12.2024, is available at the NLDC website.

धन्यवाद,
Thanks

Report for previous day

Date of Reporting: 05-Dec-2024

A. Power Supply Position at All India and Regional level

	NR	WR	SR	ER	NER	TOTAL
Demand Met during Evening Peak hrs(MW) (at 19:00 hrs; from RLDCs)	52315	62452	43342	21172	2617	181898
Peak Shortage (MW)	0	0	0	0	0	0
Energy Met (MU)	1171	1510	1009	431	47	4169
Hydro Gen (MU)	115	37	78	21	14	265
Wind Gen (MU)	23	150	51	-	-	223
Solar Gen (MU)*	143.93	81.77	94.56	2.35	0.99	324
Energy Shortage (MU)	0.28	0.00	0.00	0.00	0.00	0.28
Maximum Demand Met During the Day (MW) (From NLDC SCADA)	62078	74488	47910	21373	2845	204287
Time Of Maximum Demand Met	10:22	10:21	07:44	17:45	17:17	10:21

B. Frequency Profile (%)

Region	FVI	< 49.7	49.7 - 49.8	49.8 - 49.9	< 49.9	49.9 - 50.05	> 50.05
All India	0.028	0.00	0.20	2.96	3.16	81.50	15.35

C. Power Supply Position in States

Region	States	Max.Demand Met during the day (MW)	Shortage during maximum Demand (MW)	Energy Met (MU)	Drawal Schedule (MU)	OD(+)/UD(-) (MU)	Max OD (MW)	Energy Shortage (MU)
NR	Punjab	9446	0	159.9	69.2	0.4	362	0.00
	Haryana	8250	0	153.1	117.3	-0.5	837	0.00
	Rajasthan	17094	0	323.6	120.9	1.9	685	0.00
	Delhi	3978	0	72.8	72.5	-1.2	243	0.00
	UP	17525	0	314.6	91.8	-1.2	385	0.00
	Uttarakhand	2208	0	41.7	30.7	0.3	82	0.00
	HP	2093	0	37.1	29.5	-0.7	117	0.00
	J&K(UT) & Ladakh(UT)	2811	0	60.2	55.0	-0.3	159	0.28
	Chandigarh	210	0	3.7	3.8	-0.1	35	0.00
WR	Railways_NR ISTS	190	0	4.1	3.9	0.2	23	0.00
	Chhattisgarh	4572	0	92.5	35.8	-0.7	175	0.00
	Gujarat	21452	0	413.8	183.1	-2.8	671	0.00
	MP	18111	0	334.0	206.0	-3.3	676	0.00
	Maharashtra	27949	0	591.4	227.0	-6.4	682	0.00
	Goa	731	0	15.6	14.2	0.8	51	0.00
	DNHDDPDCL	1355	0	31.1	30.9	0.2	77	0.00
	AMNSIL	884	0	19.1	8.6	0.6	333	0.00
	BALCO	530	0	12.7	12.7	0.0	10	0.00
SR	RIL JAMNAGAR	1	0	0.0	0.0	0.0	0	0.00
	Andhra Pradesh	8591	0	183.0	45.8	-0.1	477	0.00
	Telangana	11093	0	213.4	114.4	-0.6	724	0.00
	Karnataka	10934	0	208.1	41.2	-2.4	446	0.00
	Kerala	4209	0	82.5	66.3	1.8	376	0.00
	Tamil Nadu	15608	0	314.6	168.6	-1.6	647	0.00
ER	Puducherry	366	0	7.6	7.5	-0.4	43	0.00
	Bihar	4598	0	84.2	78.4	-0.9	175	0.00
	DVC	3138	0	66.4	-41.3	-0.7	295	0.00
	Jharkhand	2011	0	37.8	26.2	0.4	160	0.00
	Odisha	5255	0	101.3	29.0	-0.9	409	0.00
	West Bengal	7060	0	139.7	15.0	-1.8	148	0.00
	Sikkim	114	0	1.8	1.8	0.0	32	0.00
	Railways_ER ISTS	22	0	0.2	0.2	0.0	6	0.00
NER	Arunachal Pradesh	162	0	2.8	2.6	0.1	40	0.00
	Assam	1592	0	26.6	19.4	0.2	132	0.00
	Manipur	232	0	2.9	3.3	-0.4	36	0.00
	Meghalaya	377	0	6.6	5.5	-0.1	180	0.00
	Mizoram	143	0	2.0	1.7	-0.1	15	0.00
	Nagaland	185	0	2.7	2.5	0.0	11	0.00
	Tripura	229	0	3.9	4.6	0.0	34	0.00

D. Transnational Exchanges (MU) - Import(+ve)/Export(-ve)

	Bhutan	Nepal	Bangladesh	Godda -> Bangladesh
Actual (MU)	-3.6	-1.1	-11.2	-17.0
Day Peak (MW)	-366.6	-218.4	-479.0	-763.0

E. Import/Export by Regions (in MU) - Import(+ve)/Export(-ve); OD(+)/UD(-)

	NR	WR	SR	ER	NER	TOTAL
Schedule(MU)	247.4	-195.2	131.4	-188.9	5.3	0.0
Actual(MU)	242.7	-193.8	119.4	-179.7	3.8	-7.6
O/D/U/D(MU)	-4.7	1.4	-12.0	9.2	-1.5	-7.6

F. Generation Outage(MW)

	NR	WR	SR	ER	NER	TOTAL	% Share
Central Sector	5679	9064	8488	3978	705	27914	47
State Sector	10613	12729	5754	2321	332	31749	53
Total	16292	21793	14242	6299	1036	59663	100

G. Sourcewise generation (Gross) (MU)

	NR	WR	SR	ER	NER	All India	% Share
Coal	636	1452	592	655	9	3344	74
Lignite	24	13	23	0	0	60	1
Hydro	115	37	78	21	14	265	6
Nuclear	31	64	76	0	0	172	4
Gas, Naptha & Diesel	2	11	6	0	24	43	1
RES (Wind, Solar, Biomass & Others)	193	235	180	5	1	613	14
Total	1001	1813	953	681	48	4497	100

Share of RES in total generation (%)	19.27	12.94	18.84	0.78	2.11	13.64
Share of Non-fossil fuel (Hydro,Nuclear and RES) in total generation(%)	33.90	18.53	34.97	3.89	31.18	23.35

H. All India Demand Diversity Factor

Based on Regional Max Demands	1.021
Based on State Max Demands	1.053

I. All India Peak Demand and shortage at Solar and Non-Solar Hour

	Max Demand Met(MW)	Time	Shortage(MW)
Solar hr	204287	10:21	50
Non-Solar hr	194437	18:19	161

Diversity factor = Sum of regional or state maximum demands / All India maximum demand

**Note: All generation MU figures are gross

***Godda (Jharkhand) -> Bangladesh power exchange is through the radial connection (isolated from Indian Grid)

Solar Hours -> 06:00 to 18:00hrs and rest are Non-Solar Hours

*Source: RLDCs for solar connected to ISTS; SLDCs for embedded solar. Limited visibility of embedded solar data.

Executive Director-NLDC

INTER-REGIONAL EXCHANGES								
Import=(+ve) /Export =(-ve) for NET (MU)								
Date of Reporting: 05-Dec-2024								
Sl No	Voltage Level	Line Details	No. of Circuit	Max Import (MW)	Max Export (MW)	Import (MU)	Export (MU)	NET (MU)
Import/Export of ER (With NR)								
1	HVDC	ALIPURDUAR-AGRA	2	0	0	0.0	0.0	0.0
2	HVDC	PUSAULI B/B	-	0	249	0.0	6.1	-6.1
3	765 kV	GAYA-VARANASI	2	2	1377	0.0	18.1	-18.1
4	765 kV	SASARAM-FATEHPUR	1	0	609	0.0	7.9	-7.9
5	765 kV	GAYA-BALIA	1	0	809	0.0	13.1	-13.1
6	400 kV	PUSAULI-VARANASI	1	0	196	0.0	3.2	-3.2
7	400 kV	PUSAULI -ALLAHABAD	1	0	141	0.0	2.7	-2.7
8	400 kV	MUZAFFARPUR-GORAKHPUR	2	70	660	0.0	8.8	-8.8
9	400 kV	PATNA-BALIA	2	0	1261	0.0	20.7	-20.7
10	400 kV	NAUBATPUR-BALIA	2	0	862	0.0	6.5	-6.5
11	400 kV	BIHARSHARIEFF-BALIA	2	59	293	0.0	5.0	-5.0
12	400 kV	MOTIHARI-GORAKHPUR	2	0	672	0.0	10.3	-10.3
13	400 kV	BIHARSHARIEFF-VARANASI	2	9	456	0.0	0.0	0.0
14	220 kV	SAHUPURI-KARAMNASA	1	0	111	0.0	0.3	-0.3
15	132 kV	NAGAR UNTARI-RIHAND	1	0	0	0.2	0.0	0.2
16	132 kV	GARWAH-RIHAND	1	30	0	0.5	0.0	0.5
17	132 kV	KARMANASA-SAHUPURI	1	0	0	0.0	0.0	0.0
18	132 kV	KARMANASA-CHANDAULI	1	0	0	0.0	0.0	0.0
ER-NR						0.7	102.7	-102.0
Import/Export of ER (With WR)								
1	765 kV	JHARSUGUDA-DHARAMJAIGARH	4	292	759	0.0	3.4	-3.4
2	765 kV	NEW RANCHI-DHARAMJAIGARH	2	284	970	0.0	7.5	-7.5
3	765 kV	JHARSUGUDA-DURG	2	0	615	0.0	10.8	-10.8
4	400 kV	JHARSUGUDA-RAIGARH	4	0	677	0.0	9.9	-9.9
5	400 kV	RANCHI-SIPAT	2	33	383	0.0	3.8	-3.8
6	220 kV	BUDHIPADAR-RAIGARH	1	0	111	0.0	1.5	-1.5
7	220 kV	BUDHIPADAR-KORBA	2	40	135	0.0	0.8	-0.8
ER-WR						0.0	37.7	-37.7
Import/Export of ER (With SR)								
1	HVDC	JEYPORE-GAZUWAKA B/B	2	0	169	0.0	4.0	-4.0
2	HVDC	TALCHER-KOLAR BIPOLE	2	0	1337	0.0	26.1	-26.1
3	765 kV	ANGUL-SRIKAKULAM	2	0	2668	0.0	53.4	-53.4
4	400 kV	TALCHER-I/C	2	1618	60	12.0	0.0	12.0
5	220 kV	BALIMELA-UPPER-SILERRU	1	0	0	0.0	0.0	0.0
ER-SR						0.0	83.5	-83.5
Import/Export of ER (With NER)								
1	400 kV	BINAGURI-BONGAIGAON	2	237	128	1.8	0.4	1.4
2	400 kV	ALIPURDUAR-BONGAIGAON	2	457	162	3.8	0.0	3.8
3	220 kV	ALIPURDUAR-SALAKATI	2	100	23	1.0	0.0	1.0
ER-NER						6.6	0.4	6.2
Import/Export of NER (With NR)								
1	HVDC	BISWANATH CHARIALI-AGRA	2	658	0	10.7	0.0	10.7
NER-NR						10.7	0.0	10.7
Import/Export of WR (With NR)								
1	HVDC	CHAMPA-KURUKSHETRA	2	0	2549	0.0	44.8	-44.8
2	HVDC	VINDHYACHAL B/B	-	0	307	0.0	7.2	-7.2
3	HVDC	MUNDRA-MOHINDERGARH	2	0	690	0.0	17.0	-17.0
4	765 kV	GWALIOR-AGRA	2	0	2103	0.0	24.7	-24.7
5	765 kV	GWALIOR-PHAGI	2	546	1939	0.7	22.4	-21.8
6	765 kV	JABALPUR-ORAI	2	0	976	0.0	23.2	-23.2
7	765 kV	GWALIOR-ORAI	1	1078	0	15.5	0.0	15.5
8	765 kV	SATNA-ORAI	1	0	1025	0.0	19.3	-19.3
9	765 kV	BANASKANTHA-CHITORGARH	2	869	1009	4.9	8.7	-3.8
10	765 kV	VINDHYACHAL-VARANASI	2	0	1981	0.0	33.9	-33.9
11	400 kV	ZERDA-KANKROLI	1	209	144	1.3	0.9	0.4
12	400 kV	ZERDA -BHINMAL	1	145	100	0.9	0.6	0.3
13	400 kV	VINDHYACHAL -RIHAND	1	970	0	21.7	0.0	21.7
14	400 kV	RAPP-SHUJALPUR	2	663	271	3.6	1.3	2.3
15	400 kV	NEEMUCH-Chittorgarh	2	705	198	4.6	0.7	3.9
16	220 kV	BHANPURA-RANPUR	1	0	197	0.0	3.3	-3.3
17	220 kV	BHANPURA-MORAK	1	0	30	0.0	1.6	-1.6
18	220 kV	MEHGAON-AURAIYA	1	105	0	1.2	0.0	1.2
19	220 kV	MALANPUR-AURAIYA	1	73	3	0.7	0.0	0.7
20	132 kV	GWALIOR-SAWAI MADHOPUR	1	0	0	0.0	0.0	0.0
21	132 kV	RAJGHAT-LALITPUR	2	0	0	0.0	0.0	0.0
WR-NR						55.0	209.8	-154.8
Import/Export of WR (With SR)								
1	HVDC	BHADRAWATI B/B	-	0	410	0.0	9.6	-9.6
2	HVDC	RAIGARH-PUGALUR	2	0	1104	0.0	21.1	-21.1
3	765 kV	SOLAPUR-RAICHUR	2	1051	1134	4.6	8.8	-4.2
4	765 kV	WARDHA-NIZAMABAD	2	0	2098	0.0	33.7	-33.7
5	765 kV	WARORA-WARANGAL(NEW)	2	0	2081	0.0	35.9	-35.9
6	400 kV	KOLHAPUR-KUDGI	2	1661	0	25.6	0.0	25.6
7	220 kV	KOLHAPUR-CHIKODI	2	0	0	0.0	0.0	0.0
8	220 kV	PONDA-AMBEWADI	1	0	0	0.0	0.0	0.0
9	220 kV	XELDEM-AMBEWADI	1	0	132	2.4	0.0	2.4
WR-SR						32.5	109.2	-76.6
INTERNATIONAL EXCHANGES								
State	Region		Line Name	Max (MW)	Min (MW)	Avg (MW)	Import(+ve)/Export(-ve) Energy Exchange (MU)	
BHUTAN	ER		400kV MANGDECHHU-ALIPURDUAR 1,2&3 i.e. ALIPURDUAR RECEIPT (from MANGDECHU HEP 4*180MW)	163	-68	37	0.89	
	ER		400kV TALA-BINAGURI 1,2,4 (& 400kV MALBASE - BINAGURI) i.e. BINAGURI RECEIPT (from TALA HEP 6*170MW)	230	-126	69	1.64	
	ER		220kV CHUKHA-BIRPARA 1&2 (& 220kV MALBASE - BIRPARA) i.e. BIRPARA RECEIPT (from CHUKHA HEP 4*84MW)	-259	-197	-235	-5.65	
	NER		132kV GELEPHU-SALAKATI	-22	-1	-12	-0.28	
	NER		132kV MOTANGA-RANGIA	-37	0	-9	-0.21	
NEPAL	NR		NEPAL IMPORT (FROM UP)	-44	0	0	0.00	
	NR		132kV MAHENDRANAGAR-TANAKPUR(NHPC)	-44	0	-20	-0.48	
	ER		NEPAL IMPORT (FROM BIHAR)	0	0	0	0.00	
	ER		400kV DHALKEBAR-MUZAFFARPUR 1&2	-223	135	-26	-0.63	
BANGLADESH	ER		BHERAMARA B/B HVDC (B'DESH)	-431	-423	-426	-10.22	
	ER (Isolated from Indian Grid)		400kV GODDA_TPS-RAHANPUR (B'DESH) D/C	-763	-604	-706	-16.95	
	NER		132kV COMILLA-SURAJMANI NAGAR 1&2	-48	0	-41	-0.98	

CROSS BORDER EXCHANGE SCHEDULE

Date of Reporting: 05-Dec-2024

Export From India (in MU)

Country	GNA (ISGS/PPA)	T-GNA							TOTAL
		BILATERAL TOTAL	COLLECTIVE						
			IDAM			RTM			
			IEX	PXIL	HPX	IEX	PXIL	HPX	
Bhutan	0.00	0.00	4.65	0.00	0.00	0.20	0.00	0.00	4.85
Nepal	0.29	0.00	0.78	0.00	0.00	0.47	0.00	0.00	1.54
Bangladesh	10.63	0.00	0.00	0.00	0.00	0.00	0.00	0.00	10.63
Myanmar	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total Export	10.92	0.00	5.43	0.00	0.00	0.67	0.00	0.00	17.02

Import by India(in MU)

Country	GNA (ISGA/PPA)	T-GNA							TOTAL
		BILATERAL TOTAL	COLLECTIVE						
			IDAM			RTM			
			IEX	PXIL	HPX	IEX	PXIL	HPX	
Bhutan	0.73	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.73
Nepal	0.00	0.00	0.50	0.00	0.00	0.00	0.00	0.00	0.50
Bangladesh	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Myanmar	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total Import	0.73	0.00	0.50	0.00	0.00	0.00	0.00	0.00	1.23

Net from India(in MU)

-ve : Export / +ve : Import

Country	GNA (ISGS/PPA)	T-GNA							TOTAL
		BILATERAL TOTAL	COLLECTIVE						
			IDAM			RTM			
			IEX	PXIL	HPX	IEX	PXIL	HPX	
Bhutan	0.73	0.00	-4.65	0.00	0.00	-0.20	0.00	0.00	-4.12
Nepal	-0.29	0.00	-0.28	0.00	0.00	-0.47	0.00	0.00	-1.04
Bangladesh	-10.63	0.00	0.00	0.00	0.00	0.00	0.00	0.00	-10.63
Myanmar	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total Net	-10.19	0.00	-4.93	0.00	0.00	-0.67	0.00	0.00	-15.79

15 Min (INSTANTANEOUS) ALL INDIA GRID FREQUENCY, GENERATION & DEMAND MET (SCADA DATA)												
TIME	FREQUENCY (Hz)	DEMAND MET (MW)	NUCLEAR (MW)	WIND (MW)	SOLAR (MW)	HYDRO** (MW)	GAS (MW)	THERMAL (MW)	OTHERS* (MW)	NET DEMAND MET (MW)	TOTAL GENERATION (MW)	NET TRANSNATIONAL EXCHANGE (MW) (+ve) Import, (-ve) Export
		(A)	(B)	(C)	(D)	(E)	(F)	(G)	(H)	(I=A-(C+D))	(J=B+C+D+E+F+G+H)	(K)
0:00	50.05	145088	6755	14853	152	7024	1803	115323	2911	130083	148821	-588
0:15	49.95	143559	6759	14859	149	6712	1761	114914	2848	128551	148002	-693
0:30	50.00	143135	6761	14961	151	6857	1622	113834	2826	128023	147012	-669
0:45	50.05	142141	6763	14963	153	6470	1625	113109	2845	127025	145928	-708
1:00	49.95	141439	6759	15029	151	6332	1622	112386	2836	126259	145115	-709
1:15	49.95	140829	6773	14817	150	6160	1628	112098	2848	125862	144474	-649
1:30	49.95	139863	6781	14727	145	6396	1790	111083	2863	124991	143785	-652
1:45	49.90	139328	6751	14590	140	6387	1765	110728	2766	124598	143127	-633
2:00	50.00	138404	6766	14429	138	6544	1776	109925	2779	123837	142357	-653
2:15	49.95	138545	6765	14266	134	6201	1785	110384	2866	124145	142401	-658
2:30	49.95	138131	6760	13989	134	5835	1630	110556	2809	124008	141713	-682
2:45	50.00	137876	6762	13711	140	5802	1781	110662	2848	124025	141706	-682
3:00	50.05	137929	6781	13532	143	6081	1627	110429	2955	124254	141548	-697
3:15	50.00	137578	6777	13436	145	6248	1795	110117	2894	123997	141412	-699
3:30	50.00	137502	6773	13402	147	6457	1624	110155	2722	123953	141280	-704
3:45	50.05	137719	6785	13428	150	6414	1826	110259	2759	124141	141621	-684
4:00	50.10	137700	6777	13495	150	6491	1612	110162	2790	124055	141477	-670
4:15	49.99	139190	6776	13355	145	6635	1828	111556	2743	125690	143038	-717
4:30	50.05	140764	6786	13195	145	6731	1814	113157	2757	127424	144585	-760
4:45	49.99	143296	6769	13127	144	6853	1618	115837	2772	130025	147120	-814
5:00	49.95	145382	6772	13063	144	6903	1612	117974	2774	132175	149242	-845
5:15	49.90	149308	6784	12985	147	7122	1804	121481	2929	136176	153252	-774
5:30	50.05	153587	6776	12875	165	7630	1784	125220	2820	140547	157270	-559
5:45	50.05	157379	6773	12716	165	8329	1577	128589	2808	144498	160957	-538
6:00	50.05	161183	6767	12573	157	10493	1570	130793	2833	148453	165186	-531
6:15	50.04	166387	6772	12315	247	11946	1560	134490	2795	153825	170125	-572
6:30	50.04	173048	6784	12117	252	15167	1554	138107	2811	160679	176792	-560
6:45	49.94	178499	6777	11968	421	17110	1714	141522	2842	166110	182354	-576
7:00	49.89	183377	6779	11837	875	18301	1624	144952	2836	170665	187204	-634
7:15	49.94	187705	6774	11732	1594	19436	1632	147262	2824	174379	191254	-570
7:30	49.99	190893	6770	11667	2904	20064	1623	148484	2889	176322	194401	-550
7:45	50.04	193610	6772	11532	4947	20328	1636	148706	2905	177131	196826	-544
8:00	50.10	193757	6781	11358	7939	18806	1846	147286	2937	174460	196953	-541
8:15	50.04	195462	6786	11319	11005	17083	1812	147714	2931	173138	198650	-487
8:30	50.05	197195	6772	10976	14843	14514	1652	148604	2956	171376	200317	-539
8:45	50.10	197785	6781	10420	18587	12928	1827	147418	2957	168778	200918	-507
9:00	50.04	199445	6785	9824	22685	11901	1836	146349	2950	166936	202330	-519
9:15	49.99	202446	6781	9121	26871	11622	1649	146788	2931	166454	205763	-533
9:30	49.94	204024	6754	8221	29792	11260	1646	146168	3007	166011	206848	-519
9:45	49.99	203616	6769	7467	32823	9422	1644	145220	3005	163326	206350	-563
10:00	49.99	203439	6737	7007	35648	8609	1541	143563	2981	160784	206086	-610
10:15	49.99	203857	6737	6575	37873	8355	1614	142282	2997	159409	206433	-543
10:30	50.04	203601	6756	6459	40667	7051	1658	140943	2983	156475	206517	-618
10:45	50.04	202824	6630	6342	42523	6726	1648	139611	2954	153959	206434	-874
11:00	50.04	201714	6627	6253	44118	6103	1534	137545	2987	151343	205167	-940
11:15	50.09	200255	6637	6239	45783	5872	1542	134765	2925	148233	203763	-1052
11:30	50.09	198546	6641	6111	46681	5808	1547	132405	2971	145754	202164	-1041
11:45	49.99	197183	6631	6083	47641	5933	1549	129914	2911	143459	200662	-1007
12:00	50.10	195450	6631	6078	48759	5857	1551	127159	2889	140613	198924	-998
12:15	50.05	193961	6766	6108	48479	5877	1662	125575	2918	139374	197385	-1037
12:30	50.05	193233	6752	6277	48246	5918	1533	124950	2940	138710	196616	-1040
12:45	50.00	191726	6680	6591	48152	6436	1537	123464	2955	136983	195815	-1067
13:00	49.99	189331	6678	6605	47632	6406	1644	121170	2999	135094	193134	-1055
13:15	49.99	185945	6681	6651	46709	6023	1542	119378	2958	132585	189942	-1057
13:30	49.99	185595	6687	6628	46392	6319	1624	119256	2946	132575	189852	-1067
13:45	49.94	186086	6676	6511	45321	6928	1539	120152	2949	134254	190076	-1039
14:00	50.04	186383	6675	6502	44135	7306	1524	121235	2826	135746	190203	-1078
14:15	49.94	185832	6679	6476	42428	7439	1628	122167	2913	136928	189730	-1090
14:30	50.00	186642	6690	6454	40598	7766	1644	124352	2895	139590	190399	-1056
14:45	49.94	187136	6680	6473	38401	7631	1527	127437	2858	142262	191007	-1105
15:00	50.04	187543	6669	6552	36287	7713	1530	129890	2862	144704	191503	-1104
15:15	49.99	187338	6677	6652	33845	7948	1525	131815	2900	146841	191362	-1046
15:30	49.99	187889	6737	6781	30955	7983	1527	134713	2960	150153	191656	-1089
15:45	49.99	186836	6739	6976	27769	7854	1526	136575	2881	152091	190320	-969
16:00	50.04	186433	6732	7169	23611	8730	1527	139152	2823	155653	189744	-963
16:15	49.94	184915	6668	7289	19609	8926	1523	141342	2820	158017	188177	-725
16:30	49.99	186777	6664	7309	15423	11661	1510	144155	2855	164045	189577	-629
16:45	49.94	187731	6654	7322	11039	14420	1524	147175	2826	169370	190960	-685
17:00	49.99	188319	6657	7100	7209	17073	1520	148714	2790	174010	191063	-579
17:15	49.99	188165	6658	6902	4046	19284	1510	149365	2825	177217	190590	-532
17:30	50.04	188834	6665	6840	1827	21092	1545	150585	2889	180167	191443	-502
17:45	49.89	189965	6659	6860	657	24147	1560	151408	2812	182448	194103	-518
18:00	49.94	192628	6668	7091	263	25271	1572	151970	2932	185274	195767	-485
18:15	49.84	194080	6670	7475	185	26295	1606	152248	2868	186420	197347	-459
18:30	49.99	193883	6675	7755	76	26429	1593	151892	2779	186052	197199	-448
18:45	50.04	192055	6679	8183	79	25387	1649	150764	2771	183793	195512	-478
19:00	50.04	189062	6677	8555	88	24334	1672	148272	2789	180419	192387	-482
19:15	50.04	186163	6681	8890	93	22280	1811	147008	2790	177180	189553	-507
19:30	49.99	183575	6681	9227	92	20276	1672	146197	2783	174256	186928	-482
19:45	50.04	180814	6686	9515	91	18626	1774	144557	2824	171208	184073	-479
20:00	50.04	176338	6712	9792	87	16766	1772	141718	2793	166459	179640	-468
20:15	49.99	173254	6697	10185	103	14551	1767	140203	2820	162966	176326	-450
20:30	49.99	170793	6702	10363	87	13636	1780	138620	2828	160343	174016	-426
20:45	49.99	169013	6710	10474	51	13289	1670	136909	2813	158488	171916	-442
21:00	50.04	166137	6696	10480	44	12184	1668	135255	2798	155613	169125	-428
21:15	49.94	163753	6712	10580	44	11267	1668	133638	2822	153129	166731	-416
21:30	49.99	162358	6711	10672	46	10900	1677	132342	2868	151640	165216	-426
21:45	50.04	160393	6716	10779	67	10102	1670	131211	2810	149547	163355	-417
22:00	50.09	158112	6727	10578	65	9994	1672	129233	2799	147469	161068	-422
22:15	49.98	157646	6736	10606	65	9683	1814	128795	2845	146975	160544	-421
22:30	49.98	156400	6740	10634	63	9434	1674	128115	2794	145703	159454	-442
22:45	4											