



National Load Despatch Centre
राष्ट्रीय भार प्रेषण केंद्र
GRID CONTROLLER OF INDIA LIMITED
ग्रिड कंट्रोलर ऑफ इंडिया लिमिटेड

(Government of India Enterprise/ भारत सरकार का उद्यम)
B-9, QUTUB INSTITUTIONAL AREA, KATWARIA SARAI, NEW DELHI -110016
बी-9, कुतुब इन्स्टीट्यूशनल एरिया, कटवारिया सराये, न्यू दिल्ली-110016

Ref: GRID-INDIA/NLDC/SO/Daily PSP Report

दिनांक: 24.10.2025

To,

- कार्यकारी निदेशक, पू.क्षे.भा.प्रे.के., 14, गोल्फ क्लब रोड, कोलकाता - 700033
Executive Director, ERLDC, 14 Golf Club Road, Tollygunge, Kolkata, 700033
- कार्यकारी निदेशक, ऊ.क्षे.भा.प्रे.के., 18/ए, शाहीद जीत सिंह सनसनवाल मार्ग, नई दिल्ली - 110016
Executive Director, NRLDC, 18-A, Shaheed Jeet Singh Marg, Katwaria Sarai, New Delhi - 110016
- कार्यकारी निदेशक, प.क्षे.भा.प्रे.के., एफ3, एम आई डी सी क्षेत्र, अंधेरी, मुंबई - 400093
Executive Director, WRLDC, F-3, M.I.D.C. Area, Marol, Andheri (East), Mumbai-400093
- कार्यकारी निदेशक, ऊ.पू.क्षे.भा.प्रे.के., डोंगतेह, लोअर नोंग्रह, लापालंग, शिलोंग - 793006
Executive Director, NERLDC, Dongteih, Lower Nongrah, Lapalang, Shillong - 793006, Meghalaya
- कार्यकारी निदेशक, द.क्षे.भा.प्रे.के., 29, रेस कोर्स क्रॉस रोड, बंगलुरु - 560009
Executive Director, SRLDC, 29, Race Course Cross Road, Bangalore-560009

Sub: Daily PSP Report for the date 23.10.2025.

महोदय/Sir,

आईईजीसी-2023 की धारा स.-38(1) के प्रावधान के अनुसार, दिनांक 23-अक्टूबर-2025 की अखिल भारतीय प्रणाली की दैनिक ग्रिड निष्पादन रिपोर्ट रांभांप्रेके की वेबसाइट पर उपलब्ध है।

As per article 38(1) of the Indian Electricity Grid Code, the daily report pertaining power supply position of All India Power System for the date 23.10.2025, is available at the NLDC website.

धन्यवाद,
Thanks

Report for previous day

Date of Reporting: 24-Oct-2025

A. Power Supply Position at All India and Regional level

	NR	WR	SR	ER	NER	TOTAL
Demand Met during Evening Peak hrs(MW) (at 19:00 hrs; from RLDCs)	53652	55011	43800	27294	3400	183157
Peak Shortage (MW)	0	0	0	0	0	0
Energy Met (MU)	1177	1265	980	581	66	4068
Hydro Gen (MU)	190	36	142	66	27	461
Wind Gen (MU)	7	135	67	-	-	210
Solar Gen (MU)*	170.95	135.30	94.17	3.37	1.11	405
Energy Shortage (MU)	0.00	0.00	0.00	0.00	0.00	0.00
Maximum Demand Met During the Day (MW) (From NLDC SCADA)	55970	56904	46858	27394	3653	190183
Time Of Maximum Demand Met	18:31	18:32	18:33	18:01	17:44	18:32

B. Frequency Profile (%)

Region	FV1	< 49.7	49.7 - 49.8	49.8 - 49.9	< 49.9	49.9 - 50.05	> 50.05
All India	0.033	0.00	0.38	6.52	6.90	82.03	11.08

C. Power Supply Position in States

Region	States	Max.Demand Met during the day (MW)	Shortage during maximum Demand (MW)	Energy Met (MU)	Drawal Schedule (MU)	OD(+)/UD(-) (MU)	Max OD (MW)	Energy Shortage (MU)
NR	Punjab	7836	0	151.9	75.0	0.8	637	0.00
	Haryana	7443	0	154.4	131.3	-1.4	532	0.00
	Rajasthan	12625	0	253.3	76.2	-2.5	676	0.00
	Delhi	4004	0	82.3	80.7	-0.7	138	0.00
	UP	19577	0	412.4	148.4	-1.1	200	0.00
	Uttarakhand	1848	0	34.1	20.1	0.4	150	0.00
	HP	1576	0	29.7	10.7	-0.8	82	0.00
	J&K(UT) & Ladakh(UT)	2703	0	50.5	39.5	0.6	504	0.00
	Chandigarh	220	0	3.9	3.9	0.1	20	0.00
	Railways_NR ISTS	207	0	4.5	4.0	0.4	38	0.00
WR	Chhattisgarh	4808	0	100.2	57.1	-4.3	441	0.00
	Gujarat	15628	0	330.4	155.4	-2.7	950	0.00
	MP	13019	0	257.0	150.9	0.0	554	0.00
	Maharashtra	22682	0	496.9	171.0	-2.8	786	0.00
	Goa	709	0	15.4	12.6	2.3	55	0.00
	DNHDDPDCL	1142	0	25.1	24.7	0.4	0	0.00
	AMNSIL	954	0	20.6	13.3	0.4	272	0.00
	BALCO	538	0	12.8	12.8	0.0	7	0.00
	RIL JAMNAGAR	256	0	6.1	6.2	-0.1	0	0.00
	Andhra Pradesh	8630	0	181.6	60.2	-0.1	761	0.00
SR	Telangana	11261	0	214.8	105.9	0.0	621	0.00
	Karnataka	10170	0	199.5	52.4	-2.3	368	0.00
	Kerala	4019	0	81.4	47.4	-1.1	488	0.00
	Tamil Nadu	15478	0	293.2	152.7	-3.0	760	0.00
	Puducherry	420	0	9.0	8.7	-0.3	38	0.00
	Bihar	7015	0	140.2	133.4	-1.3	442	0.00
ER	DVC	3112	0	67.9	-27.0	0.4	531	0.00
	Jharkhand	2225	0	43.1	33.2	-0.2	277	0.00
	Odisha	6262	0	121.8	50.5	-1.8	382	0.00
	West Bengal	9627	0	206.5	71.1	-3.3	186	0.00
	Sikkim	56	0	0.9	1.0	-0.1	7	0.00
	Railways_ER ISTS	9	0	0.2	0.2	0.0	5	0.00
NER	Arunachal Pradesh	201	0	3.1	3.1	-0.2	18	0.00
	Assam	2282	0	42.3	34.0	0.1	144	0.00
	Manipur	214	0	3.1	3.1	0.0	91	0.00
	Meghalaya	334	0	5.9	4.2	-0.1	276	0.00
	Mizoram	137	0	2.2	1.2	0.0	53	0.00
	Nagaland	186	0	3.0	2.7	-0.1	12	0.00
	Tripura	346	0	6.6	6.8	0.2	36	0.00

D. Transnational Exchanges (MU) - Import(+ve)/Export(-ve)

	Bhutan	Nepal	Bangladesh	Godda -> Bangladesh
Actual (MU)	17.6	25.7	-25.7	-31.4
Day Peak (MW)	806.5	1135.8	-1082.2	-1473.0

E. Import/Export by Regions (in MU) - Import(+ve)/Export(-ve); OD(+)/UD(-)

	NR	WR	SR	ER	NER	TOTAL
Schedule(MU)	172.9	-227.0	128.2	-87.2	13.1	0.0
Actual(MU)	175.5	-216.3	119.6	-103.8	11.3	-13.7
O/D/U/D(MU)	2.6	10.7	-8.6	-16.6	-1.9	-13.7

F. Generation Outage(MW)

	NR	WR	SR	ER	NER	TOTAL	% Share
Central Sector	7137	12556	10158	1905	265	32020	42
State Sector	10214	19309	12493	1807	179	44002	58
Total	17351	31865	22651	3712	444	76022	100

G. Sourcewise generation (Gross) (MU)

	NR	WR	SR	ER	NER	All India	% Share
Coal	643	1181	511	672	11	3019	69
Lignite	27	13	24	0	0	64	1
Hydro	190	36	142	66	27	461	11
Nuclear	31	65	64	0	0	160	4
Gas, Naptha & Diesel	3	7	5	0	21	35	1
RES (Wind, Solar, Biomass & Others)	186	272	182	6	1	646	15
Total	1081	1573	927	744	60	4385	100

Share of RES in total generation (%)	17.19	17.27	19.59	0.78	1.84	14.73
Share of Non-fossil fuel (Hydro,Nuclear and RES) in total generation(%)	37.71	23.65	41.79	9.66	46.43	28.89

H. All India Demand Diversity Factor

Based on Regional Max Demands	1.003
Based on State Max Demands	1.050

I. All India Peak Demand and shortage at Solar and Non-Solar Hour

	Max Demand Met(MW)	Time	Shortage(MW)
Solar hr	180476	10:49	0
Non-Solar hr	190183	18:32	0

Diversity factor = Sum of regional or state maximum demands / All India maximum demand

**Note: All generation MU figures are gross

***Godha (Jharkhand) -> Bangladesh power exchange is through the radial connection (isolated from Indian Grid)

Solar Hours -> 06:00 to 18:00hrs and rest are Non-Solar Hours

*Source: RLDCs for solar connected to ISTS; SLDCs for embedded solar. Limited visibility of embedded solar data.

Executive Director-NLDC

INTER-REGIONAL EXCHANGES

Import=(+ve)/Export =(-ve) for NET (MU)
Date of Reporting: 24-Oct-2025

Sl No	Voltage Level	Line Details	No. of Circuit	Max Import (MW)	Max Export (MW)	Import (MU)	Export (MU)	NET (MU)
Import/Export of ER (With NR)								
1	HVDC	ALIPURDUAR-AGRA	2	0	312	0.0	7.3	-7.3
2	HVDC	PUSAULI B/B	-	0	47	0.0	2.6	-2.6
3	765 kV	GAYANARANASI	2	513	660	0.0	3.3	-3.3
4	765 kV	SASARAM-FATEHPUR	1	234	370	0.0	1.5	-1.5
5	765 kV	GAYA-BALIA	1	0	616	0.0	9.6	-9.6
6	400 kV	PUSAULI-VARANASI	1	0	131	0.0	2.4	-2.4
7	400 kV	PUSAULI-ALLAHABAD	1	31	36	0.0	0.1	-0.1
8	400 kV	MUZAFFARPUR-GORAKHPUR	2	164	545	0.0	5.7	-5.7
9	400 kV	PATNA-BALIA	2	145	606	0.0	7.0	-7.0
10	400 kV	NAUBATPUR-BALIA	2	15	319	0.0	1.2	-1.2
11	400 kV	BIHARSHARIFF-BALIA	2	449	33	4.8	0.0	4.8
12	400 kV	MOTIHARI-GORAKHPUR	2	30	413	0.0	5.4	-5.4
13	400 kV	BIHARSARIFF-SAHUPURI	2	218	252	0.0	0.8	-0.8
14	220 kV	SAHUPURI-KARMANASA	1	0	59	0.0	1.4	-1.4
15	132 kV	NAGAR UNTARI-RIHAND	1	0	0	0.0	0.0	0.0
16	132 kV	GARWAH-RIHAND	1	30	0	0.7	0.0	0.7
17	132 kV	KARMANASA-SAHUPURI	1	0	0	0.0	0.0	0.0
18	132 kV	KARMANASA-CHANDAULI	1	0	0	0.0	0.0	0.0
ER-NR						5.4	48.3	-42.9
Import/Export of ER (With WR)								
1	765 kV	JHARSUGUDA-DHARAMJAIGARH	4	1001	310	5.9	0.0	5.9
2	765 kV	NEW RANCHI-DHARAMJAIGARH	2	1494	99	19.5	0.0	19.5
3	765 kV	JHARSUGUDA-DURG	2	83	649	0.0	9.1	-9.1
4	400 kV	JHARSUGUDA-RAIGARH	4	460	258	1.1	0.0	1.1
5	400 kV	RANCHI-SIPAT	2	354	103	3.2	0.0	3.2
6	400 kV	JEYPORE-JACDALPUR	2	400	219	0.0	1.8	-1.8
7	220 kV	BUDHIPADAR-RAIGARH	1	48	104	0.0	0.7	-0.7
8	220 kV	BUDHIPADAR-KORBA	2	167	82	0.6	0.0	0.6
ER-WR						30.3	11.6	18.7
Import/Export of ER (With SR)								
1	HVDC	JEYPORE-GAZUWAKA B/B	2	0	319	0.0	7.6	-7.6
2	HVDC	TALCHER-KOLAR BIPOLE	2	0	1623	0.0	40.9	-40.9
3	765 kV	ANGUL-SRIKAKULAM	2	0	2763	0.0	43.6	-43.6
4	400 kV	TALCHER I/C	2	357	692	0.0	6.2	-6.2
5	220 kV	BALIMELA-UPPER-SILERRU	1	0	0	0.0	0.0	0.0
ER-SR						0.0	92.1	-92.1
Import/Export of ER (With NER)								
1	400 kV	BINAGURI-BONGAIGAON	2	0	578	0.0	9.1	-9.1
2	400 kV	ALIPURDUAR-BONGAIGAON	2	0	922	0.0	13.6	-13.6
3	220 kV	ALIPURDUAR-SALAKATI	2	0	172	0.0	2.7	-2.7
ER-NER						0.0	25.4	-25.4
Import/Export of NER (With NR)								
1	HVDC	BISWANATH CHARIALI-AGRA	2	0	604	0.0	14.5	-14.5
NER-NR						0.0	14.5	-14.5
Import/Export of WR (With NR)								
1	HVDC	CHAMPA-KURUKSHETRA	2	0	1006	0.0	23.0	-23.0
2	HVDC	VINDHYACHAL B/B	-	195	0	4.9	0.0	4.9
3	HVDC	MUNDRA-MOHINDERGARH	2	0	401	0.0	9.8	-9.8
4	765 kV	GWALIOR-AGRA	2	0	1601	0.0	25.2	-25.2
5	765 kV	GWALIOR-PHAGI	2	719	1854	2.5	22.5	-19.9
6	765 kV	JABALPUR-ORAI	2	0	746	0.0	23.8	-23.8
7	765 kV	GWALIOR-ORAI	1	952	0	14.8	0.0	14.8
8	765 kV	SATNA-ORAI	1	0	858	0.0	15.1	-15.1
9	765 kV	BANASKANTHA-CHITORGARH	2	1421	1119	14.1	3.9	10.2
10	765 kV	VINDHYACHAL-VARANASI	2	0	2205	0.0	43.0	-43.0
11	400 kV	ZERDA-KANKROLI	1	303	89	3.2	0.1	3.0
12	400 kV	ZERDA -BHINMAL	1	206	62	2.2	0.1	2.1
13	400 kV	VINDHYACHAL -RIHAND	1	0	1	0.0	0.0	0.0
14	400 kV	RAPP-SHUJALPUR	2	558	268	2.9	2.7	0.3
15	400 kV	NEEMUCH-Chittorgarh	2	585	349	3.1	3.8	-0.7
16	220 kV	BHANPURA-RANPUR	1	0	176	0.0	1.2	-1.2
17	220 kV	BHANPURA-MORAK	1	0	30	0.0	1.1	-1.1
18	220 kV	MEHGAON-AURAIYA	1	62	4	0.5	0.0	0.5
19	220 kV	MALANPUR-AURAIYA	1	42	16	0.2	0.0	0.1
20	132 kV	RAIGHAT-LALITPUR	2	0	0	0.0	0.0	0.0
WR-NR						48.3	175.2	-126.9
Import/Export of WR (With SR)								
1	HVDC	BHADRAWATI B/B	-	0	974	0.0	12.7	-12.7
2	HVDC	RAIGARH-PUGALUR	2	0	3006	0.0	25.2	-25.2
3	765 kV	SOLAPUR-RAICHUR	2	988	1189	5.0	3.8	1.2
4	765 kV	WARDHA-NIZAMABAD	2	0	2417	0.0	26.3	-26.3
5	765 kV	WARORA-WARANGAL(NEW)	2	0	2502	0.0	30.1	-30.1
6	400 kV	KOLHAPUR-KUDGI	2	1275	0	21.7	0.0	21.7
7	220 kV	KOLHAPUR-CHIKODI	2	0	0	0.0	0.0	0.0
8	220 kV	PONDA-AMBEWADI	1	0	0	0.0	0.0	0.0
9	220 kV	XELDEM-AMBEWADI	1	0	108	0.0	0.0	0.0
WR-SR						28.7	98.1	-69.4

INTERNATIONAL EXCHANGES					Import(+ve)/Export(-ve)		
State	Region	Line Name	Max (MW)	Min (MW)	Avg (MW)	Energy Exchange (MU)	
BHUTAN	ER	400kV MANGDECHHU-ALIPURDUAR 1,2&3 I.e. ALIPURDUAR RECEIPT (from MANGDECHU HEP 4*180MW)	546	459	512	12.28	
	ER	400kV TALA-BINAGURI 1,2,4 (& 400kV MALBASE - BINAGURI) I.e. BINAGURI RECEIPT (from TALA HEP 6*170MW)	374	227	300	7.20	
	ER	220kV CHUKHA-BIRPARA 1&2 (& 220kV MALBASE - BIRPARA) I.e. BIRPARA RECEIPT (from CHUKHA HEP 4*84MW)	-98	-30	-60	-1.45	
	NER	132kV GELEPHU-SALAKATI	-35	-27	-29	-0.69	
	NER	132kV MOTANGA-RANGIA	18	0	9	0.21	
NEPAL	NR	NEPAL IMPORT (FROM UP)	0	0	0	0.00	
	NR	132kV MAHENDRANAGAR-TANAKPUR(NHPC)	68	0	63	1.52	
	ER	NEPAL IMPORT (FROM BIHAR)	213	154	181	4.35	
	ER	400kV DHALKEBAR-MUZAFFARPUR 1&2	899	764	828	19.86	
BANGLADESH	ER	BHERAMARA B/B HVDC (B'DESH)	-992	-980	-988	-23.71	
	ER (Isolated from Indian Grid)	400kV GODDA_TPS-RAHANPUR (B'DESH) D/C	-1473	-1001	-1308	-31.38	
	NER	132kV COMILLA-SURAJMANI NAGAR 1&2	-100	0	-81	-1.94	

CROSS BORDER EXCHANGE SCHEDULE

Date of Reporting: 24-Oct-2025

Export From India (in MU)

Country	GNA (ISGS/PPA)	T-GNA							TOTAL
		BILATERAL TOTAL	COLLECTIVE						
			IDAM			RTM			
			IEX	PXIL	HPX	IEX	PXIL	HPX	
Bhutan	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Nepal	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Bangladesh	24.33	0.16	0.00	0.00	0.00	0.00	0.00	0.00	24.49
Myanmar	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total Export	24.33	0.16	0.00	0.00	0.00	0.00	0.00	0.00	24.49

Import by India(in MU)

Country	GNA (ISGA/PPA)	T-GNA							TOTAL	
		BILATERAL TOTAL	COLLECTIVE							
			IDAM			RTM				
			IEX	PXIL	HPX	IEX	PXIL	HPX		
Bhutan	3.85	0.00	0.93	0.00	0.00	0.00	0.00	0.00	4.78	
Nepal	9.14	4.77	5.85	0.00	0.00	0.00	3.87	0.00	0.00	23.63
Bangladesh	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Myanmar	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total Import	12.99	4.77	6.78	0.00	0.00	0.00	3.87	0.00	0.00	28.41

Net from India(in MU)

-ve : Export / +ve : Import

Country	GNA (ISGS/PPA)	T-GNA							TOTAL	
		BILATERAL TOTAL	COLLECTIVE							
			IDAM			RTM				
			IEX	PXIL	HPX	IEX	PXIL	HPX		
Bhutan	3.85	0.00	0.93	0.00	0.00	0.00	0.00	0.00	4.78	
Nepal	9.14	4.77	5.85	0.00	0.00	0.00	3.87	0.00	0.00	23.63
Bangladesh	-24.33	-0.16	0.00	0.00	0.00	0.00	0.00	0.00	0.00	-24.49
Myanmar	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total Net	-11.34	4.61	6.78	0.00	0.00	0.00	3.87	0.00	0.00	3.92

15 Min (INSTANTANEOUS) ALL INDIA GRID FREQUENCY, GENERATION & DEMAND MET (SCADA DATA)												
TIME	FREQUENCY (Hz)	DEMAND MET (MW)	NUCLEAR (MW)	WIND (MW)	SOLAR (MW)	HYDRO** (MW)	GAS (MW)	THERMAL (MW)	OTHERS* (MW)	NET DEMAND (MW)	TOTAL GENERATION (MW)	NET TRANSNATIONAL EXCHANGE (MW)
		(A)	(B)	(C)	(D)	(E)	(F)	(G)	(H)	(I=A-(C+D))	(J=B+C+D+E+F+G+H)	(+ve) Import, (-ve) Export
0:00	50.00	156373	6058	9681	0	17797	1467	121866	1518	146692	158387	624
0:15	50.00	155118	6064	9587	0	17412	1440	121037	1498	145531	157038	565
0:30	50.00	154117	6053	9455	0	17073	1443	120487	1499	144662	156010	566
0:45	50.00	153135	6047	9214	0	16582	1438	120177	1556	143921	155014	626
1:00	50.00	151978	6067	9022	0	16601	1443	119204	1561	142956	153898	604
1:15	50.00	150918	6054	8609	0	16311	1431	118778	1585	142309	152768	585
1:30	49.95	150106	6057	8384	0	16397	1451	118323	1520	141722	152132	565
1:45	49.95	149454	6053	8344	0	15876	1451	118291	1532	141110	151547	584
2:00	50.00	148556	6075	8443	0	15429	1453	117668	1520	140113	150588	606
2:15	49.95	148504	6063	8413	0	15483	1451	117493	1485	140091	150388	592
2:30	49.95	148268	6057	8301	0	15540	1447	117262	1502	139967	150109	625
2:45	50.00	147258	6050	8401	0	15347	1446	116604	1471	138857	149319	581
3:00	50.00	146836	6057	8499	0	15167	1458	115996	1514	138337	148691	591
3:15	50.00	146908	6067	8618	0	15079	1495	116121	1492	138290	148872	569
3:30	50.00	146865	6052	8813	0	15284	1495	115716	1514	138052	148874	568
3:45	50.00	146620	6062	8864	0	14715	1467	115659	1582	137756	148349	614
4:00	50.00	146719	6081	9005	0	14684	1504	115598	1537	137714	148409	618
4:15	50.00	147167	6065	9140	0	15005	1512	115775	1535	138027	149032	613
4:30	50.00	147370	6060	9167	0	15019	1508	115824	1560	138203	149138	603
4:45	49.95	148075	6056	9323	0	15014	1499	116427	1563	138752	149882	600
5:00	50.00	149967	6068	9348	138	15713	1495	117480	1545	140481	151787	605
5:15	49.95	152091	6071	9285	139	16013	1494	119419	1535	142667	153956	615
5:30	50.05	154180	6072	9506	139	16469	1488	121031	1618	144535	156323	611
5:45	50.05	156081	6073	9687	144	17430	1501	121638	1560	146250	158033	631
6:00	50.05	157837	6080	9644	136	19038	1481	121953	1518	148057	159850	624
6:15	50.05	160930	6070	9488	200	21875	1404	122531	1495	151242	163063	616
6:30	50.00	164178	6071	9589	408	23799	1424	123222	1561	154181	166074	617
6:45	49.95	166805	6053	9612	990	24598	1418	124636	1580	156203	168887	617
7:00	50.00	168946	6065	9677	2303	24776	1427	124897	1519	156966	170664	598
7:15	50.05	170323	6082	9786	4544	24349	1414	124326	1501	155993	172002	622
7:30	50.05	172228	6070	9735	7788	24396	1422	122813	1559	154705	173783	629
7:45	50.10	173126	6070	9806	11927	20708	1433	122715	1650	151393	174309	647
8:00	50.10	173096	6076	9761	16614	18037	1426	120480	1598	146721	173992	600
8:15	50.05	175000	6072	9593	21478	16683	1429	118866	1604	143929	175725	579
8:30	50.15	176822	6064	9238	26928	16116	1433	116032	1612	140656	177423	570
8:45	50.10	176924	6059	8928	31837	15764	1432	111768	1642	136159	177430	608
9:00	50.10	177643	6069	8354	36254	14569	1413	109563	1710	133035	177932	568
9:15	50.05	178855	6049	7746	40109	14058	1403	108427	1719	131000	179511	587
9:30	50.05	179623	6039	7477	43624	13679	1410	106083	1704	128522	180016	588
9:45	50.00	179506	6063	7260	47157	13415	1417	103057	1763	125089	180132	639
10:00	50.00	179727	6029	7055	49006	13412	1411	101328	1812	123666	180053	629
10:15	49.95	179521	6034	6939	50807	13573	1409	99398	1764	121775	179924	661
10:30	49.95	180081	6042	7055	52242	13552	1402	98435	1770	120784	180498	676
10:45	49.90	180043	6027	7083	52911	13650	1377	97729	1764	120049	180541	642
11:00	50.01	180060	6023	7318	54172	13672	1370	95869	1798	118570	180222	657
11:15	49.95	179196	6034	7401	54885	13175	1377	94613	1845	116910	179330	663
11:30	50.01	179498	6044	7432	55933	13292	1348	93804	1804	116133	179657	688
11:45	50.00	179209	6039	7697	54764	13956	1392	93647	1769	116748	179264	674
12:00	50.00	178912	6035	7715	54381	13572	1388	94065	1797	116816	178953	683
12:15	50.00	17938	6033	7871	54665	13400	1389	93122	1760	115402	178240	676
12:30	50.00	177857	6036	7823	54169	13326	1396	93700	1849	115865	178299	650
12:45	49.95	177542	6032	7969	53187	13474	1369	94043	1744	116386	177818	663
13:00	50.00	175278	6023	7966	51786	12927	1384	93707	1760	115526	175553	634
13:15	49.95	173359	6018	7950	49896	12710	1391	94123	1777	115513	173865	624
13:30	49.95	173350	6020	8104	49189	12899	1385	94437	1763	116057	173797	618
13:45	49.95	174312	6010	8042	49356	12888	1374	95035	1774	116914	174479	634
14:00	49.90	175114	6006	7988	48596	13022	1359	96471	1733	118530	175175	592
14:15	49.85	174574	6009	7699	47806	13067	1374	97195	1684	119069	174834	636
14:30	49.80	175843	6020	7411	47760	13883	1381	98061	1717	120672	176233	629
14:45	49.81	177089	5982	7419	46780	14432	1374	99543	1724	122890	177254	599
15:00	50.01	178373	5987	7384	45331	14067	1366	102986	1670	125658	178791	614
15:15	50.01	178790	6005	7500	43043	14077	1370	106168	1658	128247	179821	599
15:30	50.01	178979	6013	7301	39433	15203	1351	108847	1702	132245	179850	597
15:45	50.01	178147	6001	7260	35528	14654	1378	112810	1653	135359	179284	624
16:00	50.01	178534	5984	7423	31549	15197	1384	116650	1612	139562	179799	609
16:15	50.01	177216	6014	7432	26850	15562	1375	119389	1707	142934	178329	618
16:30	50.01	177419	6009	7409	22011	15997	1388	123967	1631	147999	178412	661
16:45	50.01	177090	6011	7402	16849	17632	1375	127914	1615	152839	178798	619
17:00	50.06	177730	6006	7435	12238	19144	1396	131502	1705	158057	179426	584
17:15	50.06	177704	6012	7251	8193	19813	1435	135440	1572	162260	179716	556
17:30	50.06	180324	6007	7170	4825	22280	1439	139201	1518	168329	182440	520
17:45	50.01	183442	6023	7260	2505	24461	1460	142380	1537	173677	185626	517
18:00	49.96	186636	6018	7144	1152	26730	1468	145218	1495	178340	189225	548
18:15	49.91	188681	6012	7195	802	28601	1489	145808	1514	180684	191421	571
18:30	50.06	190040	6011	6777	758	30006	1492	146139	1512	182505	192695	539
18:45	50.01	189258	6023	7596	307	30050	1446	144914	1511	181355	191847	549
19:00	50.01	187746	6016	7820	244	29477	1462	143702	1563	179682	190284	549
19:15	50.01	185927	6032	7985	251	29221	1474	142154	1525	177691	188642	491
19:30	50.01	184140	6040	8245	0	28641	1463	140635	1568	175895	186592	486
19:45	49.96	181644	6015	8576	0	28164	1465	138412	1564	173068	184196	537
20:00	50.01	179724	6038	8945	0	28138	1470	136110	1540	170779	182241	532
20:15	50.01	178603	6026	8850	0	27574	1459	135595	1580	169753	181084	524
20:30	50.01	177721	6047	9283	0	25769	1460	135890	1569	168438	180018	559
20:45	50.00	176878	6034	9685	0	25363	1469	135226	1632	167193	179409	557
21:00	50.04	175329	6051	9752	0	24491	1468	134281	1627	165577	177670	566
21:15	50.04	173510	6023	9774	0	23446	1456	133479	1630	163736	175808	568
21:30	49.99	171455	6021	9656	0	22614	1455	132349	1675	161799	173770	540
21:45	49.99	170458	6027	9571	0	22051	1459	131988	1722	160887	172818	578
22:00	49.99	168515	6032	9428	0	21674	1468	130508	1660	159087	170770	588
22:15	49.99	168878	6012	9127	0	21129	1460	131756	1689	159751	171173	577
22:30	50.04	168738	6024	9151	0	21040	1458	131797	1665	159587	171135	569
22:45	49.89	167565	6019	9016	0							