



National Load Despatch Centre
राष्ट्रीय भार प्रेषण केंद्र
GRID CONTROLLER OF INDIA LIMITED
ग्रिड कंट्रोलर ऑफ इंडिया लिमिटेड

(Government of India Enterprise/ भारत सरकार का उद्यम)
B-9, QUTUB INSTITUTIONAL AREA, KATWARIA SARAI, NEW DELHI -110016
बी-9, कुतुब इन्स्टीट्यूशनल एरिया, कटवारिया सराये, न्यू दिल्ली-110016

Ref: GRID-INDIA/NLDC/SO/Daily PSP Report

दिनांक: 19.07.2025

To,

- कार्यकारी निदेशक, पू.क्षे.भा.प्रे.के., 14, गोल्फ क्लब रोड, कोलकाता - 700033
Executive Director, ERLDC, 14 Golf Club Road, Tollygunge, Kolkata, 700033
- कार्यकारी निदेशक, ऊ.क्षे.भा.प्रे.के., 18/ए, शाहीद जीत सिंह सनसनवाल मार्ग, नई दिल्ली - 110016
Executive Director, NRLDC, 18-A, Shaheed Jeet Singh Marg, Katwaria Sarai, New Delhi - 110016
- कार्यकारी निदेशक, प.क्षे.भा.प्रे.के., एफ3, एम आई डी सी क्षेत्र, अंधेरी, मुंबई - 400093
Executive Director, WRLDC, F-3, M.I.D.C. Area, Marol, Andheri (East), Mumbai-400093
- कार्यकारी निदेशक, ऊ.पू.क्षे.भा.प्रे.के., डोंगतेह, लोअर नोंग्रह, लापलंग, शिलोंग - 793006
Executive Director, NERLDC, Dongteih, Lower Nongrah, Lapalang, Shillong - 793006, Meghalaya
- कार्यकारी निदेशक, द.क्षे.भा.प्रे.के., 29, रेस कोर्स क्रॉस रोड, बंगलुरु - 560009
Executive Director, SRLDC, 29, Race Course Cross Road, Bangalore-560009

Sub: Daily PSP Report for the date 18.07.2025.

महोदय/Sir,

आईईजीसी-2023 की धारा स.-38(1) के प्रावधान के अनुसार, दिनांक 18-जुलाई-2025 की अखिल भारतीय प्रणाली की दैनिक ग्रिड निष्पादन रिपोर्ट रांभांप्रेके की वेबसाइट पर उपलब्ध है।

As per article 38(1) of the Indian Electricity Grid Code, the daily report pertaining power supply position of All India Power System for the date 18.07.2025, is available at the NLDC website.

धन्यवाद,
Thanks

Report for previous day

Date of Reporting: 19-Jul-2025

A. Power Supply Position at All India and Regional level

	NR	WR	SR	ER	NER	TOTAL
Demand Met during Evening Peak hrs(MW) (at 20:00 hrs; from RLDCs)	71524	62560	48903	29527	3875	216389
Peak Shortage (MW)	215	0	0	0	0	215
Energy Met (MU)	1575	1463	1246	651	81	5016
Hydro Gen (MU)	414	97	188	94	37	829
Wind Gen (MU)	20	109	188	-	-	317
Solar Gen (MU)*	106.94	95.82	98.13	3.23	0.95	305
Energy Shortage (MU)	0.46	0.00	0.00	0.00	0.00	0.46
Maximum Demand Met During the Day (MW) (From NLDC SCADA)	72573	63597	58057	30602	3934	217773
Time Of Maximum Demand Met	22:36	19:28	09:56	22:55	19:05	11:00

B. Frequency Profile (%)

Region	FVI	< 49.7	49.7 - 49.8	49.8 - 49.9	< 49.9	49.9 - 50.05	> 50.05
All India	0.050	0.68	2.31	3.04	6.04	68.92	25.04

C. Power Supply Position in States

Region	States	Max.Demand Met during the day (MW)	Shortage during maximum Demand (MW)	Energy Met (MU)	Drawal Schedule (MU)	OD(+)/UD(-) (MU)	Max OD (MW)	Energy Shortage (MU)
NR	Punjab	16124	0	322.3	193.1	-1.6	761	0.00
	Haryana	11715	0	250.8	185.6	-1.3	398	0.02
	Rajasthan	10995	0	242.8	85.0	-5.1	904	0.00
	Delhi	6143	0	128.5	118.5	-2.1	253	0.00
	UP	27375	0	477.0	167.8	2.0	619	0.00
	Uttarakhand	2499	0	49.9	14.8	0.3	249	0.44
	HP	1829	0	37.6	-5.9	0.6	122	0.00
	J&K(UT) & Ladakh(UT)	2646	0	55.5	28.8	1.8	358	0.00
	Chandigarh	313	0	6.7	6.6	0.1	35	0.00
	Railways NR ISTS	210	0	4.2	3.7	0.6	46	0.00
WR	Chhattisgarh	5320	0	117.7	68.6	-1.0	279	0.00
	Gujarat	20661	0	456.7	154.1	-1.2	830	0.00
	MP	10462	0	226.8	87.7	-0.1	621	0.00
	Maharashtra	25656	0	578.8	214.9	0.3	1050	0.00
	Goa	573	0	14.1	12.2	1.4	54	0.00
	DNHDDPDCL	1397	0	32.7	32.5	0.2	40	0.00
	AMNSIL	841	0	19.0	8.8	0.8	264	0.00
	BALCO	532	0	12.7	12.7	0.0	10	0.00
	RIL JAMNAGAR	237	0	4.6	4.7	-0.1	0	0.00
	Andhra Pradesh	10838	0	230.0	62.6	0.3	490	0.00
SR	Telangana	15112	0	271.4	131.3	0.4	809	0.00
	Karnataka	14105	0	255.2	56.0	-1.3	777	0.00
	Kerala	3825	0	76.6	30.7	-0.9	230	0.00
	Tamil Nadu	17481	0	402.2	172.8	-0.8	1411	0.00
	Puducherry	520	0	11.1	10.7	0.0	69	0.00
	Bihar	8079	0	165.3	151.0	2.8	380	0.00
ER	DVC	3279	0	67.8	-51.0	0.0	466	0.00
	Jharkhand	2096	0	42.9	35.2	-0.9	217	0.00
	Odisha	6602	0	140.2	53.7	-0.3	466	0.00
	West Bengal	10992	0	232.7	102.4	-1.9	248	0.00
	Sikkim	89	0	1.5	1.1	0.4	32	0.00
	Railways ER ISTS	18	0	0.1	0.2	0.0	0	0.00
NER	Arunachal Pradesh	205	0	4.2	3.9	0.0	28	0.00
	Assam	2657	0	53.3	45.3	0.9	152	0.00
	Manipur	180	0	3.4	3.3	0.1	58	0.00
	Meghalaya	329	0	5.8	2.0	-0.1	96	0.00
	Mizoram	124	0	3.7	0.8	1.3	49	0.00
	Nagaland	189	0	4.0	2.9	0.5	12	0.00
	Tripura	332	0	6.2	4.5	-0.1	43	0.00

D. Transnational Exchanges (MU) - Import(+ve)/Export(-ve)

	Bhutan	Nepal	Bangladesh	Godda -> Bangladesh
Actual (MU)	40.3	15.6	-22.9	-23.7
Day Peak (MW)	1813.9	811.5	-978.0	-1266.0

E. Import/Export by Regions (in MU) - Import(+ve)/Export(-ve); OD(+)/UD(-)

	NR	WR	SR	ER	NER	TOTAL
Schedule(MU)	258.0	-266.0	41.1	-41.6	8.4	0.0
Actual(MU)	249.7	-280.2	51.7	-36.5	9.4	-6.0
O/D/U/D(MU)	-8.3	-14.2	10.6	5.0	0.9	-6.0

F. Generation Outage(MW)

	NR	WR	SR	ER	NER	TOTAL	% Share
Central Sector	5269	13530	7032	6490	422	32742	53
State Sector	7419	10576	7977	2819	199	28990	47
Total	12688	24105	15009	9309	621	61732	100

G. Sourcewise generation (Gross) (MU)

	NR	WR	SR	ER	NER	All India	% Share
Coal	794	1446	627	648	15	3530	66
Lignite	18	14	37	0	0	68	1
Hydro	414	97	188	94	37	829	15
Nuclear	37	41	65	0	0	143	3
Gas, Naptha & Diesel	25	49	9	0	20	103	2
RES (Wind, Solar, Biomass & Others)	135	208	332	5	1	681	13
Total	1423	1854	1257	747	73	5354	100

Share of RES in total generation (%)	9.47	11.21	26.38	0.71	1.31	12.71
Share of Non-fossil fuel (Hydro,Nuclear and RES) in total generation(%)	41.13	18.63	46.54	13.24	51.79	30.86

H. All India Demand Diversity Factor

Based on Regional Max Demands	1.050
Based on State Max Demands	1.113

I. All India Peak Demand and shortage at Solar and Non-Solar Hour

	Max Demand Met(MW)	Time	Shortage(MW)
Solar hr	217773	11:00	0
Non-Solar hr	215110	22:26	185

Diversity factor = Sum of regional or state maximum demands / All India maximum demand

**Note: All generation MU figures are gross

***Godda (Jharkhand) -> Bangladesh power exchange is through the radial connection (isolated from Indian Grid)

Solar Hours -> 06:00 to 18:00hrs and rest are Non-Solar Hours

*Source: RLDCs for solar connected to ISTS; SLDCs for embedded solar. Limited visibility of embedded solar data.

INTER-REGIONAL EXCHANGES

Import=(+ve)/Export =(-ve) for NET (MU)
Date of Reporting: 19-Jul-2025

Sl No	Voltage Level	Line Details	No. of Circuit	Max Import (MW)	Max Export (MW)	Import (MU)	Export (MU)	NET (MU)
Import/Export of ER (With NR)								
1	HVDC	ALIPURDUAR-AGRA	2	0	311	0.0	7.3	-7.3
2	HVDC	PUSAULI B/B	-	0	47	0.0	2.7	-2.7
3	765 kV	GAYA-VARANASI	2	702	562	0.0	2.9	-2.9
4	765 kV	SASARAM-FATEHPUR	1	300	291	0.0	2.1	-2.1
5	765 kV	GAYA-BALIA	1	0	654	0.0	9.3	-9.3
6	400 kV	PUSAULI-VARANASI	1	0	137	0.0	2.7	-2.7
7	400 kV	PUSAULI-ALLAHABAD	1	37	29	0.0	2.5	-2.5
8	400 kV	MUZAFFARPUR-GORAKHPUR	2	208	377	0.0	4.3	-4.3
9	400 kV	PATNA-BALIA	2	256	474	0.0	6.0	-6.0
10	400 kV	NAUBATPUR-BALIA	2	138	82	0.0	1.0	-1.0
11	400 kV	BIHARSHARIFF-BALIA	2	405	24	3.3	0.0	3.3
12	400 kV	MOTIHARI-GORAKHPUR	2	130	232	0.0	2.7	-2.7
13	400 kV	BIHARSARIFF-SAHUPURI	2	147	194	0.0	1.4	-1.4
14	220 kV	SAHUPURI-KARAMNANA	1	0	101	0.0	1.1	-1.1
15	132 kV	NAGAR UNTARI-RIHAND	1	0	0	0.0	0.0	0.0
16	132 kV	GARWAH-RIHAND	1	30	0	0.2	0.0	0.2
17	132 kV	KARMANASA-SAHUPURI	1	0	0	0.0	0.0	0.0
18	132 kV	KARMANASA-CHANDAUJI	1	0	0	0.0	0.0	0.0
ER-NR						3.5	46.2	-42.7
Import/Export of ER (With WR)								
1	765 kV	JHARSUGUDA-DHARAMJAIGARH	4	1350	0	18.2	0.0	18.2
2	765 kV	NEW RANCHI-DHARAMJAIGARH	2	1858	433	24.3	0.0	24.3
3	765 kV	JHARSUGUDA-DURG	2	104	427	0.0	2.5	-2.5
4	400 kV	JHARSUGUDA-RAIGARH	4	609	31	7.5	0.0	7.5
5	400 kV	RANCHI-SIPAT	2	485	177	5.5	0.0	5.5
6	400 kV	JEYPORE-JAGDALPUR	2	244	172	0.0	0.4	-0.4
7	220 kV	BUDHIPADAR-RAIGARH	1	61	60	0.1	0.0	0.1
8	220 kV	BUDHIPADAR-KORBA	2	74	147	0.0	0.5	-0.5
ER-WR						55.6	3.5	52.1
Import/Export of ER (With SR)								
1	HVDC	JEYPORE-GAZUWAKA B/B	2	0	111	0.0	2.6	-2.6
2	HVDC	TALCHER-KOLAR BIPOLE	2	0	1338	0.0	29.0	-29.0
3	765 kV	ANGUL-SRIKAKULAM	2	0	2624	0.0	31.9	-31.9
4	400 kV	TALCHER-I/C	2	305	60	3.5	0.0	3.5
5	220 kV	BALIMELA-UPPER-SILERRU	1	0	0	0.0	0.0	0.0
ER-SR						0.0	63.5	-63.5
Import/Export of ER (With NER)								
1	400 kV	BINAGURI-BONGAIGAON	2	52	324	0.1	4.1	-4.0
2	400 kV	ALIPURDUAR-BONGAIGAON	2	0	651	0.0	10.4	-10.4
3	220 kV	ALIPURDUAR-SALAKATI	2	0	129	0.0	2.0	-2.0
ER-NER						0.1	16.5	-16.4
Import/Export of NER (With NR)								
1	HVDC	BISWANATH CHARIALI-AGRA	2	0	355	0.0	8.5	-8.5
NER-NR						0.0	8.5	-8.5
Import/Export of WR (With NR)								
1	HVDC	CHAMPA-KURUKSHETRA	2	0	2015	0.0	37.9	-37.9
2	HVDC	VINDHYACHAL B/B	-	46	0	1.3	0.0	1.3
3	HVDC	MUNDRA-MOHINDERGARH	2	0	1452	0.0	36.3	-36.3
4	765 kV	GWALIOR-AGRA	2	265	2215	0.1	32.0	-31.9
5	765 kV	GWALIOR-PHAGI	2	0	1505	0.0	23.2	-23.2
6	765 kV	JABALPUR-ORAI	2	5	1068	0.0	31.1	-31.1
7	765 kV	GWALIOR-ORAI	1	686	0	11.3	0.0	11.3
8	765 kV	SATNA-ORAI	1	0	927	0.0	18.0	-18.0
9	765 kV	BANASKANTHA-CHITTOGARH	2	1912	549	15.0	0.4	14.6
10	765 kV	VINDHYACHAL-VARANASI	2	0	3212	0.0	47.7	-47.7
11	400 kV	ZERDA-KANKROLI	1	368	0	3.5	0.0	3.5
12	400 kV	ZERDA-BHINMAL	1	254	0	2.1	0.0	2.1
13	400 kV	VINDHYACHAL-RIHAND	1	0	1	0.0	0.0	0.0
14	400 kV	RAPP-SHUJALPUR	2	189	315	0.6	3.0	-2.3
15	400 kV	NEEMU/CH-Chittorgarh	2	50	457	0.0	5.7	-5.7
16	220 kV	BHANPURA-RANPUR	1	0	130	0.0	2.5	-2.5
17	220 kV	BHANPURA-MORAK	1	0	30	0.0	2.2	-2.2
18	220 kV	MEHGAON-AURAIYA	1	78	36	0.2	0.0	0.2
19	220 kV	MALANPUR-AURAIYA	1	68	46	0.0	0.0	0.0
20	132 kV	RAJGHAT-LALITPUR	2	0	0	0.0	0.0	0.0
WR-NR						34.0	240.0	-206.0
Import/Export of WR (With SR)								
1	HVDC	BHADRAWATI B/B	-	0	1007	0.0	11.4	-11.4
2	HVDC	RAIGARH-PUGAUR	2	0	4010	0.0	53.8	-53.8
3	765 kV	SOLAPUR-RAICHUR	2	3306	438	35.5	0.4	35.1
4	765 kV	WARDHA-NIZAMABAD	2	1242	2382	3.3	19.0	-15.7
5	765 kV	WARORA-WARANGAL(NEW)	2	1239	2288	3.2	16.5	-13.4
6	400 kV	KOLHAPUR-KUDGI	2	2114	0	35.2	0.0	35.2
7	220 kV	KOLHAPUR-CHIKODI	2	0	0	0.0	0.0	0.0
8	220 kV	PONDA-AMBEWADI	1	0	0	0.0	0.0	0.0
9	220 kV	XELDEM-AMBEWADI	1	0	102	1.9	0.0	1.9
WR-SR						79.0	101.1	-22.1

INTERNATIONAL EXCHANGES				Import(+ve)/Export(-ve)		
State	Region	Line Name	Max (MW)	Min (MW)	Avg (MW)	Energy Exchange (MU)
BHUTAN	ER	400kV MANGDECHHU-ALIPURDUAR 1,2&3 I.e. ALIPURDUAR RECEIPT (from MANGDECHHU HEP 4*180MW)	1146	925	1046	25.11
	ER	400kV TALA-BINAGURI 1,2,4 (& 400kV MALBASE - BINAGURI) I.e. BINAGURI RECEIPT (from TALA HEP 6*170MW)	614	430	520	12.48
	ER	220kV CHUKHA-BIRPARA 1&2 (& 220kV MALBASE - BIRPARA) I.e. BIRPARA RECEIPT (from CHUKHA HEP 4*84MW)	113	11	57	1.37
	NER	132kV GELEPHU-SALAKATI	20	7	14	0.32
	NER	132kV MOTANGA-RANGIA	55	30	42	1.01
NEPAL	NR	NEPAL IMPORT (FROM UP)	-41	0	0	-0.01
	NR	132kV MAHENDRANAGAR-TANAKPUR(NHPC)	40	0	13	0.31
	ER	NEPAL IMPORT (FROM BIHAR)	152	104	125	3.00
	ER	400kV DHALKEBAR-MUZAFFARPUR 1&2	616	332	513	12.30
BANGLADESH	ER	BHERAMARA B/B HVDC (B'DESH)	-953	-803	-927	-22.26
	ER (Isolated from Indian Grid)	400kV GODDA_TPS-RAHANPUR (B'DESH) D/C	-1266	-820	-988	-23.70
	NER	132kV COMILLA-SURAJMANI NAGAR 1&2	-30	0	-26	-0.62

CROSS BORDER EXCHANGE SCHEDULE

Date of Reporting: 19-Jul-2025

Export From India (in MU)

Country	GNA (ISGS/PPA)	T-GNA							TOTAL
		BILATERAL TOTAL	COLLECTIVE						
			IDAM			RTM			
			IEX	PXIL	HPX	IEX	PXIL	HPX	
Bhutan	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Nepal	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Bangladesh	23.01	0.08	0.00	0.00	0.00	0.00	0.00	0.00	23.09
Myanmar	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total Export	23.01	0.08	0.00	0.00	0.00	0.00	0.00	0.00	23.09

Import by India(in MU)

Country	GNA (ISGA/PPA)	T-GNA							TOTAL
		BILATERAL TOTAL	COLLECTIVE						
			IDAM			RTM			
			IEX	PXIL	HPX	IEX	PXIL	HPX	
Bhutan	38.84	0.00	1.18	0.00	0.00	0.18	0.00	0.00	40.20
Nepal	8.44	0.08	4.97	0.00	0.00	2.99	0.00	0.00	16.48
Bangladesh	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Myanmar	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total Import	47.28	0.08	6.15	0.00	0.00	3.17	0.00	0.00	56.68

Net from India(in MU)

-ve : Export / +ve : Import

Country	GNA (ISGS/PPA)	T-GNA							TOTAL	
		BILATERAL TOTAL	COLLECTIVE							
			IDAM			RTM				
			IEX	PXIL	HPX	IEX	PXIL	HPX		
Bhutan	38.84	0.00	1.18	0.00	0.00	0.18	0.00	0.00	40.20	
Nepal	8.44	0.08	4.97	0.00	0.00	0.00	2.99	0.00	0.00	16.48
Bangladesh	-23.01	-0.08	0.00	0.00	0.00	0.00	0.00	0.00	0.00	-23.09
Myanmar	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total Net	24.27	0.00	6.15	0.00	0.00	0.00	3.17	0.00	0.00	33.59

15 Min (INSTANTANEOUS) ALL INDIA GRID FREQUENCY, GENERATION & DEMAND MET (SCADA DATA)												
TIME	FREQUENCY (Hz)	DEMAND MET (MW)	NUCLEAR (MW)	WIND (MW)	SOLAR (MW)	HYDRO** (MW)	GAS (MW)	THERMAL (MW)	OTHERS* (MW)	NET DEMAND (MW)	TOTAL GENERATION (MW)	NET TRANSNATIONAL EXCHANGE (MW)
		(A)	(B)	(C)	(D)	(E)	(F)	(G)	(H)	(I=A-(C+D))	(J=B+C+D+E+F+G+H)	(K)
0:00	50.07	202943	5386	13467	0	32788	3760	146157	1865	189476	203423	1310
0:15	50.02	202244	5381	13463	0	33129	3650	145268	1819	188781	202710	1381
0:30	50.02	201253	5374	13456	0	33056	3648	145137	1876	187797	202547	1372
0:45	50.02	199731	5376	13528	0	33197	3583	143808	1808	186203	201300	1369
1:00	49.97	198118	5381	13646	0	32876	3415	142263	1800	184472	199381	1407
1:15	50.02	196762	5380	13714	0	32964	3469	140805	1801	183048	198133	1405
1:30	50.02	195708	5382	13669	0	32610	3391	138815	1835	182039	195702	1379
1:45	50.07	194674	5382	13393	0	32442	3214	138443	1881	181281	194755	1393
2:00	50.02	193907	5385	12910	0	32088	3189	139943	1803	180997	195318	1272
2:15	49.96	191775	5384	12342	0	32273	3163	138991	1811	179433	193964	1328
2:30	50.02	191109	5397	11758	0	32458	3173	138787	1762	179351	193335	1375
2:45	50.02	190795	5381	11553	0	32476	3009	138549	1737	179242	192705	1381
3:00	49.99	190188	5379	11463	0	32023	3120	138488	1750	178725	192223	1381
3:15	49.99	190008	5388	11429	0	31966	3129	138335	1742	178579	191989	1364
3:30	49.99	189467	5377	11478	0	31909	3010	137829	1740	177989	191343	1393
3:45	50.04	189163	5389	11736	0	31630	3018	137491	1734	177427	190998	1483
4:00	50.04	188713	5387	12008	0	31263	3128	137198	1779	176705	190763	1440
4:15	50.04	189395	5383	12193	0	31154	3118	137817	1765	177202	191430	1470
4:30	50.04	189889	5378	12285	0	31216	3115	138034	1801	177604	191829	1481
4:45	50.04	190151	5371	12089	0	31242	3106	138592	1717	178062	192117	1474
5:00	50.04	190071	5388	11876	44	31168	3103	138812	1723	178151	192114	1440
5:15	50.04	190796	5385	11797	40	31588	3107	139403	1706	178959	193026	1431
5:30	50.04	192299	5389	11744	38	31801	3005	140535	1684	180517	194196	1464
5:45	50.09	193220	5386	11637	54	31624	3107	141648	1733	181529	195189	1425
6:00	50.04	194633	5392	11642	72	31632	3106	143073	1694	182919	196611	1387
6:15	50.04	197252	5382	11313	498	32124	3113	144889	1715	185441	199034	1428
6:30	50.04	200162	5379	10981	1549	33344	3099	145763	1698	187632	201813	1398
6:45	50.04	200553	5389	10748	2773	33421	3097	145315	1782	187032	202525	1412
7:00	49.99	200581	5392	10311	4448	32939	3011	144495	1779	185822	202375	1419
7:15	49.89	201456	5389	9865	6004	32905	2999	144348	1773	185587	202382	1419
7:30	49.73	201566	5371	9586	8051	32787	3013	142888	1834	183929	203530	1393
7:45	49.78	201741	5355	9363	10302	32915	3033	140982	1880	182076	203830	1443
8:00	50.04	202472	5383	9102	12323	32734	3133	140363	1918	181047	204956	1506
8:15	49.99	203568	5382	9067	14567	32114	3134	140339	1915	179934	206518	1328
8:30	49.99	205121	5385	9169	17082	31682	3132	139522	1905	178870	207877	1350
8:45	50.04	207623	5394	9685	20321	31279	3027	138514	1948	177617	210168	1352
9:00	50.09	209453	5377	9995	23322	30787	3135	137690	1960	176136	212266	1309
9:15	49.99	212611	5369	10201	25345	30295	3044	138893	1949	177065	215096	1347
9:30	50.04	213655	5368	10353	26033	30127	3114	139332	2002	177269	216329	1333
9:45	50.04	215489	5362	10640	28041	29997	3020	138951	2046	176808	218057	1317
10:00	50.04	216582	5356	10701	30401	29848	3051	138113	2049	175480	219519	1399
10:15	50.03	217084	5362	10882	32695	29697	3026	136196	1993	173507	219851	1356
10:30	50.08	216952	5361	10819	34816	29690	3014	134103	2009	171317	219812	1328
10:45	50.08	216913	5379	11041	36551	28765	3003	133164	1896	169321	219799	1290
11:00	50.08	217773	5372	11175	38033	28750	3001	132151	1995	168565	220477	1282
11:15	50.08	217374	5374	11558	40278	28341	3014	129824	1989	165538	220378	1256
11:30	50.03	216805	5358	11753	41242	28603	3144	128534	2009	163810	220643	1248
11:45	49.98	215929	5368	12040	42076	28709	3140	126591	2017	161813	219941	1254
12:00	50.03	215669	5361	11871	42125	28956	3149	125311	2016	161673	218789	1230
12:15	50.03	214891	5363	12120	43366	28783	3137	123167	2029	159405	217965	1251
12:30	50.03	214067	5360	12401	43791	29045	3139	121894	1981	157875	217611	1218
12:45	49.98	213690	5358	12658	43288	29382	3142	120766	2048	157744	216642	1297
13:00	50.03	211288	5350	13005	41701	29622	3147	120355	1917	156582	215097	1093
13:15	49.98	209066	5368	13079	40457	29381	3138	118611	1928	155530	211962	978
13:30	50.03	209499	5376	13164	40689	29184	3129	119031	1924	155646	212497	1130
13:45	49.98	210980	5377	13282	39196	29671	3132	121398	2058	158502	214114	1081
14:00	49.98	211687	5359	13811	38062	29957	3135	122758	1987	159814	215069	1208
14:15	49.73	211888	5362	13883	34271	30119	3160	126202	1930	163734	214927	1119
14:30	49.88	214731	5345	13985	32325	30614	3136	130200	2023	168421	217628	1083
14:45	49.98	217131	5339	14035	31989	30605	3138	131162	1921	171107	220189	1094
15:00	49.98	217624	5369	13969	30400	30550	3138	135222	1938	173255	220586	1108
15:15	49.93	216112	5365	14222	27865	30000	3137	136734	1884	174025	219207	1124
15:30	49.93	216327	5369	14196	25432	30194	3145	138636	1890	176699	218862	1230
15:45	49.93	216932	5365	14314	23833	30078	3147	141284	1884	178785	219905	1319
16:00	50.03	216222	5377	14436	21991	29823	3150	141849	1939	179795	218565	1335
16:15	50.03	214474	5382	14291	20095	29133	3150	142738	1865	180088	216654	1331
16:30	50.03	214607	5371	14061	18805	30004	3166	143699	1843	181741	216949	1338
16:45	50.08	213856	5370	14264	17341	29599	3155	144261	1837	182251	215827	1250
17:00	50.08	211880	5346	14502	15194	29637	3331	144192	1811	182184	214013	1288
17:15	49.98	209012	5359	14774	12068	29529	3446	144077	1752	182170	211005	1289
17:30	50.03	208121	5365	14666	9881	30069	3441	144476	1733	183574	209631	1292
17:45	49.98	207225	5352	14402	7949	30615	3716	145195	1721	184874	208950	1308
18:00	50.04	206102	5355	14358	6494	31204	3970	144828	1716	185250	207925	1304
18:15	50.04	204156	5359	14251	4493	30910	4465	144048	1753	185412	205279	1195
18:30	50.04	205626	5332	14396	2982	32744	4826	145528	1828	188248	207636	1177
18:45	50.09	207045	5330	14634	1553	33321	5284	147270	1810	190858	209202	1150
19:00	50.09	208993	5320	14814	731	34398	5600	148318	1784	193448	210965	1024
19:15	50.04	210775	5335	15102	238	35510	5794	149067	1804	195435	212850	955
19:30	50.04	213123	5339	15538	81	36542	5978	149861	1824	197504	215163	971
19:45	50.04	214187	5340	15780	65	37180	6007	149712	1887	198342	215971	919
20:00	50.04	213888	5338	15977	58	37340	5770	149481	1839	197853	215803	958
20:15	49.99	214298	5340	16392	0	37420	5583	149400	1926	197906	216061	955
20:30	50.04	214194	5340	16563	0	37544	5505	149127	1913	197631	215992	917
20:45	49.99	213989	5339	16805	0	37343	5494	148876	1855	197184	215712	1034
21:00	50.04	213751	5340	16846	0	37086	5494	148689	1848	196905	215303	1064
21:15	50.04	213904	5331	16781	0	37197	5472	148464	1821	197123	215066	1138
21:30	49.99	213997	5341	16413	0	36981	5494	148932	1860	197584	215021	1136
21:45	50.04	213982	5344	16038	0	37395	5473	149055	1857	197944	215162	1148
22:00	50.04	213968	5336	15835	0	37137	5530	149389	1824	198133	215051	1176
22:15	50.04	214806	5324	15994	0	37113	5744	149939	1879	198812	215993	1163