



National Load Despatch Centre
राष्ट्रीय भार प्रेषण केंद्र
GRID CONTROLLER OF INDIA LIMITED
ग्रिड कंट्रोलर ऑफ इंडिया लिमिटेड

(Government of India Enterprise/ भारत सरकार का उद्यम)
B-9, QUTUB INSTITUTIONAL AREA, KATWARIA SARAI, NEW DELHI -110016
बी-9, कुतुब इन्स्टीट्यूशनल एरिया, कटवारिया सराये, न्यू दिल्ली-110016

Ref: GRID-INDIA/NLDC/SO/Daily PSP Report

दिनांक: 19.10.2025

To,

- कार्यकारी निदेशक, पू.क्षे.भा.प्रे.के., 14, गोल्फ क्लब रोड, कोलकाता - 700033
Executive Director, ERLDC, 14 Golf Club Road, Tollygunge, Kolkata, 700033
- कार्यकारी निदेशक, ऊ.क्षे.भा.प्रे.के., 18/ए, शाहीद जीत सिंह सनसनवाल मार्ग, नई दिल्ली - 110016
Executive Director, NRLDC, 18-A, Shaheed Jeet Singh Marg, Katwaria Sarai, New Delhi - 110016
- कार्यकारी निदेशक, प.क्षे.भा.प्रे.के., एफ3, एम आई डी सी क्षेत्र, अंधेरी, मुंबई -400093
Executive Director, WRLDC, F-3, M.I.D.C. Area, Marol, Andheri (East), Mumbai-400093
- कार्यकारी निदेशक, ऊ.पू.क्षे.भा.प्रे.के., डोंगतेह, लोअर नोंग्रह, लापालंग, शिलोंग - 793006
Executive Director, NERLDC, Dongteih, Lower Nongrah, Lapalang, Shillong - 793006, Meghalaya
- कार्यकारी निदेशक, द.क्षे.भा.प्रे.के., 29, रेस कोर्स क्रॉस रोड, बंगलुरु -560009
Executive Director, SRLDC, 29, Race Course Cross Road, Bangalore-560009

Sub: Daily PSP Report for the date 18.10.2025.

महोदय/Sir,

आईईजीसी-2023 की धारा स.-38(1) के प्रावधान के अनुसार, दिनांक 18-अक्टूबर-2025 की अखिल भारतीय प्रणाली की दैनिक ग्रिड निष्पादन रिपोर्ट रांभांप्रेके की वेबसाइट पर उपलब्ध है।

As per article 38(1) of the Indian Electricity Grid Code, the daily report pertaining power supply position of All India Power System for the date 18.10.2025, is available at the NLDC website.

धन्यवाद,
Thanks

Report for previous day

Date of Reporting: 19-Oct-2025

A. Power Supply Position at All India and Regional level

	NR	WR	SR	ER	NER	TOTAL
Demand Met during Evening Peak hrs(MW) (at 19:00 hrs; from RLDCs)	57685	63786	45852	27229	3474	198026
Peak Shortage (MW)	0	0	0	0	0	0
Energy Met (MU)	1280	1477	1098	581	63	4500
Hydro Gen (MU)	208	41	153	77	29	508
Wind Gen (MU)	6	53	52	-	-	111
Solar Gen (MU)*	202.59	150.13	118.82	3.78	1.14	476
Energy Shortage (MU)	0.00	0.00	0.00	0.00	0.00	0.00
Maximum Demand Met During the Day (MW) (From NLDC SCADA)	60125	66621	52041	27819	3598	204435
Time Of Maximum Demand Met	10:26	16:53	15:31	18:42	17:46	18:31

B. Frequency Profile (%)

Region	FVI	< 49.7	49.7 - 49.8	49.8 - 49.9	< 49.9	49.9 - 50.05	> 50.05
All India	0.038	0.00	0.41	9.41	9.81	81.67	8.52

C. Power Supply Position in States

Region	States	Max.Demand Met during the day (MW)	Shortage during maximum Demand (MW)	Energy Met (MU)	Drawal Schedule (MU)	OD(+)/UD(-) (MU)	Max OD (MW)	Energy Shortage (MU)
NR	Punjab	9398	0	180.4	82.5	-0.6	700	0.00
	Haryana	8896	0	185.0	148.7	-0.8	331	0.00
	Rajasthan	12646	0	264.3	64.1	-4.2	903	0.00
	Delhi	4489	0	92.1	89.3	0.5	309	0.00
	UP	20219	0	422.0	146.6	-1.9	363	0.00
	Uttarakhand	2183	0	42.4	27.7	-0.2	99	0.00
	HP	1804	0	33.7	13.1	-1.0	210	0.00
	J&K(UT) & Ladakh(UT)	2598	0	51.0	40.4	-0.6	297	0.00
	Chandigarh	223	0	4.1	4.0	0.1	25	0.00
	Railways_NR ISTS	221	0	4.7	3.9	0.8	79	0.00
WR	Chhattisgarh	5063	0	111.7	54.8	-0.2	300	0.00
	Gujarat	20651	0	436.4	220.7	-4.3	968	0.00
	MP	12685	0	260.1	156.9	0.0	545	0.00
	Maharashtra	26840	0	585.7	208.2	-1.7	1057	0.00
	Goa	750	0	15.6	12.9	2.2	46	0.00
	DNHDDPDCL	1347	0	31.3	31.0	0.3	73	0.00
	AMNSIL	831	0	18.6	11.7	0.0	286	0.00
	BALCO	535	0	12.8	13.4	-0.6	0	0.00
	RIL JAMNAGAR	214	0	5.0	5.1	-0.1	0	0.00
	Andhra Pradesh	9049	0	203.7	60.9	-0.1	736	0.00
SR	Telangana	12525	0	242.4	92.7	-1.4	434	0.00
	Karnataka	12280	0	238.0	70.1	1.6	1421	0.00
	Kerala	4287	0	84.9	49.6	0.1	612	0.00
	Tamil Nadu	15277	0	320.2	186.4	-2.9	594	0.00
	Puducherry	409	0	9.2	8.8	-0.2	41	0.00
	Bihar	6628	0	133.6	122.1	0.3	167	0.00
ER	DVC	3125	0	68.3	-35.5	0.8	299	0.00
	Jharkhand	2187	0	43.1	32.2	0.7	374	0.00
	Odisha	5698	0	117.8	43.5	-1.6	523	0.00
	West Bengal	10443	0	217.3	73.4	-0.7	264	0.00
	Sikkim	74	0	1.2	1.3	-0.1	15	0.00
	Railways_ER ISTS	5	0	0.1	0.1	0.0	4	0.00
NER	Arunachal Pradesh	174	0	3.1	3.0	-0.3	22	0.00
	Assam	2251	0	39.5	38.2	-4.4	111	0.00
	Manipur	225	0	3.2	3.0	0.2	40	0.00
	Meghalaya	335	0	5.8	3.1	0.0	17	0.00
	Mizoram	115	0	1.9	1.4	-0.3	11	0.00
	Nagaland	186	0	3.1	2.8	0.0	10	0.00
	Tripura	333	0	6.7	6.2	0.0	25	0.00

D. Transnational Exchanges (MU) - Import(+ve)/Export(-ve)

	Bhutan	Nepal	Bangladesh	Godda -> Bangladesh
Actual (MU)	28.6	23.4	-23.6	-31.1
Day Peak (MW)	1335.3	1085.2	-1017.1	-1477.5

E. Import/Export by Regions (in MU) - Import(+ve)/Export(-ve); OD(+)/UD(-)

	NR	WR	SR	ER	NER	TOTAL
Schedule(MU)	192.7	-158.7	95.0	-141.9	12.8	0.0
Actual(MU)	174.7	-142.4	104.4	-152.4	15.0	-0.7
O/D/U/D(MU)	-18.0	16.2	9.4	-10.5	2.2	-0.7

F. Generation Outage(MW)

	NR	WR	SR	ER	NER	TOTAL	% Share
Central Sector	7069	13081	7628	3030	315	31122	47
State Sector	9694	13937	8853	2617	179	35279	53
Total	16763	27017	16481	5647	494	66401	100

G. Sourcewise generation (Gross) (MU)

	NR	WR	SR	ER	NER	All India	% Share
Coal	711	1390	611	705	12	3430	71
Lignite	27	16	51	0	0	93	2
Hydro	208	41	153	77	29	508	10
Nuclear	26	65	65	0	0	156	3
Gas, Naptha & Diesel	5	19	5	0	19	48	1
RES (Wind, Solar, Biomass & Others)	216	204	193	6	1	620	13
Total	1193	1734	1077	789	62	4855	100

Share of RES in total generation (%)	18.09	11.78	17.90	0.76	1.87	12.77
Share of Non-fossil fuel (Hydro,Nuclear and RES) in total generation(%)	37.66	17.88	38.14	10.57	48.87	26.45

H. All India Demand Diversity Factor

Based on Regional Max Demands	1.028
Based on State Max Demands	1.062

I. All India Peak Demand and shortage at Solar and Non-Solar Hour

	Max Demand Met(MW)	Time	Shortage(MW)
Solar hr	204017	10:14	0
Non-Solar hr	204435	18:31	0

Diversity factor = Sum of regional or state maximum demands / All India maximum demand

**Note: All generation MU figures are gross

***Godda (Jharkhand) -> Bangladesh power exchange is through the radial connection (isolated from Indian Grid)

Solar Hours -> 06:00 to 18:00hrs and rest are Non-Solar Hours

*Source: RLDCs for solar connected to ISTS; SLDCs for embedded solar. Limited visibility of embedded solar data.

Executive Director-NLDC

INTER-REGIONAL EXCHANGES

Import=(+ve)/Export =(-ve) for NET (MU)
Date of Reporting: 19-Oct-2025

Sl No	Voltage Level		Line Details	No. of Circuit	Max Import (MW)	Max Export (MW)	Import (MU)	Export (MU)	NET (MU)
Import/Export of ER (With NR)									
1		HVDC	ALIPURDUAR-AGRA	2	0	311	0.0	7.5	-7.5
2		HVDC	PUSAULI B/B	-	0	47	0.0	2.6	-2.6
3		765 kV	GAYA-VARANASI	2	498	1185	0.0	13.4	-13.4
4		765 kV	SASARAM-FATEHPUR	1	211	513	0.0	5.3	-5.3
5		765 kV	GAYA-BALIA	1	0	670	0.0	10.4	-10.4
6		400 kV	PUSAULI-VARANASI	1	0	134	0.0	2.1	-2.1
7		400 kV	PUSAULI -ALLAHABAD	1	34	44	0.0	0.2	-0.2
8		400 kV	MUZAFFARPUR-GORAKHPUR	2	41	831	0.0	10.2	-10.2
9		400 kV	PATNA-BALIA	2	195	667	0.0	7.3	-7.3
10		400 kV	NAUBATPUR-BALIA	2	68	331	0.0	1.8	-1.8
11		400 kV	BIHARSHARIFF-BALIA	2	374	178	0.9	0.0	0.9
12		400 kV	MOTIHARI-GORAKHPUR	2	12	521	0.0	7.0	-7.0
13		400 kV	BIHARSARIEF SAHUPURI	2	217	384	0.0	3.3	-3.3
14		220 kV	SAHUPURI-KARAMANASA	1	0	51	0.0	1.2	-1.2
15		132 kV	NAGAR UNTARI-RIHAND	1	0	0	0.0	0.0	0.0
16		132 kV	GARWAH-RIHAND	1	30	0	0.7	0.0	0.7
17		132 kV	KARMANASA-SAHUPURI	1	0	0	0.0	0.0	0.0
18		132 kV	KARMANASA-CHANDAULI	1	0	0	0.0	0.0	0.0
ER-NR						1.6	72.2	-70.6	
Import/Export of ER (With WR)									
1		765 kV	JHARSUGUDA-DHARAMJAIGARH	4	734	760	0.0	5.1	-5.1
2		765 kV	NEW RANCHI-DHARAMJAIGARH	2	1212	973	5.6	0.0	5.6
3		765 kV	JHARSUGUDA-DURG	2	0	698	0.0	10.7	-10.7
4		400 kV	JHARSUGUDA-RAIGARH	4	478	214	2.0	0.0	2.0
5		400 kV	RANCHI-SIPAT	2	290	305	1.1	0.0	1.1
6		400 kV	JEYPORE-JAGDALPUR	2	183	387	0.0	2.9	-2.9
7		220 kV	BUDHIPADAR-RAIGARH	1	59	130	0.0	1.2	-1.2
8		220 kV	BUDHIPADAR-KORBA	2	115	89	0.3	0.0	0.3
ER-WR						9.0	20.0	-11.0	
Import/Export of ER (With SR)									
1		HVDC	JEYPORE-GAZUWAKA B/B	2	0	56	0.0	1.3	-1.3
2		HVDC	TALCHER-KOLAR BIPOLE	2	0	1622	0.0	43.9	-43.9
3		765 kV	ANGUL-SRIKAKULAM	2	0	2867	0.0	48.2	-48.2
4		400 kV	TALCHER-I/C	2	383	966	0.0	3.1	-3.1
5		220 kV	BALIMELA-UPPER-SILERRU	1	0	0	0.0	0.0	0.0
ER-SR						0.0	93.3	-93.3	
Import/Export of ER (With NER)									
1		400 kV	BINAGURI-BONGAIGAON	2	0	498	0.0	6.6	-6.6
2		400 kV	ALIPURDUAR-BONGAIGAON	2	0	841	0.0	11.8	-11.8
3		220 kV	ALIPURDUAR-SALAKATI	2	0	151	0.0	2.2	-2.2
ER-NER						0.0	20.6	-20.6	
Import/Export of NER (With NR)									
1		HVDC	BISWANATH CHARIALI-AGRA	2	0	403	0.0	5.6	-5.6
NER-NR						0.0	5.6	-5.6	
Import/Export of WR (With NR)									
1		HVDC	CHAMPA-KURUKSHETRA	2	0	2013	0.0	48.6	-48.6
2		HVDC	VINDHYACHAL B/B	-	94	0	2.4	0.0	2.4
3		HVDC	MUNDRA-MOHINDERGARH	2	0	983	0.0	24.1	-24.1
4		765 kV	GWALIOR-AGRA	2	0	1253	0.0	16.3	-16.3
5		765 kV	GWALIOR-PHAGI	2	1062	1828	3.8	23.6	-19.8
6		765 kV	JABALPUR-ORAI	2	113	888	0.0	22.6	-22.6
7		765 kV	GWALIOR-ORAI	1	699	0	11.4	0.0	11.4
8		765 kV	SATNA-ORAI	1	0	949	0.0	16.8	-16.8
9		765 kV	BANASKANTHA-CHITORGARH	2	2629	0	35.2	0.0	35.2
10		765 kV	VINDHYACHAL-VARANASI	2	0	1494	0.0	24.9	-24.9
11		400 kV	ZERDA-KANKROLI	1	468	0	7.9	0.0	7.9
12		400 kV	ZERDA -BHINMAL	1	322	0	5.4	0.0	5.4
13		400 kV	VINDHYACHAL -RIHAND	1	0	1	0.0	0.0	0.0
14		400 kV	RAPP-SHUJALPUR	2	752	215	5.0	1.0	4.0
15		400 kV	NEEMUCH-Chittorgarh	2	746	305	4.7	2.3	2.3
16		220 kV	BHANPURA-RANPUR	1	0	128	0.0	2.2	-2.2
17		220 kV	BHANPURA-MORAK	1	0	30	0.0	1.5	-1.5
18		220 kV	MEHGAON-AURAIYA	1	104	0	0.8	0.0	0.8
19		220 kV	MALANPUR-AURAIYA	1	79	10	0.5	0.0	0.5
20		132 kV	RAIGHAT-LALITPUR	2	0	0	0.0	0.0	0.0
WR-NR						77.1	183.8	-106.7	
Import/Export of WR (With SR)									
1		HVDC	BHADRAWATI B/B	-	0	307	0.0	7.2	-7.2
2		HVDC	RAIGARH-PUGALUR	2	0	2004	0.0	40.7	-40.7
3		765 kV	SOLAPUR-RAICHUR	2	1322	605	14.4	1.1	13.3
4		765 kV	WARDHA-NIZAMABAD	2	0	2182	0.0	22.0	-22.0
5		765 kV	WARORA-WARANGAL(NEW)	2	0	2406	0.0	28.3	-28.3
6		400 kV	KOLHAPUR-KUDGI	2	2147	0	35.8	0.0	35.8
7		220 kV	KOLHAPUR-CHIKODI	2	0	0	0.0	0.0	0.0
8		220 kV	PONDA-AMBEWADI	1	0	0	0.0	0.0	0.0
9		220 kV	XELDEM-AMBEWADI	1	0	112	2.2	0.0	2.2
WR-SR						52.4	99.2	-46.8	
INTERNATIONAL EXCHANGES									
State	Region	Line Name	Max (MW)	Min (MW)	Avg (MW)	Energy Exchange (MU)			
BHUTAN	ER	400kV MANGDECHHU-ALIPURDUAR 1,2&3 I.e. ALIPURDUAR RECEIPT (from MANGDECHU HEP 4*180MW)	809	580	693	16.64			
	ER	400kV TALA-BINAGURI 1,2,4 (& 400kV MALBASE - BINAGURI) I.e. BINAGURI RECEIPT (from TALA HEP 6*170MW)	549	426	482	11.56			
	ER	220kV CHUKHA-BIRPARA 1&2 (& 220kV MALBASE - BIRPARA) I.e. BIRPARA RECEIPT (from CHUKHA HEP 4*84MW)	37	-26	8	0.19			
	NER	132kV GELEPHU-SALAKATI	-26	-4	-15	-0.35			
	NER	132kV MOTANGA-RANGIA	53	0	23	0.56			
NEPAL	NR	NEPAL IMPORT (FROM UP)	0		0	0.00			
	NR	132kV MAHENDRANAGAR-TANAKPUR(NHPC)	70	0	58	1.40			
	ER	NEPAL IMPORT (FROM BIHAR)	193	133	163	3.90			
	ER	400kV DHALKEBAR-MUZAFFARPUR 1&2	827	656	753	18.07			
BANGLADESH	ER	BHERAMARA B/B HVDC (B'DESH)	-932	-922	-931	-22.34			
	ER (Isolated from Indian Grid)	400kV GODDA_TPS-RAHANPUR (B'DESH) D/C	-1477	-958	-1295	-31.08			
	NER	132kV COMILLA-SURAJMANI NAGAR 1&2	-97	0	-51	-1.22			

CROSS BORDER EXCHANGE SCHEDULE

Date of Reporting: 19-Oct-2025

Export From India (in MU)

Country	GNA (ISGS/PPA)	T-GNA							TOTAL
		BILATERAL TOTAL	COLLECTIVE						
			IDAM			RTM			
			IEX	PXIL	HPX	IEX	PXIL	HPX	
Bhutan	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Nepal	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Bangladesh	23.16	0.06	0.00	0.00	0.00	0.00	0.00	0.00	23.22
Myanmar	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total Export	23.16	0.06	0.00	0.00	0.00	0.00	0.00	0.00	23.22

Import by India(in MU)

Country	GNA (ISGA/PPA)	T-GNA							TOTAL	
		BILATERAL TOTAL	COLLECTIVE							
			IDAM			RTM				
			IEX	PXIL	HPX	IEX	PXIL	HPX		
Bhutan	11.87	0.00	1.62	0.00	0.00	0.00	0.00	0.00	13.49	
Nepal	9.21	4.66	5.85	0.00	0.00	0.00	3.04	0.00	0.00	22.76
Bangladesh	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Myanmar	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total Import	21.08	4.66	7.47	0.00	0.00	0.00	3.04	0.00	0.00	36.25

Net from India(in MU)

-ve : Export / +ve : Import

Country	GNA (ISGS/PPA)	T-GNA							TOTAL	
		BILATERAL TOTAL	COLLECTIVE							
			IDAM			RTM				
			IEX	PXIL	HPX	IEX	PXIL	HPX		
Bhutan	11.87	0.00	1.62	0.00	0.00	0.00	0.00	0.00	13.49	
Nepal	9.21	4.66	5.85	0.00	0.00	0.00	3.04	0.00	0.00	22.76
Bangladesh	-23.16	-0.06	0.00	0.00	0.00	0.00	0.00	0.00	0.00	-23.22
Myanmar	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total Net	-2.08	4.60	7.47	0.00	0.00	0.00	3.04	0.00	0.00	13.03

15 Min (INSTANTANEOUS) ALL INDIA GRID FREQUENCY, GENERATION & DEMAND MET (SCADA DATA)												
TIME	FREQUENCY (Hz)	DEMAND MET (MW)	NUCLEAR (MW)	WIND (MW)	SOLAR (MW)	HYDRO** (MW)	GAS (MW)	THERMAL (MW)	OTHERS* (MW)	NET DEMAND (MW)	TOTAL GENERATION (MW)	NET TRANSNATIONAL EXCHANGE (MW)
		(A)	(B)	(C)	(D)	(E)	(F)	(G)	(H)	(I=A-(C+D))	(J=B+C+D+E+F+G+H)	(K)
0:00	50.06	175319	5870	5855	0	206886	1703	141304	1940	169464	177358	1046
0:15	50.01	174401	5902	5843	0	19097	1744	141672	1873	168558	176131	1064
0:30	49.96	172739	5901	5783	0	18769	1739	140443	1874	166956	174509	1058
0:45	49.96	171798	5896	5682	0	18529	1731	139861	1827	166116	173526	1151
1:00	49.96	170483	5898	5567	0	18527	1732	138658	1848	164916	172230	1178
1:15	49.96	168930	5901	5352	0	17794	1733	138168	1909	163578	170857	1100
1:30	49.96	168295	5885	5167	0	17378	1732	138300	1828	163128	170290	1111
1:45	50.01	167772	5891	5119	0	17183	1723	138158	1812	162653	169886	1124
2:00	50.01	166418	5905	5158	0	16863	1739	136943	1822	161260	168430	1119
2:15	49.96	166049	5901	5170	0	16457	1742	136878	1827	160879	167975	1103
2:30	49.96	166087	5905	5224	0	16480	1734	137033	1833	160863	168209	1119
2:45	49.95	165523	5903	5198	0	16599	1738	136308	1823	160325	167569	1127
3:00	49.95	165072	5892	5115	0	16378	1748	136191	1843	159957	167167	1124
3:15	50.00	164570	5901	5163	0	16554	1778	135414	1894	159407	166704	1232
3:30	50.00	164202	5901	5327	0	16610	1782	134945	1800	158875	166365	1249
3:45	50.00	164459	5891	5366	0	16441	1775	135117	1798	159093	166388	1226
4:00	50.00	164462	5902	5390	0	16487	1783	134942	1875	159072	166379	1224
4:15	50.00	165162	5886	5381	0	16676	1752	135718	1841	159781	167254	1271
4:30	50.05	165382	5900	5435	0	16699	1752	135742	1832	159947	167360	1263
4:45	50.05	166573	5908	5414	0	16971	1757	136802	1799	161159	168651	1267
5:00	50.06	168278	5903	5455	35	17550	1751	137824	1731	162788	170249	1271
5:15	50.06	171484	5889	5520	33	18180	1760	140344	1817	165931	173543	1262
5:30	50.06	174003	5901	5545	37	18926	1759	142080	1735	168421	175983	1267
5:45	50.06	176538	5883	5679	33	20456	1744	143115	1717	170826	178627	1280
6:00	50.11	178184	5893	5694	17	21787	1744	143436	1721	172473	180292	1302
6:15	50.11	180298	5893	5748	101	22680	1718	144787	1727	174449	182654	1156
6:30	50.01	184461	5910	5775	414	23943	1729	147125	1811	178272	186707	1154
6:45	50.01	186667	5906	5689	1315	24410	1728	147857	1736	179663	188641	1124
7:00	49.96	187498	5905	5482	3189	24941	1734	146236	1758	178827	189245	1088
7:15	49.96	189132	5898	5338	6330	25039	1759	145026	1798	177464	191188	1157
7:30	50.01	190976	5888	5223	10801	24371	1819	142353	1800	174952	192255	1153
7:45	50.01	191172	5904	5039	16072	22288	1881	139338	1786	170061	192308	1179
8:00	50.01	190189	5899	4889	21781	20079	1861	134743	1883	163519	191135	1146
8:15	49.96	192244	5898	4723	28058	18738	1873	132396	1839	159463	193525	1150
8:30	49.91	194485	5895	4635	34048	17462	1780	129806	1900	155802	195526	1161
8:45	49.99	195954	5876	4504	39445	17305	1776	125852	1975	152005	196733	1146
9:00	50.09	197177	5865	4348	44420	16892	1768	122783	1971	148409	198047	1171
9:15	49.99	200471	5864	4207	48619	16063	1763	122826	1991	147645	201333	1140
9:30	49.99	201689	5886	4196	52760	15474	1770	120706	1977	144733	202769	1116
9:45	50.04	202617	5866	4185	55633	15027	1777	119284	1988	142799	203760	1134
10:00	49.98	203137	5847	4343	57488	15062	1768	117850	1997	141306	204355	1136
10:15	49.98	203908	5857	4520	59229	15408	1749	115945	2006	140159	204714	1098
10:30	49.93	203555	5847	4614	60433	15315	1769	114538	2011	138508	204527	1040
10:45	49.83	203147	5849	4655	60772	14630	1771	114317	2039	137720	204033	1059
11:00	49.93	203542	5853	4705	62034	14691	1757	113231	2035	136803	204306	1074
11:15	49.98	202366	5868	4685	63168	13798	1775	111978	2051	134513	203323	1096
11:30	50.03	202523	5854	4631	64050	14033	1755	111106	2039	133842	203468	1046
11:45	49.88	202638	5858	4482	63766	14309	1754	111212	2110	134390	203491	1039
12:00	49.98	202285	5850	4394	64147	14706	1760	110134	2061	133744	203052	1102
12:15	49.93	201686	5848	4363	63869	14550	1757	110085	2037	133454	202509	1088
12:30	49.93	201437	5858	4228	63390	14870	1757	109965	2069	133819	202137	1116
12:45	49.83	199725	5844	4068	61445	15140	1761	110321	2041	134212	200620	1054
13:00	49.93	198789	5837	3992	61418	15353	1739	109197	2039	133379	199575	1107
13:15	49.93	195814	5846	3994	60525	14744	1729	107691	2103	131295	196632	1125
13:30	49.93	196481	5844	3957	59818	15049	1732	108652	2032	132706	197084	1091
13:45	49.88	197211	5862	3823	58840	15548	1748	110203	1918	134548	197942	1029
14:00	49.98	197803	5840	3781	57553	15571	1747	112091	1905	136469	198488	999
14:15	49.93	198580	5846	3660	55951	14775	1758	115438	1890	138969	199318	1000
14:30	49.93	200431	5841	3630	54368	14883	1752	119162	1883	142433	201519	971
14:45	49.98	201362	5857	3476	52761	14914	1780	121691	1901	145125	202380	1035
15:00	50.03	201537	5843	3381	50570	14859	1783	124270	1865	147586	202571	1056
15:15	50.03	201246	5858	3293	48259	14621	1822	126654	1840	149694	202347	1062
15:30	50.03	201261	5858	3318	45065	15149	1996	129125	1831	152878	202342	1037
15:45	50.03	200902	5850	3399	41170	15363	2170	132156	1865	156333	201973	1074
16:00	50.02	199904	5847	3525	36554	15881	2501	134189	1856	159825	200353	1075
16:15	49.97	197232	5862	3557	32146	16701	2754	135330	1811	161529	198161	1092
16:30	49.92	196047	5850	3616	27557	17532	2776	138225	1807	164874	197363	1089
16:45	49.97	195016	5861	3680	21201	18737	3078	141609	1875	170135	196041	1065
17:00	50.07	195390	5852	3905	15585	20703	3012	145719	1811	175900	196587	1000
17:15	49.97	193568	5862	3909	10670	22202	3139	147387	1969	178989	195138	979
17:30	50.02	195825	5855	3790	6341	24141	3485	152402	1892	185694	197906	870
17:45	49.97	197880	5870	3680	3151	26831	3634	155165	1929	191049	200260	855
18:00	49.92	200235	5856	3494	1029	29186	3694	157341	1930	195712	202530	785
18:15	49.87	202370	5844	3300	308	31335	3782	157918	1901	198762	204388	797
18:30	50.02	204099	5851	3362	118	33431	3859	157841	1875	200619	206337	804
18:45	49.97	203625	5863	3398	79	34214	2582	157640	1905	200148	205681	846
19:00	50.02	201638	5874	3472	89	33967	2127	156341	1881	198077	203751	836
19:15	50.02	200130	5862	3676	94	33394	2089	155038	1904	196360	202057	852
19:30	49.97	198738	5860	3736	0	33261	1999	153572	1956	195002	200384	921
19:45	50.02	197399	5875	3874	0	32531	1936	152986	1914	193525	199116	902
20:00	50.02	194956	5871	4043	0	32099	1833	150987	1923	190913	196756	914
20:15	49.97	192800	5871	4108	0	30776	1736	150126	1948	188692	194565	880
20:30	49.96	191237	5867	4146	0	28341	1686	151011	1926	187091	192977	850
20:45	49.86	189940	5875	4195	0	27043	1717	150961	1912	185745	191703	895
21:00	50.01	188836	5868	4185	0	26191	1690	150814	1972	184651	190720	917
21:15	50.01	187419	5884	3943	0	24954	1682	150636	1976	183476	189075	968
21:30	50.01	185808	5875	3846	0	24224	1698	150177	1865	181962	187685	988
21:45	50.01	185026	5890	3833	0	23744	1701	149777	1874	181193	186819	994
22:00	50.06	183191	5890	3745	0	22960	1696	149025	1899	179446	185215	1007
22:15	50.01	183184	5892	3720	0	22437	1696	149533	1926	179464	185204	980
22:30	49.96	182642	5878	3891	0	22447	1697	148685	1870	178751		