



National Load Despatch Centre
राष्ट्रीय भार प्रेषण केंद्र
GRID CONTROLLER OF INDIA LIMITED
ग्रिड कंट्रोलर ऑफ इंडिया लिमिटेड

(Government of India Enterprise/ भारत सरकार का उद्यम)
B-9, QUTUB INSTITUTIONAL AREA, KATWARIA SARAI, NEW DELHI -110016
बी-9, कुतुब इंस्टीट्यूशनल एरिया, कटवारिया सराये, न्यू दिल्ली-110016

Ref: GRID-INDIA/NLDC/SO/Daily PSP Report

दिनांक: 28.12.2024

To,

- कार्यकारी निदेशक, पू.क्षे.भा.प्रे.के., 14, गोल्फ क्लब रोड, कोलकाता - 700033
Executive Director, ERLDC, 14 Golf Club Road, Tollygunge, Kolkata, 700033
- कार्यकारी निदेशक, ऊ.क्षे.भा.प्रे.के., 18/ए, शाहीद जीत सिंह सनसनवाल मार्ग, नई दिल्ली - 110016
Executive Director, NRLDC, 18-A, Shaheed Jeet Singh Marg, Katwaria Sarai, New Delhi - 110016
- कार्यकारी निदेशक, प.क्षे.भा.प्रे.के., एफ3, एम आई डी सी क्षेत्र, अंधेरी, मुंबई - 400093
Executive Director, WRLDC, F-3, M.I.D.C. Area, Marol, Andheri (East), Mumbai-400093
- कार्यकारी निदेशक, ऊ.पू.क्षे.भा.प्रे.के., डोंगतेह, लोअर नोंग्रह, लापालंग, शिलोंग - 793006
Executive Director, NERLDC, Dongteih, Lower Nongrah, Lapalang, Shillong - 793006, Meghalaya
- कार्यकारी निदेशक, द.क्षे.भा.प्रे.के., 29, रेस कोर्स क्रॉस रोड, बंगलुरु - 560009
Executive Director, SRLDC, 29, Race Course Cross Road, Bangalore-560009

Sub: Daily PSP Report for the date 27.12.2024.

महोदय/Dear Sir,

आईईजीसी-2023 की धारा स.-38(1) के प्रावधान के अनुसार, दिनांक 27-दिसंबर-2024 की अखिल भारतीय प्रणाली की दैनिक ग्रिड निष्पादन रिपोर्ट रांभांप्रेके की वेबसाइट पर उपलब्ध है।

As per article 38(1) of the Indian Electricity Grid Code, the daily report pertaining power supply position of All India Power System for the date 27.12.2024, is available at the NLDC website.

धन्यवाद,
Thanks

Report for previous day

Date of Reporting: 28-Dec-2024

A. Power Supply Position at All India and Regional level

	NR	WR	SR	ER	NER	TOTAL
Demand Met during Evening Peak hrs(MW) (at 19:00 hrs; from RLDCs)	50883	60702	43956	21730	2744	180015
Peak Shortage (MW)	0	0	0	0	0	0
Energy Met (MU)	1120	1486	1098	440	49	4193
Hydro Gen (MU)	104	39	74	14	12	244
Wind Gen (MU)	34	128	75	-	-	237
Solar Gen (MU)*	79.08	62.39	76.81	3.05	1.07	222
Energy Shortage (MU)	0.00	0.00	0.00	0.00	0.00	0.00
Maximum Demand Met During the Day (MW) (From NLDC SCADA)	59193	74722	54481	22867	2861	210819
Time Of Maximum Demand Met	10:26	10:29	09:36	17:47	17:34	09:55

B. Frequency Profile (%)

Region	FVI	< 49.7	49.7 - 49.8	49.8 - 49.9	< 49.9	49.9 - 50.05	> 50.05
All India	0.029	0.00	0.00	0.27	0.27	73.78	25.96

C. Power Supply Position in States

Region	States	Max.Demand Met during the day (MW)	Shortage during maximum Demand (MW)	Energy Met (MU)	Drawal Schedule (MU)	OD(+)/UD(-) (MU)	Max OD (MW)	Energy Shortage (MU)
NR	Punjab	7053	0	136.6	57.5	0.1	386	0.00
	Haryana	6128	0	127.4	82.2	-5.5	354	0.00
	Rajasthan	16244	0	280.7	89.9	-8.0	533	0.00
	Delhi	4722	0	80.1	78.8	-1.1	383	0.00
	UP	18547	0	335.0	92.5	-1.5	330	0.00
	Uttarakhand	2504	0	46.5	37.0	-0.7	103	0.00
	HP	2200	0	40.1	33.9	-0.8	417	0.00
	J&K(UT) & Ladakh(UT)	3096	0	65.5	63.2	-2.0	107	0.00
	Chandigarh	273	0	4.6	4.7	-0.1	34	0.00
WR	Railways_NR ISTS	204	0	4.1	3.8	0.2	37	0.00
	Chhattisgarh	5108	0	106.9	58.2	0.4	259	0.00
	Gujarat	21920	0	414.1	191.2	-3.0	513	0.00
	MP	17902	0	326.1	207.7	-5.7	439	0.00
	Maharashtra	27396	0	562.4	197.3	0.2	381	0.00
	Goa	749	0	15.3	14.3	0.4	121	0.00
	DNHDDPDCL	1312	0	30.5	30.4	0.1	22	0.00
	AMNSIL	776	0	15.8	4.7	0.9	357	0.00
	BALCO	531	0	12.7	12.7	0.0	11	0.00
SR	RIL JAMNAGAR	100	0	2.4	2.3	0.1	0	0.00
	Andhra Pradesh	8698	0	182.1	41.3	-1.6	475	0.00
	Telangana	13573	0	256.4	166.5	-0.6	659	0.00
	Karnataka	14422	0	246.1	83.8	-0.5	499	0.00
	Kerala	4385	0	86.3	70.4	1.7	321	0.00
	Tamil Nadu	15453	0	318.0	201.1	-5.9	412	0.00
	Puducherry	419	0	9.3	8.9	-0.3	48	0.00
ER	Bihar	5312	0	95.4	84.5	-1.1	191	0.00
	DVC	3247	0	69.7	-39.5	0.4	381	0.00
	Jharkhand	2036	0	38.2	27.8	-0.5	151	0.00
	Odisha	4830	0	92.4	26.4	-2.6	474	0.00
	West Bengal	7191	0	142.0	3.6	-2.0	195	0.00
	Sikkim	127	0	1.8	2.1	-0.3	28	0.00
	Railways_ER ISTS	20	0	0.2	0.2	0.0	0	0.00
NER	Arunachal Pradesh	186	0	2.9	2.8	0.0	60	0.00
	Assam	1567	0	26.9	20.2	-0.3	98	0.00
	Manipur	263	0	3.9	3.9	0.0	29	0.00
	Meghalaya	369	0	6.5	5.7	-0.2	92	0.00
	Mizoram	143	0	2.0	1.7	-0.3	5	0.00
	Nagaland	162	0	2.5	2.4	0.0	36	0.00
	Tripura	229	0	4.0	3.2	-0.2	38	0.00

D. Transnational Exchanges (MU) - Import(+ve)/Export(-ve)

	Bhutan	Nepal	Bangladesh	Godda -> Bangladesh
Actual (MU)	-6.8	-4.0	-20.3	-11.3
Day Peak (MW)	-601.8	-351.7	-998.0	-612.3

E. Import/Export by Regions (in MU) - Import(+ve)/Export(-ve); OD(+)/UD(-)

	NR	WR	SR	ER	NER	TOTAL
Schedule(MU)	207.9	-217.9	191.3	-188.4	7.1	0.0
Actual(MU)	195.7	-215.6	193.6	-190.1	5.9	-10.5
O/D/U/D(MU)	-12.2	2.4	2.3	-1.7	-1.2	-10.5

F. Generation Outage(MW)

	NR	WR	SR	ER	NER	TOTAL	% Share
Central Sector	5185	10731	5368	3358	518	25159	46
State Sector	8128	10827	8164	1909	161	29188	54
Total	13313	21557	13532	5267	679	54347	100

G. Sourcewise generation (Gross) (MU)

	NR	WR	SR	ER	NER	All India	% Share
Coal	704	1508	599	695	9	3516	77
Lignite	29	14	46	0	0	88	2
Hydro	104	39	74	14	12	244	5
Nuclear	31	54	70	0	0	155	3
Gas, Naptha & Diesel	5	15	6	0	24	51	1
RES (Wind, Solar, Biomass & Others)	139	195	180	5	1	520	11
Total	1012	1825	975	714	47	4574	100

Share of RES in total generation (%)	13.72	10.69	18.44	0.75	2.31	11.37
Share of Non-fossil fuel (Hydro,Nuclear and RES) in total generation(%)	27.10	15.81	33.21	2.65	28.47	20.09

H. All India Demand Diversity Factor

Based on Regional Max Demands	1.015
Based on State Max Demands	1.040

I. All India Peak Demand and shortage at Solar and Non-Solar Hour

	Max Demand Met(MW)	Time	Shortage(MW)
Solar hr	210819	9:55	0
Non-Solar hr	193325	18:29	0

Diversity factor = Sum of regional or state maximum demands / All India maximum demand

**Note: All generation MU figures are gross

***Godda (Jharkhand) -> Bangladesh power exchange is through the radial connection (isolated from Indian Grid)

Solar Hours -> 06:00 to 18:00hrs and rest are Non-Solar Hours

*Source: RLDCs for solar connected to ISTS; SLDCs for embedded solar. Limited visibility of embedded solar data.

Executive Director-NLDC

INTER-REGIONAL EXCHANGES								
Import=(+ve) /Export =(-ve) for NET (MU)								
Date of Reporting: 28-Dec-2024								
Sl No	Voltage Level	Line Details	No. of Circuit	Max Import (MW)	Max Export (MW)	Import (MU)	Export (MU)	NET (MU)
Import/Export of ER (With NR)								
1	HVDC	ALIPURDUAR-AGRA	2	0	0	0.0	0.0	0.0
2	HVDC	PUSAULI B/B	-	1	249	0.0	5.9	-5.9
3	765 kV	GAYA-VARANASI	2	0	944	0.0	12.8	-12.8
4	765 kV	SASARAM-FATEHPUR	1	0	529	0.0	8.1	-8.1
5	765 kV	GAYA-BALIA	1	0	752	0.0	12.5	-12.5
6	400 kV	PUSAULI-VARANASI	1	0	210	0.0	3.9	-3.9
7	400 kV	PUSAULI -ALLAHABAD	1	20	108	0.0	1.9	-1.9
8	400 kV	MUZAFFARPUR-GORAKHPUR	2	0	593	0.0	7.9	-7.9
9	400 kV	PATNA-BALIA	2	0	961	0.0	17.1	-17.1
10	400 kV	NAUBATPUR-BALIA	2	0	316	0.0	5.5	-5.5
11	400 kV	BIHARSHARIFF-BALIA	2	0	296	0.0	6.4	-6.4
12	400 kV	MOTIHARI-GORAKHPUR	2	0	502	0.0	7.9	-7.9
13	400 kV	BIHARSHARIFF-VARANASI	2	0	372	0.0	0.0	0.0
14	220 kV	SAHUPURI-KARAMNASA	1	0	70	0.0	0.8	-0.8
15	132 kV	NAGAR UNTARI-RIHAND	1	0	0	0.1	0.0	0.1
16	132 kV	GARWAH-RIHAND	1	30	0	0.5	0.0	0.5
17	132 kV	KARMANASA-SAHUPURI	1	0	0	0.0	0.0	0.0
18	132 kV	KARMANASA-CHANDAUJI	1	0	0	0.0	0.0	0.0
ER-NR						0.6	90.8	-90.2
Import/Export of ER (With WR)								
1	765 kV	JHARSUGUDA-DHARAMJAIGARH	4	324	640	0.0	4.2	-4.2
2	765 kV	NEW RANCHI-DHARAMJAIGARH	2	273	870	0.0	7.0	-7.0
3	765 kV	JHARSUGUDA-DURG	2	0	718	0.0	13.6	-13.6
4	400 kV	JHARSUGUDA-RAIGARH	4	0	704	0.0	11.9	-11.9
5	400 kV	RANCHI-SIPAT	2	56	356	0.0	3.8	-3.8
6	220 kV	BUDHIPADAR-RAIGARH	1	0	111	0.0	1.7	-1.7
7	220 kV	BUDHIPADAR-KORBA	2	39	167	0.0	1.6	-1.6
ER-WR						0.0	43.8	-43.8
Import/Export of ER (With SR)								
1	HVDC	JEYPORE-GAZUWAKA B/B	2	0	210	0.0	5.0	-5.0
2	HVDC	TALCHER-KOLAR BIPOLE	2	0	1999	0.0	46.5	-46.5
3	765 kV	ANGUL-SRIKAKULAM	2	0	2780	0.0	55.5	-55.5
4	400 kV	TALCHER-I/C	2	39	974	0.0	7.0	-7.0
5	220 kV	BALIMELA-UPPER-SILERRU	1	0	0	0.0	0.0	0.0
ER-SR						0.0	107.1	-107.1
Import/Export of ER (With NER)								
1	400 kV	BINAGURI-BONGAIGAON	2	304	109	2.1	0.1	2.0
2	400 kV	ALIPURDUAR-BONGAIGAON	2	642	32	6.0	0.0	6.0
3	220 kV	ALIPURDUAR-SALAKATI	2	108	5	1.2	0.0	1.2
ER-NER						9.2	0.1	9.1
Import/Export of NER (With NR)								
1	HVDC	BISWANATH CHARIALI-AGRA	2	660	0	15.7	0.0	15.7
NER-NR						15.7	0.0	15.7
Import/Export of WR (With NR)								
1	HVDC	CHAMPA-KURUKSHETRA	2	0	1516	0.0	33.1	-33.1
2	HVDC	VINDHYACHAL B/B	-	0	56	0.0	1.2	-1.2
3	HVDC	MUNDRA-MOHINDERGARH	2	0	1453	0.0	27.5	-27.5
4	765 kV	GWALIOR-AGRA	2	0	1566	0.0	19.2	-19.2
5	765 kV	GWALIOR-PHAGI	2	0	1622	0.0	19.4	-19.4
6	765 kV	JABALPUR-ORAI	2	0	799	0.0	21.6	-21.6
7	765 kV	GWALIOR-ORAI	1	839	94	13.0	0.0	12.9
8	765 kV	SATNA-ORAI	1	0	962	0.0	18.9	-18.9
9	765 kV	BANASKANTHA-CHITORGARH	2	943	649	5.3	5.6	-0.4
10	765 kV	VINDHYACHAL-VARANASI	2	0	2315	0.0	32.8	-32.8
11	400 kV	ZERDA-KANKROLI	1	254	54	1.7	0.1	1.6
12	400 kV	ZERDA -BHINMAL	1	175	38	1.2	0.1	1.1
13	400 kV	VINDHYACHAL -RIHAND	1	958	0	21.8	0.0	21.8
14	400 kV	RAPP-SHUJALPUR	2	396	147	3.6	0.2	3.4
15	400 kV	NEEMUCH-Chittorgarh	2	521	102	5.2	0.1	5.1
16	220 kV	BHANPURA-RANPUR	1	0	192	0.0	2.8	-2.8
17	220 kV	BHANPURA-MORAK	1	0	30	0.0	1.8	-1.8
18	220 kV	MEHGAON-AURAIYA	1	150	28	1.8	0.0	1.8
19	220 kV	MALANPUR-AURAIYA	1	114	36	1.0	0.0	1.0
20	132 kV	GWALIOR-SAWAI MADHOPUR	1	0	0	0.0	0.0	0.0
21	132 kV	RAJGHAT-LALITPUR	2	0	0	0.0	0.0	0.0
WR-NR						54.5	184.4	-129.9
Import/Export of WR (With SR)								
1	HVDC	BHADRAWATI B/B	-	0	1007	0.0	24.0	-24.0
2	HVDC	RAIGARH-PUGALUR	2	0	4006	0.0	62.7	-62.7
3	765 kV	SOLAPUR-RAICHUR	2	1248	1046	6.1	5.5	0.6
4	765 kV	WARDHA-NIZAMABAD	2	0	2198	0.0	34.7	-34.7
5	765 kV	WARORA-WARANGAL(NEW)	2	0	2265	0.0	36.8	-36.8
6	400 kV	KOLHAPUR-KUDGI	2	1796	0	26.9	0.0	26.9
7	220 kV	KOLHAPUR-CHIKODI	2	0	0	0.0	0.0	0.0
8	220 kV	PONDA-AMBEWADI	1	0	0	0.0	0.0	0.0
9	220 kV	XELDEM-AMBEWADI	1	1	128	1.2	0.0	1.2
WR-SR						34.3	163.7	-129.4
INTERNATIONAL EXCHANGES								
State	Region	Line Name	Max (MW)	Min (MW)	Avg (MW)	Import(+ve)/Export(-ve) Energy Exchange (MU)		
BHUTAN	ER	400kV MANGDECHHU-ALIPURDUAR 1,2&3 i.e. ALIPURDUAR RECEIPT (from MANGDECHU HEP 4*180MW)	-184	99	-44	-1.06		
	ER	400kV TALA-BINAGURI 1,2,4 (& 400kV MALBASE - BINAGURI) i.e. BINAGURI RECEIPT (from TALA HEP 6*170MW)	-244	203	-35	-0.85		
	ER	220kV CHUKHA-BIRPARA 1&2 (& 220kV MALBASE - BIRPARA) i.e. BIRPARA RECEIPT (from CHUKHA HEP 4*84MW)	-251	-90	-183	-4.38		
	NER	132kV GELEPHU-SALAKATI	-34	-7	-23	-0.56		
	NER	132kV MOTANGA-RANGIA	6	-9	0	0.00		
NEPAL	NR	NEPAL IMPORT (FROM UP)	-57	0	0	0.00		
	NR	132kV MAHENDRANAGAR-TANAKPUR(NHPC)	-57	0	-35	-0.84		
	ER	NEPAL IMPORT (FROM BIHAR)	-164	-34	-81	-1.95		
	ER	400kV DHALKEBAR-MUZAFFARPUR 1&2	-188	56	-50	-1.21		
BANGLADESH	ER	BHERAMARA B/B HVDC (B'DESH)	-941	-556	-806	-19.34		
	ER (Isolated from Indian Grid)	400kV GODDA_TPS-RAHANPUR (B'DESH) D/C	-612	-403	-469	-11.25		
	NER	132kV COMILLA-SURAJMANI NAGAR 1&2	-57	0	-39	-0.94		

CROSS BORDER EXCHANGE SCHEDULE

Date of Reporting: 28-Dec-2024

Export From India (in MU)

Country	GNA (ISGS/PPA)	T-GNA							TOTAL
		BILATERAL TOTAL	COLLECTIVE						
			IDAM			RTM			
			IEX	PXIL	HPX	IEX	PXIL	HPX	
Bhutan	0.00	0.00	7.13	0.00	0.00	1.04	0.00	0.00	8.17
Nepal	2.21	0.00	1.94	0.00	0.00	0.05	0.00	0.00	4.20
Bangladesh	20.16	0.00	0.00	0.00	0.00	0.00	0.00	0.00	20.16
Myanmar	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total Export	22.37	0.00	9.07	0.00	0.00	1.09	0.00	0.00	32.53

Import by India(in MU)

Country	GNA (ISGA/PPA)	T-GNA							TOTAL
		BILATERAL TOTAL	COLLECTIVE						
			IDAM			RTM			
			IEX	PXIL	HPX	IEX	PXIL	HPX	
Bhutan	0.59	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.59
Nepal	0.00	0.00	0.00	0.00	0.00	0.34	0.00	0.00	0.34
Bangladesh	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Myanmar	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total Import	0.59	0.00	0.00	0.00	0.00	0.34	0.00	0.00	0.93

Net from India(in MU)

-ve : Export / +ve : Import

Country	GNA (ISGS/PPA)	T-GNA							TOTAL
		BILATERAL TOTAL	COLLECTIVE						
			IDAM			RTM			
			IEX	PXIL	HPX	IEX	PXIL	HPX	
Bhutan	0.59	0.00	-7.13	0.00	0.00	-1.04	0.00	0.00	-7.58
Nepal	-2.21	0.00	-1.94	0.00	0.00	0.29	0.00	0.00	-3.86
Bangladesh	-20.16	0.00	0.00	0.00	0.00	0.00	0.00	0.00	-20.16
Myanmar	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total Net	-21.78	0.00	-9.07	0.00	0.00	-0.75	0.00	0.00	-31.60

Date of Reporting: 28-Dec-2024												
15 Min (INSTANTANEOUS) ALL INDIA GRID FREQUENCY, GENERATION & DEMAND MET (SCADA DATA)												
TIME	FREQUENCY (Hz)	DEMAND MET (MW)	NUCLEAR (MW)	WIND (MW)	SOLAR (MW)	HYDRO** (MW)	GAS (MW)	THERMAL (MW)	OTHERS* (MW)	NET DEMAND MET (MW)	TOTAL GENERATION (MW)	NET TRANSNATIONAL EXCHANGE (MW) (+ve) Import, (-ve) Export
		(A)	(B)	(C)	(D)	(E)	(F)	(G)	(H)	(I=A-(C+D))	(J=B+C+D+E+F+G+H)	(K)
0:00	50.02	150214	6077	11128	50	6914	1764	127529	3021	139036	156483	-1554
0:15	49.97	149313	6073	11092	50	5992	1794	127357	3039	138171	155397	-1287
0:30	50.02	148164	6076	11120	48	6024	1957	125761	3022	136996	154008	-1238
0:45	50.02	147709	6062	11155	48	6156	1942	125307	3025	136506	153695	-1259
1:00	50.07	146664	6073	11288	43	6093	1793	124173	3024	135333	152487	-1266
1:15	50.02	145609	6094	11384	47	5840	1776	123187	3048	134178	151376	-1261
1:30	50.02	145043	6088	11339	49	5739	1780	122581	3027	133655	150603	-1266
1:45	49.97	144239	6075	11375	46	5633	1935	121884	2983	132818	149931	-1240
2:00	50.02	143373	6071	11309	47	5647	1939	121101	3018	132017	149132	-1259
2:15	49.97	142949	6079	11261	42	5574	1938	120904	3028	131646	148826	-1280
2:30	49.97	142392	6078	11164	49	5671	1787	120369	3040	131179	148158	-1249
2:45	49.97	142068	6073	11213	43	5676	1779	119957	3031	130812	147772	-1117
3:00	49.97	141649	6073	11067	47	5785	1940	119596	3031	130535	147539	-1111
3:15	49.97	141470	6096	10931	49	5531	1794	119688	3050	130490	147139	-1069
3:30	49.97	141228	6080	10903	44	5703	1779	119324	3011	130281	146844	-1051
3:45	50.02	141527	6084	10880	49	5830	1784	119734	3040	130598	147401	-1086
4:00	50.07	141927	6077	10988	42	5686	1776	120003	3025	130897	147597	-1030
4:15	49.97	143841	6083	10985	45	5851	2001	122032	3081	132811	150078	-1045
4:30	50.02	145025	6075	10974	43	5746	1993	123441	3010	134008	151282	-1080
4:45	50.02	146959	6079	10959	45	5728	2006	125451	3004	135955	153272	-1150
5:00	50.02	149393	6078	10970	44	6030	2006	127487	3006	138379	155621	-1196
5:15	50.02	152693	6074	10717	46	6650	2020	129980	3024	141930	158511	-1165
5:30	50.02	157452	6071	10576	48	7367	2093	134122	3063	146828	163340	-1033
5:45	50.02	160753	6081	10394	45	8395	2249	136288	3030	150314	166482	-1049
6:00	50.17	163707	6074	10302	46	9351	2303	138086	3102	153359	169264	-954
6:15	50.07	167150	6073	10285	28	10439	2583	140195	3014	156837	172617	-1031
6:30	50.07	173138	6088	10444	100	13012	2827	143436	2987	162594	178894	-1010
6:45	50.02	177834	6091	10447	106	14234	2874	146743	3033	167281	183528	-1029
7:00	50.02	182669	6075	10459	300	15005	3123	150354	3024	171910	188340	-1004
7:15	50.07	188085	6081	10623	757	16411	3180	153698	3037	176705	193787	-1038
7:30	50.07	192160	6076	10685	1647	17403	3197	155863	3037	179828	197908	-1032
7:45	50.02	195005	6073	10612	2801	18052	3226	156628	3105	181592	200497	-1042
8:00	50.07	196141	6092	10596	4322	17860	3076	156413	3145	181223	201504	-1025
8:15	50.02	198526	6074	10549	6180	17030	3080	157563	3121	181797	203597	-998
8:30	50.02	200495	6071	10589	7862	16734	3238	158145	3138	182044	205777	-937
8:45	50.07	203553	6074	10685	10082	16569	3198	158565	3167	182786	208340	-899
9:00	50.02	204676	6057	10427	12304	15005	3038	159768	3155	181945	209754	-920
9:15	50.02	208325	6065	10103	15030	14760	3056	160951	3180	183192	213145	-917
9:30	50.02	210094	6061	9791	17690	13975	3326	160789	3221	182613	214853	-888
9:45	49.97	210378	6056	9505	18996	12999	2405	162072	3218	181877	215251	-959
10:00	50.02	210262	6067	9139	21657	12714	2039	160558	3233	179466	215407	-1046
10:15	49.92	209710	6051	8718	23981	11940	1921	159153	3184	177011	214948	-1040
10:30	50.02	209925	6058	8608	26065	11055	1930	158081	3183	175252	214980	-1044
10:45	49.97	208468	6069	8540	27840	10531	1941	155843	3297	172088	214061	-1433
11:00	50.07	208442	6047	8451	30158	10021	1954	154590	3231	169833	214452	-1634
11:15	50.02	207208	6068	8657	31641	9686	1970	151949	3227	166910	213198	-1731
11:30	50.02	207110	6043	8931	33643	9258	1903	150048	3230	164536	213056	-1735
11:45	50.02	206056	6076	9293	33947	9027	1916	148550	3208	162816	212017	-1729
12:00	50.02	204008	6050	9647	34453	8243	1898	146607	3226	159908	210124	-1747
12:15	50.02	201416	6058	9821	34315	7920	1880	144097	3206	157280	207297	-1689
12:30	49.97	199715	6054	9874	34933	7877	1872	141752	3195	154908	205557	-1686
12:45	50.02	198102	6043	9795	34295	8084	1863	140374	3272	154012	203726	-1845
13:00	50.02	194572	6046	9645	34597	8004	1849	138633	3171	150330	201945	-1864
13:15	50.02	190749	6060	9586	34805	8033	1838	135833	3218	146358	199373	-1871
13:30	50.02	189689	6052	9473	34871	8066	1853	135732	3216	145345	199263	-1853
13:45	50.02	188513	6050	9433	33189	8094	1852	135950	3245	145891	197813	-1908
14:00	50.02	187623	6032	9098	31824	7002	1844	134518	3238	146701	193556	-1894
14:15	50.02	187284	6032	8931	30755	7011	1876	135458	3225	147598	193288	-1729
14:30	50.07	187780	6038	8913	29988	6906	1884	137061	3177	148879	193967	-1803
14:45	50.12	187314	6044	8843	28319	6737	1896	138173	3131	150152	193143	-1808
15:00	50.07	186785	6040	8831	26117	7003	1883	139967	3150	151837	192991	-1785
15:15	50.07	186357	6058	8796	24457	7166	1903	140914	3129	153104	192423	-1687
15:30	50.02	186509	6042	8592	23097	7303	1877	142375	3131	154820	192417	-1702
15:45	50.02	186402	6048	8574	21123	7749	1906	144072	3074	156705	192546	-1723
16:00	50.02	185610	6029	8316	18372	8196	1903	145766	3092	158922	191674	-1715
16:15	50.02	184433	6051	8248	15796	8642	1954	146682	3066	160389	190439	-1752
16:30	49.97	184645	6037	8139	13052	9134	1952	149097	3044	163454	190455	-1582
16:45	49.92	184655	6041	7998	10222	9832	1971	150855	3018	166435	189937	-1346
17:00	50.02	184611	6048	7962	7386	11716	1959	151356	3020	169263	189447	-1131
17:15	49.97	185422	6058	7889	4849	13239	1960	152830	3034	172684	189859	-1084
17:30	50.02	188189	6030	7663	2759	16613	1942	154696	3071	177767	192774	-1037
17:45	50.07	190794	6057	7486	1283	19826	1964	155075	3043	182025	194734	-1029
18:00	50.07	191010	6051	7682	537	20706	1937	154969	3036	182791	194918	-1023
18:15	50.02	192433	6052	8075	254	20421	1967	156077	3070	184104	195916	-1000
18:30	50.07	193163	6048	8452	240	20639	1962	156332	3057	184471	196730	-998
18:45	50.07	191526	6060	8916	214	19600	1967	155459	3076	182396	195292	-983
19:00	50.13	188151	6068	9413	148	19188	1993	152092	3072	178590	191974	-1005
19:15	50.02	185390	6073	9948	141	17926	1943	150168	3049	175301	189248	-1000
19:30	50.07	182535	6067	10413	95	15709	1928	149179	3033	172027	186424	-1007
19:45	50.07	179591	6079	10894	100	14179	1978	146970	3089	168597	183289	-1026
20:00	50.02	175746	6070	11315	96	13234	1956	144157	3048	164335	179876	-1009
20:15	49.97	172662	6071	11596	84	12673	1929	142151	3031	160982	177535	-1013
20:30	50.02	169584	6080	11744	79	12365	1953	138492	3064	157761	173777	-1083
20:45	49.97	167430	6083	11956	59	11762	1903	139880	3048	155415	174691	-1204
21:00	50.02	164231	6055	12099	50	11208	1905	134777	3036	152082	169130	-1337
21:15	50.02	161563	6065	12221	46	10442	1900	133245	3045	149296	166964	-1618
21:30	49.97	158767	6082	12327	50	9934	1902	130696	3064	146390	164055	-1653
21:45	50.02	156250	6091	12296	47	9215	1882	128812	3092	143907	161435	-1635
22:00	50.07	153095	6087	12273	51	8766	1891	126274	3050	140771	158392	-1693
22:15	49.97	152193	6073	12052	48	8842	1930	125357	3094	140093	157396	-1651
22:30	49.99	150593	6083	12000								