



National Load Despatch Centre
राष्ट्रीय भार प्रेषण केंद्र
GRID CONTROLLER OF INDIA LIMITED
ग्रिड कंट्रोलर ऑफ इंडिया लिमिटेड

(Government of India Enterprise/ भारत सरकार का उद्यम)
B-9, QUTUB INSTITUTIONAL AREA, KATWARIA SARAI, NEW DELHI -110016
बी-9, कुतुब इन्स्टीट्यूशनल एरिया, कटवारिया सराये, न्यू दिल्ली-110016

Ref: GRID-INDIA/NLDC/SO/Daily PSP Report

दिनांक: 14.10.2025

To,

- कार्यकारी निदेशक, पू.क्षे.भा.प्रे.के., 14, गोल्फ क्लब रोड, कोलकाता - 700033
Executive Director, ERLDC, 14 Golf Club Road, Tollygunge, Kolkata, 700033
- कार्यकारी निदेशक, ऊ.क्षे.भा.प्रे.के., 18/ए, शाहीद जीत सिंह सनसनवाल मार्ग, नई दिल्ली - 110016
Executive Director, NRLDC, 18-A, Shaheed Jeet Singh Marg, Katwaria Sarai, New Delhi - 110016
- कार्यकारी निदेशक, प.क्षे.भा.प्रे.के., एफ3, एम आई डी सी क्षेत्र, अंधेरी, मुंबई -400093
Executive Director, WRLDC, F-3, M.I.D.C. Area, Marol, Andheri (East), Mumbai-400093
- कार्यकारी निदेशक, ऊ.पू.क्षे.भा.प्रे.के., डोंगतेह, लोअर नोंग्रह, लापालंग, शिलोंग - 793006
Executive Director, NERLDC, Dongteih, Lower Nongrah, Lapalang, Shillong - 793006, Meghalaya
- कार्यकारी निदेशक, द.क्षे.भा.प्रे.के., 29, रेस कोर्स क्रॉस रोड, बंगलुरु -560009
Executive Director, SRLDC, 29, Race Course Cross Road, Bangalore-560009

Sub: Daily PSP Report for the date 13.10.2025.

महोदय/Sir,

आईईजीसी-2023 की धारा स.-38(1) के प्रावधान के अनुसार, दिनांक 13-अक्टूबर-2025 की अखिल भारतीय प्रणाली की दैनिक ग्रिड निष्पादन रिपोर्ट रांभांप्रेके की वेबसाइट पर उपलब्ध है।

As per article 38(1) of the Indian Electricity Grid Code, the daily report pertaining power supply position of All India Power System for the date 13.10.2025, is available at the NLDC website.

धन्यवाद,
Thanks

Report for previous day

Date of Reporting: 14-Oct-2025

A. Power Supply Position at All India and Regional level

	NR	WR	SR	ER	NER	TOTAL
Demand Met during Evening Peak hrs(MW) (at 19:00 hrs; from RLDCs)	57539	65401	49006	26173	3471	201590
Peak Shortage (MW)	0	0	0	0	0	0
Energy Met (MU)	1226	1428	1115	569	65	4404
Hydro Gen (MU)	223	93	165	96	32	610
Wind Gen (MU)	3	39	35	-	-	77
Solar Gen (MU)*	193.03	150.30	127.99	3.38	1.03	476
Energy Shortage (MU)	0.00	0.00	0.00	0.00	0.00	0.00
Maximum Demand Met During the Day (MW) (From NLDC SCADA)	60894	67998	50834	27175	3640	209433
Time Of Maximum Demand Met	18:42	18:53	10:11	19:00	17:53	18:44

B. Frequency Profile (%)

Region	FVI	< 49.7	49.7 - 49.8	49.8 - 49.9	< 49.9	49.9 - 50.05	> 50.05
All India	0.041	0.46	1.44	4.28	6.18	77.77	16.05

C. Power Supply Position in States

Region	States	Max.Demand Met during the day (MW)	Shortage during maximum Demand (MW)	Energy Met (MU)	Drawal Schedule (MU)	OD(+)/UD(-) (MU)	Max OD (MW)	Energy Shortage (MU)
NR	Punjab	9700	0	181.5	84.8	-0.5	933	0.00
	Haryana	8947	0	180.1	152.8	0.7	310	0.00
	Rajasthan	11713	0	247.9	88.0	-1.2	1150	0.00
	Delhi	4511	0	90.5	88.4	-0.2	308	0.00
	UP	20761	0	394.0	125.7	0.6	545	0.00
	Uttarakhand	2245	0	40.7	24.4	0.8	119	0.00
	HP	1753	0	31.5	8.6	-0.3	80	0.00
	J&K(UT) & Ladakh(UT)	2660	0	51.0	38.4	0.5	417	0.00
	Chandigarh	229	0	4.2	4.1	0.1	21	0.00
	Railways_NR ISTS	213	0	4.4	3.8	0.6	77	0.00
WR	Chhattisgarh	5185	0	108.6	51.9	-0.7	324	0.00
	Gujarat	20950	0	439.3	217.2	-1.0	856	0.00
	MP	11906	0	242.3	142.3	0.0	559	0.00
	Maharashtra	26554	0	554.3	201.1	-0.8	702	0.00
	Goa	751	0	15.0	12.6	1.9	34	0.00
	DNHDDPDCL	1375	0	30.9	30.8	0.1	83	0.00
	AMNSIL	890	0	18.0	11.6	-0.1	277	0.00
	BALCO	559	0	13.4	13.4	0.0	9	0.00
	RIL JAMNAGAR	254	0	6.0	6.0	0.0	0	0.00
	Andhra Pradesh	9036	0	204.8	56.2	-0.8	636	0.00
SR	Telangana	11781	0	224.2	95.2	-1.9	553	0.00
	Karnataka	11958	0	238.9	61.5	-1.0	727	0.00
	Kerala	4535	0	87.4	57.6	0.3	441	0.00
	Tamil Nadu	16981	0	350.4	213.4	-0.1	1168	0.00
	Puducherry	441	0	9.6	9.3	-0.2	61	0.00
	Bihar	6531	0	129.8	120.2	-0.4	297	0.00
ER	DVC	3184	0	66.8	-30.5	-0.2	486	0.00
	Jharkhand	2116	0	42.5	30.6	-0.5	301	0.00
	Odisha	5973	0	119.7	39.8	-0.5	361	0.00
	West Bengal	9914	0	209.0	67.6	-2.0	288	0.00
	Sikkim	77	0	1.2	1.4	-0.2	9	0.00
	Railways_ER ISTS	12	0	0.1	0.1	0.0	3	0.00
NER	Arunachal Pradesh	179	0	3.2	3.1	-0.2	12	0.00
	Assam	2286	0	42.5	34.0	0.5	154	0.00
	Manipur	225	0	3.2	3.0	0.1	38	0.00
	Meghalaya	329	0	5.5	1.3	-0.2	108	0.00
	Mizoram	132	0	2.1	0.7	-0.3	3	0.00
	Nagaland	189	0	3.0	2.8	0.0	17	0.00
	Tripura	321	0	5.8	5.5	0.2	64	0.00

D. Transnational Exchanges (MU) - Import(+ve)/Export(-ve)

	Bhutan	Nepal	Bangladesh	Godda -> Bangladesh
Actual (MU)	37.6	23.1	-24.4	18.0
Day Peak (MW)	1788.6	1109.4	-1028.0	766.2

E. Import/Export by Regions (in MU) - Import(+ve)/Export(-ve); OD(+)/UD(-)

	NR	WR	SR	ER	NER	TOTAL
Schedule(MU)	178.3	-180.9	115.9	-119.3	6.1	0.0
Actual(MU)	183.8	-164.8	115.0	-147.5	4.2	-9.5
O/D/U/D(MU)	5.4	16.1	-0.9	-28.2	-1.9	-9.5

F. Generation Outage(MW)

	NR	WR	SR	ER	NER	TOTAL	% Share
Central Sector	6598	10941	6178	3430	265	27411	44
State Sector	11734	13317	7493	2177	199	34919	56
Total	18332	24257	13671	5607	464	62330	100

G. Sourcewise generation (Gross) (MU)

	NR	WR	SR	ER	NER	All India	% Share
Coal	632	1305	595	676	11	3219	67
Lignite	25	15	58	0	0	98	2
Hydro	223	93	165	96	32	610	13
Nuclear	31	65	66	0	0	162	3
Gas, Naptha & Diesel	7	23	5	0	21	55	1
RES (Wind, Solar, Biomass & Others)	297	190	185	6	1	679	14
Total	1214	1691	1074	778	66	4823	100

Share of RES in total generation (%)	24.43	11.24	17.23	0.79	1.57	14.08
Share of Non-fossil fuel (Hydro,Nuclear and RES) in total generation(%)	45.34	20.61	38.75	13.12	50.08	30.07

H. All India Demand Diversity Factor

Based on Regional Max Demands	1.005
Based on State Max Demands	1.037

I. All India Peak Demand and shortage at Solar and Non-Solar Hour

	Max Demand Met(MW)	Time	Shortage(MW)
Solar hr	196564	16:59	0
Non-Solar hr	209433	18:44	0

Diversity factor = Sum of regional or state maximum demands / All India maximum demand

**Note: All generation MU figures are gross

***Godda (Jharkhand) -> Bangladesh power exchange is through the radial connection (isolated from Indian Grid)

Solar Hours -> 06:00 to 18:00hrs and rest are Non-Solar Hours

*Source: RLDCs for solar connected to ISTS; SLDCs for embedded solar. Limited visibility of embedded solar data.

Executive Director-NLDC

INTER-REGIONAL EXCHANGES

Import=(+ve)/Export =(-ve) for NET (MU)
Date of Reporting: 14-Oct-2025

Sl No	Voltage Level	Line Details	No. of Circuit	Max Import (MW)	Max Export (MW)	Import (MU)	Export (MU)	NET (MU)
Import/Export of ER (With NR)								
1	HVDC	ALIPURDUAR-AGRA	2	0	311	0.0	7.8	-7.8
2	HVDC	PUSAULI B/B	-	0	47	0.0	2.6	-2.6
3	765 kV	GAYA-VARANASI	2	558	1270	0.0	11.2	-11.2
4	765 kV	SASARAM-FATEHPUR	1	202	586	0.0	5.8	-5.8
5	765 kV	GAYA-BALIA	1	0	661	0.0	9.6	-9.6
6	400 kV	PUSAULI-VARANASI	1	0	102	0.0	1.8	-1.8
7	400 kV	PUSAULI -ALLAHABAD	1	0	75	0.0	1.1	-1.1
8	400 kV	MUZAFFARPUR-GORAKHPUR	2	0	907	0.0	10.8	-10.8
9	400 kV	PATNA-BALIA	2	83	817	0.0	9.8	-9.8
10	400 kV	NAUBATPUR-BALIA	2	13	405	0.0	2.3	-2.3
11	400 kV	BIHARSHARIFF-BALIA	2	294	292	0.0	0.1	-0.1
12	400 kV	MOTIHARI-GORAKHPUR	2	0	570	0.0	7.6	-7.6
13	400 kV	BIHARSARIFE SAHUPURI	2	266	379	0.0	3.3	-3.3
14	220 kV	SAHUPURI-KARAMNASA	1	0	36	0.0	0.7	-0.7
15	132 kV	NAGAR UNTARI-RIHAND	1	0	0	0.0	0.0	0.0
16	132 kV	GARWAH-RIHAND	1	30	0	0.6	0.0	0.6
17	132 kV	KARMANASA-SAHUPURI	1	0	0	0.0	0.0	0.0
18	132 kV	KARMANASA-CHANDAULI	1	0	0	0.0	0.0	0.0
ER-NR						0.6	74.6	-74.0
Import/Export of ER (With WR)								
1	765 kV	JHARSUGUDA-DHARAMJAIGARH	4	819	344	5.0	0.0	5.0
2	765 kV	NEW RANCHI-DHARAMJAIGARH	2	1149	857	7.0	0.0	7.0
3	765 kV	JHARSUGUDA-DURG	2	69	1097	0.0	12.8	-12.8
4	400 kV	JHARSUGUDA-RAIGARH	4	295	519	0.0	4.2	-4.2
5	400 kV	RANCHI-SIPAT	2	265	262	0.4	0.0	0.4
6	400 kV	JEYPORE-JAGDALPUR	2	90	342	0.0	2.8	-2.8
7	220 kV	BUDHIPADAR-RAIGARH	1	31	143	0.0	1.6	-1.6
8	220 kV	BUDHIPADAR-KORBA	2	169	75	0.6	0.0	0.6
ER-WR						13.0	21.4	-8.4
Import/Export of ER (With SR)								
1	HVDC	JEYPORE-GAZUWAKA B/B	2	0	316	0.0	7.4	-7.4
2	HVDC	TALCHER-KOLAR BIPOLE	2	0	1619	0.0	37.9	-37.9
3	765 kV	ANGUL-SRIKAKULAM	2	0	2712	0.0	46.6	-46.6
4	400 kV	TALCHER-I/C	2	614	981	0.4	0.0	0.4
5	220 kV	BALIMELA-UPPER-SILERRU	1	0	0	0.0	0.0	0.0
ER-SR						0.0	91.9	-91.9
Import/Export of ER (With NER)								
1	400 kV	BINAGURI-BONGAIGAON	2	84	340	0.2	3.4	-3.2
2	400 kV	ALIPURDUAR-BONGAIGAON	2	0	692	0.0	8.8	-8.8
3	220 kV	ALIPURDUAR-SALAKATI	2	0	127	0.0	1.6	-1.6
ER-NER						0.2	13.8	-13.5
Import/Export of NER (With NR)								
1	HVDC	BISWANATH CHARIALI-AGRA	2	0	402	0.0	9.7	-9.7
NER-NR						0.0	9.7	-9.7
Import/Export of WR (With NR)								
1	HVDC	CHAMPA-KURUKSHETRA	2	0	2016	0.0	37.5	-37.5
2	HVDC	VINDHYACHAL B/B	-	0	57	0.0	1.2	-1.2
3	HVDC	MUNDRA-MOHINDERGARH	2	0	1457	0.0	25.7	-25.7
4	765 kV	GWALIOR-AGRA	2	8	1113	0.0	15.0	-15.0
5	765 kV	GWALIOR-PHAGI	2	960	2145	3.6	27.7	-24.1
6	765 kV	JABALPUR-ORAI	2	76	737	0.0	23.3	-23.3
7	765 kV	GWALIOR-ORAI	1	1151	0	17.3	0.0	17.3
8	765 kV	SATNA-ORAI	1	0	938	0.0	16.0	-16.0
9	765 kV	BANASKANTHA-CHITORGARH	2	2280	86	33.3	0.0	33.3
10	765 kV	VINDHYACHAL-VARANASI	2	0	1443	0.0	23.9	-23.9
11	400 kV	ZERDA-KANKROLI	1	450	0	7.3	0.0	7.3
12	400 kV	ZERDA -BHINMAL	1	311	0	5.0	0.0	5.0
13	400 kV	VINDHYACHAL- RIHAND	1	0	1	0.0	0.0	0.0
14	400 kV	RAPP-SHUJALPUR	2	584	283	3.4	2.8	0.6
15	400 kV	NEEMUCH-Chittorgarh	2	499	386	2.7	4.0	-1.3
16	220 kV	BHANPURA-RANPUR	1	0	116	0.0	1.6	-1.6
17	220 kV	BHANPURA-MORAK	1	0	30	0.0	2.0	-2.0
18	220 kV	MEHGAON-AURAIYA	1	110	0	1.0	0.0	1.0
19	220 kV	MALANPUR-AURAIYA	1	83	4	0.6	0.0	0.6
20	132 kV	RAIGHAT-LALITPUR	2	0	0	0.0	0.0	0.0
WR-NR						74.1	180.5	-106.3
Import/Export of WR (With SR)								
1	HVDC	BHADRAWATI B/B	-	0	970	0.0	14.9	-14.9
2	HVDC	RAIGARH-PUGALUR	2	0	3508	0.0	51.3	-51.3
3	765 kV	SOLAPUR-RAICHUR	2	1139	856	9.2	1.3	7.9
4	765 kV	WARDHA-NIZAMABAD	2	0	2321	0.0	26.6	-26.6
5	765 kV	WARORA-WARANGAL(NEW)	2	0	1502	0.0	19.3	-19.3
6	400 kV	KOLHAPUR-KUDGI	2	1906	0	35.6	0.0	35.6
7	220 kV	KOLHAPUR-CHIKODI	2	0	0	0.0	0.0	0.0
8	220 kV	PONDA-AMBEWADI	1	0	0	0.0	0.0	0.0
9	220 kV	XELDEM-AMBEWADI	1	0	118	2.0	0.0	2.0
WR-SR						46.8	113.4	-66.6
INTERNATIONAL EXCHANGES								
State	Region	Line Name	Max (MW)	Min (MW)	Avg (MW)	Import(+ve)/Export(-ve) Energy Exchange (MU)		
BHUTAN	ER	400kV MANGDECHHU-ALIPURDUAR 1,2&3 I.e. ALIPURDUAR RECEIPT (from MANGDECHU HEP 4*180MW)	995	909	990	23.75		
	ER	400kV TALA-BINAGURI 1,2,4 (& 400kV MALBASE - BINAGURI) I.e. BINAGURI RECEIPT (from TALA HEP 6*170MW)	646	439	532	12.78		
	ER	220kV CHUKHA-BIRPARA 1&2 (& 220kV MALBASE - BIRPARA) I.e. BIRPARA RECEIPT (from CHUKHA HEP 4*84MW)	49	-26	18	0.42		
	NER	132kV GELEPHU-SALAKATI	-16	0	-10	-0.23		
	NER	132kV MOTANGA-RANGIA	46	0	37	0.88		
NEPAL	NR	NEPAL IMPORT (FROM UP)	0	0	0	0.00		
	NR	132kV MAHENDRANAGAR-TANAKPUR(NHPC)	68	0	62	1.48		
	ER	NEPAL IMPORT (FROM BIHAR)	183	133	159	3.81		
	ER	400kV DHALKEBAR-MUZAFFARPUR 1&2	856	679	744	17.85		
BANGLADESH	ER	BHERAMARA B/B HVDC (B'DESH)	-961	0	-950	-22.80		
	ER (Isolated from Indian Grid)	400kV GODDA_TPS-RAHANPUR (B'DESH) D/C	766	708	749	17.97		
	NER	132kV COMILLA-SURAJMANI NAGAR 1&2	-77	0	-65	-1.56		

CROSS BORDER EXCHANGE SCHEDULE

Date of Reporting: 14-Oct-2025

Export From India (in MU)

Country	GNA (ISGS/PPA)	T-GNA							TOTAL
		BILATERAL TOTAL	COLLECTIVE						
			IDAM			RTM			
			IEX	PXIL	HPX	IEX	PXIL	HPX	
Bhutan	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Nepal	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Bangladesh	23.64	0.06	0.00	0.00	0.00	0.00	0.00	0.00	23.70
Myanmar	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total Export	23.64	0.06	0.00	0.00	0.00	0.00	0.00	0.00	23.70

Import by India(in MU)

Country	GNA (ISGA/PPA)	T-GNA							TOTAL	
		BILATERAL TOTAL	COLLECTIVE							
			IDAM			RTM				
			IEX	PXIL	HPX	IEX	PXIL	HPX		
Bhutan	18.27	0.00	1.34	0.00	0.00	0.00	0.00	0.00	19.61	
Nepal	9.21	4.66	5.84	0.00	0.00	0.00	3.42	0.00	0.00	23.13
Bangladesh	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Myanmar	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total Import	27.48	4.66	7.18	0.00	0.00	0.00	3.42	0.00	0.00	42.74

Net from India(in MU)

-ve : Export / +ve : Import

Country	GNA (ISGS/PPA)	T-GNA							TOTAL	
		BILATERAL TOTAL	COLLECTIVE							
			IDAM			RTM				
			IEX	PXIL	HPX	IEX	PXIL	HPX		
Bhutan	18.27	0.00	1.34	0.00	0.00	0.00	0.00	0.00	19.61	
Nepal	9.21	4.66	5.84	0.00	0.00	0.00	3.42	0.00	0.00	23.13
Bangladesh	-23.64	-0.06	0.00	0.00	0.00	0.00	0.00	0.00	0.00	-23.70
Myanmar	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total Net	3.84	4.60	7.18	0.00	0.00	0.00	3.42	0.00	0.00	19.04

15 Min (INSTANTANEOUS) ALL INDIA GRID FREQUENCY, GENERATION & DEMAND MET (SCADA DATA)												
TIME	FREQUENCY (Hz)	DEMAND MET (MW)	NUCLEAR (MW)	WIND (MW)	SOLAR (MW)	HYDRO** (MW)	GAS (MW)	THERMAL (MW)	OTHERS* (MW)	NET DEMAND (MW)	TOTAL GENERATION (MW)	NET TRANSNATIONAL EXCHANGE (MW)
		(A)	(B)	(C)	(D)	(E)	(F)	(G)	(H)	(I=A-(C+D))	(J=B+C+D+E+F+G+H)	(+ve) Import, (-ve) Export
0:00	50.03	165196	6115	2464	0	23855	1693	130070	1676	162732	165873	1562
0:15	49.98	163654	6119	2319	0	23162	1681	130222	1660	161335	165163	1562
0:30	49.98	162818	6110	2164	0	23505	1695	129354	1597	160654	164425	1548
0:45	49.98	161915	6118	2032	0	23353	1674	128829	1579	159883	163585	1377
1:00	50.03	160618	6126	2004	0	22942	1683	127806	1578	158614	162139	1380
1:15	50.03	159883	6130	1947	0	23267	1685	126563	1577	157936	161169	1367
1:30	50.03	158476	6122	1869	0	22512	1679	126187	1582	156607	159951	1360
1:45	49.98	157732	6125	1925	0	21733	1678	126207	1602	155807	159270	1393
2:00	50.03	157271	6134	2052	0	21731	1680	125744	1566	155219	158907	1416
2:15	50.03	157417	6126	2083	0	21458	1687	125682	1586	155334	158622	1399
2:30	50.03	156316	6116	2140	0	21414	1695	124957	1634	154176	157956	1399
2:45	50.03	156781	6135	2173	0	21267	1690	125133	1597	154608	157995	1431
3:00	50.03	156078	6126	2185	0	21131	1677	124856	1585	153893	157560	1421
3:15	50.03	156341	6138	2293	0	20864	1683	124987	1629	154048	157594	1412
3:30	49.98	155349	6142	2284	0	20866	1743	124273	1583	153065	156891	1421
3:45	50.03	156228	6129	2237	0	21118	1678	124674	1637	153991	157473	1524
4:00	49.98	155996	6129	2173	0	21132	1740	124663	1575	153823	157412	1566
4:15	49.98	157058	6125	2174	0	21147	1683	125852	1607	154884	158588	1520
4:30	49.98	158230	6130	2150	0	21317	1750	126907	1590	156080	159844	1539
4:45	49.98	159743	6137	2146	0	21807	1680	127582	1600	157597	160952	1509
5:00	49.98	161592	6118	2071	-13	22891	1678	128795	1611	159534	163151	1506
5:15	49.93	164388	6118	2066	-11	23926	1699	130391	1505	162333	165694	1486
5:30	50.03	166580	6125	2069	-10	24767	1754	132120	1521	164521	168346	1464
5:45	49.98	169690	6137	2120	-9	25945	1631	133619	1556	167579	170999	1487
6:00	50.03	171997	6129	2224	-23	26357	1676	135863	1593	169796	173819	1445
6:15	49.98	176766	6119	2258	99	28252	1629	138314	1590	174409	178261	1434
6:30	49.98	180899	6121	2437	480	29608	1664	140821	1611	177982	182742	1432
6:45	50.03	184317	6134	2591	1550	29637	1699	142414	1644	180176	185669	1417
7:00	50.03	185386	6137	2839	3608	29613	1724	141201	1631	178939	186753	1428
7:15	50.03	187431	6145	3023	6655	29730	1771	139337	1667	177753	188328	1442
7:30	50.08	187528	6131	3090	10689	28975	1784	136031	1715	173749	188415	1470
7:45	50.08	187266	6139	3153	15682	25698	1810	132803	1678	168431	186963	1437
8:00	50.03	184953	6143	2991	21070	23125	1806	127400	1751	160892	184286	1414
8:15	49.98	185193	6142	2859	26600	22404	1810	122190	1796	155734	183801	1447
8:30	50.03	185122	6132	2788	31853	21765	1813	117906	1794	150481	184051	1476
8:45	49.98	186823	6121	2574	38044	20883	1811	113962	1792	146205	185187	1394
9:00	50.03	187336	6126	2285	42463	20113	1828	110466	1880	142588	185161	1406
9:15	49.98	190214	6118	2079	46881	19527	1824	109337	1796	141254	187562	1431
9:30	49.88	190884	6093	1983	48631	19243	1845	108626	1833	140270	188254	1343
9:45	49.83	191648	6092	2012	51880	18203	1858	107682	1876	137756	189603	1424
10:00	49.98	192117	6089	2103	54868	17724	1804	105530	1831	135146	189949	1452
10:15	50.03	192350	6122	2448	58797	17370	1822	102175	1808	131105	190542	1450
10:30	49.98	193156	6105	2594	60278	17629	1801	101999	1791	130284	192197	1460
10:45	49.98	193411	6098	2714	61016	17605	1812	101660	1807	129681	192712	1445
11:00	49.98	193232	6094	2756	61289	17596	1837	101370	1823	129187	192765	1447
11:15	49.98	192082	6097	2857	60611	17393	1833	100938	1842	128614	191571	1429
11:30	49.98	191863	6099	2918	60535	17594	1831	101020	1847	128410	191844	1417
11:45	49.98	191642	6099	2948	60334	17686	1810	101170	1821	128360	191868	1520
12:00	49.98	191108	6096	2895	60387	17710	1784	100714	1888	127826	191474	1483
12:15	50.04	190581	6087	2908	60186	17612	1810	100561	1878	127487	191042	1501
12:30	50.09	190169	6089	2903	60259	17512	1794	100067	1857	127007	190481	1488
12:45	50.03	188702	6109	2979	59015	17517	1795	99575	1880	126708	188870	1531
13:00	50.09	186749	6080	3148	56546	17627	1796	99863	1938	127055	186998	1525
13:15	50.04	183384	6097	3186	54161	17197	1790	99051	1892	126037	183374	1524
13:30	50.09	183640	6092	3248	55083	16931	1777	98411	1891	125309	183433	1517
13:45	49.99	185271	6095	3366	55640	17238	1781	99289	1887	126265	185296	1510
14:00	49.99	186359	6089	3365	54831	17550	1775	100883	1880	128163	186373	1514
14:15	49.89	187383	6075	3419	53697	17682	1765	103223	1807	130267	187668	1518
14:30	49.94	189812	6072	3516	54781	18008	1771	103418	1857	131515	189423	1487
14:45	49.93	190925	6077	3716	55076	18179	1779	105273	1804	132133	191904	1501
15:00	49.94	192417	6068	4012	52654	18195	1789	109224	1795	135751	193737	1511
15:15	49.99	192378	6083	4207	49796	18424	1799	111784	1837	138375	193930	1503
15:30	50.04	193354	6074	4222	46724	18838	2010	115437	1818	142408	195123	1463
15:45	49.99	194608	6091	4253	42654	19532	2246	119710	1848	147701	196334	1473
16:00	50.04	194921	6066	4545	38167	19699	2536	123281	1819	152209	196113	1483
16:15	49.99	193090	6088	4600	33460	19487	2695	125668	1816	155030	193814	1387
16:30	49.99	194800	6058	4719	28673	21204	2775	130368	1824	161408	195621	1388
16:45	49.99	196121	6087	4700	23580	21868	2969	135821	1729	167841	196754	1363
17:00	49.99	196578	6082	4750	18323	23530	3065	140142	1745	173505	197637	1346
17:15	49.99	195481	6078	4781	12622	24183	3144	143408	1712	178078	195928	1278
17:30	49.94	197367	6090	4758	7781	25932	3433	148274	1724	184828	197992	1248
17:45	49.94	200694	6089	4819	4026	27915	3789	152920	1738	191849	201296	1192
18:00	49.94	202907	6076	4934	1644	29697	4015	155538	1753	196329	203657	1163
18:15	49.89	205523	6098	4934	575	32313	4160	156659	1773	200014	206512	1137
18:30	49.89	208505	6096	4761	237	34197	4338	158171	1785	203507	209585	1168
18:45	49.99	209271	6105	4837	188	35030	4312	157953	1750	204246	210175	1198
19:00	50.04	208123	6102	4746	185	34472	4355	156840	1745	203192	208445	1592
19:15	50.04	205383	6112	4715	257	32707	4342	157799	1783	200411	207715	1231
19:30	50.04	202928	6124	4539	0	31553	3860	155246	1767	198389	203089	1253
19:45	50.04	200456	6111	4352	0	31251	2976	154512	1763	196104	200965	1273
20:00	50.04	196856	6111	4172	0	30485	2487	152417	1738	192684	197410	1275
20:15	49.99	193432	6114	4061	0	30271	2172	149374	1797	189371	193789	1313
20:30	49.78	191535	6094	4038	0	28901	2030	149281	1751	187497	192095	1325
20:45	49.84	190731	6091	4180	0	28503	1952	148698	1797	186551	191221	1319
21:00	50.04	189685	6114	4286	0	27892	1820	148201	1798	185399	190111	1378
21:15	50.04	187387	6113	4286	0	26772	1807	146842	1792	183101	187612	1375
21:30	50.06	185971	6131	4223	0	26662	1724	145861	1785	181748	186386	1385
21:45	50.06	184715	6122	4027	0	25945	1720	145384	1881	180688	185079	1414
22:00	50.06	182228	6131	3865	0	25644	1704	143467	1805	178363	182616	1409
22:15	49.96	182876	6120	3910	0	25777	1724	143969	1749	178966	183249	1432
22:30	50.01	182036	6113	3851	0	25847	1719	1432				