



National Load Despatch Centre
राष्ट्रीय भार प्रेषण केंद्र
GRID CONTROLLER OF INDIA LIMITED
ग्रिड कंट्रोलर ऑफ इंडिया लिमिटेड

(Government of India Enterprise/ भारत सरकार का उद्यम)
B-9, QUTUB INSTITUTIONAL AREA, KATWARIA SARAI, NEW DELHI -110016
बी-9, कुतुब इन्स्टीट्यूशनल एरिया, कटवारिया सराये, न्यू दिल्ली-110016

Ref: POSOCO/NLDC/SO/Daily PSP Report

दिनांक: 01.10.2024

To,

- कार्यकारी निदेशक, पू.क्षे.भा.प्रे.के., 14, गोल्फ क्लब रोड, कोलकाता - 700033
Executive Director, ERLDC, 14 Golf Club Road, Tollygunge, Kolkata, 700033
- कार्यकारी निदेशक, ऊ.क्षे.भा.प्रे.के., 18/ए, शाहीद जीत सिंह सनसनवाल मार्ग, नई दिल्ली - 110016
Executive Director, NRLDC, 18-A, Shaheed Jeet Singh Marg, Katwaria Sarai, New Delhi - 110016
- कार्यकारी निदेशक, प.क्षे.भा.प्रे.के., एफ3, एम आई डी सी क्षेत्र, अंधेरी, मुंबई - 400093
Executive Director, WRLDC, F-3, M.I.D.C. Area, Marol, Andheri (East), Mumbai-400093
- कार्यकारी निदेशक, ऊ.पू.क्षे.भा.प्रे.के., डोंगतेह, लोअर नोंग्रह, लापलंग, शिलोंग - 793006
Executive Director, NERLDC, Dongteih, Lower Nongrah, Lapalang, Shillong - 793006, Meghalaya
- कार्यकारी निदेशक, द.क्षे.भा.प्रे.के., 29, रेस कोर्स क्रॉस रोड, बंगलुरु - 560009
Executive Director, SRLDC, 29, Race Course Cross Road, Bangalore-560009

Sub: Daily PSP Report for the date 30.09.2024.

महोदय/Dear Sir,

आईईजीसी-2023 की धारा स.-5.5.1 के प्रावधान के अनुसार, दिनांक 30-सितंबर-2024 की अखिल भारतीय प्रणाली की दैनिक ग्रिड निष्पादन रिपोर्ट रांभांप्रेके की वेबसाइट पर उपलब्ध है।

As per article 5.5.1 of the Indian Electricity Grid Code, the daily report pertaining power supply position of All India Power System for the date 30.09.2024, is available at the NLDC website.

धन्यवाद,
Thanks

Report for previous day Date of Reporting: 01-Oct-2024

A. Power Supply Position at All India and Regional level

	NR	WR	SR	ER	NER	TOTAL
Demand Met during Evening Peak hrs(MW) (at 20:00 hrs; from RLDCs)	70130	59494	48962	29029	3307	210922
Peak Shortage (MW)	1984	181	0	0	0	2165
Energy Met (MU)	1540	1351	1200	610	62	4762
Hydro Gen (MU)	282	107	173	97	28	687
Wind Gen (MU)	9	40	18	-	-	67
Solar Gen (MU)*	162.24	86.90	120.76	3.57	0.64	374
Energy Shortage (MU)	8.91	3.27	1.86	0.37	0.00	14.41
Maximum Demand Met During the Day (MW) (From NLDC SCADA)	71693	62976	57493	29531	3381	214228
Time Of Maximum Demand Met	19:14	18:45	12:26	19:56	18:06	19:14

B. Frequency Profile (%)

Region	FVI	< 49.7	49.7 - 49.8	49.8 - 49.9	< 49.9	49.9 - 50.05	> 50.05
All India	0.040	0.59	1.08	3.19	4.86	79.72	15.41

C. Power Supply Position in States

Region	States	Max.Demand Met during the day (MW)	Shortage during maximum Demand (MW)	Energy Met (MU)	Drawal Schedule (MU)	OD(+)/UD(-) (MU)	Max OD (MW)	Energy Shortage (MU)
NR	Punjab	12572	0	265.5	145.7	-0.8	428	0.00
	Haryana	10790	0	226.1	170.3	-1.7	201	0.00
	Rajasthan	14999	0	328.4	118.8	0.1	821	8.38
	Delhi	5814	0	125.0	110.7	0.0	321	0.00
	UP	23624	54	452.7	161.4	0.4	318	0.26
	Uttarakhand	2147	35	45.8	24.2	0.1	181	0.27
	HP	1817	0	35.4	9.5	0.0	164	0.00
	J&K(UT) & Ladakh(UT)	5197	0	51.0	33.5	0.3	412	0.00
	Chandigarh	290	0	5.9	5.7	0.2	55	0.00
WR	Railways_NR ISTS	198	0	4.0	3.7	0.2	65	0.00
	Chhattisgarh	5480	109	122.5	71.0	0.0	478	0.87
	Gujarat	18435	0	392.1	170.8	2.3	1432	0.00
	MP	12036	0	248.5	141.9	-2.1	468	0.00
	Maharashtra	25000	1032	514.6	184.3	1.8	1310	2.40
	Goa	718	0	14.6	14.0	0.5	78	0.00
	DNHDDPDCL	1299	0	29.8	30.0	-0.2	34	0.00
	AMNSIL	699	0	16.0	3.4	0.2	225	0.00
	BALCO	529	0	12.6	12.6	0.0	522	0.00
SR	Andhra Pradesh	10550	0	224.0	80.1	0.9	624	0.00
	Telangana	13929	0	272.3	127.1	-1.1	567	0.00
	Karnataka	12600	0	236.5	74.5	2.3	859	0.00
	Kerala	4139	161	83.9	50.1	2.4	520	1.86
	Tamil Nadu	17713	0	373.7	210.7	1.2	955	0.00
	Puducherry	441	0	10.0	9.9	-0.5	19	0.00
	Railways_SR ISTS	13	0	0.1	0.1	0.0	0	0.00
ER	Bihar	6958	388	133.4	127.4	-2.8	0	0.37
	DVC	3391	0	72.6	-49.4	-0.6	0	0.00
	Jharkhand	2146	0	44.9	32.5	1.5	0	0.00
	Odisha	6300	0	130.2	27.9	1.3	0	0.00
	West Bengal	11190	0	227.3	83.8	-1.3	0	0.00
	Sikkim	83	0	1.1	1.5	-0.4	0	0.00
NER	Railways_ER ISTS	13	0	0.1	0.1	0.0	0	0.00
	Arunachal Pradesh	166	0	3.0	2.5	0.1	35	0.00
	Assam	2243	0	40.2	34.4	0.2	339	0.00
	Manipur	216	0	2.8	2.8	0.1	44	0.00
	Meghalaya	268	0	4.6	1.2	-0.1	219	0.00
	Mizoram	120	0	1.9	0.7	-0.3	12	0.00
	Nagaland	170	0	2.9	2.5	0.0	15	0.00
	Tripura	326	0	6.1	5.8	0.6	71	0.00

D. Transnational Exchanges (MU) - Import(+ve)/Export(-ve)

	Bhutan	Nepal	Bangladesh	Godda -> Bangladesh
Actual (MU)	42.4	6.1	-23.3	-27.6
Day Peak (MW)	1975.0	305.0	-989.0	-1538.0

E. Import/Export by Regions (in MU) - Import(+ve)/Export(-ve); OD(+)/UD(-)

	NR	WR	SR	ER	NER	TOTAL
Schedule(MU)	318.5	-251.4	88.5	-156.9	1.2	0.0
Actual(MU)	295.8	-243.5	94.3	-151.6	1.6	-3.5
O/D/U/D(MU)	-22.8	7.8	5.8	5.3	0.3	-3.5

F. Generation Outage(MW)

	NR	WR	SR	ER	NER	TOTAL	% Share
Central Sector	4024	10138	2428	3056	280	19926	43
State Sector	5041	12187	7117	1984	155	26483	57
Total	9065	22325	9545	5040	435	46410	100

G. Sourcewise generation (Gross) (MU)

	NR	WR	SR	ER	NER	All India	% Share
Coal	801	1376	702	733	16	3627	71
Lignite	17	11	57	0	0	85	2
Hydro	282	107	173	97	28	687	13
Nuclear	30	52	76	0	0	158	3
Gas, Naptha & Diesel	24	45	5	0	21	96	2
RES (Wind, Solar, Biomass & Others)	177	129	170	6	1	482	9
Total	1332	1720	1181	836	66	5135	100

Share of RES in total generation (%)	13.27	7.50	14.35	0.73	0.95	9.39
Share of Non-fossil fuel (Hydro,Nuclear and RES) in total generation(%)	36.72	16.72	35.38	12.38	43.87	25.84

H. All India Demand Diversity Factor

Based on Regional Max Demands	1.050
Based on State Max Demands	1.095

I. All India Peak Demand and shortage at Solar and Non-Solar Hour

	Max Demand Met(MW)	Time	Shortage(MW)
Solar hr	211677	15:31	0
Non-Solar hr	214228	19:14	4946

Diversity factor = Sum of regional or state maximum demands / All India maximum demand

**Note: All generation MU figures are gross

***Godda (Jharkhand) -> Bangladesh power exchange is through the radial connection (isolated from Indian Grid)

Solar Hours -> 06:00 to 18:00hrs and rest are Non-Solar Hours

*Source: RLDCs for solar connected to ISTS; SLDCs for embedded solar. Limited visibility of embedded solar data.

Executive Director-NLDC

INTER-REGIONAL EXCHANGES

Import=(+ve) /Export =(-ve) for NET (MU)

Date of Reporting: 01-Oct-2024

Sl No	Voltage Level	Line Details	No. of Circuit	Max Import (MW)	Max Export (MW)	Import (MU)	Export (MU)	NET (MU)
Import/Export of ER (With NR)								
1	HVDC	ALIPURDUAR-AGRA	2	0	352	0.0	8.4	-8.4
2	HVDC	PUSAULI B/B	-	2	110	0.0	2.5	-2.5
3	765 kV	GAYA-VARANASI	2	378	902	0.0	8.4	-8.4
4	765 kV	SASARAM-FATEHPUR	1	124	409	0.0	4.7	-4.7
5	765 kV	GAYA-BALIA	1	0	590	0.0	9.4	-9.4
6	400 kV	PUSAULI-VARANASI	1	17	129	0.0	2.1	-2.1
7	400 kV	PUSAULI -ALLAHABAD	1	19	44	0.0	0.4	-0.4
8	400 kV	MUZAFFARPUR-GORAKHPUR	2	52	459	0.0	6.3	-6.3
9	400 kV	PATNA-BALIA	2	0	794	0.0	13.6	-13.6
10	400 kV	NAUBATPUR-BALIA	2	6	352	0.0	3.9	-3.9
11	400 kV	BIHARSHARIFF-BALIA	2	175	104	0.4	0.0	0.4
12	400 kV	MOTIHARI-GORAKHPUR	2	0	399	0.0	5.1	-5.1
13	400 kV	BIHARSHARIFF-VARANASI	2	269	274	0.0	3.5	-3.5
14	220 kV	SAHUPURI-KARAMNASA	1	0	116	0.0	2.0	-2.0
15	132 kV	NAGAR UNTARI-RIHAND	1	0	0	0.0	0.0	0.0
16	132 kV	GARWAH-RIHAND	1	30	0	0.5	0.0	0.5
17	132 kV	KARMANASA-SAHUPURI	1	0	0	0.0	0.0	0.0
18	132 kV	KARMANASA-CHANDAUJI	1	0	0	0.0	0.0	0.0
ER-NR						1.0	70.2	-69.3
Import/Export of ER (With WR)								
1	765 kV	JHARSUGUDA-DHARAMJAIGARH	4	34	961	0.0	13.8	-13.8
2	765 kV	NEW RANCHI-DHARAMJAIGARH	2	1375	327	15.8	0.0	15.8
3	765 kV	JHARSUGUDA-DURG	2	0	591	0.0	8.7	-8.7
4	400 kV	JHARSUGUDA-RAIGARH	4	0	660	0.0	7.7	-7.7
5	400 kV	RANCHI-SIPAT	2	281	239	1.6	0.0	1.6
6	220 kV	BUDHIPADAR-RAIGARH	1	15	134	0.0	1.4	-1.4
7	220 kV	BUDHIPADAR-KORBA	2	36	183	0.0	1.2	-1.2
ER-WR						17.4	32.9	-15.5
Import/Export of ER (With SR)								
1	HVDC	JEYPORE-GAZUWAKA B/B	2	0	531	0.0	12.6	-12.6
2	HVDC	TALCHER-KOLAR BIPOLE	2	0	1197	0.0	29.0	-29.0
3	765 kV	ANGUL-SRIKAKULAM	2	0	2601	0.0	41.7	-41.7
4	400 kV	TALCHER-I/C	2	207	0	3.5	0.0	3.5
5	220 kV	BALIMELA-UPPER-SILERRU	1	0	0	0.0	0.0	0.0
ER-SR						0.0	83.3	-83.3
Import/Export of ER (With NER)								
1	400 kV	BINAGURI-BONGAIGAON	2	0	409	0.0	4.8	-4.8
2	400 kV	ALIPURDUAR-BONGAIGAON	2	0	738	0.0	9.7	-9.7
3	220 kV	ALIPURDUAR-SALAKATI	2	0	135	0.0	2.0	-2.0
ER-NER						0.0	16.5	-16.5
Import/Export of NER (With NR)								
1	HVDC	BISWANATH CHARIALI-AGRA	2	0	703	0.0	16.8	-16.8
NER-NR						0.0	16.8	-16.8
Import/Export of WR (With NR)								
1	HVDC	CHAMPA-KURUKSHETRA	2	0	2011	0.0	46.4	-46.4
2	HVDC	VINDHYACHAL B/B	-	0	61	0.0	1.2	-1.2
3	HVDC	MUNDRA-MOHINDERGARH	2	0	1905	0.0	45.2	-45.2
4	765 kV	GWALIOR-AGRA	2	0	1424	0.2	19.0	-18.8
5	765 kV	GWALIOR-PHAGI	2	281	2020	0.6	29.6	-29.1
6	765 kV	JABALPUR-ORAI	2	0	1026	0.0	30.4	-30.4
7	765 kV	GWALIOR-ORAI	1	821	0	11.2	0.0	11.2
8	765 kV	SATNA-ORAI	1	0	987	0.0	20.2	-20.2
9	765 kV	BANASKANTHA-CHITORGARH	2	1456	0	17.3	0.0	17.3
10	765 kV	VINDHYACHAL-VARANASI	2	0	2883	0.0	42.5	-42.5
11	400 kV	ZERDA-KANKROLI	1	288	14	3.3	0.0	3.3
12	400 kV	ZERDA -BHINMAL	1	28	176	0.0	2.3	-2.3
13	400 kV	VINDHYACHAL -RIHAND	1	0	1	0.0	0.0	0.0
14	400 kV	RAPP-SHUJALPUR	2	312	465	1.4	4.5	-3.1
15	400 kV	NEEMUCH-Chittorgarh	2	226	540	0.5	5.8	-5.2
16	220 kV	BHANPURA-RANPUR	1	0	105	0.0	1.7	-1.7
17	220 kV	BHANPURA-MORAK	1	0	30	0.0	2.1	-2.1
18	220 kV	MEHGAON-AURAIYA	1	98	0	1.0	0.0	1.0
19	220 kV	MALANPUR-AURAIYA	1	68	7	0.5	0.0	0.5
20	132 kV	GWALIOR-SAWAI MADHOPUR	1	0	0	0.0	0.0	0.0
21	132 kV	RAJGHAT-LALITPUR	2	0	0	0.0	0.0	0.0
WR-NR						36.0	250.9	-214.9
Import/Export of WR (With SR)								
1	HVDC	BHADRAWATI B/B	-	299	0	7.2	0.0	7.2
2	HVDC	RAIGARH-PUGALUR	2	0	2001	0.0	31.4	-31.4
3	765 kV	SOLAPUR-RAICHUR	2	933	803	5.4	1.6	3.9
4	765 kV	WARDHA-NIZAMABAD	2	0	2390	0.0	28.2	-28.2
5	765 kV	WARORA-WARANGAL(NEW)	2	0	2335	0.0	28.7	-28.7
6	400 kV	KOLHAPUR-KUDGI	2	1628	0	28.7	0.0	28.7
7	220 kV	KOLHAPUR-CHIKODI	2	0	0	0.0	0.0	0.0
8	220 kV	PONDA-AMBEWADI	1	89	0	1.5	0.0	1.5
9	220 kV	XELDEM-AMBEWADI	1	0	125	2.5	0.0	2.5
WR-SR						45.3	89.9	-44.6

INTERNATIONAL EXCHANGES					Import(+ve)/Export(-ve)		
State	Region	Line Name	Max (MW)	Min (MW)	Avg (MW)	Energy Exchange (MU)	
BHUTAN	ER	400kV MANGDECHHU-ALIPURDUAR 1,2&3 i.e. ALIPURDUAR RECEIPT (from MANGDECHU HEP 4*180MW)	792	723	743	17.84	
	ER	400kV TALA-BINAGURI 1,2,4 (& 400kV MALBASE - BINAGURI) i.e. BINAGURI RECEIPT (from TALA HEP 6*170MW)	893	643	833	19.99	
	ER	220kV CHUKHA-BIRPARA 1&2 (& 220kV MALBASE - BIRPARA) i.e. BIRPARA RECEIPT (from CHUKHA HEP 4*84MW)	129	62	105	2.52	
	NER	132kV GELEPHU-SALAKATI	39	0	31	0.74	
	NER	132kV MOTANGA-RANGIA	64	0	55	1.31	
NEPAL	NR	NEPAL IMPORT (FROM UP)	-37	0	0	0.00	
	NR	132kV MAHENDRANAGAR-TANAKPUR(NHPC)	66	0	53	1.27	
	ER	NEPAL IMPORT (FROM BIHAR)	-11	0	-4	-0.10	
	ER	400kV DHALKEBAR-MUZAFFARPUR 1&2	250	30	205	4.92	
BANGLADESH	ER	BHERAMARA B/B HVDC (B'DESH)	-908	-904	-905	-21.71	
	ER (Isolated from Indian Grid)	400kV GODDA_TPS-RAHANPUR (B'DESH) D/C	-1538	-903	-1149	-27.58	
	NER	132kV COMILLA-SURAJMANI NAGAR 1&2	-81	0	-68	-1.63	

Export From India (in MU)

Country	GNA (ISGS/PPA)	T-GNA							TOTAL
		BILATERAL TOTAL	COLLECTIVE						
			IDAM			RTM			
			IEX	PXIL	HPX	IEX	PXIL	HPX	
Bhutan	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Nepal	0.38	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.38
Bangladesh	22.51	0.00	0.00	0.00	0.00	0.00	0.00	0.00	22.51
Myanmar	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total Export	22.89	0.00	0.00	0.00	0.00	0.00	0.00	0.00	22.89

Import by India(in MU)

Country	GNA (ISGA/PPA)	T-GNA							TOTAL
		BILATERAL TOTAL	COLLECTIVE						
			IDAM			RTM			
			IEX	PXIL	HPX	IEX	PXIL	HPX	
Bhutan	40.09	0.00	2.23	0.00	0.00	0.06	0.00	0.00	42.38
Nepal	5.46	0.00	0.37	0.00	0.00	1.36	0.00	0.00	7.19
Bangladesh	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Myanmar	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total Import	45.55	0.00	2.60	0.00	0.00	1.42	0.00	0.00	49.57

Net from India(in MU)

-ve : Export / +ve : Import

Country	GNA (ISGS/PPA)	T-GNA							TOTAL
		BILATERAL TOTAL	COLLECTIVE						
			IDAM			RTM			
			IEX	PXIL	HPX	IEX	PXIL	HPX	
Bhutan	40.09	0.00	2.23	0.00	0.00	0.06	0.00	0.00	42.38
Nepal	5.08	0.00	0.37	0.00	0.00	1.36	0.00	0.00	6.81
Bangladesh	-22.51	0.00	0.00	0.00	0.00	0.00	0.00	0.00	-22.51
Myanmar	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total Net	22.66	0.00	2.60	0.00	0.00	1.42	0.00	0.00	26.68