



National Load Despatch Centre
राष्ट्रीय भार प्रेषण केंद्र
GRID CONTROLLER OF INDIA LIMITED
ग्रिड कंट्रोलर ऑफ इंडिया लिमिटेड

(Government of India Enterprise/ भारत सरकार का उद्यम)
B-9, QUTUB INSTITUTIONAL AREA, KATWARIA SARAI, NEW DELHI -110016
बी-9, कुतुब इन्स्टीट्यूशनल एरिया, कटवारिया सराये, न्यू दिल्ली-110016

Ref: GRID-INDIA/NLDC/SO/Daily PSP Report

दिनांक: 03.02.2025

To,

- कार्यकारी निदेशक, पू.क्षे.भा.प्रे.के., 14, गोल्फ क्लब रोड, कोलकाता - 700033
Executive Director, ERLDC, 14 Golf Club Road, Tollygunge, Kolkata, 700033
- कार्यकारी निदेशक, ऊ.क्षे.भा.प्रे.के., 18/ए, शाहीद जीत सिंह सनसनवाल मार्ग, नई दिल्ली - 110016
Executive Director, NRLDC, 18-A, Shaheed Jeet Singh Marg, Katwaria Sarai, New Delhi - 110016
- कार्यकारी निदेशक, प.क्षे.भा.प्रे.के., एफ3, एम आई डी सी क्षेत्र, अंधेरी, मुंबई - 400093
Executive Director, WRLDC, F-3, M.I.D.C. Area, Marol, Andheri (East), Mumbai-400093
- कार्यकारी निदेशक, ऊ.पू.क्षे.भा.प्रे.के., डोंगतेह, लोअर नोंग्रह, लापालंग, शिलोंग - 793006
Executive Director, NERLDC, Dongteih, Lower Nongrah, Lapalang, Shillong - 793006, Meghalaya
- कार्यकारी निदेशक, द.क्षे.भा.प्रे.के., 29, रेस कोर्स क्रॉस रोड, बंगलुरु - 560009
Executive Director, SRLDC, 29, Race Course Cross Road, Bangalore-560009

Sub: Daily PSP Report for the date 02.02.2025.

महोदय/Dear Sir,

आई०ई०जी०सी०-2023 की धारा स.-38(1) के प्रावधान के अनुसार, दिनांक 02- फ़रवरी -2025 की अखिल भारतीय प्रणाली की दैनिक ग्रिड निष्पादन रिपोर्ट रा०भा०प्रे०के० की वेबसाइट पर उपलब्ध है।

As per article 38(1) of the Indian Electricity Grid Code, the daily report pertaining power supply position of All India Power System for the date 02.02.2025, is available at the NLDC website.

धन्यवाद,
Thanks

ग्रिड कंट्रोलर ऑफ इंडिया लिमिटेड
राष्ट्रीय भार प्रेषण केंद्र, नई दिल्ली



Report for previous day

Date of Reporting: 03-Feb-2025

A. Power Supply Position at All India and Regional level

	NR	WR	SR	ER	NER	TOTAL
Demand Met during Evening Peak hrs(MW) (at 19:00 hrs; from RLDCs)	54215	63339	43753	22238	2606	186151
Peak Shortage (MW)	0	135	0	0	0	135
Energy Met (MU)	1192	1551	1204	463	49	4459
Hydro Gen (MU)	93	45	70	21	10	238
Wind Gen (MU)	31	50	57	-	-	138
Solar Gen (MU)*	179.20	117.23	148.40	3.28	0.82	449
Energy Shortage (MU)	0.00	0.84	0.00	0.11	0.00	0.95
Maximum Demand Met During the Day (MW) (From NLDC SCADA)	64648	76671	60642	22398	2681	224441
Time Of Maximum Demand Met	09:43	10:19	09:49	18:16	17:54	09:43

B. Frequency Profile (%)

Region	FVI	< 49.7	49.7 - 49.8	49.8 - 49.9	< 49.9	49.9 - 50.05	> 50.05
All India	0.028	0.00	0.05	2.23	2.28	82.43	15.29

C. Power Supply Position in States

Region	States	Max.Demand Met during the day (MW)	Shortage during maximum Demand (MW)	Energy Met (MU)	Drawal Schedule (MU)	OD(+)/UD(-) (MU)	Max OD (MW)	Energy Shortage (MU)
NR	Punjab	8420	0	149.8	58.2	-1.5	433	0.00
	Haryana	7772	0	142.8	103.2	-2.1	481	0.00
	Rajasthan	18406	0	337.2	113.4	-5.8	266	0.00
	Delhi	4583	0	72.7	65.4	-1.5	284	0.00
	UP	18860	0	342.9	95.3	0.0	610	0.00
	Uttarakhand	2254	0	39.9	30.6	-0.1	103	0.00
	HP	1993	0	35.3	29.5	-0.9	156	0.00
	J&K(UT) & Ladakh(UT)	3040	0	63.9	62.7	-2.6	830	0.00
	Chandigarh	231	0	3.7	4.1	-0.4	25	0.00
	Railways NR ISTS	197	0	4.0	3.9	0.2	30	0.00
WR	Chhattisgarh	5886	0	127.0	74.4	-0.8	224	0.00
	Gujarat	22136	0	412.2	178.9	-2.0	463	0.00
	MP	18596	0	348.2	229.1	-3.7	534	0.84
	Maharashtra	27642	0	587.4	232.3	-6.2	427	0.00
	Goa	656	0	13.4	12.9	0.2	64	0.00
	DNHDDPDCL	1222	0	28.7	28.8	-0.1	29	0.00
	AMNSIL	814	0	17.4	9.0	0.3	286	0.00
	BALCO	531	0	12.7	12.7	0.0	7	0.00
	RIL JAMNAGAR	185	0	4.4	4.5	-0.1	0	0.00
	Andhra Pradesh	12009	0	217.7	48.5	-0.5	638	0.00
SR	Telangana	14826	0	282.3	161.5	0.3	845	0.00
	Karnataka	16478	0	291.0	101.5	-0.5	619	0.00
	Kerala	4369	0	83.7	68.0	1.4	368	0.00
	Tamil Nadu	14818	0	321.3	182.4	-1.1	758	0.00
	Puducherry	363	0	8.3	8.0	-0.3	17	0.00
	Bihar	5205	0	100.7	87.3	1.5	286	0.11
ER	DVC	3244	0	68.3	-39.2	-0.1	301	0.00
	Jharkhand	2038	0	38.2	30.0	-1.1	232	0.00
	Odisha	4997	0	101.9	30.9	-1.0	308	0.00
	West Bengal	7198	0	151.8	27.3	-2.0	134	0.00
	Sikkim	99	0	1.6	1.8	-0.2	3	0.00
	Railways ER ISTS	28	0	0.3	0.3	0.0	4	0.00
NER	Arunachal Pradesh	192	0	3.3	3.5	-0.3	28	0.00
	Assam	1442	0	26.9	21.8	0.2	250	0.00
	Manipur	246	0	3.7	3.8	-0.1	24	0.00
	Meghalaya	339	0	6.3	5.5	-0.3	105	0.00
	Mizoram	125	0	2.0	1.8	-0.3	15	0.00
	Nagaland	154	0	2.5	2.5	0.0	13	0.00
	Tripura	227	0	4.2	3.1	0.3	48	0.00

D. Transnational Exchanges (MU) - Import(+ve)/Export(-ve)

	Bhutan	Nepal	Bangladesh	Godda -> Bangladesh
Actual (MU)	-6.9	-10.5	-21.6	-16.3
Day Peak (MW)	-514.3	-607.2	-1003.0	-763.0

E. Import/Export by Regions (in MU) - Import(+ve)/Export(-ve); OD(+)/UD(-)

	NR	WR	SR	ER	NER	TOTAL
Schedule(MU)	183.0	-214.3	183.7	-161.4	8.9	0.0
Actual(MU)	161.4	-199.0	178.4	-154.7	7.1	-6.8
O/D/U/D(MU)	-21.6	15.3	-5.4	6.7	-1.9	-6.8

F. Generation Outage(MW)

	NR	WR	SR	ER	NER	TOTAL	% Share
Central Sector	4669	6703	4628	3856	697	20553	42
State Sector	7093	12228	5899	2559	161	27940	58
Total	11762	18931	10527	6415	858	48493	100

G. Sourcewise generation (Gross) (MU)

	NR	WR	SR	ER	NER	All India	% Share
Coal	717	1584	661	677	14	3654	75
Lignite	27	16	49	0	0	92	2
Hydro	93	45	70	21	10	238	5
Nuclear	33	54	71	0	0	158	3
Gas, Naptha & Diesel	9	10	10	0	22	51	1
RES (Wind, Solar, Biomass & Others)	236	171	237	6	1	650	13
Total	1115	1880	1098	704	46	4843	100

Share of RES in total generation (%)	21.13	9.09	21.56	0.88	1.82	13.43
Share of Non-fossil fuel (Hydro,Nuclear and RES) in total generation(%)	32.44	14.36	34.39	3.82	22.82	21.61

H. All India Demand Diversity Factor

Based on Regional Max Demands	1.011
Based on State Max Demands	1.032

I. All India Peak Demand and shortage at Solar and Non-Solar Hour

	Max Demand Met(MW)	Time	Shortage(MW)
Solar hr	224441	9:43	255
Non-Solar hr	193168	18:53	0

Diversity Factor = Sum of regional or state maximum demands / All India maximum demand

**Note: All generation MU figures are gross

***Godda (Jharkhand) -> Bangladesh power exchange is through the radial connection (isolated from Indian Grid)

Solar Hours -> 06:00 to 18:00hrs and rest are Non-Solar Hours

*Source: RLDCs for solar connected to ISTS; SLDCs for embedded solar. Limited visibility of embedded solar data.

Executive Director-NLDC

INTER-REGIONAL EXCHANGES

Import=(+ve) /Export =(-ve) for NET (MU)

Date of Reporting: 03-Feb-2025

Sl No	Voltage Level	Line Details	No. of Circuit	Max Import (MW)	Max Export (MW)	Import (MU)	Export (MU)	NET (MU)
Import/Export of ER (With NR)								
1	HVDC	ALIPURDUAR-AGRA	2	0	0	0.0	0.0	0.0
2	HVDC	PUSAULI B/B	-	0	49	0.0	1.3	-1.3
3	765 kV	GAYA-VARANASI	2	326	971	0.0	12.5	-12.5
4	765 kV	SASARAM-FATEHPUR	1	63	577	0.0	8.1	-8.1
5	765 kV	GAYA-BALIA	1	0	670	0.0	9.0	-9.0
6	400 kV	PUSAULI-VARANASI	1	0	90	0.0	1.0	-1.0
7	400 kV	PUSAULI -ALLAHABAD	1	43	35	0.0	0.3	-0.3
8	400 kV	MUZAFFARPUR-GORAKHPUR	2	261	674	0.0	5.4	-5.4
9	400 kV	PATNA-BALIA	2	45	821	0.0	11.6	-11.6
10	400 kV	NAUBATPUR-BALIA	2	38	274	0.0	3.6	-3.6
11	400 kV	BIHARSHARIFF-BALIA	2	273	331	0.0	1.6	-1.6
12	400 kV	MOTIHARI-GORAKHPUR	2	36	482	0.0	6.3	-6.3
13	400 kV	BIHARSHARIFF-VARANASI	2	0	0	0.0	0.0	0.0
14	400 kV	BIHARSHARIFF-SAHUPURI	2	336	443	0.0	5.3	-5.3
15	220 kV	SAHUPURI-KARMANASA	1	0	58	0.0	0.2	-0.2
16	132 kV	NAGAR UNTARI-RIHAND	1	0	0	0.1	0.0	0.1
17	132 kV	GARWAH-RIHAND	1	30	0	0.3	0.0	0.3
18	132 kV	KARMANASA-SAHUPURI	1	0	0	0.0	0.0	0.0
19	132 kV	KARMANASA-CHANDAULI	1	0	0	0.0	0.0	0.0
ER-NR						0.5	66.0	-65.6
Import/Export of ER (With WR)								
1	765 kV	JHARSUGUDA-DHARAMJAIGARH	4	762	562	1.2	0.0	1.2
2	765 kV	NEW RANCHI-DHARAMJAIGARH	2	696	1165	0.0	7.1	-7.1
3	765 kV	JHARSUGUDA-DURG	2	0	1057	0.0	19.5	-19.5
4	400 kV	JHARSUGUDA-RAIGARH	4	0	801	0.0	14.2	-14.2
5	400 kV	RANCHI-SIPAT	2	137	422	0.0	3.9	-3.9
6	220 kV	BUDHIPADAR-RAIGARH	1	17	90	0.0	0.8	-0.8
7	220 kV	BUDHIPADAR-KORBA	2	84	99	0.2	0.0	0.2
ER-WR						1.4	45.4	-44.0
Import/Export of ER (With SR)								
1	HVDC	JEYPORE-GAZUWAKA B/B	2	0	363	0.0	8.6	-8.6
2	HVDC	TALCHER-KOLAR BIPOLE	2	0	1252	0.0	30.2	-30.2
3	765 kV	ANGUL-SRIKAKULAM	2	0	2795	0.0	48.1	-48.1
4	400 kV	TALCHER-I/C	2	163	466	2.0	0.0	2.0
5	220 kV	BALIMELA-UPPER-SILERRU	1	0	0	0.0	0.0	0.0
ER-SR						0.0	86.9	-86.9
Import/Export of ER (With NER)								
1	400 kV	BINAGURI-BONGAIGAON	2	247	41	2.3	0.1	2.2
2	400 kV	ALIPURDUAR-BONGAIGAON	2	456	0	5.0	0.0	5.0
3	220 kV	ALIPURDUAR-SALAKATI	2	86	0	1.1	0.0	1.1
ER-NER						8.4	0.1	8.3
Import/Export of NER (With NR)								
1	HVDC	BISWANATH CHARIALI-AGRA	2	664	0	15.7	0.0	15.7
NER-NR						15.7	0.0	15.7
Import/Export of WR (With NR)								
1	HVDC	CHAMPA-KURUKSHETRA	2	0	3028	0.0	57.8	-57.8
2	HVDC	VINDHYACHAL B/B	-	27	147	0.0	2.4	-2.4
3	HVDC	MUNDRA-MOHINDERGARH	2	0	1452	0.0	24.9	-24.9
4	765 kV	GWALIOR-AGRA	2	396	1736	0.6	14.5	-13.9
5	765 kV	GWALIOR-PHAGI	2	591	1491	1.7	17.6	-15.9
6	765 kV	JABALPUR-ORAI	2	114	945	0.0	16.0	-16.0
7	765 kV	GWALIOR-ORAI	1	792	0	14.1	0.0	14.1
8	765 kV	SATNA-ORAI	1	0	950	0.0	16.5	-16.5
9	765 kV	BANASKANTHA-CHITORGARH	2	993	62	9.3	0.0	9.3
10	765 kV	VINDHYACHAL-VARANASI	2	0	2036	0.0	28.3	-28.3
11	400 kV	ZERDA-KANKROLI	1	220	8	2.6	0.0	2.6
12	400 kV	ZERDA-BHINMAL	1	152	6	1.8	0.0	1.8
13	400 kV	VINDHYACHAL-RIHAND	1	974	0	21.3	0.0	21.3
14	400 kV	RAPP-SHUJALPUR	2	649	232	6.5	0.5	5.9
15	400 kV	NEEMUCH-Chittorgarh	2	704	248	7.0	0.6	6.4
16	220 kV	BHANPURA-RANPUR	1	0	202	0.0	3.3	-3.3
17	220 kV	BHANPURA-MORAK	1	0	30	0.0	2.1	-2.1
18	220 kV	MEHGAON-AURAIYA	1	135	0	1.9	0.0	1.9
19	220 kV	MALANPUR-AURAIYA	1	95	0	1.2	0.0	1.2
20	132 kV	GWALIOR-SAWAI MADHOPUR	1	0	0	0.0	0.0	0.0
21	132 kV	RAJGHAT-LALITPUR	2	0	0	0.0	0.0	0.0
WR-NR						67.8	184.5	-116.7
Import/Export of WR (With SR)								
1	HVDC	BHADRAWATI B/B	-	0	1008	0.0	24.0	-24.0
2	HVDC	RAIGARH-PUGALUR	2	0	3004	0.0	68.0	-68.0
3	765 kV	SOLAPUR-RAICHUR	2	1374	1289	10.7	6.9	3.7
4	765 kV	WARDHA-NIZAMABAD	2	101	2492	0.1	29.4	-29.3
5	765 kV	WARORA-WARANGAL(NEW)	2	0	2749	0.0	34.9	-34.9
6	400 kV	KOLHAPUR-KUDGI	2	1604	0	24.1	0.0	24.1
7	220 kV	KOLHAPUR-CHIKODI	2	0	0	0.0	0.0	0.0
8	220 kV	PONDA-AMBEWADI	1	0	0	0.0	0.0	0.0
9	220 kV	XELDEM-AMBEWADI	1	0	112	2.1	0.0	2.1
WR-SR						37.0	163.2	-126.3

INTERNATIONAL EXCHANGES					Import(+ve)/Export(-ve)	
State	Region	Line Name	Max (MW)	Min (MW)	Avg (MW)	Energy Exchange (MU)
BHUTAN	ER	400kV MANGDECHHU-ALIPURDUAR 1,2&3 i.e. ALIPURDUAR RECEIPT (from MANGDECHU HEP 4*180MW)	193	-18	53	1.27
	ER	400kV TALA-BINAGURI 1,2,4 (& 400kV MALBASE - BINAGURI) i.e. BINAGURI RECEIPT (from TALA HEP 6*170MW)	-285	99	-121	-2.89
	ER	220kV CHUKHA-BIRPARA 1&2 (& 220kV MALBASE - BIRPARA) i.e. BIRPARA RECEIPT (from CHUKHA HEP 4*84MW)	-280	-120	-210	-5.03
	NER	132kV GELEPHU-SALAKATI	-22	-9	-16	-0.39
	NER	132kV MOTANGA-RANGIA	13	3	8	0.19
NEPAL	NR	NEPAL IMPORT (FROM UP)	0	0	0	-0.96
	NR	132kV MAHENDRANAGAR-TANAKPUR(NHPC)	0	0	0	-0.97
	ER	NEPAL IMPORT (FROM BIHAR)	-195	-90	-156	-3.74
	ER	400kV DHALKEBAR-MUZAFFARPUR 1&2	-358	3	-203	-4.88
BANGLADESH	ER	BHERAMARA B/B HVDC (B'DESH)	-930	-638	-842	-20.20
	ER (Isolated from Indian Grid)	400kV GODDA_TPS-RAHANPUR (B'DESH) D/C	-763	-401	-681	-16.35
	NER	132kV COMILLA-SURAJMANI NAGAR 1&2	-73	0	-58	-1.40

Export From India (in MU)

Country	GNA (ISGS/PPA)	T-GNA							TOTAL
		BILATERAL TOTAL	COLLECTIVE						
			IDAM			RTM			
			IEX	PXIL	HPX	IEX	PXIL	HPX	
Bhutan	0.00	0.32	7.32	0.00	0.00	0.36	0.00	0.00	8.00
Nepal	3.93	0.00	3.99	0.00	0.00	1.29	0.00	0.00	9.21
Bangladesh	20.85	0.00	0.00	0.00	0.00	0.00	0.00	0.00	20.85
Myanmar	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total Export	24.78	0.32	11.31	0.00	0.00	1.65	0.00	0.00	38.06

Import by India(in MU)

Country	GNA (ISGA/PPA)	T-GNA							TOTAL
		BILATERAL TOTAL	COLLECTIVE						
			IDAM			RTM			
			IEX	PXIL	HPX	IEX	PXIL	HPX	
Bhutan	0.79	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.79
Nepal	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Bangladesh	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Myanmar	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total Import	0.79	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.79

Net from India(in MU)

-ve : Export / +ve : Import

Country	GNA (ISGS/PPA)	T-GNA							TOTAL
		BILATERAL TOTAL	COLLECTIVE						
			IDAM			RTM			
			IEX	PXIL	HPX	IEX	PXIL	HPX	
Bhutan	0.79	-0.32	-7.32	0.00	0.00	-0.36	0.00	0.00	-7.21
Nepal	-3.93	0.00	-3.99	0.00	0.00	-1.29	0.00	0.00	-9.21
Bangladesh	-20.85	0.00	0.00	0.00	0.00	0.00	0.00	0.00	-20.85
Myanmar	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total Net	-23.99	-0.32	-11.31	0.00	0.00	-1.65	0.00	0.00	-37.27

