



National Load Despatch Centre
राष्ट्रीय भार प्रेषण केंद्र
GRID CONTROLLER OF INDIA LIMITED
ग्रिड कंट्रोलर ऑफ इंडिया लिमिटेड

(Government of India Enterprise/ भारत सरकार का उद्यम)
B-9, QUTUB INSTITUTIONAL AREA, KATWARIA SARAI, NEW DELHI -110016
बी-9, कुतुब इन्स्टीट्यूशनल एरिया, कटवारिया सराये, न्यू दिल्ली-110016

Ref: GRID-INDIA/NLDC/SO/Daily PSP Report

दिनांक: 16.12.2024

To,

- कार्यकारी निदेशक, पू.क्षे.भा.प्रे.के., 14, गोल्फ क्लब रोड, कोलकाता - 700033
Executive Director, ERLDC, 14 Golf Club Road, Tollygunge, Kolkata, 700033
- कार्यकारी निदेशक, ऊ.क्षे.भा.प्रे.के., 18/ए, शाहीद जीत सिंह सनसनवाल मार्ग, नई दिल्ली - 110016
Executive Director, NRLDC, 18-A, Shaheed Jeet Singh Marg, Katwaria Sarai, New Delhi - 110016
- कार्यकारी निदेशक, प.क्षे.भा.प्रे.के., एफ3, एम आई डी सी क्षेत्र, अंधेरी, मुंबई - 400093
Executive Director, WRLDC, F-3, M.I.D.C. Area, Marol, Andheri (East), Mumbai-400093
- कार्यकारी निदेशक, ऊ.पू.क्षे.भा.प्रे.के., डोंगतेह, लोअर नोंग्रह, लापालंग, शिलोंग - 793006
Executive Director, NERLDC, Dongteih, Lower Nongrah, Lapalang, Shillong - 793006, Meghalaya
- कार्यकारी निदेशक, द.क्षे.भा.प्रे.के., 29, रेस कोर्स क्रॉस रोड, बंगलुरु - 560009
Executive Director, SRLDC, 29, Race Course Cross Road, Bangalore-560009

Sub: Daily PSP Report for the date 15.12.2024.

महोदय/Dear Sir,

आईईजीसी-2023 की धारा स.-38(1) के प्रावधान के अनुसार, दिनांक 15-दिसंबर-2024 की अखिल भारतीय प्रणाली की दैनिक ग्रिड निष्पादन रिपोर्ट रांभांप्रेके की वेबसाइट पर उपलब्ध है।

As per article 38(1) of the Indian Electricity Grid Code, the daily report pertaining power supply position of All India Power System for the date 15.12.2024, is available at the NLDC website.

धन्यवाद,
Thanks

Report for previous day

Date of Reporting: 16-Dec-2024

A. Power Supply Position at All India and Regional level

	NR	WR	SR	ER	NER	TOTAL
Demand Met during Evening Peak hrs(MW) (at 19:00 hrs; from RLDCs)	53431	58662	37444	20756	2524	172817
Peak Shortage (MW)	0	0	0	0	0	0
Energy Met (MU)	1178	1410	954	431	47	4020
Hydro Gen (MU)	114	30	69	17	13	244
Wind Gen (MU)	11	92	79	-	-	181
Solar Gen (MU)*	163.77	102.00	126.68	3.19	1.17	397
Energy Shortage (MU)	0.00	0.00	0.00	0.00	0.00	0.00
Maximum Demand Met During the Day (MW) (From NLDC SCADA)	65275	71564	47769	21638	2660	205080
Time Of Maximum Demand Met	10:22	09:57	09:24	18:00	17:18	09:37

B. Frequency Profile (%)

Region	FVI	< 49.7	49.7 - 49.8	49.8 - 49.9	< 49.9	49.9 - 50.05	> 50.05
All India	0.045	0.00	0.39	4.19	4.58	73.07	22.35

C. Power Supply Position in States

Region	States	Max.Demand Met during the day (MW)	Shortage during maximum Demand (MW)	Energy Met (MU)	Drawal Schedule (MU)	OD(+)/UD(-) (MU)	Max OD (MW)	Energy Shortage (MU)
NR	Punjab	9247	0	157.6	71.8	-0.9	471	0.00
	Haryana	8024	0	145.1	94.7	-1.8	381	0.00
	Rajasthan	17196	0	321.6	119.9	-2.7	486	0.00
	Delhi	4344	0	71.7	71.3	-1.2	249	0.00
	UP	19196	0	331.9	113.4	-1.5	731	0.00
	Uttarakhand	2263	0	41.5	30.2	0.3	98	0.00
	HP	1994	0	36.4	29.8	-3.2	175	0.00
	J&K(UT) & Ladakh(UT)	3063	0	64.1	60.1	-0.9	413	0.00
	Chandigarh	219	0	3.9	3.7	0.2	58	0.00
WR	Railways_NR ISTS	201	0	4.1	3.8	0.3	33	0.00
	Chhattisgarh	4735	0	95.4	34.8	-1.3	281	0.00
	Gujarat	20487	0	385.6	188.6	-1.2	559	0.00
	MP	18149	0	332.1	212.7	-4.6	589	0.00
	Maharashtra	25699	0	524.6	187.4	-5.8	554	0.00
	Goa	630	0	12.0	11.2	0.4	64	0.00
	DNHDDPDCL	1228	0	28.3	28.4	-0.1	45	0.00
	AMNSIL	786	0	17.8	9.7	0.2	257	0.00
	BALCO	531	0	12.6	12.7	-0.1	7	0.00
SR	RIL JAMNAGAR	75	0	1.8	1.7	0.1	0	0.00
	Andhra Pradesh	9699	0	189.3	58.7	0.6	612	0.00
	Telangana	12262	0	231.5	149.8	0.1	552	0.00
	Karnataka	12155	0	211.8	39.6	-2.5	379	0.00
	Kerala	3743	0	70.8	56.7	0.4	232	0.00
	Tamil Nadu	11688	0	242.9	115.7	-8.3	584	0.00
ER	Puducherry	340	0	7.5	7.5	-0.2	27	0.00
	Bihar	4889	0	90.6	79.4	-1.0	8	0.00
	DVC	3021	0	68.0	-33.7	2.3	371	0.00
	Jharkhand	1965	0	37.0	26.1	-0.9	226	0.00
	Odisha	4961	0	100.7	25.1	0.6	664	0.00
	West Bengal	6308	0	132.7	8.7	-1.9	453	0.00
	Sikkim	98	0	1.6	1.5	0.1	31	0.00
NER	Railways_ER ISTS	26	0	0.2	0.1	0.1	3	0.00
	Arunachal Pradesh	167	0	2.7	2.8	-0.3	16	0.00
	Assam	1432	0	25.9	18.2	0.7	115	0.00
	Manipur	246	0	2.9	3.8	-0.9	19	0.00
	Meghalaya	334	0	6.3	6.1	-0.2	27	0.00
	Mizoram	129	0	2.5	1.6	-0.1	17	0.00
	Nagaland	160	0	2.4	2.4	-0.1	50	0.00
	Tripura	222	0	4.2	3.2	0.0	45	0.00

D. Transnational Exchanges (MU) - Import(+ve)/Export(-ve)

	Bhutan	Nepal	Bangladesh	Godda -> Bangladesh
Actual (MU)	-6.3	-3.2	-12.8	-14.3
Day Peak (MW)	-513.1	-255.0	-548.0	-766.0

E. Import/Export by Regions (in MU) - Import(+ve)/Export(-ve); OD(+)/UD(-)

	NR	WR	SR	ER	NER	TOTAL
Schedule(MU)	227.4	-184.4	119.3	-167.8	5.5	0.0
Actual(MU)	220.6	-176.5	103.4	-158.9	3.8	-7.6
O/D/U/D(MU)	-6.8	7.9	-15.9	9.0	-1.7	-7.6

F. Generation Outage(MW)

	NR	WR	SR	ER	NER	TOTAL	% Share
Central Sector	4579	9114	8108	4338	518	26657	45
State Sector	7388	13356	8084	3099	191	32117	55
Total	11967	22470	16192	7437	709	58774	100

G. Sourcewise generation (Gross) (MU)

	NR	WR	SR	ER	NER	All India	% Share
Coal	672	1397	521	641	8	3239	74
Lignite	24	7	27	0	0	58	1
Hydro	114	30	69	17	13	244	6
Nuclear	32	68	70	0	0	169	4
Gas, Naptha & Diesel	2	8	3	0	25	38	1
RES (Wind, Solar, Biomass & Others)	200	198	230	6	1	636	14
Total	1044	1709	920	664	48	4384	100

Share of RES in total generation (%)	19.19	11.58	25.00	0.94	2.46	14.50
Share of Non-fossil fuel (Hydro,Nuclear and RES) in total generation(%)	33.20	17.32	40.15	3.44	30.49	23.93

H. All India Demand Diversity Factor

Based on Regional Max Demands	1.018
Based on State Max Demands	1.033

I. All India Peak Demand and shortage at Solar and Non-Solar Hour

	Max Demand Met(MW)	Time	Shortage(MW)
Solar hr	205080	9:37	0
Non-Solar hr	183666	18:26	0

Diversity factor = Sum of regional or state maximum demands / All India maximum demand

**Note: All generation MU figures are gross

***Godda (Jharkhand) -> Bangladesh power exchange is through the radial connection (isolated from Indian Grid)

Solar Hours -> 06:00 to 18:00hrs and rest are Non-Solar Hours

*Source: RLDCs for solar connected to ISTS; SLDCs for embedded solar. Limited visibility of embedded solar data.

Executive Director-NLDC

INTER-REGIONAL EXCHANGES								
Import=(+ve) /Export =(-ve) for NET (MU)								
Date of Reporting: 16-Dec-2024								
Sl No	Voltage Level	Line Details	No. of Circuit	Max Import (MW)	Max Export (MW)	Import (MU)	Export (MU)	NET (MU)
Import/Export of ER (With NR)								
1	HVDC	ALIPURDUAR-AGRA	2	0	0	0.0	0.0	0.0
2	HVDC	PUSAULI B/B	-	0	249	0.0	5.9	-5.9
3	765 kV	GAYA-VARANASI	2	14	1014	0.0	12.0	-12.0
4	765 kV	SASARAM-FATEHPUR	1	0	563	0.0	6.8	-6.8
5	765 kV	GAYA-BALIA	1	0	650	0.0	11.6	-11.6
6	400 kV	PUSAULI-VARANASI	1	0	209	0.0	3.8	-3.8
7	400 kV	PUSAULI -ALLAHABAD	1	0	124	0.0	2.0	-2.0
8	400 kV	MUZAFFARPUR-GORAKHPUR	2	0	574	0.0	7.9	-7.9
9	400 kV	PATNA-BALIA	2	0	989	0.0	16.5	-16.5
10	400 kV	NAUBATPUR-BALIA	2	0	319	0.0	5.3	-5.3
11	400 kV	BIHARSHARIFF-BALIA	2	15	248	0.0	3.2	-3.2
12	400 kV	MOTIHARI-GORAKHPUR	2	0	579	0.0	9.1	-9.1
13	400 kV	BIHARSHARIFF-VARANASI	2	0	0	0.0	0.0	0.0
14	220 kV	SAHUPURI-KARAMNASA	1	0	67	0.0	0.6	-0.6
15	132 kV	NAGAR UNTARI-RIHAND	1	0	0	0.1	0.0	0.1
16	132 kV	GARWAH-RIHAND	1	30	0	0.5	0.0	0.5
17	132 kV	KARMANASA-SAHUPURI	1	0	0	0.0	0.0	0.0
18	132 kV	KARMANASA-CHANDAULI	1	0	0	0.0	0.0	0.0
ER-NR						0.6	84.5	-83.9
Import/Export of ER (With WR)								
1	765 kV	JHARSUGUDA-DHARAMJAIGARH	4	0	966	0.0	13.6	-13.6
2	765 kV	NEW RANCHI-DHARAMJAIGARH	2	899	939	0.0	1.2	-1.2
3	765 kV	JHARSUGUDA-DURG	2	0	684	0.0	12.1	-12.1
4	400 kV	JHARSUGUDA-RAIGARH	4	0	685	0.0	9.3	-9.3
5	400 kV	RANCHI-SIPAT	2	0	0	0.0	0.0	0.0
6	220 kV	BUDHIPADAR-RAIGARH	1	0	104	0.0	1.2	-1.2
7	220 kV	BUDHIPADAR-KORBA	2	98	81	0.6	0.0	0.6
ER-WR						0.6	37.4	-36.8
Import/Export of ER (With SR)								
1	HVDC	JEYPORE-GAZUWAKA B/B	2	0	260	0.0	6.2	-6.2
2	HVDC	TALCHER-KOLAR BIPOLE	2	0	1645	0.0	39.7	-39.7
3	765 kV	ANGUL-SRIKAKULAM	2	0	2765	0.0	48.4	-48.4
4	400 kV	TALCHER-I/C	2	229	157	2.9	0.0	2.9
5	220 kV	BALIMELA-UPPER-SILERRU	1	0	0	0.0	0.0	0.0
ER-SR						0.0	94.3	-94.3
Import/Export of ER (With NER)								
1	400 kV	BINAGURI-BONGAIGAON	2	256	0	3.5	0.0	3.5
2	400 kV	ALIPURDUAR-BONGAIGAON	2	455	0	7.1	0.0	7.1
3	220 kV	ALIPURDUAR-SALAKATI	2	96	0	1.5	0.0	1.5
ER-NER						12.1	0.0	12.1
Import/Export of NER (With NR)								
1	HVDC	BISWANATH CHARIALI-AGRA	2	669	0	16.3	0.0	16.3
NER-NR						16.3	0.0	16.3
Import/Export of WR (With NR)								
1	HVDC	CHAMPA-KURUKSHETRA	2	0	2034	0.0	47.3	-47.3
2	HVDC	VINDHYACHAL B/B	-	0	55	0.0	1.2	-1.2
3	HVDC	MUNDRA-MOHINDERGARH	2	0	1457	0.0	32.5	-32.5
4	765 kV	GWALIOR-AGRA	2	0	1672	0.0	23.2	-23.2
5	765 kV	GWALIOR-PHAGI	2	167	1658	0.2	20.7	-20.5
6	765 kV	JABALPUR-ORAI	2	0	819	0.0	28.2	-28.2
7	765 kV	GWALIOR-ORAI	1	904	0	13.9	0.0	13.9
8	765 kV	SATNA-ORAI	1	0	953	0.0	18.6	-18.6
9	765 kV	BANASKANTHA-CHITORGARH	2	968	325	7.8	1.0	6.8
10	765 kV	VINDHYACHAL-VARANASI	2	0	2580	0.0	35.6	-35.6
11	400 kV	ZERDA-KANKROLI	1	280	52	2.5	0.1	2.5
12	400 kV	ZERDA -BHINMAL	1	194	36	1.7	0.0	1.7
13	400 kV	VINDHYACHAL -RIHAND	1	964	0	21.6	0.0	21.6
14	400 kV	RAPP-SHUJALPUR	2	461	183	3.0	0.9	2.1
15	400 kV	NEEMUCH-Chittorgarh	2	480	203	3.0	0.9	2.1
16	220 kV	BHANPURA-RANPUR	1	0	205	0.0	3.3	-3.3
17	220 kV	BHANPURA-MORAK	1	0	30	0.0	1.9	-1.9
18	220 kV	MEHGAON-AURAIYA	1	115	0	1.3	0.0	1.3
19	220 kV	MALANPUR-AURAIYA	1	81	4	0.7	0.0	0.7
20	132 kV	GWALIOR-SAWAI MADHOPUR	1	0	0	0.0	0.0	0.0
21	132 kV	RAJGHAT-LALITPUR	2	0	0	0.0	0.0	0.0
WR-NR						55.8	215.3	-159.5
Import/Export of WR (With SR)								
1	HVDC	BHADRAWATI B/B	-	0	1007	0.0	22.9	-22.9
2	HVDC	RAIGARH-PUGALUR	2	0	1002	0.0	23.5	-23.5
3	765 kV	SOLAPUR-RAICHUR	2	2353	629	15.0	2.7	12.4
4	765 kV	WARDHA-NIZAMABAD	2	92	1985	0.0	24.0	-24.0
5	765 kV	WARORA-WARANGAL(NEW)	2	134	2103	0.1	26.9	-26.9
6	400 kV	KOLHAPUR-KUDGI	2	1913	0	28.7	0.0	28.7
7	220 kV	KOLHAPUR-CHIKODI	2	0	0	0.0	0.0	0.0
8	220 kV	PONDA-AMBEWADI	1	0	0	0.0	0.0	0.0
9	220 kV	XELDEM-AMBEWADI	1	1	114	2.4	0.0	2.4
WR-SR						46.2	100.0	-53.8
INTERNATIONAL EXCHANGES								
State	Region	Line Name	Max (MW)	Min (MW)	Avg (MW)	Import(+ve)/Export(-ve) Energy Exchange (MU)		
BHUTAN	ER	400kV MANGDECHHU-ALIPURDUAR 1,2&3 i.e. ALIPURDUAR RECEIPT (from MANGDECHU HEP 4*180MW)	-130	103	-11	-0.26		
	ER	400kV TALA-BINAGURI 1,2,4 (& 400kV MALBASE - BINAGURI) i.e. BINAGURI RECEIPT (from TALA HEP 6*170MW)	-199	151	-35	-0.84		
	ER	220kV CHUKHA-BIRPARA 1&2 (& 220kV MALBASE - BIRPARA) i.e. BIRPARA RECEIPT (from CHUKHA HEP 4*84MW)	-269	-142	-201	-4.82		
	NER	132kV GELEPHU-SALAKATI	-26	-14	-20	-0.48		
	NER	132kV MOTANGA-RANGIA	12	0	4	0.10		
NEPAL	NR	NEPAL IMPORT (FROM UP)	-72	0	0	0.00		
	NR	132kV MAHENDRANAGAR-TANAKPUR(NHPC)	-72	0	-42	-1.02		
	ER	NEPAL IMPORT (FROM BIHAR)	0	0	0	0.00		
	ER	400kV DHALKEBAR-MUZAFFARPUR 1&2	-255	-16	-91	-2.19		
BANGLADESH	ER	BHERAMARA B/B HVDC (B'DESH)	-490	-488	-489	-11.73		
	ER (Isolated from Indian Grid)	400kV GODDA_TPS-RAHANPUR (B'DESH) D/C	-766	-404	-597	-14.32		
	NER	132kV COMILLA-SURAJMANI NAGAR 1&2	-58	0	-45	-1.08		

CROSS BORDER EXCHANGE SCHEDULE

Date of Reporting: 16-Dec-2024

Export From India (in MU)

Country	GNA (ISGS/PPA)	T-GNA							TOTAL
		BILATERAL TOTAL	COLLECTIVE						
			IDAM			RTM			
			IEX	PXIL	HPX	IEX	PXIL	HPX	
Bhutan	0.00	0.00	6.81	0.00	0.00	0.73	0.00	0.00	7.54
Nepal	0.13	0.00	0.00	0.00	0.00	2.65	0.00	0.00	2.78
Bangladesh	12.20	0.00	0.00	0.00	0.00	0.00	0.00	0.00	12.20
Myanmar	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total Export	12.33	0.00	6.81	0.00	0.00	3.38	0.00	0.00	22.52

Import by India(in MU)

Country	GNA (ISGA/PPA)	T-GNA							TOTAL
		BILATERAL TOTAL	COLLECTIVE						
			IDAM			RTM			
			IEX	PXIL	HPX	IEX	PXIL	HPX	
Bhutan	0.65	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.65
Nepal	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Bangladesh	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Myanmar	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total Import	0.65	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.65

Net from India(in MU)

-ve : Export / +ve : Import

Country	GNA (ISGS/PPA)	T-GNA							TOTAL
		BILATERAL TOTAL	COLLECTIVE						
			IDAM			RTM			
			IEX	PXIL	HPX	IEX	PXIL	HPX	
Bhutan	0.65	0.00	-6.81	0.00	0.00	-0.73	0.00	0.00	-6.89
Nepal	-0.13	0.00	0.00	0.00	0.00	-2.65	0.00	0.00	-2.78
Bangladesh	-12.20	0.00	0.00	0.00	0.00	0.00	0.00	0.00	-12.20
Myanmar	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total Net	-11.68	0.00	-6.81	0.00	0.00	-3.38	0.00	0.00	-21.87

Date of Reporting: 16-Dec-2024												
15 Min (INSTANTANEOUS) ALL INDIA GRID FREQUENCY, GENERATION & DEMAND MET (SCADA DATA)												
TIME	FREQUENCY (Hz)	DEMAND MET (MW)	NUCLEAR (MW)	WIND (MW)	SOLAR (MW)	HYDRO** (MW)	GAS (MW)	THERMAL (MW)	OTHERS* (MW)	NET DEMAND MET (MW)	TOTAL GENERATION (MW)	NET TRANSNATIONAL EXCHANGE (MW) (+ve) Import, (-ve) Export
		(A)	(B)	(C)	(D)	(E)	(F)	(G)	(H)	(I=A-(C+D))	(J=B+C+D+E+F+G+H)	(K)
0:00	50.02	144602	6628	12638	4634	6935	1550	117674	3073	127330	153132	-913
0:15	49.92	143313	6631	12519	4621	6823	1562	116018	3069	126173	151243	-963
0:30	49.92	142549	6631	12291	4621	7151	1564	115226	3094	125637	150578	-960
0:45	50.02	141813	6642	12008	4621	7371	1562	114620	3102	125184	149926	-964
1:00	49.97	140614	6644	11652	4621	7110	1561	114062	3096	124341	148746	-1041
1:15	49.97	139617	6636	11538	4621	6935	1553	113428	3084	123458	147795	-1024
1:30	49.97	138877	6640	11209	4620	6870	1556	113046	3083	123048	147024	-1037
1:45	49.97	138679	6640	10754	4620	6719	1557	113455	3070	123305	146815	-1024
2:00	49.97	137744	6650	10401	4620	6777	1456	112926	3104	122723	145934	-1063
2:15	49.97	137103	6650	10028	4626	6726	1409	112763	3098	122449	145300	-1021
2:30	49.97	136757	6651	9642	4626	6768	1409	112912	3108	122489	145116	-1036
2:45	49.97	136358	6640	9542	4626	6685	1407	112612	3127	122190	144639	-1047
3:00	50.02	136216	6653	9460	4626	6751	1404	112487	3162	122130	144543	-1063
3:15	49.96	136516	6650	9498	4626	6840	1408	112624	3134	122392	144780	-1089
3:30	50.02	136307	6629	9467	4624	6771	1408	112508	3126	122216	144533	-1093
3:45	50.02	136682	6642	9482	4626	6700	1408	113065	3087	122574	145010	-1076
4:00	50.02	136747	6654	9341	4626	6700	1402	113179	3094	122780	144996	-1049
4:15	49.97	138499	6644	9248	4626	6794	1399	115118	3112	124625	146941	-1090
4:30	50.02	140133	6631	9107	4626	7152	1412	116545	3083	126400	148556	-1104
4:45	49.97	141774	6652	8932	4626	7495	1562	118037	3071	128216	150375	-1120
5:00	50.02	143822	6644	8899	4626	7818	1568	120141	3071	130297	152767	-1152
5:15	49.97	146758	6657	8818	4627	7811	1567	123035	3057	133313	155572	-1124
5:30	50.02	150154	6651	8826	4627	8598	1398	125524	3080	136701	158704	-974
5:45	50.02	153189	6653	8869	4630	9439	1562	127422	3117	139690	161692	-987
6:00	50.12	155442	6643	9129	4632	10352	1572	128926	3051	141681	164305	-1031
6:15	50.05	158779	6659	9182	5389	10956	1401	130597	3047	144208	167231	-666
6:30	50.10	164034	6649	9266	1031	14117	1537	132543	3051	153737	168194	-672
6:45	50.00	167922	6643	9204	1131	15467	1545	134844	3048	157587	171882	-657
7:00	50.05	172040	6633	9224	1532	16614	1407	137369	3064	161284	175843	-700
7:15	49.95	176114	6638	9261	2473	17996	1413	139015	3049	164380	179845	-675
7:30	49.95	179963	6646	9388	3492	18733	1539	140446	3072	167083	183316	-682
7:45	50.00	184153	6641	9521	6195	18798	1534	141661	3105	168437	187455	-673
8:00	50.10	186306	6635	9432	10137	17519	1405	141097	3182	166737	189407	-697
8:15	50.05	189424	6648	9262	14796	14502	1412	143385	3158	165366	193163	-693
8:30	50.15	192991	6652	8960	20069	12689	1633	142858	3197	163962	196058	-673
8:45	50.10	195410	6658	8564	25120	11700	1416	142372	3208	161726	199038	-713
9:00	50.05	197933	6633	8046	30383	11008	1428	140767	3244	159504	201509	-736
9:15	49.99	202345	6641	7535	34426	10081	1426	141890	3252	160384	205251	-735
9:30	50.04	204471	6648	7138	38517	9987	1437	140495	3288	158816	207510	-771
9:45	49.99	204744	6602	6625	41535	9707	1419	138568	3268	156584	207724	-867
10:00	49.99	204704	6637	6355	44486	9231	1422	136161	3315	153863	207607	-927
10:15	50.00	204490	6634	6021	46715	8133	1400	135968	3308	151754	208179	-933
10:30	50.00	204192	6624	5777	48740	7699	1383	134538	3277	149675	208038	-980
10:45	50.05	203275	6642	5536	50825	7079	1390	131937	3308	146914	206717	-1102
11:00	50.00	202098	6638	5284	52142	6507	1393	130552	3356	144672	205872	-1235
11:15	49.99	200278	6631	5197	53230	6544	1390	128684	3327	141851	205003	-1328
11:30	49.99	199688	6625	4976	54160	6357	1393	126712	3344	140552	203567	-1280
11:45	49.91	198029	6628	4790	54248	6218	1396	125255	3369	138991	201904	-1300
12:00	49.96	196204	6619	4647	54595	6197	1391	123346	3349	136962	200144	-1334
12:15	49.80	193814	6618	4498	54645	6024	1395	120982	3308	134671	197470	-1268
12:30	49.91	193261	6596	4401	54919	6378	1396	119782	3329	133941	196801	-1282
12:45	49.96	192071	6611	4439	54869	6417	1399	118744	3257	132763	195736	-1250
13:00	50.06	190564	6602	4416	54728	6869	1386	117182	3252	131420	194435	-1248
13:15	50.00	187436	6632	4459	54156	6213	1385	114812	3252	128821	190909	-1237
13:30	50.00	185540	6567	4337	53525	6033	1386	114024	3260	127678	189132	-1279
13:45	50.06	184505	6552	4362	52627	6187	1385	113937	3226	127516	188276	-1334
14:00	50.11	182968	6547	4308	51296	5934	1391	113883	3247	127364	186606	-1295
14:15	50.21	181907	6558	4298	49677	5774	1383	114610	3226	127932	185526	-1311
14:30	50.21	181690	6543	4402	47872	6107	1377	115950	3182	129416	185433	-1349
14:45	50.16	181436	6543	4499	45807	6352	1378	118351	3213	131130	186143	-1394
15:00	50.11	181050	6524	4619	43264	6549	1433	119717	3227	133167	185333	-1423
15:15	50.01	180034	6539	4770	40614	6826	1436	120673	3168	134650	184026	-1408
15:30	50.01	179820	6539	4841	37528	7288	1427	123127	3164	137451	183914	-1379
15:45	49.96	179035	6538	4951	34144	8019	1431	125151	3212	139940	183446	-1369
16:00	49.91	178503	6532	5150	30175	8992	1420	127690	3146	143178	183105	-1342
16:15	49.86	176314	6527	5098	25691	8696	1424	130026	3082	145525	180544	-1101
16:30	49.86	177340	6530	5175	20857	9792	1427	134569	3093	151308	181443	-816
16:45	50.01	178361	6526	5283	15269	11888	1421	138862	3059	157809	182308	-795
17:00	50.01	178531	6540	5350	10646	13668	1412	142007	3014	162535	182637	-825
17:15	50.06	177084	6513	5496	6615	15348	1404	142587	2985	164973	180948	-697
17:30	50.06	178140	6527	5728	3957	17401	1415	144425	2978	168455	182431	-747
17:45	50.06	180062	6536	5977	2319	20017	1393	145509	2961	171766	184712	-751
18:00	50.06	181596	6547	6370	2282	21540	1401	145431	2896	172944	186467	-714
18:15	50.01	182823	6539	6769	6484	21773	1397	146137	2942	169570	192041	-702
18:30	50.06	183254	6539	7285	6498	22061	1402	146266	2964	169471	193015	-666
18:45	50.06	182161	6547	7777	6486	21870	1400	144063	3008	167898	191151	-644
19:00	50.06	180104	6546	8260	6478	21086	1394	142247	2948	165366	188959	-628
19:15	50.06	178239	6545	8794	6479	20032	1400	140979	2968	162966	187197	-649
19:30	50.01	175621	6550	9279	6479	17460	1421	140055	2969	159863	184213	-646
19:45	50.01	172932	6558	9590	5025	15293	1431	139047	2993	158317	179937	-598
20:00	50.06	169812	6556	9833	5032	13645	1445	137379	3012	154947	176902	-590
20:15	49.96	166343	6551	10026	4797	12372	1462	135047	3032	151520	173287	-563
20:30	50.01	164270	6557	10116	4798	12056	1489	133007	3087	149356	171110	-596
20:45	49.96	161981	6551	10232	4769	11931	1482	130732	3013	146980	168710	-558
21:00	50.01	158800	6557	10303	4762	11421	1476	127947	2996	143735	165462	-589
21:15	50.01	156382	6560	10120	4759	10572	1557	126704	3014	141503	163286	-729
21:30	50.01	154101	6556	10084	4759	10273	1565	125568	3035	139258	161840	-844
21:45	50.01	151876	6559	10131	4759	9744	1570	123310	3053	136986	159126	-962
22:00	50.06	149344	6555	10066	4759	9553	1558	122172	3036	134519	157699	-1095
22:15	49.96	149251	6557	9978	4762	9821	1562	121108	3037	134511	156825	-1058
22:30	50.06	147793	6566									