



National Load Despatch Centre
राष्ट्रीय भार प्रेषण केंद्र
GRID CONTROLLER OF INDIA LIMITED
ग्रिड कंट्रोलर ऑफ इंडिया लिमिटेड

(Government of India Enterprise/ भारत सरकार का उद्यम)
B-9, QUTUB INSTITUTIONAL AREA, KATWARIA SARAI, NEW DELHI -110016
बी-9, कुतुब इन्स्टीट्यूशनल एरिया, कटवारिया सराये, न्यू दिल्ली-110016

Ref: GRID-INDIA/NLDC/SO/Daily PSP Report

दिनांक: 04.12.2025

To,

- कार्यकारी निदेशक, पू.क्षे.भा.प्रे.के., 14, गोल्फ क्लब रोड, कोलकाता - 700033
Executive Director, ERLDC, 14 Golf Club Road, Tollygunge, Kolkata, 700033
- कार्यकारी निदेशक, ऊ.क्षे.भा.प्रे.के., 18/ए, शाहीद जीत सिंह सनसनवाल मार्ग, नई दिल्ली - 110016
Executive Director, NRLDC, 18-A, Shaheed Jeet Singh Marg, Katwaria Sarai, New Delhi - 110016
- कार्यकारी निदेशक, प.क्षे.भा.प्रे.के., एफ3, एम आई डी सी क्षेत्र, अंधेरी, मुंबई - 400093
Executive Director, WRLDC, F-3, M.I.D.C. Area, Marol, Andheri (East), Mumbai-400093
- कार्यकारी निदेशक, ऊ.पू.क्षे.भा.प्रे.के., डोंगतेह, लोअर नोंग्रह, लापालंग, शिलोंग - 793006
Executive Director, NERLDC, Dongteih, Lower Nongrah, Lapalang, Shillong - 793006, Meghalaya
- कार्यकारी निदेशक, द.क्षे.भा.प्रे.के., 29, रेस कोर्स क्रॉस रोड, बंगलुरु - 560009
Executive Director, SRLDC, 29, Race Course Cross Road, Bangalore-560009

Sub: Daily PSP Report for the date 03.12.2025.

महोदय/Sir,

आईईजीसी-2023 की धारा स.-38(1) के प्रावधान के अनुसार, दिनांक 3-दिसंबर-2025 की अखिल भारतीय प्रणाली की दैनिक ग्रिड निष्पादन रिपोर्ट रांभांप्रेके की वेबसाइट पर उपलब्ध है।

As per article 38(1) of the Indian Electricity Grid Code, the daily report pertaining power supply position of All India Power System for the date 03.12.2025, is available at the NLDC website.

धन्यवाद,
Thanks

Report for previous day

Date of Reporting: 04-Dec-2025

A. Power Supply Position at All India and Regional level

	NR	WR	SR	ER	NER	TOTAL
Demand Met during Evening Peak hrs(MW) (at 19:00 hrs; from RLDCs)	56583	63662	47412	22144	2769	192570
Peak Shortage (MW)	0	0	0	0	0	0
Energy Met (MU)	1252	1500	1104	448	51	4354
Hydro Gen (MU)	123	52	105	27	13	320
Wind Gen (MU)	23	108	49	-	-	179
Solar Gen (MU)*	170.87	153.23	81.41	2.85	0.94	409
Energy Shortage (MU)	0.42	0.00	0.00	0.00	0.00	0.42
Maximum Demand Met During the Day (MW) (From NLDC SCADA)	67576	71668	54830	22621	2979	215296
Time Of Maximum Demand Met	10:24	09:58	09:52	17:45	17:03	09:58

B. Frequency Profile (%)

Region	FVI	< 49.7	49.7 - 49.8	49.8 - 49.9	< 49.9	49.9 - 50.05	> 50.05
All India	0.049	0.27	1.38	6.21	7.86	73.88	18.26

C. Power Supply Position in States

Region	States	Max.Demand Met during the day (MW)	Shortage during maximum Demand (MW)	Energy Met (MU)	Drawal Schedule (MU)	OD(+)/UD(-) (MU)	Max OD (MW)	Energy Shortage (MU)
NR	Punjab	10060	0	171.8	76.0	-0.3	594	0.00
	Haryana	9120	0	168.0	129.3	-1.0	269	0.00
	Rajasthan	18012	0	331.0	111.8	-0.4	1035	0.00
	Delhi	4211	0	78.9	72.1	1.3	440	0.00
	UP	19377	0	348.5	81.3	-0.5	232	0.00
	Uttarakhand	2338	0	42.6	32.4	1.0	208	0.27
	HP	2175	0	38.9	28.8	-0.3	74	0.00
	J&K(UT) & Ladakh(UT)	3100	0	64.5	59.3	-0.3	205	0.15
	Chandigarh	234	0	3.9	3.9	0.1	21	0.00
	Railways_NR ISTS	197	0	4.1	3.8	0.3	29	0.00
WR	Chhattisgarh	4754	0	92.9	33.5	-1.5	657	0.00
	Gujarat	21861	0	425.3	176.3	-7.0	1043	0.00
	MP	18097	0	334.8	205.6	0.0	469	0.00
	Maharashtra	26662	0	564.7	188.4	-5.2	619	0.00
	Goa	715	0	14.3	11.7	2.1	53	0.00
	DNHDDPDCL	1350	0	30.5	30.4	0.1	41	0.00
	AMNSIL	862	0	18.3	11.1	0.6	265	0.00
	BALCO	562	0	13.4	13.5	-0.1	12	0.00
	RIL JAMNAGAR	260	0	5.9	5.9	0.0	0	0.00
	Andhra Pradesh	9512	0	196.7	47.7	0.9	633	0.00
SR	Telangana	11814	0	216.3	90.4	-0.8	868	0.00
	Karnataka	16230	0	283.2	114.5	-1.6	584	0.00
	Kerala	4359	0	87.1	67.1	0.0	373	0.00
	Tamil Nadu	15784	0	312.0	206.3	-0.4	1577	0.00
	Puducherry	402	0	8.3	8.1	-0.3	43	0.00
	Bihar	5110	0	92.0	77.6	-0.6	266	0.00
ER	DVC	3206	0	66.3	-48.0	1.3	450	0.00
	Jharkhand	2163	0	39.1	32.5	-2.3	225	0.00
	Odisha	4973	0	95.5	14.2	-2.2	384	0.00
	West Bengal	7711	0	152.8	32.6	-2.3	199	0.00
	Sikkim	108	0	1.7	1.6	0.0	44	0.00
	Railways_ER ISTS	27	0	0.2	0.2	0.0	4	0.00
NER	Arunachal Pradesh	181	0	3.1	3.0	-0.1	22	0.00
	Assam	1699	0	28.8	23.3	0.3	140	0.00
	Manipur	251	0	3.8	3.6	0.2	47	0.00
	Meghalaya	359	0	6.1	5.1	-0.2	41	0.00
	Mizoram	157	0	2.3	1.8	-0.2	10	0.00
	Nagaland	175	0	2.5	2.7	-0.4	11	0.00
	Tripura	231	0	4.1	4.9	0.1	46	0.00

D. Transnational Exchanges (MU) - Import(+ve)/Export(-ve)

	Bhutan	Nepal	Bangladesh	Godda -> Bangladesh
Actual (MU)	-5.2	11.3	-21.8	-26.2
Day Peak (MW)	-475.7	695.9	-999.6	-1391.7

E. Import/Export by Regions (in MU) - Import(+ve)/Export(-ve); OD(+)/UD(-)

	NR	WR	SR	ER	NER	TOTAL
Schedule(MU)	216.4	-220.1	193.6	-199.8	9.9	0.0
Actual(MU)	210.9	-218.5	193.7	-198.7	8.2	-4.3
O/D/U/D(MU)	-5.5	1.6	0.2	1.1	-1.7	-4.3

F. Generation Outage(MW)

	NR	WR	SR	ER	NER	TOTAL	% Share
Central Sector	5699	14880	7788	6280	530	35177	50
State Sector	11859	12030	8674	2187	205	34954	50
Total	17558	26909	16462	8467	735	70131	100

G. Sourcewise generation (Gross) (MU)

	NR	WR	SR	ER	NER	All India	% Share
Coal	722	1447	651	691	12	3523	74
Lignite	25	10	42	0	0	76	2
Hydro	123	52	105	27	13	320	7
Nuclear	37	52	46	0	0	136	3
Gas, Naptha & Diesel	10	20	4	0	22	56	1
RES (Wind, Solar, Biomass & Others)	219	264	154	6	1	644	14
Total	1136	1845	1003	724	48	4755	100

Share of RES in total generation (%)	19.32	14.31	15.40	0.78	1.96	13.55
Share of Non-fossil fuel (Hydro,Nuclear and RES) in total generation(%)	33.45	19.96	30.51	4.47	29.49	23.14

H. All India Demand Diversity Factor

Based on Regional Max Demands	1.020
Based on State Max Demands	1.060

I. All India Peak Demand and shortage at Solar and Non-Solar Hour

	Max Demand Met(MW)	Time	Shortage(MW)
Solar hr	215296	9:58	0
Non-Solar hr	199826	18:24	0

Diversity factor = Sum of regional or state maximum demands / All India maximum demand

**Note: All generation MU figures are gross

***Godda (Jharkhand) -> Bangladesh power exchange is through the radial connection (isolated from Indian Grid)

Solar Hours -> 06:00 to 18:00hrs and rest are Non-Solar Hours

*Source: RLDCs for solar connected to ISTS; SLDCs for embedded solar. Limited visibility of embedded solar data.

Executive Director-NLDC

INTER-REGIONAL EXCHANGES

Import=(+ve)/Export =(-ve) for NET (MU)
Date of Reporting: 04-Dec-2025

Sl No	Voltage Level	Line Details	No. of Circuit	Max Import (MW)	Max Export (MW)	Import (MU)	Export (MU)	NET (MU)
Import/Export of ER (With NR)								
1	HVDC	ALIPURDUAR-AGRA	2	0	0	0.0	0.0	0.0
2	HVDC	PUSAULI B/B	-	0	47	0.0	2.4	-2.4
3	765 kV	GAYA-VARANASI	2	0	1294	0.0	18.7	-18.7
4	765 kV	SASARAM-FATEHPUR	1	0	711	0.0	10.9	-10.9
5	765 kV	GAYA-BALIA	1	0	605	0.0	9.9	-9.9
6	400 kV	PUSAULI-VARANASI	1	47	72	0.0	0.6	-0.6
7	400 kV	PUSAULI-ALLAHABAD	1	0	144	0.0	1.7	-1.7
8	400 kV	MUZAFFARPUR-GORAKHPUR	2	97	748	0.0	7.3	-7.3
9	400 kV	PATNA-BALIA	2	0	907	0.0	15.0	-15.0
10	400 kV	NAUBATPUR-BALIA	2	61	247	0.0	5.0	-5.0
11	400 kV	BIHARSHARIFF-BALIA	2	192	329	0.0	1.3	-1.3
12	400 kV	MOTIHARI-GORAKHPUR	2	0	533	0.0	7.8	-7.8
13	400 kV	BIHARSARIFF-SAHUPURI	2	0	509	0.0	6.5	-6.5
14	220 kV	SAHUPURI-KARMANASA	1	39	5	0.0	1.4	-1.4
15	132 kV	NAGAR UNTARI-RIHAND	1	0	0	0.0	0.0	0.0
16	132 kV	GARWAH-RIHAND	1	30	0	0.6	0.0	0.6
17	132 kV	KARMANASA-SAHUPURI	1	0	0	0.0	0.0	0.0
18	132 kV	KARMANASA-CHANDAULI	1	0	0	0.0	0.0	0.0
ER-NR						0.6	88.3	-87.7
Import/Export of ER (With WR)								
1	765 kV	JHARSUGUDA-DHARAMJAIGARH	4	0	1114	0.0	18.8	-18.8
2	765 kV	NEW RANCHI-DHARAMJAIGARH	2	62	1290	0.0	19.1	-19.1
3	765 kV	JHARSUGUDA-DURG	2	0	1259	0.0	24.2	-24.2
4	400 kV	JHARSUGUDA-RAIGARH	4	187	337	0.2	0.0	0.2
5	400 kV	RANCHI-SIPAT	2	15	368	0.0	4.8	-4.8
6	400 kV	JEYPORE-JACDALPUR	2	34	170	0.0	2.7	-2.7
7	220 kV	BUDHIPADAR-RAIGARH	1	0	138	0.0	2.0	-2.0
8	220 kV	BUDHIPADAR-KORBA	2	128	60	1.1	0.0	1.1
ER-WR						4.0	68.8	-64.9
Import/Export of ER (With SR)								
1	HVDC	JEYPORE-GAZUWAKA B/B	2	0	314	0.0	8.0	-8.0
2	HVDC	TALCHER-KOLAR BIPOLE	2	0	1620	0.0	47.3	-47.3
3	765 kV	ANGUL-SRIKAKULAM	2	0	2891	0.0	49.4	-49.4
4	400 kV	TALCHER I/C	2	0	412	0.0	2.8	-2.8
5	220 kV	BALIMELA-UPPER-SILERRU	1	2	0	0.0	0.0	0.0
ER-SR						0.0	104.6	-104.6
Import/Export of ER (With NER)								
1	400 kV	BINAGURI-BONGAIGAON	2	304	122	1.2	0.2	1.0
2	400 kV	ALIPURDUAR-BONGAIGAON	2	560	76	3.5	0.0	3.5
3	220 kV	ALIPURDUAR-SALAKATI	2	110	1	1.1	0.0	1.1
ER-NER						5.8	0.2	5.6
Import/Export of NER (With NR)								
1	HVDC	BISWANATH CHARIALI-AGRA	2	664	0	15.6	0.0	15.6
NER-NR						15.6	0.0	15.6
Import/Export of WR (With NR)								
1	HVDC	CHAMPA-KURUKSHETRA	2	0	4053	0.0	80.4	-80.4
2	HVDC	VINDHYACHAL B/B	-	242	105	4.6	0.6	4.0
3	HVDC	MUNDRA-MOHINDERGARH	2	0	789	0.0	19.4	-19.4
4	765 kV	GWALIOR-AGRA	2	336	1492	0.6	12.8	-12.3
5	765 kV	GWALIOR-PHAGI	2	511	1838	0.7	25.7	-25.1
6	765 kV	JABALPUR-ORAI	2	59	739	0.0	17.5	-17.5
7	765 kV	GWALIOR-ORAI	1	968	0	6.7	0.0	6.7
8	765 kV	SATNA-ORAI	1	0	969	0.0	18.6	-18.6
9	765 kV	BANASKANTHA-CHITORGARH	2	1716	347	17.8	0.4	17.4
10	765 kV	VINDHYACHAL-VARANASI	2	0	1892	0.0	26.5	-26.5
11	400 kV	ZERDA-KANKROLI	1	324	0	3.7	0.0	3.7
12	400 kV	ZERDA -BHINMAL	1	223	0	2.6	0.0	2.6
13	400 kV	VINDHYACHAL -RIHAND	1	968	0	21.9	0.0	21.9
14	400 kV	RAPP-SHUJALPUR	2	608	174	3.8	0.7	3.2
15	400 kV	NEEMUCH-Chittorgarh	2	671	258	4.0	1.1	2.9
16	220 kV	BHANPURA-RANPUR	1	0	131	0.0	2.1	-2.1
17	220 kV	BHANPURA-MORAK	1	0	30	0.0	1.8	-1.8
18	220 kV	MEHGAON-AURAIYA	1	160	0	1.4	0.0	1.4
19	220 kV	MALANPUR-AURAIYA	1	125	7	0.5	0.0	0.5
20	132 kV	RAIGHAT-LALITPUR	2	0	0	0.0	0.0	0.0
WR-NR						68.3	207.7	-139.4
Import/Export of WR (With SR)								
1	HVDC	BHADRAWATI B/B	-	0	251	0.0	6.0	-6.0
2	HVDC	RAIGARH-PUGALUR	2	0	4009	0.0	80.0	-80.0
3	765 kV	SOLAPUR-RAICHUR	2	377	1246	0.3	11.8	-11.5
4	765 kV	WARDHA-NIZAMABAD	2	0	2278	0.0	32.6	-32.6
5	765 kV	WARORA-WARANGAL(NEW)	2	0	2354	0.0	38.4	-38.4
6	400 kV	KOLHAPUR-KUDGI	2	1338	0	22.9	0.0	22.9
7	220 kV	KOLHAPUR-CHIKODI	2	0	0	0.0	0.0	0.0
8	220 kV	PONDA-AMBEWADI	1	0	0	0.0	0.0	0.0
9	220 kV	XELDEM-AMBEWADI	1	0	112	0.2	0.0	2.2
WR-SR						25.3	168.9	-143.6

INTERNATIONAL EXCHANGES					Import(+ve)/Export(-ve)	
State	Region	Line Name	Max (MW)	Min (MW)	Avg (MW)	Energy Exchange (MU)
BHUTAN	ER	400kV MANGDECHHU-ALIPURDUAR 1,2&3 I.e. ALIPURDUAR RECEIPT (from MANGDECHU HEP 4*180MW)	-101	52	4	0.10
	ER	400kV TALA-BINAGURI 1,2,4 (& 400kV MALBASE - BINAGURI) I.e. BINAGURI RECEIPT (from TALA HEP 6*170MW)	320	-73	130	3.12
	ER	220kV CHUKHA-BIRPARA 1&2 (& 220kV MALBASE - BIRPARA) I.e. BIRPARA RECEIPT (from CHUKHA HEP 4*84MW)	-317	-223	-280	-6.72
	NER	132kV GELEPHU-SALAKATI	-71	0	-55	-1.31
	NER	132kV MOTANGA-RANGIA	-36	0	-14	-0.34
NEPAL	NR	NEPAL IMPORT (FROM UP)	0	0	0	0.00
	NR	132kV MAHENDRANAGAR-TANAKPUR(NHPC)	56	0	35	0.84
	ER	NEPAL IMPORT (FROM BIHAR)	0	0	0	0.00
	ER	400kV DHALKEBAR-MUZAFFARPUR 1&2	544	108	438	10.50
BANGLADESH	ER	BHERAMARA B/B HVDC (B'DESH)	-890	-652	-815	-19.55
	ER (Isolated from Indian Grid)	400kV GODDA_TPS-RAHANPUR (B'DESH) D/C	-1392	-822	-1090	-26.16
	NER	132kV COMILLA-SURAJMANI NAGAR 1&2	-104	0	-94	-2.26

CROSS BORDER EXCHANGE SCHEDULE

Date of Reporting: 04-Dec-2025

Export From India (in MU)

Country	GNA (ISGS/PPA)	T-GNA							TOTAL
		BILATERAL TOTAL	COLLECTIVE						
			IDAM			RTM			
			IEX	PXIL	HPX	IEX	PXIL	HPX	
Bhutan	0.00	0.31	4.98	0.00	0.00	0.20	0.00	0.00	5.49
Nepal	0.02	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.02
Bangladesh	20.40	0.00	0.00	0.00	0.00	0.00	0.00	0.00	20.40
Myanmar	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total Export	20.42	0.31	4.98	0.00	0.00	0.20	0.00	0.00	25.91

Import by India(in MU)

Country	GNA (ISGA/PPA)	T-GNA							TOTAL
		BILATERAL TOTAL	COLLECTIVE						
			IDAM			RTM			
			IEX	PXIL	HPX	IEX	PXIL	HPX	
Bhutan	0.06	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.06
Nepal	0.00	0.00	1.46	0.00	0.00	8.87	0.00	0.00	10.33
Bangladesh	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Myanmar	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total Import	0.06	0.00	1.46	0.00	0.00	8.87	0.00	0.00	10.39

Net from India(in MU)

-ve : Export / +ve : Import

Country	GNA (ISGS/PPA)	T-GNA							TOTAL
		BILATERAL TOTAL	COLLECTIVE						
			IDAM			RTM			
			IEX	PXIL	HPX	IEX	PXIL	HPX	
Bhutan	0.06	-0.31	-4.98	0.00	0.00	-0.20	0.00	0.00	-5.43
Nepal	-0.02	0.00	1.46	0.00	0.00	8.87	0.00	0.00	10.31
Bangladesh	-20.40	0.00	0.00	0.00	0.00	0.00	0.00	0.00	-20.40
Myanmar	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total Net	-20.36	-0.31	-3.52	0.00	0.00	8.67	0.00	0.00	-15.52

