



National Load Despatch Centre
राष्ट्रीय भार प्रेषण केंद्र
GRID CONTROLLER OF INDIA LIMITED
ग्रिड कंट्रोलर ऑफ इंडिया लिमिटेड

(Government of India Enterprise/ भारत सरकार का उद्यम)
B-9, QUTUB INSTITUTIONAL AREA, KATWARIA SARAI, NEW DELHI -110016
बी-9, कुतुब इन्स्टीट्यूशनल एरिया, कटवारिया सराये, न्यू दिल्ली-110016

Ref: GRID-INDIA/NLDC/SO/Daily PSP Report

दिनांक: 08.11.2024

To,

- कार्यकारी निदेशक, पू.क्षे.भा.प्रे.के., 14, गोल्फ क्लब रोड, कोलकाता - 700033
Executive Director, ERLDC, 14 Golf Club Road, Tollygunge, Kolkata, 700033
- कार्यकारी निदेशक, ऊ.क्षे.भा.प्रे.के., 18/ए, शाहीद जीत सिंह सनसनवाल मार्ग, नई दिल्ली - 110016
Executive Director, NRLDC, 18-A, Shaheed Jeet Singh Marg, Katwaria Sarai, New Delhi - 110016
- कार्यकारी निदेशक, प.क्षे.भा.प्रे.के., एफ3, एम आई डी सी क्षेत्र, अंधेरी, मुंबई - 400093
Executive Director, WRLDC, F-3, M.I.D.C. Area, Marol, Andheri (East), Mumbai-400093
- कार्यकारी निदेशक, ऊ.पू.क्षे.भा.प्रे.के., डोंगतेह, लोअर नोंग्रह, लापलंग, शिलोंग - 793006
Executive Director, NERLDC, Dongteih, Lower Nongrah, Lapalang, Shillong - 793006, Meghalaya
- कार्यकारी निदेशक, द.क्षे.भा.प्रे.के., 29, रेस कोर्स क्रॉस रोड, बंगलुरु - 560009
Executive Director, SRLDC, 29, Race Course Cross Road, Bangalore-560009

Sub: Daily PSP Report for the date 07.11.2024.

महोदय/Dear Sir,

आईईजीसी-2023 की धारा स.-38(1) के प्रावधान के अनुसार, दिनांक 7-नवंबर-2024 की अखिल भारतीय प्रणाली की दैनिक ग्रिड निष्पादन रिपोर्ट रांभांप्रेके की वेबसाइट पर उपलब्ध है।

As per article 38(1) of the Indian Electricity Grid Code, the daily report pertaining power supply position of All India Power System for the date 07.11.2024, is available at the NLDC website.

धन्यवाद,
Thanks

Report for previous day

Date of Reporting: 08-Nov-2024

A. Power Supply Position at All India and Regional level

	NR	WR	SR	ER	NER	TOTAL
Demand Met during Evening Peak hrs(MW) (at 19:00 hrs; from RLDCs)	54455	60170	45774	22884	2736	186019
Peak Shortage (MW)	0	0	0	0	0	0
Energy Met (MU)	1238	1435	1096	489	53	4311
Hydro Gen (MU)	139	33	111	45	21	348
Wind Gen (MU)	9	45	26	-	-	80
Solar Gen (MU)*	151.01	90.14	117.88	3.32	0.74	363
Energy Shortage (MU)	0.00	0.00	0.00	0.00	0.00	0.00
Maximum Demand Met During the Day (MW) (From NLDC SCADA)	58632	65934	51762	23536	2992	199121
Time Of Maximum Demand Met	18:23	15:32	11:57	18:40	17:16	10:46

B. Frequency Profile (%)

Region	FVI	< 49.7	49.7 - 49.8	49.8 - 49.9	< 49.9	49.9 - 50.05	> 50.05
All India	0.023	0.00	0.03	0.72	0.75	83.58	15.67

C. Power Supply Position in States

Region	States	Max.Demand Met during the day (MW)	Shortage during maximum Demand (MW)	Energy Met (MU)	Drawal Schedule (MU)	OD(+)/UD(-) (MU)	Max OD (MW)	Energy Shortage (MU)
NR	Punjab	7332	0	148.5	77.7	-1.7	348	0.00
	Haryana	7365	0	152.5	111.0	-1.4	189	0.00
	Rajasthan	16530	0	329.2	124.2	-3.4	454	0.00
	Delhi	4108	0	81.0	72.8	-0.8	205	0.00
	UP	18988	0	390.5	152.4	-0.7	319	0.00
	Uttarakhand	2091	0	41.5	29.1	1.0	131	0.00
	HP	1927	0	34.6	22.5	-0.9	84	0.00
	J&K(UT) & Ladakh(UT)	2654	0	52.8	46.0	-0.2	166	0.00
	Chandigarh	209	0	4.0	4.0	-0.1	40	0.00
WR	Railways NR ISTS	198	0	4.0	3.9	0.1	31	0.00
	Chhattisgarh	4485	0	96.8	35.7	-2.1	264	0.00
	Gujarat	19268	0	393.6	203.9	-0.4	860	0.00
	MP	14947	0	298.2	171.5	-3.1	463	0.00
	Maharashtra	26149	0	570.0	233.9	3.1	671	0.00
	Goa	726	0	15.2	14.4	0.2	53	0.00
	DNHDDPDCL	1285	0	29.7	29.8	-0.1	39	0.00
	AMNSIL	820	0	18.5	8.9	0.4	267	0.00
	BALCO	532	0	12.7	12.7	0.0	11	0.00
SR	Andhra Pradesh	10790	0	219.8	71.6	1.2	937	0.00
	Telangana	10068	0	204.0	92.1	0.1	417	0.00
	Karnataka	12732	0	242.1	99.8	2.5	548	0.00
	Kerala	4505	0	85.0	64.7	1.3	333	0.00
	Tamil Nadu	15826	0	335.7	194.3	1.3	1002	0.00
	Puducherry	435	0	9.4	9.3	-0.4	35	0.00
ER	Bihar	5136	0	103.4	93.4	0.4	202	0.00
	DVC	3192	0	65.3	-41.8	0.1	461	0.00
	Jharkhand	1889	0	38.4	25.9	-0.9	155	0.00
	Odisha	5419	0	106.7	37.6	-1.5	433	0.00
	West Bengal	8521	0	173.7	42.6	-2.8	263	0.00
	Sikkim	91	0	1.4	1.5	-0.1	12	0.00
	Railways ER ISTS	24	0	0.1	0.1	0.0	9	0.00
NER	Arunachal Pradesh	147	0	2.6	2.1	0.3	357	0.00
	Assam	1782	0	32.6	23.8	1.6	199	0.00
	Manipur	208	0	2.6	2.8	-0.2	114	0.00
	Meghalaya	371	0	6.5	4.7	0.1	76	0.00
	Mizoram	124	0	1.7	1.4	-1.3	36	0.00
	Nagaland	156	0	2.3	2.2	-0.1	22	0.00
	Tripura	269	0	4.5	5.4	0.0	35	0.00

D. Transnational Exchanges (MU) - Import(+ve)/Export(-ve)

	Bhutan	Nepal	Bangladesh	Godda -> Bangladesh
Actual (MU)	8.2	12.1	-23.4	-16.4
Day Peak (MW)	491.9	558.2	-984.0	-723.0

E. Import/Export by Regions (in MU) - Import(+ve)/Export(-ve); OD(+)/UD(-)

	NR	WR	SR	ER	NER	TOTAL
Schedule(MU)	265.5	-211.4	153.4	-209.4	2.0	0.0
Actual(MU)	254.5	-207.6	163.0	-218.3	0.6	-7.8
O/D/U/D(MU)	-10.9	3.8	9.7	-8.9	-1.4	-7.8

F. Generation Outage(MW)

	NR	WR	SR	ER	NER	TOTAL	% Share
Central Sector	4859	7149	5998	2076	597	20678	41
State Sector	7578	10281	9701	2299	230	30089	59
Total	12437	17430	15699	4375	827	50767	100

G. Sourcewise generation (Gross) (MU)

	NR	WR	SR	ER	NER	All India	% Share
Coal	687	1528	592	723	14	3543	76
Lignite	27	19	55	0	0	102	2
Hydro	139	33	111	45	21	348	7
Nuclear	35	50	76	0	0	161	3
Gas, Naptha & Diesel	9	11	5	0	20	46	1
RES (Wind, Solar, Biomass & Others)	171	137	166	5	1	480	10
Total	1068	1778	1004	773	57	4680	100

Share of RES in total generation (%)	15.98	7.72	16.54	0.66	1.30	10.25
Share of Non-fossil fuel (Hydro,Nuclear and RES) in total generation(%)	32.29	12.35	35.13	6.46	38.79	21.14

H. All India Demand Diversity Factor

Based on Regional Max Demands	1.018
Based on State Max Demands	1.061

I. All India Peak Demand and shortage at Solar and Non-Solar Hour

	Max Demand Met(MW)	Time	Shortage(MW)
Solar hr	199121	10:46	0
Non-Solar hr	196506	18:31	0

Diversity factor = Sum of regional or state maximum demands / All India maximum demand

**Note: All generation MU figures are gross

***Godda (Jharkhand) -> Bangladesh power exchange is through the radial connection (isolated from Indian Grid)

Solar Hours -> 06:00 to 18:00hrs and rest are Non-Solar Hours

*Source: RLDCs for solar connected to ISTS; SLDCs for embedded solar. Limited visibility of embedded solar data.

Executive Director-NLDC

INTER-REGIONAL EXCHANGES

Import=(+ve) /Export =(-ve) for NET (MU)

Date of Reporting: 08-Nov-2024

Sl No	Voltage Level	Line Details	No. of Circuit	Max Import (MW)	Max Export (MW)	Import (MU)	Export (MU)	NET (MU)
Import/Export of ER (With NR)								
1	HVDC	ALIPURDUAR-AGRA	2	0	301	0.0	7.1	-7.1
2	HVDC	PUSAULI B/B	-	0	297	0.0	7.2	-7.2
3	765 kV	GAYA-VARANASI	2	258	1097	0.0	15.9	-15.9
4	765 kV	SASARAM-FATEHPUR	1	11	716	0.0	9.1	-9.1
5	765 kV	GAYA-BALIA	1	0	631	0.0	11.7	-11.7
6	400 kV	PUSAULI-VARANASI	1	0	206	0.0	3.6	-3.6
7	400 kV	PUSAULI -ALLAHABAD	1	0	190	0.0	3.5	-3.5
8	400 kV	MUZAFFARPUR-GORAKHPUR	2	68	567	0.0	8.2	-8.2
9	400 kV	PATNA-BALIA	2	0	963	0.0	16.9	-16.9
10	400 kV	NAUBATPUR-BALIA	2	0	316	0.0	5.7	-5.7
11	400 kV	BIHARSHARIFF-BALIA	2	162	138	0.0	0.9	-0.9
12	400 kV	MOTIHARI-GORAKHPUR	2	0	517	0.0	8.9	-8.9
13	400 kV	BIHARSHARIFF-VARANASI	2	0	0	0.0	0.0	0.0
14	220 kV	SAHUPURI-KARAMNASA	1	0	100	0.0	1.7	-1.7
15	132 kV	NAGAR UNTARI-RIHAND	1	0	0	0.0	0.0	0.0
16	132 kV	GARWAH-RIHAND	1	0	0	0.4	0.0	0.4
17	132 kV	KARMANASA-SAHUPURI	1	0	0	0.0	0.0	0.0
18	132 kV	KARMANASA-CHANDAUJI	1	0	0	0.0	0.0	0.0
ER-NR						0.4	100.1	-99.7
Import/Export of ER (With WR)								
1	765 kV	JHARSUGUDA-DHARAMJAIGARH	4	479	181	2.4	0.0	2.4
2	765 kV	NEW RANCHI-DHARAMJAIGARH	2	661	576	0.6	0.0	0.6
3	765 kV	JHARSUGUDA-DURG	2	0	979	0.0	19.0	-19.0
4	400 kV	JHARSUGUDA-RAIGARH	4	0	673	0.0	8.8	-8.8
5	400 kV	RANCHI-SIPAT	2	152	319	0.0	2.1	-2.1
6	220 kV	BUDHIPADAR-RAIGARH	1	0	97	0.0	1.0	-1.0
7	220 kV	BUDHIPADAR-KORBA	2	157	50	1.1	0.0	1.1
ER-WR						4.1	30.9	-26.8
Import/Export of ER (With SR)								
1	HVDC	JEYPORE-GAZUWAKA B/B	2	0	528	0.0	12.6	-12.6
2	HVDC	TALCHER-KOLAR BIPOLE	2	0	1987	0.0	45.9	-45.9
3	765 kV	ANGUL-SRIKAKULAM	2	0	2664	0.0	54.3	-54.3
4	400 kV	TALCHER-I/C	2	215	235	0.0	1.9	-1.9
5	220 kV	BALIMELA-UPPER-SILERRU	1	0	0	0.0	0.0	0.0
ER-SR						0.0	112.7	-112.7
Import/Export of ER (With NER)								
1	400 kV	BINAGURI-BONGAIGAON	2	0	603	0.0	9.4	-9.4
2	400 kV	ALIPURDUAR-BONGAIGAON	2	0	851	0.0	12.1	-12.1
3	220 kV	ALIPURDUAR-SALAKATI	2	0	158	0.0	2.3	-2.3
ER-NER						0.0	23.7	-23.7
Import/Export of NER (With NR)								
1	HVDC	BISWANATH CHARIALI-AGRA	2	0	1005	0.0	24.1	-24.1
NER-NR						0.0	24.1	-24.1
Import/Export of WR (With NR)								
1	HVDC	CHAMPA-KURUKSHETRA	2	0	1015	0.0	23.3	-23.3
2	HVDC	VINDHYACHAL B/B	-	137	140	0.0	2.4	-2.4
3	HVDC	MUNDRA-MOHINDERGARH	2	0	1447	0.0	36.3	-36.3
4	765 kV	GWALIOR-AGRA	2	0	1239	0.0	20.0	-20.0
5	765 kV	GWALIOR-PHAGI	2	247	2013	0.4	29.8	-29.4
6	765 kV	JABALPUR-ORAI	2	0	836	0.0	30.4	-30.4
7	765 kV	GWALIOR-ORAI	1	897	0	14.9	0.0	14.9
8	765 kV	SATNA-ORAI	1	0	1033	0.0	22.0	-22.0
9	765 kV	BANASKANTHA-CHITORGARH	2	1540	0	18.6	0.0	18.6
10	765 kV	VINDHYACHAL-VARANASI	2	0	2087	0.0	36.4	-36.4
11	400 kV	ZERDA-KANKROLI	1	346	0	4.6	0.0	4.6
12	400 kV	ZERDA -BHINMAL	1	240	0	3.2	0.0	3.2
13	400 kV	VINDHYACHAL -RIHAND	1	962	0	21.6	0.0	21.6
14	400 kV	RAPP-SHUJALPUR	2	554	207	2.9	1.2	1.6
15	400 kV	NEEMUCH-Chittorgarh	2	0	0	2.2	0.0	2.2
16	220 kV	BHANPURA-RANPUR	1	0	212	0.0	3.6	-3.6
17	220 kV	BHANPURA-MORAK	1	0	30	0.0	2.2	-2.2
18	220 kV	MEHGAON-AURAIYA	1	39	0	1.4	0.0	1.4
19	220 kV	MALANPUR-AURAIYA	1	66	0	0.8	0.0	0.8
20	132 kV	GWALIOR-SAWAI MADHOPUR	1	0	0	0.0	0.0	0.0
21	132 kV	RAJGHAT-LALITPUR	2	0	0	0.0	0.0	0.0
WR-NR						70.3	207.5	-137.2
Import/Export of WR (With SR)								
1	HVDC	BHADRAWATI B/B	-	0	1009	0.0	13.2	-13.2
2	HVDC	RAIGARH-PUGALUR	2	0	2505	0.0	43.9	-43.9
3	765 kV	SOLAPUR-RAICHUR	2	934	934	4.1	4.8	-0.7
4	765 kV	WARDHA-NIZAMABAD	2	0	1851	0.0	29.5	-29.5
5	765 kV	WARORA-WARANGAL(NEW)	2	572	207	0.0	36.7	-36.7
6	400 kV	KOLHAPUR-KUDGI	2	1482	0	24.9	0.0	24.9
7	220 kV	KOLHAPUR-CHIKODI	2	0	0	0.0	0.0	0.0
8	220 kV	PONDA-AMBEWADI	1	0	0	0.0	0.0	0.0
9	220 kV	XELDEM-AMBEWADI	1	0	109	2.2	0.0	2.2
WR-SR						31.1	128.2	-97.1

INTERNATIONAL EXCHANGES							Import(+ve)/Export(-ve)
State	Region	Line Name	Max (MW)	Min (MW)	Avg (MW)	Energy Exchange (MU)	
BHUTAN	ER	400kV MANGDECHHU-ALIPURDUAR 1,2&3 i.e. ALIPURDUAR RECEIPT (from MANGDECHHU HEP 4*180MW)	210	117	160	3.84	
	ER	400kV TALA-BINAGURI 1,2,4 (& 400kV MALBASE - BINAGURI) i.e. BINAGURI RECEIPT (from TALA HEP 6*170MW)	285	203	246	5.89	
	ER	220kV CHUKHA-BIRPARA 1&2 (& 220kV MALBASE - BIRPARA) i.e. BIRPARA RECEIPT (from CHUKHA HEP 4*84MW)	-151	-56	-100	-2.40	
	NER	132kV GELEPHU-SALAKATI	20	2	12	0.28	
	NER	132kV MOTANGA-RANGIA	33	15	26	0.63	
NEPAL	NR	NEPAL IMPORT (FROM UP)	0	0	0	0.00	
	NR	132kV MAHENDRANAGAR-TANAKPUR(NHPC)	66	0	62	1.50	
	ER	NEPAL IMPORT (FROM BIHAR)	0	0	0	0.00	
	ER	400kV DHALKEBAR-MUZAFFARPUR 1&2	492	320	440	10.56	
BANGLADESH	ER	BHERAMARA B/B HVDC (B'DESH)	-920	-918	-918	-22.04	
	ER (Isolated from Indian Grid)	400kV GODDA_TPS-RAHANPUR (B'DESH) D/C	-723	-503	-683	-16.38	
	NER	132kV COMILLA-SURAJMANI NAGAR 1&2	-64	0	-55	-1.32	

Export From India (in MU)

Country	GNA (ISGS/PPA)	T-GNA							TOTAL
		BILATERAL TOTAL	COLLECTIVE						
			IDAM			RTM			
			IEX	PXIL	HPX	IEX	PXIL	HPX	
Bhutan	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Nepal	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Bangladesh	22.95	0.00	0.00	0.00	0.00	0.00	0.00	0.00	22.95
Myanmar	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total Export	22.95	0.00	0.00	0.00	0.00	0.00	0.00	0.00	22.95

Import by India(in MU)

Country	GNA (ISGA/PPA)	T-GNA							TOTAL
		BILATERAL TOTAL	COLLECTIVE						
			IDAM			RTM			
			IEX	PXIL	HPX	IEX	PXIL	HPX	
Bhutan	7.95	0.00	0.00	0.00	0.00	0.00	0.00	0.00	7.95
Nepal	0.00	0.00	0.28	0.00	0.00	10.55	0.00	0.00	10.83
Bangladesh	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Myanmar	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total Import	7.95	0.00	0.28	0.00	0.00	10.55	0.00	0.00	18.78

Net from India(in MU)

-ve : Export / +ve : Import

Country	GNA (ISGS/PPA)	T-GNA							TOTAL
		BILATERAL TOTAL	COLLECTIVE						
			IDAM			RTM			
			IEX	PXIL	HPX	IEX	PXIL	HPX	
Bhutan	7.95	0.00	0.00	0.00	0.00	0.00	0.00	0.00	7.95
Nepal	0.00	0.00	0.28	0.00	0.00	10.55	0.00	0.00	10.83
Bangladesh	-22.95	0.00	0.00	0.00	0.00	0.00	0.00	0.00	-22.95
Myanmar	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total Net	-15.00	0.00	0.28	0.00	0.00	10.55	0.00	0.00	-4.17

15 Min (INSTANTANEOUS) ALL INDIA GRID FREQUENCY, GENERATION & DEMAND MET (SCADA DATA)												
TIME	FREQUENCY (Hz)	DEMAND MET (MW)	NUCLEAR (MW)	WIND (MW)	SOLAR (MW)	HYDRO** (MW)	GAS (MW)	THERMAL (MW)	OTHERS* (MW)	NET DEMAND MET (MW)	TOTAL GENERATION (MW)	NET TRANSNATIONAL EXCHANGE (MW) (+ve) Import, (-ve) Export
		(A)	(B)	(C)	(D)	(E)	(F)	(G)	(H)	(I=A-(C+D))	(J=B+C+D+E+F+G +H)	(K)
18:30	50.05	196312	6469	3061	288	27085	1900	159926	1461	192963	200190	-220
18:45	50.05	194755	6461	3215	116	26426	1909	158885	1467	191424	198479	-252
19:00	50.05	192234	6464	3384	114	25852	1848	156694	1358	188736	195714	-195
19:15	50.05	189798	6462	3590	55	24319	1861	155221	1401	186153	192909	-178
19:30	50.05	187593	6468	3550	55	23188	1915	154263	1384	183988	190823	-186
19:45	50.00	184963	6462	3613	54	20595	1864	154352	1386	181296	188326	-179
20:00	50.05	182212	6475	3457	53	19592	1865	152686	1411	178702	185539	-169
20:15	50.00	179502	6474	3454	41	19128	1868	150738	1379	176007	183082	-128
20:30	49.95	178761	6469	3433	43	18633	1900	150177	1383	175285	182038	-106
20:45	50.00	177309	6461	3421	44	18781	1899	149003	1375	173844	180984	-123
21:00	50.00	176023	6469	3547	76	18781	1902	147423	1368	172400	179566	-96
21:15	50.00	174548	6472	3660	78	17804	1918	146750	1329	170810	178011	-134
21:30	50.05	173247	6475	3802	78	17523	1916	145751	1360	169367	176905	-117
21:45	50.05	172110	6474	3983	78	17008	1874	144742	1358	168049	175517	-106
22:00	50.10	169848	6481	3958	82	15439	1867	144096	1340	165808	173263	-118
22:15	50.00	170221	6489	4023	82	14519	1868	145111	1395	166116	173487	-118
22:30	50.05	169404	6490	4169	82	14765	1877	144355	1340	165153	173078	-115
22:45	50.00	168323	6493	4117	82	14314	1881	143573	1396	164124	171856	-98
23:00	50.00	167247	6489	4162	82	14079	1873	142770	1326	163003	170781	-104
23:15	50.00	166757	6508	4263	82	13177	1881	142967	1367	162412	170245	-83
23:30	50.00	165636	6502	4336	81	12794	1871	142285	1352	161219	169221	-66
23:45	49.95	163980	6497	4320	81	11904	1868	141425	1374	159579	167469	-60

*Others include (i) Biomass from Punjab (ii) Some of the state sector IPP & non-conventional generation in SR (small capacity) (iii) Solar generation in Odisha(manually punched).

** Hydro generation is excluding Bhutan hydro.

***Bhutan hydro is accounted for in net transnational exchange.

Disclaimer:

1. The information provided is for general informational purposes only.
2. The data is provided "as is" without any guarantees or warranties.
3. All Data is operational SCADA data telemetered and reporting at NLDC through RLDC/SLDC.
4. Data is subject to errors due to telemetry loss/freeze/garbage value etc.
5. Demand met and RE generation data is incident on transmission system. Resources in distribution system plus behind the meter (BTM) generation excluded.
6. Users are advised to ensure its accuracy, completeness and relevance for their purposes, and, in this respect, GRID-INDIA shall not be responsible for any errors or omissions.