



National Load Despatch Centre
राष्ट्रीय भार प्रेषण केंद्र
GRID CONTROLLER OF INDIA LIMITED
ग्रिड कंट्रोलर ऑफ इंडिया लिमिटेड

(Government of India Enterprise/ भारत सरकार का उद्यम)
B-9, QUTUB INSTITUTIONAL AREA, KATWARIA SARAI, NEW DELHI -110016
बी-9, कुतुब इन्स्टीट्यूशनल एरिया, कटवारिया सराये, न्यू दिल्ली-110016

Ref: GRID-INDIA/NLDC/SO/Daily PSP Report

दिनांक: 11.07.2025

To,

- कार्यकारी निदेशक, पू.क्षे.भा.प्रे.के., 14, गोल्फ क्लब रोड, कोलकाता - 700033
Executive Director, ERLDC, 14 Golf Club Road, Tollygunge, Kolkata, 700033
- कार्यकारी निदेशक, ऊ.क्षे.भा.प्रे.के., 18/ए, शाहीद जीत सिंह सनसनवाल मार्ग, नई दिल्ली - 110016
Executive Director, NRLDC, 18-A, Shaheed Jeet Singh Marg, Katwaria Sarai, New Delhi - 110016
- कार्यकारी निदेशक, प.क्षे.भा.प्रे.के., एफ3, एम आई डी सी क्षेत्र, अंधेरी, मुंबई -400093
Executive Director, WRLDC, F-3, M.I.D.C. Area, Marol, Andheri (East), Mumbai-400093
- कार्यकारी निदेशक, ऊ.पू.क्षे.भा.प्रे.के., डोंगतेह, लोअर नोंग्रह, लापालंग, शिलोंग - 793006
Executive Director, NERLDC, Dongteih, Lower Nongrah, Lapalang, Shillong - 793006, Meghalaya
- कार्यकारी निदेशक, द.क्षे.भा.प्रे.के., 29, रेस कोर्स क्रॉस रोड, बंगलुरु -560009
Executive Director, SRLDC, 29, Race Course Cross Road, Bangalore-560009

Sub: Daily PSP Report for the date 10.07.2025.

महोदय/Sir,

आईईजीसी-2023 की धारा स.-38(1) के प्रावधान के अनुसार, दिनांक 10-जुलाई-2025 की अखिल भारतीय प्रणाली की दैनिक ग्रिड निष्पादन रिपोर्ट रांभांप्रेके की वेबसाइट पर उपलब्ध है।

As per article 38(1) of the Indian Electricity Grid Code, the daily report pertaining power supply position of All India Power System for the date 10.07.2025, is available at the NLDC website.

धन्यवाद,
Thanks

Report for previous day

Date of Reporting: 11-Jul-2025

A. Power Supply Position at All India and Regional level

	NR	WR	SR	ER	NER	TOTAL
Demand Met during Evening Peak hrs(MW) (at 20:00 hrs; from RLDCs)	72786	59865	51131	27900	3663	215345
Peak Shortage (MW)	0	0	0	0	0	0
Energy Met (MU)	1573	1365	1282	594	72	4886
Hydro Gen (MU)	379	65	184	94	36	757
Wind Gen (MU)	22	137	209	-	-	368
Solar Gen (MU)*	183.29	108.76	128.08	1.78	1.00	423
Energy Shortage (MU)	0.00	0.00	0.20	0.00	0.00	0.20
Maximum Demand Met During the Day (MW) (From NLDC SCADA)	73601	60170	60080	28177	3568	214411
Time Of Maximum Demand Met	22:21	19:38	10:24	20:01	21:28	22:29

B. Frequency Profile (%)

Region	FVI	< 49.7	49.7 - 49.8	49.8 - 49.9	< 49.9	49.9 - 50.05	> 50.05
All India	0.043	0.00	0.07	4.26	4.33	72.68	23.00

C. Power Supply Position in States

Region	States	Max.Demand Met during the day (MW)	Shortage during maximum Demand (MW)	Energy Met (MU)	Drawal Schedule (MU)	OD(+)/UD(-) (MU)	Max OD (MW)	Energy Shortage (MU)
NR	Punjab	12224	0	275.9	162.8	-3.0	705	0.00
	Haryana	10412	0	214.1	156.0	-4.4	595	0.00
	Rajasthan	12962	0	286.8	126.5	-4.8	352	0.00
	Delhi	5863	0	124.8	116.3	-2.2	232	0.00
	UP	27437	0	528.0	240.5	1.6	402	0.00
	Uttarakhand	2376	0	49.1	15.8	0.4	218	0.00
	HP	1680	0	36.0	-2.9	-0.9	65	0.00
	J&K(UT) & Ladakh(UT)	2448	0	48.2	24.0	-0.7	139	0.00
	Chandigarh	286	0	6.1	6.2	-0.1	15	0.00
	Railways NR ISTS	207	0	4.2	3.8	0.4	38	0.00
WR	Chhattisgarh	4398	0	97.6	60.8	0.1	302	0.00
	Gujarat	18151	0	409.6	153.0	0.3	1095	0.00
	MP	10985	0	236.1	124.6	-0.1	456	0.00
	Maharashtra	24619	0	536.1	183.0	-2.0	869	0.00
	Goa	594	0	15.2	12.1	2.6	78	0.00
	DNHDDPDCL	1392	0	32.4	32.3	0.1	47	0.00
	AMNSIL	918	0	20.3	9.4	0.3	307	0.00
	BALCO	530	0	12.6	12.7	-0.1	19	0.00
	RIL JAMNAGAR	243	0	5.4	5.4	0.0	-	0.00
	Andhra Pradesh	11805	0	239.2	34.8	0.1	627	0.00
SR	Telangana	13053	0	248.6	110.1	-0.1	970	0.00
	Karnataka	14687	0	272.9	70.0	4.1	1322	0.00
	Kerala	4085	0	80.3	32.3	-0.4	199	0.00
	Tamil Nadu	19199	0	429.1	191.4	1.7	1129	0.00
	Puducherry	498	40	11.4	10.5	0.2	65	0.20
ER	Bihar	7680	0	153.4	145.3	-2.1	303	0.00
	DVC	2982	0	65.1	-41.3	-0.2	342	0.00
	Jharkhand	2032	0	38.7	31.3	-1.7	194	0.00
	Odisha	5933	0	130.3	56.7	-1.4	494	0.00
	West Bengal	9660	0	205.0	72.8	-2.3	387	0.00
	Sikkim	84	0	1.5	1.3	0.2	30	0.00
NER	Railways ER ISTS	14	0	0.1	0.2	-0.1	0	0.00
	Arunachal Pradesh	210	0	3.8	3.5	-0.1	94	0.00
	Assam	2473	0	48.5	42.2	0.4	154	0.00
	Manipur	220	0	3.2	3.1	0.1	126	0.00
	Meghalaya	332	0	5.6	1.0	-0.1	120	0.00
	Mizoram	174	0	2.0	0.7	0.1	57	0.00
	Nagaland	186	0	3.1	2.8	0.0	90	0.00
	Tripura	280	0	5.3	3.1	0.4	126	0.00

D. Transnational Exchanges (MU) - Import(+ve)/Export(-ve)

	Bhutan	Nepal	Bangladesh	Godda -> Bangladesh
Actual (MU)	45.2	9.0	-22.9	-21.7
Day Peak (MW)	2186.0	658.5	-1006.0	-1060.0

E. Import/Export by Regions (in MU) - Import(+ve)/Export(-ve); OD(+)/UD(-)

	NR	WR	SR	ER	NER	TOTAL
Schedule(MU)	281.9	-255.7	43.2	-73.4	4.0	0.0
Actual(MU)	253.0	-260.2	68.8	-75.0	5.4	-7.9
OD/UD(MU)	-28.9	-4.5	25.6	-1.6	1.4	-7.9

F. Generation Outage(MW)

	NR	WR	SR	ER	NER	TOTAL	% Share
Central Sector	5074	12958	7332	5865	582	31810	51
State Sector	6904	11917	9997	1909	199	30926	49
Total	11978	24875	17329	7774	781	62736	100

G. Sourcewise generation (Gross) (MU)

	NR	WR	SR	ER	NER	All India	% Share
Coal	747	1308	588	639	12	3294	63
Lignite	18	12	34	0	0	65	1
Hydro	379	65	184	94	36	757	14
Nuclear	34	56	65	0	0	155	3
Gas, Naptha & Diesel	23	57	9	0	21	109	2
RES (Wind, Solar, Biomass & Others)	212	247	389	4	1	853	16
Total	1413	1745	1269	736	70	5233	100

Share of RES in total generation (%)	15.03	14.15	30.66	0.52	1.32	16.30
Share of Non-fossil fuel (Hydro,Nuclear and RES) in total generation(%)	44.26	21.08	50.28	13.22	52.92	33.74

H. All India Demand Diversity Factor

Based on Regional Max Demands	1.052
Based on State Max Demands	1.088

I. All India Peak Demand and shortage at Solar and Non-Solar Hour

	Max Demand Met(MW)	Time	Shortage(MW)
Solar hr	210107	10:25	0
Non-Solar hr	214411	22:29	40

Diversity factor = Sum of regional or state maximum demands / All India maximum demand

**Note: All generation MU figures are gross

***Godda (Jharkhand) -> Bangladesh power exchange is through the radial connection (isolated from Indian Grid)

Solar Hours -> 06:00 to 18:00hrs and rest are Non-Solar Hours

*Source: RLDCs for solar connected to ISTS; SLDCs for embedded solar. Limited visibility of embedded solar data.

Executive Director-NLDC

INTER-REGIONAL EXCHANGES

Import=(+ve) /Export =(-ve) for NET (MU)
Date of Reporting: 11-Jul-2025

Sl No	Voltage Level	Line Details	No. of Circuit	Max Import (MW)	Max Export (MW)	Import (MU)	Export (MU)	NET (MU)
Import/Export of ER (With NR)								
1	HVDC	ALIPURDUAR-AGRA	2	0	311	0.0	7.5	-7.5
2	HVDC	PUSAULI-BB	-	0	47	0.0	2.6	-2.6
3	765 kV	GAYA-VARANASI	2	687	712	0.0	3.7	-3.7
4	765 kV	SASARAM-FATEHPUR	1	256	329	0.0	2.2	-2.2
5	765 kV	GAYA-BALIA	1	0	705	0.0	9.3	-9.3
6	400 kV	PUSAULI-VARANASI	1	0	136	0.0	1.8	-1.8
7	400 kV	PUSAULI-ALLAHABAD	1	32	52	0.0	0.6	-0.6
8	400 kV	MUZAFFARPUR-GORAKHPUR	2	2	828	0.0	11.2	-11.2
9	400 kV	PATNA-BALIA	2	196	663	0.0	8.4	-8.4
10	400 kV	NAUBATPUR-BALIA	2	181	435	0.0	1.9	-1.9
11	400 kV	BIHARSHARIFF-BALIA	2	374	165	1.1	0.0	1.1
12	400 kV	MOTIHARI-GORAKHPUR	2	0	530	0.0	7.9	-7.9
13	400 kV	BIHARSHARIFF-SAHUPURI	2	185	320	0.0	3.7	-3.7
14	220 kV	SAHUPURI-KARAMNANA	1	0	121	0.0	2.0	-2.0
15	132 kV	NAGAR UNTARI-RIHAND	1	0	0	0.0	0.0	0.0
16	132 kV	GARWAH-RIHAND	1	30	0	0.5	0.0	0.5
17	132 kV	KARMANASA-SAHUPURI	1	0	0	0.0	0.5	-0.5
18	132 kV	KARMANASA-CHANDAULI	1	0	0	0.0	0.0	0.0
						ER-NR	1.6	63.3
								-61.7
Import/Export of ER (With WR)								
1	765 kV	JHARSUGUDA-DHARAMJAIGARH	4	1361	0	20.5	0.0	20.5
2	765 kV	NEW RANCHI-DHARAMJAIGARH	2	1710	752	18.2	0.0	18.2
3	765 kV	JHARSUGUDA-DURG	2	103	486	0.0	3.9	-3.9
4	400 kV	JHARSUGUDA-RAIGARH	4	218	243	0.5	0.0	0.5
5	400 kV	RANCHI-SIPAT	2	428	237	4.2	0.0	4.2
6	400 kV	JEYPORE-JAGDALPUR	2	180	362	0.0	3.0	-3.0
7	220 kV	BUDHIPADAR-RAIGARH	1	81	23	0.7	0.0	0.7
8	220 kV	BUDHIPADAR-KORBA	2	122	37	0.8	0.0	0.8
						ER-WR	44.9	6.9
								38.0
Import/Export of ER (With SR)								
1	HVDC	JEYPORE-GAZUWAKA B/B	2	198	0	4.7	0.0	4.7
2	HVDC	TALCHER-KOLAR BIPOLE	2	0	1475	0.0	29.0	-29.0
3	765 kV	ANGUL-SRIKAKULAM	2	0	3047	0.0	46.4	-46.4
4	400 kV	TALCHER-I/C	2	290	407	1.5	0.0	1.5
5	220 kV	BALIMELA-UPPER-SILERRU	1	0	0	0.0	0.0	0.0
						ER-SR	4.7	75.3
								-70.6
Import/Export of ER (With NER)								
1	400 kV	BINAGURI-BONGAIGAON	2	182	260	0.2	2.4	-2.2
2	400 kV	ALIPURDUAR-BONGAIGAON	2	0	634	0.0	9.0	-9.0
3	220 kV	ALIPURDUAR-SALAKATI	2	15	110	0.0	1.4	-1.4
						ER-NER	0.2	12.8
								-12.6
Import/Export of NER (With NR)								
1	HVDC	BISWANATH CHARIALI-AGRA	2	0	353	0.0	8.4	-8.4
						NER-NR	0.0	8.4
								-8.4
Import/Export of WR (With NR)								
1	HVDC	CHAMPA-KURUKSHETRA	2	0	3019	0.0	49.4	-49.4
2	HVDC	VINDHYACHAL-B/B	2	282	0	7.3	0.0	7.3
3	HVDC	MUNDRA-MOHINDERGARH	2	0	1170	0.0	29.1	-29.1
4	765 kV	GWALIOR-AGRA	2	589	1997	0.8	24.8	-24.0
5	765 kV	GWALIOR-PHAGI	2	775	1658	2.7	20.4	-17.7
6	765 kV	JABALPUR-ORAI	2	102	1094	0.0	27.6	-27.6
7	765 kV	GWALIOR-ORAI	1	659	0	10.3	0.0	10.3
8	765 kV	SATNA-ORAI	1	0	973	0.0	17.2	-17.2
9	765 kV	BANASKANTHA-CHITORGARH	2	1445	726	11.6	2.0	9.6
10	765 kV	VINDHYACHAL-VARANASI	2	0	2730	0.0	47.1	-47.1
11	400 kV	ZERDA-KANKROLI	1	300	33	2.3	0.0	2.3
12	400 kV	ZERDA-BHINMAL	1	207	24	1.6	0.0	1.6
13	400 kV	VINDHYACHAL-RIHAND	1	0	1	0.0	0.0	0.0
14	400 kV	RAPP-SHUJALPUR	2	383	557	2.5	4.5	-2.0
15	400 kV	NEEMUCH-Chittorgarh	2	375	567	1.9	5.0	-3.2
16	220 kV	BHANPURA-RANPUR	1	0	151	0.0	2.9	-2.9
17	220 kV	BHANPURA-MORAK	1	0	30	0.0	2.3	-2.3
18	220 kV	MEHGAON-AURAIYA	1	111	1	0.9	0.0	0.9
19	220 kV	MALANPUR-AURAIYA	1	90	13	0.5	0.1	0.5
20	132 kV	RAJGHAT-LALITPUR	2	0	0	0.0	0.0	0.0
						WR-NR	42.3	232.2
								-189.9
Import/Export of WR (With SR)								
1	HVDC	BHADRAWATI B/B	-	1005	0	24.0	0.0	24.0
2	HVDC	RAIGARH-PUGAULUR	2	0	801	0.0	16.1	-16.1
3	765 kV	SOLAPUR-RAICHUR	2	953	1586	6.3	5.5	0.8
4	765 kV	WARDHAN-NIZAMABAD	2	0	2925	0.0	34.4	-34.4
5	765 kV	WARORA-WARANGAL(NEW)	2	0	2904	0.0	33.5	-33.5
6	400 kV	KOLHAPUR-KUDGI	2	1616	0	25.0	0.0	25.0
7	220 kV	KOLHAPUR-CHIKODI	2	0	0	0.0	0.0	0.0
8	220 kV	PONDA-AMBEWADI	1	0	0	0.0	0.0	0.0
9	220 kV	XELDEM-AMBEWADI	1	0	112	2.1	0.0	2.1
						WR-SR	57.4	89.6
								-32.2

INTERNATIONAL EXCHANGES				Import(+ve)/Export(-ve)		
State	Region	Line Name	Max (MW)	Min (MW)	Avg (MW)	Energy Exchange (MU)
BHUTAN	ER	400kV MANGDECHHU-ALIPURDUAR 1,2&3 i.e. ALIPURDUAR RECEIPT (from MANGDECHHU HEP 4*180MW)	1380	1135	1213	29.12
	ER	400kV TALA-BINAGURI 1,2,4 (& 400kV MALBASE - BINAGURI) i.e. BINAGURI RECEIPT (from TALA HEP 6*170MW)	817	470	560	13.44
	ER	220kV CHUKHA-BIRPARA 1&2 (& 220kV MALBASE - BIRPARA) i.e. BIRPARA RECEIPT (from CHUKHA HEP 4*84MW)	-279	96	60	1.44
	NER	132kV GELEPHU-SALAKATI	21	7	10	0.23
	NER	132kV MOTANGA-RANGIA	47	20	41	0.98
NEPAL	NR	NEPAL IMPORT (FROM UP)	-18	0	0	0.00
	NR	132kV MAHENDRANAGAR-TANAKPUR(NHPC)	-18	0	-3	-0.08
	ER	NEPAL IMPORT (FROM BIHAR)	129	79	129	3.12
	ER	400kV DHALKEBAR-MUZAFFARPUR 1&2	514	108	250	6.00
BANGLADESH	ER	BHERAMARA B/B HVDC (B'DESH)	-970	-921	-926	-22.23
	ER (Isolated from Indian Grid)	400kV GODDA_TPS-RAHANPUR (B'DESH) D/C	-1060	-812	-904	-21.70
	NER	132kV COMILLA-SURAJMANI NAGAR 1&2	-36	0	-29	-0.70

CROSS BORDER EXCHANGE SCHEDULE

Date of Reporting: 11-Jul-2025

Export From India (in MU)

Country	GNA (ISGS/PPA)	T-GNA							TOTAL
		BILATERAL TOTAL	COLLECTIVE						
			IDAM			RTM			
			IEX	PXIL	HPX	IEX	PXIL	HPX	
Bhutan	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Nepal	0.24	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.24
Bangladesh	23.01	0.01	0.00	0.00	0.00	0.00	0.00	0.00	23.02
Myanmar	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total Export	23.25	0.01	0.00	0.00	0.00	0.00	0.00	0.00	23.26

Import by India(in MU)

Country	GNA (ISGA/PPA)	T-GNA							TOTAL
		BILATERAL TOTAL	COLLECTIVE						
			IDAM			RTM			
			IEX	PXIL	HPX	IEX	PXIL	HPX	
Bhutan	43.99	0.00	1.17	0.00	0.00	0.21	0.00	0.00	45.37
Nepal	6.32	0.01	3.36	0.00	0.00	1.20	0.00	0.00	10.89
Bangladesh	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Myanmar	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total Import	50.31	0.01	4.53	0.00	0.00	1.41	0.00	0.00	56.26

Net from India(in MU)

-ve : Export / +ve : Import

Country	GNA (ISGS/PPA)	T-GNA							TOTAL
		BILATERAL TOTAL	COLLECTIVE						
			IDAM			RTM			
			IEX	PXIL	HPX	IEX	PXIL	HPX	
Bhutan	43.99	0.00	1.17	0.00	0.00	0.21	0.00	0.00	45.37
Nepal	6.08	0.01	3.36	0.00	0.00	1.20	0.00	0.00	10.65
Bangladesh	-23.01	-0.01	0.00	0.00	0.00	0.00	0.00	0.00	-23.02
Myanmar	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total Net	27.06	0.00	4.53	0.00	0.00	1.41	0.00	0.00	33.00

15 Min (INSTANTANEOUS) ALL INDIA GRID FREQUENCY, GENERATION & DEMAND MET (SCADA DATA)												
TIME	FREQUENCY (Hz)	DEMAND MET (MW)	NUCLEAR (MW)	WIND (MW)	SOLAR (MW)	HYDRO** (MW)	GAS (MW)	THERMAL (MW)	OTHERS* (MW)	NET DEMAND MET (MW)	TOTAL GENERATION (MW)	NET TRANSNATIONAL EXCHANGE (MW)
		(A)	(B)	(C)	(D)	(E)	(F)	(G)	(H)	(I=A-(C+D))	(J=B+C+D+E+F+G+H)	(K) (+ve) Import, (-ve) Export
0:00	50.04	201873	5958	19267	0	30191	3910	140606	1840	182606	201772	1028
0:15	50.04	200903	5964	19043	0	30270	3816	139999	1816	181860	200908	1023
0:30	49.99	199736	5971	18651	0	30179	3772	139281	1831	181085	199685	1111
0:45	49.99	198771	5954	18668	0	29804	3709	138896	1815	180103	198846	1106
1:00	50.04	196940	5960	18551	0	29376	3633	137626	1805	178389	196951	1127
1:15	50.04	195563	5970	18442	0	29405	3610	136384	1850	177121	195661	1148
1:30	49.99	194914	5960	18101	0	29270	3629	136433	1814	176813	195207	1129
1:45	49.99	193674	5972	17900	0	29229	3651	135589	1815	175774	194156	1174
2:00	49.99	192088	5963	17271	0	28917	3700	135159	1839	174817	192849	1247
2:15	49.99	191300	5966	16980	0	29196	3689	134686	1824	174320	192341	1226
2:30	49.99	190883	5965	16590	0	29449	3675	134330	1861	174293	191870	1194
2:45	49.99	190172	5964	16196	0	29650	3650	133846	1809	173976	191115	1304
3:00	50.04	189918	5973	15932	0	29448	3638	134062	1809	173986	190862	1336
3:15	50.04	188990	5978	15596	0	29353	3520	133802	1804	173394	190053	1336
3:30	50.04	188633	5969	15224	0	29102	3600	133812	1838	173409	189545	1373
3:45	50.04	187899	5976	14972	0	28898	3603	133486	1833	172927	188768	1374
4:00	50.04	187370	5979	14871	0	28755	3616	133252	1806	172499	188279	1367
4:15	50.04	188308	5980	14765	0	28688	3597	134391	1811	173543	189232	1347
4:30	50.04	188479	5968	14659	0	28821	3494	134545	1802	173820	189289	1309
4:45	50.04	188878	5971	14386	0	28867	3505	135094	1818	174492	189641	1329
5:00	50.09	188311	5984	14339	8	28578	3496	134979	1879	173964	189263	1340
5:15	50.04	188952	5970	14318	6	28344	3555	135616	1822	174628	189631	1305
5:30	50.09	190526	5978	14197	5	28808	3623	136667	1813	176324	191091	1290
5:45	50.09	192038	5980	14171	23	28813	3815	137708	1887	177844	192397	1302
6:00	50.09	193106	5963	14052	43	28887	3755	138941	1852	179011	193493	1305
6:15	49.99	195805	5962	14042	672	29367	4212	139909	1777	181091	195941	1271
6:30	49.89	198621	5966	13844	2178	30072	3883	140953	1832	182599	198728	1244
6:45	49.89	199715	5959	13241	4085	30699	3901	140548	1766	182389	200199	1118
7:00	49.99	199823	5977	12885	6683	30219	3760	138886	1772	180255	200182	1110
7:15	49.99	200775	5966	12775	9276	30365	3851	137194	1770	178724	201197	1106
7:30	49.99	199827	5990	12634	12366	29659	3850	134322	1836	174827	200657	1128
7:45	50.04	199913	5961	12834	16056	28824	3769	131970	1835	171023	201249	1105
8:00	50.04	199192	5971	13053	19253	28250	3711	128322	1831	166886	200391	1127
8:15	50.04	199876	5952	13900	23617	27778	3649	124842	1866	162359	201604	1073
8:30	50.04	201299	5970	14330	27806	27078	3619	122274	1850	159163	202927	1069
8:45	49.99	202821	5971	14953	31411	26149	3615	120509	1828	156457	204436	1112
9:00	50.04	204294	5954	15414	34328	26209	3624	118658	1900	154552	206087	1106
9:15	49.99	206722	5962	15781	37094	26299	3694	118197	1867	153847	208894	1084
9:30	50.04	209171	5964	16366	40931	25660	3699	116558	1859	151874	211037	1068
9:45	50.09	209498	5963	16297	43089	25202	3694	115406	1793	150112	211444	1132
10:00	49.94	209228	5936	16180	43918	25133	3705	114197	1797	149130	210866	1126
10:15	49.94	209506	5921	16202	45539	25062	3734	112887	1745	147765	211090	1120
10:30	49.99	209462	5932	16001	48027	24751	3749	111057	1730	145434	211247	1117
10:45	50.04	209478	5949	15683	48032	24709	3743	111476	1725	145763	211317	1144
11:00	49.99	209483	5930	15705	49169	24786	3722	110398	1707	144609	211417	1121
11:15	50.09	208473	5941	15543	50544	24557	3597	108581	1736	142386	210499	1221
11:30	50.04	207612	5945	15360	50671	24146	3459	108220	1746	141581	209547	1144
11:45	50.04	207608	5933	15222	50905	23938	3447	108501	1743	141481	209689	1123
12:00	50.09	207768	5903	15303	51323	23949	3449	107997	1732	141142	209656	1138
12:15	50.09	206340	5930	15175	52055	23843	3451	106981	1714	139110	209149	1181
12:30	50.24	206081	5864	15352	52724	22877	3429	106068	1775	138005	208089	1077
12:45	49.99	204841	5913	15076	52366	23327	3445	104623	1797	137399	206547	1103
13:00	50.19	202342	5914	14890	51741	23147	3510	103252	1716	135711	204170	962
13:15	50.24	200914	5918	15134	51343	22926	3491	102360	1703	134437	202875	956
13:30	50.14	200470	5932	15393	50682	23222	3487	102277	1736	134395	202729	963
13:45	50.04	202252	5910	15356	49700	23972	3496	103368	1799	137196	203601	986
14:00	50.09	203403	5927	15302	49589	24137	3492	104310	1770	138512	204527	1042
14:15	50.04	203783	5911	15623	48458	24580	3469	104823	1773	139702	204637	1174
14:30	49.99	205449	5900	15935	47458	24979	3494	106681	1754	142056	206201	1206
14:45	49.99	205496	5915	16672	46038	25614	3538	106550	1777	142786	206104	1220
15:00	49.99	206060	5913	17074	43516	25838	3541	108665	1730	145470	206277	1216
15:15	49.94	205284	5914	17549	41295	26064	3443	109448	1757	146440	205470	1237
15:30	49.94	205817	5914	17776	38022	26819	3553	111842	1769	150019	205695	1230
15:45	49.94	206102	5907	17633	34852	27385	3569	115037	1766	153617	206149	1221
16:00	49.94	205825	5911	17459	32964	27995	3573	116660	1720	155402	206282	1251
16:15	49.89	204636	5905	17300	30419	28193	3618	118090	1780	156917	205305	1319
16:30	49.94	206353	5900	17475	29744	27930	3685	120638	1689	159134	207061	1356
16:45	50.04	205563	5914	17412	27679	27435	3747	122401	1713	160472	206301	1340
17:00	49.99	203843	5927	17165	24790	27884	3797	123704	1660	161888	204927	1364
17:15	49.94	202382	5946	16595	21494	28502	3954	125453	1621	164293	203565	1409
17:30	49.94	202260	5923	16556	17219	28847	4261	128506	1634	168485	202946	1343
17:45	49.89	201067	5910	16292	15951	29340	4331	128001	1719	168824	201544	1355
18:00	50.05	200820	5928	15827	10865	29620	4303	131904	1636	174128	200083	1305
18:15	50.04	199374	5928	15517	8100	29079	4463	133543	1605	175757	198235	1310
18:30	50.04	202014	5938	15757	5955	30781	4780	137050	1710	180302	201971	1270
18:45	50.04	203733	5936	15318	3660	32296	5109	140002	1624	184755	203945	1239
19:00	50.04	207842	5936	15480	2132	33974	5492	143273	1687	190230	207974	1259
19:15	49.99	209922	5936	15059	972	35095	5724	145341	1671	193891	209798	1264
19:30	49.79	211715	5933	14817	214	36140	5864	146687	1676	196684	211331	1230
19:45	49.89	212832	5945	14536	-32	36281	6394	147746	1775	198328	212645	1246
20:00	50.04	213222	5948	14366	-51	36411	6840	147899	1699	198907	213112	1244
20:15	50.04	212710	5951	14365	0	36289	6464	147717	1708	198345	212494	1219
20:30	50.04	212957	5965	14124	0	36352	6173	148338	1721	198833	212673	1244
20:45	50.04	212867	5966	14127	0	36050	5870	148946	1698	198740	212657	1265
21:00	50.04	212891	5959	14065	0	36573	5803	148528	1710	198826	212638	1269
21:15	49.99	212991	5956	13970	0	36552	5818	148630				