



National Load Despatch Centre
राष्ट्रीय भार प्रेषण केंद्र
GRID CONTROLLER OF INDIA LIMITED
ग्रिड कंट्रोलर ऑफ इंडिया लिमिटेड

(Government of India Enterprise/ भारत सरकार का उद्यम)
B-9, QUTUB INSTITUTIONAL AREA, KATWARIA SARAI, NEW DELHI -110016
बी-9, कुतुब इन्स्टीट्यूशनल एरिया, कटवारिया सराये, न्यू दिल्ली-110016

Ref: POSOCO/NLDC/SO/Daily PSP Report

दिनांक: 02.07.2024

To,

- कार्यकारी निदेशक, पू.क्षे.भा.प्रे.के., 14, गोल्फ क्लब रोड, कोलकाता - 700033
Executive Director, ERLDC, 14 Golf Club Road, Tollygunge, Kolkata, 700033
- कार्यकारी निदेशक, ऊ.क्षे.भा.प्रे.के., 18/ए, शाहीद जीत सिंह सनसनवाल मार्ग, नई दिल्ली - 110016
Executive Director, NRLDC, 18-A, Shaheed Jeet Singh Marg, Katwaria Sarai, New Delhi - 110016
- कार्यकारी निदेशक, प.क्षे.भा.प्रे.के., एफ3, एम आई डी सी क्षेत्र, अंधेरी, मुंबई - 400093
Executive Director, WRLDC, F-3, M.I.D.C. Area, Marol, Andheri (East), Mumbai-400093
- कार्यकारी निदेशक, ऊ.पू.क्षे.भा.प्रे.के., डोंगतेह, लोअर नोंग्रह, लापलंग, शिलोंग - 793006
Executive Director, NERLDC, Dongteih, Lower Nongrah, Lapalang, Shillong - 793006, Meghalaya
- कार्यकारी निदेशक, द.क्षे.भा.प्रे.के., 29, रेस कोर्स क्रॉस रोड, बंगलुरु - 560009
Executive Director, SRLDC, 29, Race Course Cross Road, Bangalore-560009

Sub: Daily PSP Report for the date 01.07.2024.

महोदय/महोदया,
Dear Sir/Madam,

आईईजीसी-2010 की धारा स.-5.5.1 के प्रावधान के अनुसार, दिनांक 01-07-2024 की अखिल भारतीय प्रणाली की दैनिक ग्रिड निष्पादन रिपोर्ट रांभांप्रेके की वेबसाइट पर उपलब्ध है।

As per article 5.5.1 of the Indian Electricity Grid Code, the daily report pertaining power supply position of All India Power System for the date 01.07.2024, is available at the NLDC website.

धन्यवाद,
Thanks

Report for previous day

Date of Reporting: 02-Jul-2024

A. Power Supply Position at All India and Regional level

	NR	WR	SR	ER	NER	TOTAL
Demand Met during Evening Peak hrs(MW) (at 20:00 hrs; from RLDCs)	77536	55413	45317	26070	2826	207162
Peak Shortage (MW)	0	0	0	0	0	0
Energy Met (MU)	1709	1276	1070	571	53	4678
Hydro Gen (MU)	350	34	66	63	40	554
Wind Gen (MU)	39	176	196	-	-	412
Solar Gen (MU)*	159.34	51.56	95.49	2.56	0.26	309
Energy Shortage (MU)	0.22	0.00	0.00	0.00	0.00	0.22
Maximum Demand Met During the Day (MW) (From NLDC SCADA)	79469	56337	50120	27454	2890	208851
Time Of Maximum Demand Met	21:30	19:47	10:44	22:51	19:15	21:28

B. Frequency Profile (%)

Region	FVI	< 49.7	49.7 - 49.8	49.8 - 49.9	< 49.9	49.9 - 50.05	> 50.05
All India	0.030	0.00	0.00	1.97	1.97	77.29	20.74

C. Power Supply Position in States

Region	States	Max.Demand Met during the day (MW)	Shortage during maximum Demand (MW)	Energy Met (MU)	Drawal Schedule (MU)	OD(+)/UD(-) (MU)	Max OD (MW)	Energy Shortage (MU)
NR	Punjab	15701	0	330.8	205.7	-3.0	197	0.00
	Haryana	12311	0	255.6	192.2	-1.9	274	0.00
	Rajasthan	14057	0	305.5	85.8	0.3	446	0.00
	Delhi	7196	0	142.4	130.0	0.1	288	0.00
	UP	25992	0	521.1	267.8	-1.3	472	0.00
	Uttarakhand	2458	0	51.6	28.7	0.2	268	0.22
	HP	1804	0	38.4	4.8	0.7	102	0.00
	J&K(UT) & Ladakh(UT)	3665	0	51.5	30.7	-4.9	0	0.00
	Chandigarh	412	0	8.3	8.3	0.0	44	0.00
WR	Railways_NR ISTS	206	0	4.3	3.8	0.5	71	0.00
	Chhattisgarh	4911	0	110.3	59.7	-1.9	191	0.00
	Gujarat	16640	0	371.1	142.8	-7.1	1280	0.00
	MP	10011	0	217.5	107.1	-4.0	384	0.00
	Maharashtra	22900	0	504.6	153.7	-5.9	1203	0.00
	Goa	661	0	14.8	13.7	0.9	64	0.00
	DNHDDPDCL	1245	0	28.3	28.9	-0.6	56	0.00
	AMNSIL	772	0	16.6	6.2	0.8	287	0.00
	BALCO	525	0	12.5	12.6	-0.1	7	0.00
SR	Andhra Pradesh	9094	0	195.3	45.5	-1.4	437	0.00
	Telangana	10042	0	204.1	132.9	0.6	644	0.00
	Karnataka	12402	0	224.3	51.8	-3.7	421	0.00
	Kerala	3736	0	78.2	43.4	1.8	481	0.00
	Tamil Nadu	16901	0	357.9	163.2	-0.1	1784	0.00
	Puducherry	464	0	10.3	9.9	-0.2	44	0.00
	Bihar	6685	0	134.9	127.3	-3.0	403	0.00
ER	DVC	3353	0	71.5	-34.1	-1.2	320	0.00
	Jharkhand	2098	0	40.8	29.8	-0.7	225	0.00
	Odisha	5266	0	109.9	35.8	-1.4	363	0.00
	West Bengal	10027	0	212.4	70.9	-1.6	222	0.00
	Sikkim	86	0	1.2	1.4	-0.2	22	0.00
	Railways_ER ISTS	15	0	0.2	0.1	0.0	3	0.00
NER	Arunachal Pradesh	107	0	1.9	2.8	-1.5	0	0.00
	Assam	1820	0	33.6	25.0	0.6	185	0.00
	Manipur	174	0	2.6	2.9	-0.3	17	0.00
	Meghalaya	323	0	5.8	0.4	-0.2	75	0.00
	Mizoram	109	0	1.6	1.0	-0.5	0	0.00
	Nagaland	145	0	2.4	2.4	-0.3	35	0.00
	Tripura	269	0	4.7	4.0	-0.2	10	0.00

D. Transnational Exchanges (MU) - Import(+ve)/Export(-ve)

	Bhutan	Nepal	Bangladesh	Godda -> Bangladesh
Actual (MU)	33.9	13.6	-24.5	-11.1
Day Peak (MW)	1621.0	705.3	-1031.0	-763.8

E. Import/Export by Regions (in MU) - Import(+ve)/Export(-ve); OD(+)/UD(-)

	NR	WR	SR	ER	NER	TOTAL
Schedule(MU)	398.9	-334.7	53.6	-105.0	-12.8	0.0
Actual(MU)	371.9	-337.8	74.4	-105.2	-17.9	-14.5
O/D/U/D(MU)	-27.0	-3.1	20.8	-0.2	-5.0	-14.5

F. Generation Outage(MW)

	NR	WR	SR	ER	NER	TOTAL	% Share
Central Sector	4380	10485	6798	3766	597	26025	48
State Sector	6696	12075	7848	1249	119	27987	52
Total	11075	22560	14646	5015	716	54012	100

G. Sourcewise generation (Gross) (MU)

	NR	WR	SR	ER	NER	All India	% Share
Coal	791	1372	558	686	14	3421	68
Lignite	30	13	55	0	0	98	2
Hydro	350	34	66	63	40	554	11
Nuclear	29	58	52	0	0	139	3
Gas, Naptha & Diesel	20	25	5	0	21	71	1
RES (Wind, Solar, Biomass & Others)	207	230	321	4	0	763	15
Total	1428	1732	1056	753	76	5046	100

Share of RES in total generation (%)	14.47	13.30	30.38	0.59	0.34	15.12
Share of Non-fossil fuel (Hydro,Nuclear and RES) in total generation(%)	41.08	18.60	41.47	8.99	53.66	28.84

H. All India Demand Diversity Factor

Based on Regional Max Demands	1.035
Based on State Max Demands	1.075

I. All India Peak Demand and shortage at Solar and Non-Solar Hour

	Max Demand Met(MW)	Time	Shortage(MW)
Solar hr	203429	11:58	0
Non-Solar hr	208851	21:28	0

Diversity factor = Sum of regional or state maximum demands / All India maximum demand

**Note: All generation MU figures are gross

***Godda (Jharkhand) -> Bangladesh power exchange is through the radial connection (isolated from Indian Grid)

Solar Hours -> 07:00 to 17:00hrs and rest are Non-Solar Hours

*Source: RLDCs for solar connected to ISTS; SLDCs for embedded solar. Limited visibility of embedded solar data.

Executive Director-NLDC

INTER-REGIONAL EXCHANGES

Import=(+ve) /Export =(-ve) for NET (MU)

Date of Reporting: 02-Jul-2024

Sl No	Voltage Level	Line Details	No. of Circuit	Max Import (MW)	Max Export (MW)	Import (MU)	Export (MU)	NET (MU)
Import/Export of ER (With NR)								
1	HVDC	ALIPURDUAR-AGRA	2	0	0	0.0	0.0	0.0
2	HVDC	PUSAULI B/B	-	0	95	0.0	2.5	-2.5
3	765 kV	GAYA-VARANASI	2	259	762	0.0	9.7	-9.7
4	765 kV	SASARAM-FATEHPUR	1	25	540	0.0	8.3	-8.3
5	765 kV	GAYA-BALIA	1	0	671	0.0	9.6	-9.6
6	400 kV	PUSAULI-VARANASI	1	6	101	0.0	0.9	-0.9
7	400 kV	PUSAULI -ALLAHABAD	1	7	102	0.0	1.5	-1.5
8	400 kV	MUZAFFARPUR-GORAKHPUR	2	0	1117	0.0	18.6	-18.6
9	400 kV	PATNA-BALIA	2	0	858	0.0	12.3	-12.3
10	400 kV	NAUBATPUR-BALIA	2	3	259	0.0	3.9	-3.9
11	400 kV	BIHARSHARIFF-BALIA	2	68	270	0.0	3.4	-3.4
12	400 kV	MOTIHARI-GORAKHPUR	2	0	659	0.0	11.9	-11.9
13	400 kV	BIHARSHARIFF-VARANASI	2	43	366	0.0	0.0	0.0
14	220 kV	SAHUPURI-KARAMNASA	1	30	64	0.0	1.0	-1.0
15	132 kV	NAGAR UNTARI-RIHAND	1	0	0	0.0	0.0	0.0
16	132 kV	GARWAH-RIHAND	1	30	0	0.5	0.0	0.5
17	132 kV	KARMANASA-SAHUPURI	1	0	0	0.0	0.0	0.0
18	132 kV	KARMANASA-CHANDAULI	1	0	0	0.0	0.0	0.0
ER-NR						0.5	83.6	-83.1
Import/Export of ER (With WR)								
1	765 kV	JHARSUGUDA-DHARAMJAIGARH	4	126	1068	0.0	11.9	-11.9
2	765 kV	NEW RANCHI-DHARAMJAIGARH	2	1735	150	24.9	0.0	24.9
3	765 kV	JHARSUGUDA-DURG	2	0	644	0.0	9.7	-9.7
4	400 kV	JHARSUGUDA-RAIGARH	4	279	370	0.0	1.6	-1.6
5	400 kV	RANCHI-SIPAT	2	439	80	3.9	0.0	3.9
6	220 kV	BUDHIPADAR-RAIGARH	1	0	163	0.0	2.5	-2.5
7	220 kV	BUDHIPADAR-KORBA	2	0	138	0.0	1.4	-1.4
ER-WR						28.8	27.1	1.7
Import/Export of ER (With SR)								
1	HVDC	JEYPORE-GAZUWAKA B/B	2	202	0	4.8	0.0	4.8
2	HVDC	TALCHER-KOLAR BIPOLE	2	0	1688	0.0	41.0	-41.0
3	765 kV	ANGUL-SRIKAKULAM	2	0	2574	0.0	47.1	-47.1
4	400 kV	TALCHER-I/C	2	0	717	0.0	9.3	-9.3
5	220 kV	BALIMELA-UPPER-SILERRU	1	0	0	0.0	0.0	0.0
ER-SR						4.8	88.1	-83.3
Import/Export of ER (With NER)								
1	400 kV	BINAGURI-BONGAIGAON	2	671	0	12.4	0.0	12.4
2	400 kV	ALIPURDUAR-BONGAIGAON	2	876	0	15.1	0.0	15.1
3	220 kV	ALIPURDUAR-SALAKATI	2	169	0	3.0	0.0	3.0
ER-NER						30.5	0.0	30.5
Import/Export of NER (With NR)								
1	HVDC	BISWANATH CHARIALI-AGRA	2	507	0	11.9	0.0	11.9
NER-NR						11.9	0.0	11.9
Import/Export of WR (With NR)								
1	HVDC	CHAMPA-KURUKSHETRA	2	0	3021	0.0	73.2	-73.2
2	HVDC	VINDHYACHAL B/B	-	0	512	0.0	12.0	-12.0
3	HVDC	MUNDRA-MOHINDERGARH	2	0	1450	0.0	36.3	-36.3
4	765 kV	GWALIOR-AGRA	2	0	3200	0.0	50.3	-50.3
5	765 kV	GWALIOR-PHAGI	2	450	1769	1.3	23.8	-22.4
6	765 kV	JABALPUR-ORAI	2	0	1411	0.0	46.2	-46.2
7	765 kV	GWALIOR-ORAI	1	631	0	9.9	0.0	9.9
8	765 kV	SATNA-ORAI	1	0	1222	0.0	23.1	-23.1
9	765 kV	BANASKANTHA-CHITORGARH	2	855	2107	3.3	12.4	-9.1
10	765 kV	VINDHYACHAL-VARANASI	2	0	3235	0.0	54.0	-54.0
11	400 kV	ZERDA-KANKROLI	1	238	304	1.3	1.5	-0.2
12	400 kV	ZERDA -BHINMAL	1	165	210	0.9	1.0	-0.1
13	400 kV	VINDHYACHAL -RIHAND	1	972	0	21.6	0.0	21.6
14	400 kV	RAPP-SHUJALPUR	2	263	718	1.1	6.7	-5.7
15	400 kV	NEEMUCH-Chittorgarh	2	292	690	1.1	6.3	-5.1
16	220 kV	BHANPURA-RANPUR	1	0	69	0.0	1.1	-1.1
17	220 kV	BHANPURA-MORAK	1	0	30	0.0	2.1	-2.1
18	220 kV	MEHGAON-AURAIYA	1	47	46	0.3	0.1	0.2
19	220 kV	MALANPUR-AURAIYA	1	25	56	0.1	0.6	-0.6
20	132 kV	GWALIOR-SAWAI MADHOPUR	1	0	0	0.0	0.0	0.0
21	132 kV	RAJGHAT-LALITPUR	2	0	0	0.0	0.0	0.0
WR-NR						40.9	350.7	-309.8
Import/Export of WR (With SR)								
1	HVDC	BHADRAWATI B/B	-	501	0	10.6	0.0	10.6
2	HVDC	RAIGARH-PUGALUR	2	0	2503	0.0	31.7	-31.7
3	765 kV	SOLAPUR-RAICHUR	2	1512	302	16.1	0.2	15.9
4	765 kV	WARDHA-NIZAMABAD	2	0	2210	0.0	28.0	-28.0
5	765 kV	WARORA-WARANGAL(NEW)	2	0	2235	0.0	27.3	-27.3
6	400 kV	KOLHAPUR-KUDGI	2	1896	0	35.2	0.0	35.2
7	220 kV	KOLHAPUR-CHIKODI	2	0	0	0.0	0.0	0.0
8	220 kV	PONDA-AMBEWADI	1	0	1	0.0	0.0	0.0
9	220 kV	XELDEM-AMBEWADI	1	1	0	0.0	0.0	0.0
WR-SR						61.9	87.2	-25.3

INTERNATIONAL EXCHANGES					Import(+ve)/Export(-ve)		
State	Region	Line Name	Max (MW)	Min (MW)	Avg (MW)	Energy Exchange (MU)	
BHUTAN	ER	400kV MANGDECHHU-ALIPURDUAR 1,2&3 i.e. ALIPURDUAR RECEIPT (from MANGDECHU HEP 4*180MW)	718	0	643	15.43	
	ER	400kV TALA-BINAGURI 1,2,4 (& 400kV MALBASE - BINAGURI) i.e. BINAGURI RECEIPT (from TALA HEP 6*170MW)	786	709	724	17.37	
	ER	220kV CHUKHA-BIRPARA 1&2 (& 220kV MALBASE - BIRPARA) i.e. BIRPARA RECEIPT (from CHUKHA HEP 4*84MW)	-28	24	-2	-0.06	
	NER	132kV GELEPHU-SALAKATI	12	0	9	0.21	
	NER	132kV MOTANGA-RANGIA	52	0	39	0.94	
NEPAL	NR	NEPAL IMPORT (FROM UP)	-9	0	0	0.00	
	NR	132kV MAHENDRANAGAR-TANAKPUR(NHPC)	66	0	44	1.05	
	ER	NEPAL IMPORT (FROM BIHAR)	0	0	0	0.00	
	ER	400kV DHALKEBAR-MUZAFFARPUR 1&2	639	394	525	12.59	
BANGLADESH	ER	BHERAMARA B/B HVDC (B'DESH)	-947	-944	-946	-22.71	
	ER (Isolated from Indian Grid)	400kV GODDA_TPS-RAHANPUR (B'DESH) D/C	-764	0	-464	-11.14	
	NER	132kV COMILLA-SURAJMANI NAGAR 1&2	-84	0	-76	-1.82	

Export From India (in MU)

Country	GNA (ISGS/PPA)	T-GNA							TOTAL
		BILATERAL TOTAL	COLLECTIVE						
			IDAM			RTM			
			IEX	PXIL	HPX	IEX	PXIL	HPX	
Bhutan	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Nepal	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Bangladesh	22.60	0.00	0.00	0.00	0.00	0.00	0.00	0.00	22.60
Myanmar	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total Export	22.60	0.00	0.00	0.00	0.00	0.00	0.00	0.00	22.60

Import by India(in MU)

Country	GNA (ISGA/PPA)	T-GNA							TOTAL
		BILATERAL TOTAL	COLLECTIVE						
			IDAM			RTM			
			IEX	PXIL	HPX	IEX	PXIL	HPX	
Bhutan	31.04	0.00	1.09	0.00	0.00	0.06	0.00	0.00	32.19
Nepal	2.63	0.00	8.32	0.00	0.00	2.21	0.00	0.00	13.16
Bangladesh	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Myanmar	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total Import	33.67	0.00	9.41	0.00	0.00	2.27	0.00	0.00	45.35

Net from India(in MU)

-ve : Export / +ve : Import

Country	GNA (ISGS/PPA)	T-GNA							TOTAL
		BILATERAL TOTAL	COLLECTIVE						
			IDAM			RTM			
			IEX	PXIL	HPX	IEX	PXIL	HPX	
Bhutan	31.04	0.00	1.09	0.00	0.00	0.06	0.00	0.00	32.19
Nepal	2.63	0.00	8.32	0.00	0.00	2.21	0.00	0.00	13.16
Bangladesh	-22.60	0.00	0.00	0.00	0.00	0.00	0.00	0.00	-22.60
Myanmar	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total Net	11.07	0.00	9.41	0.00	0.00	2.27	0.00	0.00	22.75