



National Load Despatch Centre
राष्ट्रीय भार प्रेषण केंद्र
GRID CONTROLLER OF INDIA LIMITED
ग्रिड कंट्रोलर ऑफ इंडिया लिमिटेड

(Government of India Enterprise/ भारत सरकार का उद्यम)
B-9, QUTUB INSTITUTIONAL AREA, KATWARIA SARAI, NEW DELHI -110016
बी-9, कुतुब इन्स्टीट्यूशनल एरिया, कटवारिया सराये, न्यू दिल्ली-110016

Ref: GRID-INDIA/NLDC/SO/Daily PSP Report

दिनांक: 31.05.2025

To,

- कार्यकारी निदेशक, पू.क्षे.भा.प्रे.के., 14, गोल्फ क्लब रोड, कोलकाता - 700033
Executive Director, ERLDC, 14 Golf Club Road, Tollygunge, Kolkata, 700033
- कार्यकारी निदेशक, ऊ.क्षे.भा.प्रे.के., 18/ए, शाहीद जीत सिंह सनसनवाल मार्ग, नई दिल्ली - 110016
Executive Director, NRLDC, 18-A, Shaheed Jeet Singh Marg, Katwaria Sarai, New Delhi - 110016
- कार्यकारी निदेशक, प.क्षे.भा.प्रे.के., एफ3, एम आई डी सी क्षेत्र, अंधेरी, मुंबई -400093
Executive Director, WRLDC, F-3, M.I.D.C. Area, Marol, Andheri (East), Mumbai-400093
- कार्यकारी निदेशक, ऊ.पू.क्षे.भा.प्रे.के., डोंगतेह, लोअर नोंग्रह, लापालंग, शिलोंग - 793006
Executive Director, NERLDC, Dongteih, Lower Nongrah, Lapalang, Shillong - 793006, Meghalaya
- कार्यकारी निदेशक, द.क्षे.भा.प्रे.के., 29, रेस कोर्स क्रॉस रोड, बंगलुरु -560009
Executive Director, SRLDC, 29, Race Course Cross Road, Bangalore-560009

Sub: Daily PSP Report for the date 30.05.2025.

महोदय/Sir,

आईईजीसी-2023 की धारा स.-38(1) के प्रावधान के अनुसार, दिनांक 30-मई-2025 की अखिल भारतीय प्रणाली की दैनिक ग्रिड निष्पादन रिपोर्ट रांभांप्रेके की वेबसाइट पर उपलब्ध है।

As per article 38(1) of the Indian Electricity Grid Code, the daily report pertaining power supply position of All India Power System for the date 30.05.2025, is available at the NLDC website.

धन्यवाद,
Thanks

Report for previous day

Date of Reporting: 31-May-2025

A. Power Supply Position at All India and Regional level

	NR	WR	SR	ER	NER	TOTAL
Demand Met during Evening Peak hrs(MW) (at 20:00 hrs; from RLDCs)	72942	64184	44904	27840	1997	211867
Peak Shortage (MW)	0	0	0	0	0	0
Energy Met (MU)	1600	1443	1025	611	40	4719
Hydro Gen (MU)	301	39	83	76	36	535
Wind Gen (MU)	33	287	269	-	-	589
Solar Gen (MU)*	172.29	132.39	97.19	3.08	0.22	405
Energy Shortage (MU)	0.00	0.00	0.00	0.00	0.00	0.00
Maximum Demand Met During the Day (MW) (From NLDC SCADA)	77574	61824	47316	29556	2045	212060
Time Of Maximum Demand Met	22:39	19:41	09:12	22:50	20:00	22:39

B. Frequency Profile (%)

Region	FVI	< 49.7	49.7 - 49.8	49.8 - 49.9	< 49.9	49.9 - 50.05	> 50.05
All India	0.094	0.00	0.00	0.71	0.71	70.58	28.71

C. Power Supply Position in States

Region	States	Max.Demand Met during the day (MW)	Shortage during maximum Demand (MW)	Energy Met (MU)	Drawal Schedule (MU)	OD(+)/UD(-) (MU)	Max OD (MW)	Energy Shortage (MU)
NR	Punjab	11384	0	229.5	123.3	-0.2	630	0.00
	Haryana	10151	0	211.0	161.0	0.0	410	0.00
	Rajasthan	15771	0	328.1	129.9	-3.5	743	0.00
	Delhi	6289	0	129.8	118.1	-3.9	163	0.00
	UP	28020	0	553.4	273.5	-2.0	934	0.00
	Uttarakhand	2410	0	50.3	27.7	-0.4	173	0.00
	HP	1730	0	38.3	3.7	-0.5	127	0.00
	J&K(UT) & Ladakh(UT)	2763	0	49.1	39.9	0.3	1076	0.00
	Chandigarh	346	0	6.7	6.9	-0.2	31	0.00
	Railways NR ISTS	206	0	4.3	4.0	0.3	36	0.00
WR	Chhattisgarh	4902	0	110.1	52.0	-0.8	305	0.00
	Gujarat	21871	0	458.8	157.7	-8.7	883	0.00
	MP	11892	0	265.3	150.8	-4.9	444	0.00
	Maharashtra	24740	0	527.6	153.7	-4.2	1024	0.00
	Goa	618	0	15.8	13.1	2.4	173	0.00
	DNHDDPDCL	1367	0	31.6	31.6	0.0	48	0.00
	AMNSIL	789	0	16.8	6.6	0.1	277	0.00
	BALCO	536	0	12.8	12.7	0.1	13	0.00
	RIL JAMNAGAR	200	0	3.8	3.9	0.0	0	0.00
	Andhra Pradesh	9152	0	201.9	45.1	-0.4	571	0.00
SR	Telangana	8862	0	189.7	88.8	0.4	495	0.00
	Karnataka	10002	0	196.0	71.7	-2.9	606	0.00
	Kerala	3677	0	72.3	46.8	-2.2	348	0.00
	Tamil Nadu	16504	0	354.4	167.7	-4.9	1502	0.00
	Puducherry	488	0	10.4	10.6	-0.2	42	0.00
	Bihar	7612	0	157.1	148.8	-2.5	327	0.00
ER	DVC	3266	0	72.1	-26.3	1.0	534	0.00
	Jharkhand	2093	0	44.2	36.7	-0.7	208	0.00
	Odisha	6475	0	127.7	53.6	2.3	675	0.00
	West Bengal	10949	0	208.8	82.8	-0.3	421	0.00
	Sikkim	82	0	1.3	1.5	-0.2	10	0.00
	Railways ER ISTS	26	0	0.2	0.2	0.0	0	0.00
NER	Arunachal Pradesh	140	0	3.4	3.4	-0.4	22	0.00
	Assam	1295	0	21.6	14.9	-0.3	185	0.00
	Manipur	178	0	2.7	3.0	-0.2	21	0.00
	Meghalaya	218	0	4.0	-0.3	-0.5	24	0.00
	Mizoram	84	0	1.8	1.8	-0.4	10	0.00
	Nagaland	142	0	2.4	2.7	-0.3	14	0.00
	Tripura	250	0	4.0	3.3	-0.7	38	0.00

D. Transnational Exchanges (MU) - Import(+ve)/Export(-ve)

	Bhutan	Nepal	Bangladesh	Godda -> Bangladesh
Actual (MU)	52.0	3.0	-18.1	-21.4
Day Peak (MW)	2525.0	117.0	-980.0	-1027.0

E. Import/Export by Regions (in MU) - Import(+ve)/Export(-ve); OD(+)/UD(-)

	NR	WR	SR	ER	NER	TOTAL
Schedule(MU)	359.9	-352.6	68.8	-54.5	-21.7	0.0
Actual(MU)	386.7	-349.8	22.5	-42.1	-23.8	-6.4
OD/UD(MU)	26.8	2.8	-46.2	12.4	-2.1	-6.4

F. Generation Outage(MW)

	NR	WR	SR	ER	NER	TOTAL	% Share
Central Sector	5344	7195	4068	2720	335	19662	37
State Sector	7299	10901	14361	1349	280	34190	63
Total	12643	18096	18429	4069	615	53852	100

G. Sourcewise generation (Gross) (MU)

	NR	WR	SR	ER	NER	All India	% Share
Coal	721	1362	456	643	10	3191	63
Lignite	19	18	41	0	0	78	2
Hydro	301	39	83	76	36	535	11
Nuclear	35	59	71	0	0	166	3
Gas, Naptha & Diesel	18	12	4	0	22	55	1
RES (Wind, Solar, Biomass & Others)	214	421	398	5	0	1039	21
Total	1308	1910	1053	723	68	5063	100

Share of RES in total generation (%)	16.38	22.04	37.79	0.68	0.34	20.51
Share of Non-fossil fuel (Hydro,Nuclear and RES) in total generation(%)	42.10	27.16	52.48	11.15	53.17	34.35

H. All India Demand Diversity Factor

Based on Regional Max Demands	1.029
Based on State Max Demands	1.072

I. All India Peak Demand and shortage at Solar and Non-Solar Hour

	Max Demand Met(MW)	Time	Shortage(MW)
Solar hr	202566	15:27	0
Non-Solar hr	212060	22:39	0

Diversity factor = Sum of regional or state maximum demands / All India maximum demand

**Note: All generation MU figures are gross

***Godda (Jharkhand) -> Bangladesh power exchange is through the radial connection (isolated from Indian Grid)

Solar Hours > 06:00 to 18:00hrs and rest are Non-Solar Hours

*Source: RLDCs for solar connected to ISTS; SLDCs for embedded solar. Limited visibility of embedded solar data.

Executive Director-NLDC

INTER-REGIONAL EXCHANGES

Import=(+ve) /Export =(-ve) for NET (MU)
Date of Reporting: 31-May-2025

Sl No	Voltage Level	Line Details	No. of Circuit	Max Import (MW)	Max Export (MW)	Import (MU)	Export (MU)	NET (MU)
Import/Export of ER (With NR)								
1	HVDC	ALIPURDUAR-AGRA	2	0	0	0.0	0.0	0.0
2	HVDC	PUSAULI -B/B	-	0	47	0.0	2.4	-2.4
3	765 kV	GAYA-VARANASI	2	723	962	0.0	1.2	-1.2
4	765 kV	SASARAM-FATEHPUR	1	204	403	0.0	1.5	-1.5
5	765 kV	GAYA-BALIA	1	0	853	0.0	10.7	-10.7
6	400 kV	PUSAULI-VARANASI	1	0	128	0.0	2.0	-2.0
7	400 kV	PUSAULI -ALLAHABAD	1	36	60	0.0	0.3	-0.3
8	400 kV	MUZAFFARPUR-GORAKHPUR	2	0	953	0.0	11.8	-11.8
9	400 kV	PATNA-BALIA	2	1	1144	0.0	11.1	-11.1
10	400 kV	NAUBATPUR-BALIA	2	53	759	0.0	2.8	-2.8
11	400 kV	BIHARSHARIFF-BALIA	2	170	340	0.0	2.2	-2.2
12	400 kV	MOTIHARI-GORAKHPUR	2	0	678	0.0	7.4	-7.4
13	400 kV	BIHARSARIFF-SAHUPURI	2	102	239	0.0	1.3	-1.3
14	220 kV	SAHUPURI-KARAMNESA	1	0	113	0.0	2.5	-2.5
15	132 kV	NAGAR UNTARI-RIHAND	1	0	0	0.1	0.0	0.1
16	132 kV	GARWAH-RIHAND	1	30	0	0.6	0.0	0.6
17	132 kV	KARMANASA-SAHUPURI	1	0	0	0.0	0.0	0.0
18	132 kV	KARMANASA-CHANDAULI	1	0	0	0.0	0.0	0.0
						ER-NR	0.7	-56.5
Import/Export of ER (With WR)								
1	765 kV	JHARSUGUDA-DHARAMJAIGARH	4	777	1193	0.0	3.9	-3.9
2	765 kV	NEW RANCHI-DHARAMJAIGARH	2	1835	0	27.4	0.0	27.4
3	765 kV	JHARSUGUDA-DURG	2	297	403	0.0	3.9	-3.9
4	400 kV	JHARSUGUDA-RAIGARH	4	506	266	1.3	0.0	1.3
5	400 kV	RANCHI-SIPAT	2	501	0	5.0	0.0	5.0
6	220 kV	BUDHIPADAR-RAIGARH	1	85	75	0.0	0.1	-0.1
7	220 kV	BUDHIPADAR-KORBA	2	208	36	1.6	0.0	1.6
						ER-WR	35.3	27.6
Import/Export of ER (With SR)								
1	HVDC	JEYPORE-GAZUWAKA B/B	2	360	0	8.4	0.0	8.4
2	HVDC	TALCHER-KOLAR BIPOLE	2	0	1615	0.0	33.4	-33.4
3	765 kV	ANGUL-SRIKAKULAM	2	0	2371	0.0	38.4	-38.4
4	400 kV	TALCHER-I/C	2	878	488	3.0	0.0	3.0
5	220 kV	BALIMELA-UPPER-SILERRU	1	0	0	0.0	0.0	0.0
						ER-SR	8.4	-63.4
Import/Export of ER (With NER)								
1	400 kV	BINAGURI-BONGAIGAON	2	455	0	7.6	0.0	7.6
2	400 kV	ALIPURDUAR-BONGAIGAON	2	294	17	3.3	0.0	3.3
3	220 kV	ALIPURDUAR-SALAKATI	2	105	0	1.7	0.0	1.7
						ER-NER	12.6	12.6
Import/Export of NER (With NR)								
1	HVDC	BISWANATH CHARIALI-AGRA	2	0	504	0.0	12.1	-12.1
						NER-NR	0.0	-12.1
Import/Export of WR (With NR)								
1	HVDC	CHAMPA-KURUKSHETRA	2	0	4045	0.0	80.8	-80.8
2	HVDC	VINDHYACHAL B/B	-	0	303	0.0	7.3	-7.3
3	HVDC	MUNDRA-MOHINDERGARH	2	0	1451	0.0	36.3	-36.3
4	765 kV	GWALIOR-AGRA	2	0	3134	0.0	41.3	-41.3
5	765 kV	GWALIOR-PHAGI	2	839	1486	5.5	14.1	-8.6
6	765 kV	JABALPUR-ORAI	2	0	1382	0.0	38.0	-38.0
7	765 kV	GWALIOR-ORAI	1	610	0	8.3	0.0	8.3
8	765 kV	SATNA-ORAI	1	0	1194	0.0	18.4	-18.4
9	765 kV	BANASKANTHA-CHITORGARH	2	0	2216	0.0	28.8	-28.8
10	765 kV	VINDHYACHAL-VARANASI	2	0	3162	0.0	54.7	-54.7
11	400 kV	ZERDA-KANKROLI	1	65	259	0.1	2.8	-2.7
12	400 kV	ZERDA-BHINMAL	1	183	310	0.7	4.3	-3.6
13	400 kV	VINDHYACHAL -RIHAND	1	0	1	0.0	0.0	0.0
14	400 kV	RAPP-SHUJALPUR	2	400	562	1.8	3.9	-2.0
15	400 kV	NEEMUCH-Chittorgarh	2	363	509	0.8	4.4	-3.6
16	220 kV	BHANPURA-RANPUR	1	0	165	0.0	3.4	-3.4
17	220 kV	BHANPURA-MORAK	1	0	30	0.0	2.3	-2.3
18	220 kV	MEHGAON-AURAIYA	1	80	28	0.4	0.1	0.3
19	220 kV	MALANPUR-AURAIYA	1	53	44	0.2	0.4	-0.2
20	132 kV	RAJGHAT-LALITPUR	2	0	0	0.0	0.0	0.0
						WR-NR	17.8	-323.2
Import/Export of WR (With SR)								
1	HVDC	BHADRAWATI B/B	-	505	0	12.0	0.0	12.0
2	HVDC	RAIGARH-PUGALUR	2	0	1305	0.0	24.4	-24.4
3	765 kV	SOLAPUR-RAICHUR	2	1580	721	16.5	1.3	15.2
4	765 kV	WARDHA-NIZAMABAD	2	417	1653	0.6	16.0	-15.4
5	765 kV	WARORA-WARANAGAL(NEW)	2	320	1936	0.3	19.8	-19.5
6	400 kV	KOLHAPUR-KUDGI	2	1633	0	31.0	0.0	31.0
7	220 kV	KOLHAPUR-CHIKODI	2	0	0	0.0	0.0	0.0
8	220 kV	PONDA-AMBEWADI	1	0	0	0.0	0.0	0.0
9	220 kV	XELDEM-AMBEWADI	1	0	116	2.2	0.0	2.2
						WR-SR	62.6	1.2

INTERNATIONAL EXCHANGES					Import(+ve)/Export(-ve)	
State	Region	Line Name	Max (MW)	Min (MW)	Avg (MW)	Energy Exchange (MU)
BHUTAN	ER	400kV MANGDECHHU-ALIPURDUAR 1,2&3 i.e. ALIPURDUAR RECEIPT (from MANGDECHHU HEP 4*180MW)	1572	1014	1293	31.03
	ER	400kV TALA-BINAGURI 1,2,4 (& 400kV MALBASE - BINAGURI) i.e. BINAGURI RECEIPT (from TALA HEP 6*170MW)	889	543	763	18.31
	ER	220kV CHUKHA-BIRPARA 1&2 (& 220kV MALBASE - BIRPARA) i.e. BIRPARA RECEIPT (from CHUKHA HEP 4*84MW)	107	-6	63	1.52
	NER	132kV GELEPHU-SALAKATI	49	0	31	0.74
	NER	132kV MOTANGA-RANGIA	34	0	18	0.42
NEPAL	NR	NEPAL IMPORT (FROM UP)	-74	0	-42	-1.01
	NR	132kV MAHENDRANAGAR-TANAKPUR(NHPC)	-74	0	-50	-1.19
	ER	NEPAL IMPORT (FROM BIHAR)	0	0	0	0.00
	ER	400kV DHALKEBAR-MUZAFFARPUR 1&2	117	0	117	5.20
BANGLADESH	ER	BHERAMARA B/B HVDC (B'DESH)	-959	-462	-743	-17.83
	ER (Isolated from Indian Grid)	400kV GODDA_TPS-RAHANPUR (B'DESH) D/C	-1027	-812	-891	-21.37
	NER	132kV COMILLA-SURAJMANI NAGAR 1&2	-21	0	-10	-0.23

CROSS BORDER EXCHANGE SCHEDULE

Date of Reporting: 31-May-2025

Export From India (in MU)

Country	GNA (ISGS/PPA)	T-GNA							TOTAL
		BILATERAL TOTAL	COLLECTIVE						
			IDAM			RTM			
			IEX	PXIL	HPX	IEX	PXIL	HPX	
Bhutan	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Nepal	0.41	0.00	0.00	0.00	0.00	0.64	0.00	0.00	1.05
Bangladesh	18.91	0.00	0.00	0.00	0.00	0.00	0.00	0.00	18.91
Myanmar	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total Export	19.32	0.00	0.00	0.00	0.00	0.64	0.00	0.00	19.96

Import by India(in MU)

Country	GNA (ISGA/PPA)	T-GNA							TOTAL
		BILATERAL TOTAL	COLLECTIVE						
			IDAM			RTM			
			IEX	PXIL	HPX	IEX	PXIL	HPX	
Bhutan	49.99	0.00	0.52	0.00	0.00	0.04	0.00	0.00	50.55
Nepal	0.00	0.00	0.00	0.00	0.00	4.45	0.00	0.00	4.45
Bangladesh	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Myanmar	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total Import	49.99	0.00	0.52	0.00	0.00	4.49	0.00	0.00	55.00

Net from India(in MU)

-ve : Export / +ve : Import

Country	GNA (ISGS/PPA)	T-GNA							TOTAL
		BILATERAL TOTAL	COLLECTIVE						
			IDAM			RTM			
			IEX	PXIL	HPX	IEX	PXIL	HPX	
Bhutan	49.99	0.00	0.52	0.00	0.00	0.04	0.00	0.00	50.55
Nepal	-0.41	0.00	0.00	0.00	0.00	3.81	0.00	0.00	3.40
Bangladesh	-18.91	0.00	0.00	0.00	0.00	0.00	0.00	0.00	-18.91
Myanmar	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total Net	30.67	0.00	0.52	0.00	0.00	3.85	0.00	0.00	35.04

15 Min (INSTANTANEOUS) ALL INDIA GRID FREQUENCY, GENERATION & DEMAND MET (SCADA DATA)													
TIME	FREQUENCY (Hz)	DEMAND MET (MW)	NUCLEAR (MW)	WIND (MW)	SOLAR (MW)	HYDRO** (MW)	GAS (MW)	THERMAL (MW)	OTHERS* (MW)	NET DEMAND MET (MW)	TOTAL GENERATION (MW)	NET TRANSNATIONAL EXCHANGE (MW)	
		(A)	(B)	(C)	(D)	(E)	(F)	(G)	(H)	(I=A-(C+D))	(J=B+C+D+E+F+G+H)	(+ve) Import, (-ve) Export	
0:00	50.07	205036	6278	22037	0	22689	2949	150399	1760	182999	206112		1042
0:15	50.07	202730	6282	22346	0	22001	2825	148922	1737	180384	204113		950
0:30	50.02	201870	6275	22348	0	22493	2758	147531	1706	179522	203111		1007
0:45	50.02	199393	6277	22384	0	22540	2644	145221	1708	177009	200774		1013
1:00	49.97	197628	6279	22690	0	22325	2518	143430	1748	174938	198990		1032
1:15	49.97	196492	6268	22365	0	22385	2523	142514	1661	174127	197716		1049
1:30	49.92	194671	6285	22026	0	22314	2466	140978	1675	172645	195744		1094
1:45	49.97	192884	6253	21833	0	22012	2443	139990	1655	171051	194186		1085
2:00	49.97	191389	6269	21636	0	22061	2433	138462	1660	169753	192521		1084
2:15	50.07	190094	6272	21796	0	21852	2426	137151	1663	168298	191160		1214
2:30	50.07	188333	6270	21885	0	21547	2415	135700	1658	166448	189475		1172
2:45	50.07	187000	6290	21934	0	20632	2424	134743	1647	165066	187670		1288
3:00	50.02	185609	6277	21867	0	20580	2439	133526	1674	163742	186363		1480
3:15	50.02	184047	6286	21690	0	20335	2347	132544	1675	162357	184877		1522
3:30	50.07	182143	6280	21649	0	19675	2329	131453	1688	160494	183074		1511
3:45	50.07	181158	6273	21848	0	19536	2333	130296	1722	159310	182008		1545
4:00	50.02	180862	6271	21857	0	19610	2341	129931	1665	159005	181675		1568
4:15	49.97	180812	6272	21650	0	19602	2330	130008	1669	159162	181531		1590
4:30	50.02	180204	6266	21909	0	19414	2341	129283	1666	158295	180879		1602
4:45	50.02	180005	6285	21984	0	19408	2340	128847	1699	158021	180563		1640
5:00	50.07	179313	6273	21928	209	19405	2348	128005	1661	157176	179829		1702
5:15	50.07	179442	6279	22326	210	18963	2344	128119	1690	156906	179931		1706
5:30	50.02	179686	6281	22219	216	19179	2336	128210	1693	157251	180134		1664
5:45	49.97	180333	6268	22213	262	19771	2353	128045	1671	157858	180583		1649
6:00	50.02	179399	6285	22514	408	19905	2352	126295	1698	156477	179457		1683
6:15	50.02	179400	6287	22183	1637	20170	2353	125500	1698	155580	179828		1608
6:30	49.97	179573	6292	22031	2845	20402	2356	123851	1676	154697	179453		1582
6:45	49.97	180206	6268	21558	4556	20467	2354	122659	1686	154092	179548		1736
7:00	49.97	179842	6276	21166	6724	20819	2354	120575	1725	151952	179639		1714
7:15	49.97	180365	6259	21096	9258	20790	2361	118616	1708	150011	180088		1724
7:30	50.07	180529	6255	21244	12562	20699	2384	115169	1744	146723	180057		1750
7:45	50.22	180024	6269	21417	15694	19875	2365	112171	1772	142913	179563		1744
8:00	50.37	179752	6290	21511	18061	18675	2369	110838	1764	140180	179508		1642
8:15	50.32	181632	6283	22075	20775	18152	2363	109696	1786	138782	181130		1640
8:30	50.32	183930	6273	22688	23830	17387	2369	108461	1824	137412	182832		1658
8:45	50.27	186374	6263	23259	26634	17064	2370	108074	1767	136481	185431		1670
9:00	50.32	187634	6278	22492	29952	16514	2374	107243	1778	135190	186631		1640
9:15	50.22	188100	6273	23263	32829	16038	2373	105063	1808	132008	187647		1597
9:30	49.97	189346	6270	23471	32096	16968	2378	105979	1865	133779	189027		1671
9:45	49.97	196556	6228	24435	37901	16685	2388	106850	1871	134220	196358		1682
10:00	50.02	196740	6241	24609	40938	16226	2382	105316	1914	131193	197626		1690
10:15	50.07	197059	6235	24444	42445	16115	2360	104186	1893	130170	197678		1722
10:30	50.07	196708	6254	24329	43559	15844	2281	103625	1909	128820	197801		1824
10:45	50.27	197969	6243	24079	47066	15088	2292	102941	1876	126824	199585		1771
11:00	50.17	197216	6271	23581	47420	14894	2291	102720	1907	126215	199084		1732
11:15	49.97	197128	6240	22916	46067	15508	2293	104413	1897	128145	199334		1296
11:30	50.02	197466	6237	22494	45368	15641	2144	105318	1983	129604	199185		1269
11:45	49.97	197691	6243	22221	45417	15801	2196	105450	1916	130053	199244		1467
12:00	49.97	197811	6242	22440	45549	15604	2187	105545	1961	129822	199528		1462
12:15	49.97	197266	6222	22795	46504	15494	2175	104533	1873	127967	199596		1234
12:30	49.97	197082	6224	22898	46461	15557	2213	103901	1930	127723	199184		1333
12:45	49.97	196949	6217	22963	46242	15170	2215	104146	1895	127744	198848		1560
13:00	50.02	195905	6199	22819	46186	15045	2196	103613	1879	126900	197937		1600
13:15	50.02	193817	6204	22553	44884	14603	2030	103937	1903	126380	196114		1647
13:30	50.07	194910	6204	22774	45511	14723	2199	103252	1924	126625	196587		1630
13:45	49.97	196078	6212	22855	45503	14959	2188	104597	1877	127720	198191		1395
14:00	50.02	197716	6209	22515	46603	15632	2190	104848	1915	128598	199912		1432
14:15	50.07	199284	6225	22264	48176	15264	2036	105735	1876	128844	201576		1392
14:30	50.07	201335	6204	22330	48513	15629	2048	107038	1853	130492	203615		1490
14:45	49.97	201323	6211	22525	47246	15897	2022	107700	1814	131552	203415		1422
15:00	50.02	202470	6203	22635	45764	15837	2059	110106	1790	134071	204394		1558
15:15	49.97	202343	6201	23569	43599	15990	2139	110977	1798	135175	204273		1630
15:30	50.02	202380	6011	24186	40640	16419	2158	112665	1787	137554	203866		1459
15:45	50.02	202021	6001	24438	37626	16816	2170	114231	1768	139957	203050		1558
16:00	50.02	200662	5999	24455	35461	17163	2175	115026	1779	140746	202058		1578
16:15	50.07	199088	6013	24667	33053	17280	2193	115681	1736	141368	200623		1473
16:30	50.02	199099	6003	24922	30399	18129	2198	117258	1732	143778	200641		1518
16:45	50.02	197601	6010	24979	26914	18355	2190	118668	1686	145708	198802		1615
17:00	50.02	196437	6010	24829	23338	18943	2160	120707	1666	148270	197653		1508
17:15	49.97	194785	6026	24817	20135	19454	2201	121790	1681	149833	196104		1333
17:30	50.02	193962	6016	25001	16071	19700	2208	124612	1666	152890	195274		1327
17:45	49.97	193532	6019	25207	12584	19454	2202	127872	1680	155741	195018		1334
18:00	50.02	192639	6028	25615	9691	19233	2159	129783	1683	157333	194192		1338
18:15	50.02	192051	6043	26119	6852	19327	2175	131356	1737	159080	193609		1354
18:30	49.97	194876	6016	26595	4692	20971	2196	134425	1698	163589	196593		1321
18:45	50.07	197782	6037	27284	2741	22128	2222	137210	1727	167757	199349		1282
19:00	50.02	200532	6042	27455	1565	23060	2306	140193	1742	171512	202363		1286
19:15	49.97	203188	6043	27213	714	23732	2307	143513	1715	175261	205237		1124
19:30	49.97	206247	6036	27248	303	25085	2361	145614	1749	178696	208396		1099
19:45	49.97	208201	6042	27200	237	25524	2380	147419	1679	180764	210481		1094
20:00	50.02	208455	6053	26958	214	25403	2408	147959	1715	181283	210710		1098
20:15	49.97	208105	6072	26830	0	24899	2494	147926	1710	181275	209931		1112
20:30	50.02	209014	6060	26958	0	25069	2435	148641	1777	182056	210940		1136
20:45	49.97	208548	6051	26542	0	24484	2512	149226	1775	182006	210590		1107
21:00	50.02	208848	6033	26484	0	24685	2519	149403	1734	182364	210858		1104
21:15	50.02	208670	6055	26532	0	25060	2544	148805	1762	182138	210758		1195
21:30	50.07	209334	6059	26									