



National Load Despatch Centre
राष्ट्रीय भार प्रेषण केंद्र
GRID CONTROLLER OF INDIA LIMITED
ग्रिड कंट्रोलर ऑफ इंडिया लिमिटेड

(Government of India Enterprise/ भारत सरकार का उद्यम)
B-9, QUTUB INSTITUTIONAL AREA, KATWARIA SARAI, NEW DELHI -110016
बी-9, कुतुब इन्स्टीट्यूशनल एरिया, कटवारिया सराये, न्यू दिल्ली-110016

Ref: GRID-INDIA/NLDC/SO/Daily PSP Report

दिनांक: 29.12.2025

To,

- कार्यकारी निदेशक, पू.क्षे.भा.प्रे.के., 14, गोल्फ क्लब रोड, कोलकाता - 700033
Executive Director, ERLDC, 14 Golf Club Road, Tollygunge, Kolkata, 700033
- कार्यकारी निदेशक, ऊ.क्षे.भा.प्रे.के., 18/ए, शाहीद जीत सिंह सनसनवाल मार्ग, नई दिल्ली - 110016
Executive Director, NRLDC, 18-A, Shaheed Jeet Singh Marg, Katwaria Sarai, New Delhi - 110016
- कार्यकारी निदेशक, प.क्षे.भा.प्रे.के., एफ3, एम आई डी सी क्षेत्र, अंधेरी, मुंबई - 400093
Executive Director, WRLDC, F-3, M.I.D.C. Area, Marol, Andheri (East), Mumbai-400093
- कार्यकारी निदेशक, ऊ.पू.क्षे.भा.प्रे.के., डोंगतेह, लोअर नोंग्रह, लापालंग, शिलोंग - 793006
Executive Director, NERLDC, Dongteih, Lower Nongrah, Lapalang, Shillong - 793006, Meghalaya
- कार्यकारी निदेशक, द.क्षे.भा.प्रे.के., 29, रेस कोर्स क्रॉस रोड, बंगलुरु - 560009
Executive Director, SRLDC, 29, Race Course Cross Road, Bangalore-560009

Sub: Daily PSP Report for the date 28.12.2025.

महोदय/Sir,

आईईजीसी-2023 की धारा स.-38(1) के प्रावधान के अनुसार, दिनांक 28-दिसंबर-2025 की अखिल भारतीय प्रणाली की दैनिक ग्रिड निष्पादन रिपोर्ट रांभांप्रेके की वेबसाइट पर उपलब्ध है।

As per article 38(1) of the Indian Electricity Grid Code, the daily report pertaining power supply position of All India Power System for the date 28.12.2025, is available at the NLDC website.

धन्यवाद,
Thanks

Report for previous day

Date of Reporting: 29-Dec-2025

A. Power Supply Position at All India and Regional level

	NR	WR	SR	ER	NER	TOTAL
Demand Met during Evening Peak hrs(MW) (at 19:00 hrs; from RLDCs)	58578	66950	44040	22612	2649	194829
Peak Shortage (MW)	0	0	0	0	0	0
Energy Met (MU)	1271	1539	1121	464	50	4445
Hydro Gen (MU)	127	39	75	17	14	272
Wind Gen (MU)	5	51	59	-	-	115
Solar Gen (MU)*	161.94	163.02	148.28	3.03	0.84	477
Energy Shortage (MU)	0.00	0.00	0.00	0.00	0.00	0.00
Maximum Demand Met During the Day (MW) (From NLDC SCADA)	67702	78291	57249	23217	2779	226172
Time Of Maximum Demand Met	10:28	10:28	09:22	17:41	17:38	09:57

B. Frequency Profile (%)

Region	FV1	< 49.7	49.7 - 49.8	49.8 - 49.9	< 49.9	49.9 - 50.05	> 50.05
All India	0.031	0.23	0.51	3.45	4.19	83.71	12.11

C. Power Supply Position in States

Region	States	Max.Demand Met during the day (MW)	Shortage during maximum Demand (MW)	Energy Met (MU)	Drawal Schedule (MU)	OD(+)/UD(-) (MU)	Max OD (MW)	Energy Shortage (MU)
NR	Punjab	8026	0	149.1	67.1	-1.8	321	0.00
	Haryana	7999	0	151.7	107.2	-2.0	219	0.00
	Rajasthan	18090	0	336.7	126.3	-1.0	921	0.00
	Delhi	4773	0	78.7	75.8	0.4	413	0.00
	UP	21628	0	400.7	100.4	-0.3	720	0.00
	Uttarakhand	2523	0	45.2	34.4	0.7	191	0.00
	HP	2066	0	36.4	29.7	-1.0	122	0.00
	J&K(UT) & Ladakh(UT)	3145	0	65.0	60.9	-1.7	59	0.00
	Chandigarh	231	0	4.0	4.0	0.0	17	0.00
	Railways_NR ISTS	190	0	3.9	3.5	0.3	43	0.00
WR	Chhattisgarh	5235	0	107.9	49.9	-1.0	161	0.00
	Gujarat	23632	0	435.1	191.2	0.0	740	0.00
	MP	19342	0	347.5	225.8	0.0	677	0.00
	Maharashtra	27818	0	566.3	171.6	-11.0	521	0.00
	Goa	634	0	12.6	10.0	2.1	43	0.00
	DNHDDPDCL	1271	0	29.6	29.4	0.2	45	0.00
	AMNSIL	877	0	19.6	11.9	0.8	284	0.00
	BALCO	594	0	14.2	14.3	-0.1	17	0.00
	RIL JAMNAGAR	262	0	6.3	6.6	-0.3	0	0.00
	Andhra Pradesh	11329	0	210.0	62.5	0.3	645	0.00
SR	Telangana	13904	0	244.1	106.4	-0.2	1504	0.00
	Karnataka	15152	0	268.4	83.0	-0.6	572	0.00
	Kerala	3957	0	73.6	54.4	0.3	388	0.00
	Tamil Nadu	14861	0	317.0	177.8	-0.5	764	0.00
	Puducherry	361	0	8.0	7.5	-0.1	21	0.00
	Bihar	6148	0	116.8	104.5	0.9	200	0.00
ER	DVC	3071	0	64.9	-31.7	-1.5	317	0.00
	Jharkhand	2350	0	41.3	30.9	-1.8	145	0.00
	Odisha	4882	0	94.7	12.9	-2.3	354	0.00
	West Bengal	6951	0	144.7	24.2	-2.0	220	0.00
	Sikkim	99	0	1.6	1.6	0.0	12	0.00
	Railways_ER ISTS	16	0	0.2	0.1	0.0	4	0.00
NER	Arunachal Pradesh	179	0	3.4	3.2	0.0	11	0.00
	Assam	1545	0	27.6	21.6	0.2	116	0.00
	Manipur	247	0	3.8	3.9	-0.1	34	0.00
	Meghalaya	323	0	6.1	5.7	-0.1	49	0.00
	Mizoram	150	0	2.3	2.0	0.0	11	0.00
	Nagaland	153	0	2.7	2.6	-0.1	22	0.00
	Tripura	222	0	3.8	4.5	-0.2	40	0.00

D. Transnational Exchanges (MU) - Import(+ve)/Export(-ve)

	Bhutan	Nepal	Bangladesh	Godda -> Bangladesh
Actual (MU)	-13.2	-4.3	-12.7	-26.3
Day Peak (MW)	-987.7	-427.2	-557.0	-1467.6

E. Import/Export by Regions (in MU) - Import(+ve)/Export(-ve); OD(+)/UD(-)

	NR	WR	SR	ER	NER	TOTAL
Schedule(MU)	220.5	-179.6	129.6	-177.8	7.3	0.0
Actual(MU)	222.5	-186.9	123.7	-178.4	5.7	-13.5
O/D/U/D(MU)	1.9	-7.3	-5.8	-0.6	-1.7	-13.5

F. Generation Outage(MW)

	NR	WR	SR	ER	NER	TOTAL	% Share
Central Sector	5934	12209	6718	4840	87	29788	54
State Sector	7669	9120	6074	2376	205	25444	46
Total	13603	21329	12792	7216	292	55232	100

G. Sourcewise generation (Gross) (MU)

	NR	WR	SR	ER	NER	All India	% Share
Coal	770	1507	649	704	13	3643	75
Lignite	17	15	47	0	0	79	2
Hydro	127	39	75	17	14	272	6
Nuclear	46	53	47	0	0	145	3
Gas, Naptha & Diesel	3	10	9	0	22	44	1
RES (Wind, Solar, Biomass & Others)	192	217	247	6	1	663	14
Total	1155	1841	1075	727	49	4847	100

Share of RES in total generation (%)	16.65	11.78	22.98	0.84	1.70	13.68
Share of Non-fossil fuel (Hydro,Nuclear and RES) in total generation(%)	31.63	16.76	34.32	3.16	30.01	22.29

H. All India Demand Diversity Factor

Based on Regional Max Demands	1.013
Based on State Max Demands	1.035

I. All India Peak Demand and shortage at Solar and Non-Solar Hour

	Max Demand Met(MW)	Time	Shortage(MW)
Solar hr	226172	9:57	0
Non-Solar hr	201285	17:56	0

Diversity factor = Sum of regional or state maximum demands / All India maximum demand

**Note: All generation MU figures are gross

***Godda (Jharkhand) -> Bangladesh power exchange is through the radial connection (isolated from Indian Grid)

Solar Hours -> 06:00 to 18:00hrs and rest are Non-Solar Hours

*Source: RLDCs for solar connected to ISTS; SLDCs for embedded solar. Limited visibility of embedded solar data.

Executive Director-NLDC

INTER-REGIONAL EXCHANGES

Import=(+ve)/Export =(-ve) for NET (MU)
Date of Reporting: 29-Dec-2025

Sl No	Voltage Level	Line Details	No. of Circuit	Max Import (MW)	Max Export (MW)	Import (MU)	Export (MU)	NET (MU)
Import/Export of ER (With NR)								
1	HVDC	ALIPURDUAR-AGRA	2	0	320	0.0	0.4	-0.4
2	HVDC	PUSAULI B/B	-	0	47	0.0	2.4	-2.4
3	765 kV	GAYA-VARANASI	2	65	1388	0.0	18.7	-18.7
4	765 kV	SASARAM-FATEHPUR	1	73	670	0.0	7.3	-7.3
5	765 kV	GAYA-BALIA	1	0	775	0.0	13.8	-13.8
6	400 kV	PUSAULI-VARANASI	1	27	116	0.0	0.9	-0.9
7	400 kV	PUSAULI-ALLAHABAD	1	22	127	0.0	1.4	-1.4
8	400 kV	MUZAFFARPUR-GORAKHPUR	2	293	727	0.0	7.0	-7.0
9	400 kV	PATNA-BALIA	2	0	1157	0.0	17.7	-17.7
10	400 kV	NAUBATPUR-BALIA	2	0	531	0.0	5.1	-5.1
11	400 kV	BIHARSHARIFF-BALIA	2	303	332	0.0	1.0	-1.0
12	400 kV	MOTIHARI-GORAKHPUR	2	121	613	0.0	6.1	-6.1
13	400 kV	BIHARSARIFF-SAHUPURI	2	62	492	0.0	5.7	-5.7
14	220 kV	SAHUPURI-KARMANASA	1	5	34	0.0	0.6	-0.6
15	132 kV	NAGAR UNTARI-RIHAND	1	0	0	0.1	0.0	0.1
16	132 kV	GARWAH-RIHAND	1	30	0	0.7	0.0	0.7
17	132 kV	KARMANASA-SAHUPURI	1	0	30	0.0	0.0	0.0
18	132 kV	KARMANASA-CHANDAULI	1	0	20	0.0	0.9	-0.9
ER-NR						0.8	89.0	-88.2
Import/Export of ER (With WR)								
1	765 kV	JHARSUGUDA-DHARAMJAIGARH	4	137	1017	0.0	8.3	-8.3
2	765 kV	NEW RANCHI-DHARAMJAIGARH	2	615	866	0.0	5.4	-5.4
3	765 kV	JHARSUGUDA-DURG	2	0	1157	0.0	22.2	-22.2
4	400 kV	JHARSUGUDA-RAIGARH	4	90	531	0.0	5.7	-5.7
5	400 kV	RANCHI-SIPAT	2	174	266	0.0	1.5	-1.5
6	400 kV	JEYPORE-JACDALPUR	2	406	316	0.0	0.0	2.9
7	220 kV	BUDHIPADAR-RAIGARH	1	0	128	0.0	1.8	-1.8
8	220 kV	BUDHIPADAR-KORBA	2	105	90	0.2	0.0	0.2
ER-WR						3.1	44.9	-41.8
Import/Export of ER (With SR)								
1	HVDC	JEYPORE-GAZUWAKA B/B	2	0	623	0.0	8.1	-8.1
2	HVDC	TALCHER-KOLAR BIPOLE	2	0	1450	0.0	39.7	-39.7
3	765 kV	ANGUL-SRIKAKULAM	2	0	2729	0.0	48.0	-48.0
4	400 kV	TALCHER/UC	2	252	616	3.3	0.0	3.3
5	220 kV	BALIMELA-UPPER-SILERRU	1	0	0	0.0	0.0	0.0
ER-SR						0.0	95.9	-95.9
Import/Export of ER (With NER)								
1	400 kV	BINAGURI-BONGAIGAON	2	374	342	1.2	2.5	-1.3
2	400 kV	ALIPURDUAR-BONGAIGAON	2	649	414	0.7	0.0	0.7
3	220 kV	ALIPURDUAR-SALAKATI	2	129	48	0.5	0.0	0.5
ER-NER						2.5	2.5	0.0
Import/Export of NER (With NR)								
1	HVDC	BISWANATH CHARIALI-AGRA	2	652	0	8.4	0.0	8.4
NER-NR						8.4	0.0	8.4
Import/Export of WR (With NR)								
1	HVDC	CHAMPA-KURUKSHETRA	2	0	3016	0.0	56.0	-56.0
2	HVDC	VINDHYACHAL B/B	-	0	304	0.0	7.2	-7.2
3	HVDC	MUNDRA-MOHINDERGARH	2	0	1459	0.0	27.2	-27.2
4	765 kV	GWALIOR-AGRA	2	0	2124	0.0	22.9	-22.9
5	765 kV	GWALIOR-PHAGI	2	337	2245	0.0	24.9	-24.9
6	765 kV	JABALPUR-ORAI	2	0	1001	0.0	28.1	-28.1
7	765 kV	GWALIOR-ORAI	1	960	0	14.6	0.0	14.6
8	765 kV	SATNA-ORAI	1	0	1124	0.0	30.3	-30.3
9	765 kV	BANASKANTHA-CHITORGARH	2	2086	0	25.4	0.0	25.4
10	765 kV	VINDHYACHAL-VARANASI	2	0	2296	0.0	34.9	-34.9
11	400 kV	ZERDA-KANKROLI	1	305	0	4.3	0.0	4.3
12	400 kV	ZERDA -BHINMAL	1	210	0	3.0	0.0	3.0
13	400 kV	VINDHYACHAL -RIHAND	1	972	0	0.0	21.4	-21.4
14	400 kV	RAPP-SHUJALPUR	2	662	311	4.3	1.2	3.2
15	400 kV	NEEMUCH-Chittorgarh	2	565	499	0.0	0.1	-0.1
16	220 kV	BHANPURA-RANPUR	1	0	135	0.0	2.2	-2.2
17	220 kV	BHANPURA-MORAK	1	0	30	0.0	1.4	-1.4
18	220 kV	MEHGAON-AURAIYA	1	99	11	1.1	0.0	1.1
19	220 kV	MALANPUR-AURAIYA	1	70	23	0.6	0.1	0.5
20	132 kV	RAIGHAT-LALITPUR	2	0	0	0.0	0.0	0.0
WR-NR						53.3	247.8	-194.5
Import/Export of WR (With SR)								
1	HVDC	BHADRAWATI B/B	-	0	307	0.0	7.2	-7.2
2	HVDC	RAIGARH-PUGALUR	2	0	2006	0.0	42.1	-42.1
3	765 kV	SOLAPUR-RAICHUR	2	1030	951	6.6	4.9	1.7
4	765 kV	WARDHA-NIZAMABAD	2	266	2013	0.0	22.4	-22.4
5	765 kV	WARORA-WARANGAL(NEW)	2	0	2441	0.0	34.3	-34.3
6	400 kV	KOLHAPUR-KUDGI	2	1477	0	25.6	0.0	25.6
7	220 kV	KOLHAPUR-CHIKODI	2	0	0	0.0	0.0	0.0
8	220 kV	PONDA-AMBEWADI	1	0	0	0.0	0.0	0.0
9	220 kV	XELDEM-AMBEWADI	1	0	121	0.0	2.1	-2.1
WR-SR						34.3	110.9	-76.6

INTERNATIONAL EXCHANGES					Import(+ve)/Export(-ve)		
State	Region	Line Name	Max (MW)	Min (MW)	Avg (MW)	Energy Exchange (MU)	
BHUTAN	ER	400kV MANGDECHHU-ALIPURDUAR 1,2&3 I.e. ALIPURDUAR RECEIPT (from MANGDECHU HEP 4*180MW)	-271	32	-125	-2.99	
	ER	400kV TALA-BINAGURI 1,2,4 (& 400kV MALBASE - BINAGURI) I.e. BINAGURI RECEIPT (from TALA HEP 6*170MW)	240	-233	-26	-0.61	
	ER	220kV CHUKHA-BIRPARA 1&2 (& 220kV MALBASE - BIRPARA) I.e. BIRPARA RECEIPT (from CHUKHA HEP 4*84MW)	-354	-247	-319	-7.66	
	NER	132kV GELEPHU-SALAKATI	-62	0	-55	-1.32	
	NER	132kV MOTANGA-RANGIA	-49	0	-27	-0.65	
NEPAL	NR	NEPAL IMPORT (FROM UP)	0	0	0	-0.66	
	NR	132kV MAHENDRANAGAR-TANAKPUR(NHPC)	0	0	0	0.00	
	ER	NEPAL IMPORT (FROM BIHAR)	29	0	-10	-0.24	
	ER	400kV DHALKEBAR-MUZAFFARPUR 1&2	282	-236	-142	-3.40	
BANGLADESH	ER	BHERAMARA B/B HVDC (B'DESH)	-453	-431	-444	-10.65	
	ER (Isolated from Indian Grid)	400kV GODDA_TPS-RAHANPUR (B'DESH) D/C	-1468	-820	-1095	-26.29	
	NER	132kV COMILLA-SURAJMANI NAGAR 1&2	-105	0	-85	-2.03	

CROSS BORDER EXCHANGE SCHEDULE

Date of Reporting: 29-Dec-2025

Export From India (in MU)

Country	GNA (ISGS/PPA)	T-GNA							TOTAL	
		BILATERAL TOTAL	COLLECTIVE							
			IDAM			RTM				
			IEX	PXIL	HPX	IEX	PXIL	HPX		
Bhutan	0.00	0.00	14.01	0.00	0.00	0.00	0.00	0.00	14.01	
Nepal	0.62	0.00	0.48	0.00	0.00	0.00	1.49	0.00	0.00	2.59
Bangladesh	11.02	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	11.02
Myanmar	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total Export	11.64	0.00	14.49	0.00	0.00	0.00	1.49	0.00	0.00	27.62

Import by India(in MU)

Country	GNA (ISGA/PPA)	T-GNA							TOTAL	
		BILATERAL TOTAL	COLLECTIVE							
			IDAM			RTM				
			IEX	PXIL	HPX	IEX	PXIL	HPX		
Bhutan	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	
Nepal	0.00	0.00	0.00	0.00	0.00	0.00	2.04	0.00	0.00	2.04
Bangladesh	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Myanmar	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total Import	0.00	0.00	0.00	0.00	0.00	0.00	2.04	0.00	0.00	2.04

Net from India(in MU)

-ve : Export / +ve : Import

Country	GNA (ISGS/PPA)	T-GNA							TOTAL	
		BILATERAL TOTAL	COLLECTIVE							
			IDAM			RTM				
			IEX	PXIL	HPX	IEX	PXIL	HPX		
Bhutan	0.00	0.00	-14.01	0.00	0.00	0.00	0.00	0.00	-14.01	
Nepal	-0.62	0.00	-0.48	0.00	0.00	0.00	0.54	0.00	0.00	-0.56
Bangladesh	-11.02	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	-11.02
Myanmar	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total Net	-11.64	0.00	-14.49	0.00	0.00	0.00	0.54	0.00	0.00	-25.59

