National Load Despatch Centre
राष्ट्रीय भार प्रेषण केंद्र
GRID CONTROLLER OF INDIA LIMITED
ग्रिड कंट्रोलर ऑफ इंडिया लिमिटेड
(Government of India Enterprise/ भारत सरकार का उद्यम)
B-9, QUTUB INSTITUTIONAL AREA, KATWARIA SARAI, NEW DELHI -110016
बी-9, क़ुतुब इन्स्टीट्यूशनल एरिया, कटवारिया सराये, न्यू दिल्ली-110016

Ref: GRID-INDIA/NLDC/SO/Daily PSP Report दिनांक: 17.05.2025

To,

1. कार्यकारी निदेशक, पू .क्षे .भा .प्रे .के.,14 , गोल्फ क्लब रोड , कोलकाता - 700033
   Executive Director, ERLDC, 14 Golf Club Road, Tollygunge, Kolkata, 700033
2. कार्यकारी निदेशक, ऊ. क्षे. भा. प्रे. के., 18/ ए , शहीद जीत सिंह सनसनवाल मार्ग, नई दिल्ली – 110016
   Executive Director, NRLDC, 18-A, Shaheed Jeet Singh Marg, Katwaria Sarai, New Delhi – 110016
3. कार्यकारी निदेशक, प .क्षे .भा .प्रे .के., एफ3-, एम आई डी सी क्षेत्र , अंधेरी, मुंबई –400093
   Executive Director, WRLDC, F-3, M.I.D.C. Area, Marol, Andheri (East), Mumbai-400093
4. कार्यकारी निदेशक, ऊ. पू. क्षे. भा. प्रे. के., डोंगतिएह, लोअर नोंग्रह , लापलंग, शिलोंग – 793006
   Executive Director, NERLDC, Dongteih, Lower Nongrah, Lapalang, Shillong - 793006, Meghalaya
5. कार्यकारी निदेशक , द .क्षे .भा .प्रे .के.,29 , रेस कोर्स क्रॉस रोड, बंगलुरु –560009
   Executive Director, SRLDC, 29, Race Course Cross Road, Bangalore-560009

Sub: Daily PSP Report for the date 16.05.2025.

महोदय/Sir,

आई०ई०जी०सी०-2023 की धारा स.-38(1) के प्रावधान के अनुसार, दिनांक 16-मई-2025 की अखिल भारतीय प्रणाली की दैनिक ग्रिड निष्पादन रिपोर्ट रा०भा०प्रे०के० की वेबसाइट पर उप्लब्ध है |

As per article 38(1) of the Indian Electricity Grid Code, the daily report pertaining power supply position of All India Power System for the date 16.05.2025, is available at the NLDC website.

धन्यवाद,
Thanks

ग्रिड कंट्रोलर ऑफ इंडिया लिमिटेड
राष्ट्रीय भार प्रेषण केंद्र, नई दिल्ली

ग्रिड-इंडिया GRID-INDIA

Report for previous day **Date of Reporting: 17-May-2025**

A. Power Supply Position at All India and Regional level

	NR	WR	SR	ER	NER	TOTAL
Demand Met during Evening Peak hrs(MW) (at 20:00 hrs; from RLDCs)	71608	65049	50695	27904	3060	218316
Peak Shortage (MW)	0	0	0	0	0	0
Energy Met (MU)	1643	1575	1191	660	57	5125
Hydro Gen (MU)	286	44	82	50	25	487
Wind Gen (MU)	49	107	86	-	-	242
Solar Gen (MU)*	217.89	143.69	125.97	3.76	0.73	492
Energy Shortage (MU)	0.37	0.88	0.00	0.15	0.00	1.40
Maximum Demand Met During the Day (MW) (From NLDC SCADA)	75681	69043	55690	30106	3067	228757
Time Of Maximum Demand Met	23:05	15:34	15:27	15:18	18:28	15:00

B. Frequency Profile (%)

Region	FVI	< 49.7	49.7 - 49.8	49.8 - 49.9	< 49.9	49.9 - 50.05	> 50.05
All India	0.033	0.00	0.38	3.07	3.45	81.16	15.39

C. Power Supply Position in States

Region	States	Max.Demand Met during the day (MW)	Shortage during maximum Demand (MW)	Energy Met (MU)	Drawal Schedule (MU)	OD(+)/UD(-) (MU)	Max OD (MW)	Energy Shortage (MU)
NR	Punjab	10881	0	232.4	118.0	2.2	628	0.00
	Haryana	10089	0	215.0	158.1	-2.9	361	0.37
	Rajasthan	15725	0	337.0	109.4	-4.3	320	0.00
	Delhi	6789	0	132.9	124.4	-4.2	202	0.00
	UP	27624	0	571.3	239.1	-0.5	787	0.00
	Uttarakhand	2481	0	51.7	29.8	-0.5	203	0.00
	HP	1778	0	37.4	11.3	-0.7	201	0.00
	J&K(UT) & Ladakh(UT)	2612	0	54.9	30.0	-0.3	229	0.00
	Chandigarh	330	0	6.6	6.6	-0.1	20	0.00
	Railways_NR ISTS	205	0	4.3	3.8	0.5	63	0.00
WR	Chhattisgarh	5554	0	125.1	68.4	0.4	642	0.00
	Gujarat	23506	0	478.4	156.1	-10.9	624	0.00
	MP	13382	0	297.4	171.7	-1.1	491	0.88
	Maharashtra	25571	0	590.2	206.3	0.6	780	0.00
	Goa	789	0	17.6	17.4	0.2	63	0.00
	DNHDDPDCL	1312	0	30.2	30.3	-0.1	94	0.00
	AMNSIL	906	0	20.5	9.3	0.5	263	0.00
	BALCO	535	0	12.8	12.7	0.1	19	0.00
	RIL JAMNAGAR	166	0	2.6	2.4	0.2	0	0.00
SR	Andhra Pradesh	10561	0	217.6	80.1	-2.4	549	0.00
	Telangana	9720	0	206.4	85.7	-1.1	438	0.00
	Karnataka	12851	0	253.4	77.6	-1.5	358	0.00
	Kerala	5129	0	100.2	68.4	0.4	397	0.00
	Tamil Nadu	18868	0	402.2	216.8	-4.9	611	0.00
	Puducherry	528	0	11.1	11.3	-0.3	38	0.00
ER	Bihar	7632	0	154.8	144.1	0.2	472	0.15
	DVC	3375	0	74.6	-31.0	0.5	331	0.00
	Jharkhand	2230	0	48.4	42.9	-1.3	164	0.00
	Odisha	6433	0	134.1	49.3	-1.0	402	0.00
	West Bengal	11945	0	246.7	111.0	-2.3	348	0.00
	Sikkim	62	0	0.9	1.4	-0.5	42	0.00
	Railways_ER ISTS	19	0	0.2	0.2	0.0	3	0.00
NER	Arunachal Pradesh	157	0	3.1	3.1	-0.2	56	0.00
	Assam	1930	0	34.3	27.6	0.3	110	0.00
	Manipur	221	0	3.3	3.4	-0.1	10	0.00
	Meghalaya	322	0	5.4	1.5	0.0	35	0.00
	Mizoram	134	0	2.1	2.0	-0.3	12	0.00
	Nagaland	135	0	2.8	2.8	0.0	22	0.00
	Tripura	306	0	6.3	5.3	0.2	45	0.00

D. Transnational Exchanges (MU) - Import(+ve)/Export(-ve)

	Bhutan	Nepal	Bangladesh	Godda -> Bangladesh
Actual (MU)	28.8	-5.5	-23.1	-30.9
Day Peak (MW)	1433.0	-682.4	-983.0	-1468.0

E. Import/Export by Regions (in MU) - Import(+ve)/Export(-ve); OD(+)/UD(-)

	NR	WR	SR	ER	NER	TOTAL
Schedule(MU)	269.7	-348.5	120.7	-41.2	-0.7	0.0
Actual(MU)	240.4	-347.7	126.4	-27.6	0.8	-7.7
O/D/U/D(MU)	-29.3	0.9	5.7	13.6	1.5	-7.7

F. Generation Outage(MW)

	NR	WR	SR	ER	NER	TOTAL	% Share
Central Sector	1939	5012	4492	2683	335	14461	42
State Sector	4279	8091	5766	1334	179	19649	58
Total	6218	13103	10258	4017	514	34110	100

G. Sourcewise generation (Gross) (MU)

	NR	WR	SR	ER	NER	All India	% Share
Coal	841	1598	669	714	12	3834	70
Lignite	20	18	43	0	0	81	1
Hydro	286	44	82	50	25	487	9
Nuclear	33	63	71	0	0	167	3
Gas, Naptha & Diesel	41	82	13	0	23	159	3
RES (Wind, Solar, Biomass & Others)	277	253	242	6	1	779	14
Total	1498	2059	1120	770	61	5507	100

Share of RES in total generation (%)	18.47	12.29	21.64	0.78	1.24	14.14
Share of Non-fossil fuel (Hydro,Nuclear and RES) in total generation(%)	39.77	17.50	35.31	7.22	42.82	26.02

H. All India Demand Diversity Factor

Based on Regional Max Demands	1.021
Based on State Max Demands	1.061

I. All India Peak Demand and shortage at Solar and Non-Solar Hour

	Max Demand Met(MW)	Time	Shortage(MW)
Solar hr	228757	15:00	0
Non-Solar hr	224077	23:01	25

Diversity factor = Sum of regional or state maximum demands / All India maximum demand

**Note: All generation MU figures are gross

***Godda (Jharkhand) -> Bangladesh power exchange is through the radial connection (isolated from Indian Grid)

Solar Hours -> 06:00 to 18:00hrs and rest are Non-Solar Hours

*Source: RLDCs for solar connected to ISTS; SLDCs for embedded solar. Limited visibility of embedded solar data.

Executive Director-NLDC

INTER-REGIONAL EXCHANGES

Import=(+ve) /Export =(-ve) for NET (MU)
Date of Reporting: 17-May-2025

Sl No	Voltage Level	Line Details	No. of Circuit	Max Import (MW)	Max Export (MW)	Import (MU)	Export (MU)	NET (MU)
Import/Export of ER (With NR)								
1	HVDC	ALIPURDUAR-AGRA	2	0	0	0.0	0.0	0.0
2	HVDC	PUSAULI B/B	-	0	47	0.0	2.4	-2.4
3	765 kV	GAYA-VARANASI	2	1173	308	6.2	0.0	6.2
4	765 kV	SASARAM-FATEHPUR	1	499	183	2.2	0.0	2.2
5	765 kV	GAYA-BALIA	1	0	634	0.0	9.3	-9.3
6	400 kV	PUSAULI-VARANASI	1	0	157	0.0	2.7	-2.7
7	400 kV	PUSAULI -ALLAHABAD	1	60	22	0.4	0.0	0.4
8	400 kV	MUZAFFARPUR-GORAKHPUR	2	219	626	0.0	4.4	-4.4
9	400 kV	PATNA-BALIA	2	306	605	0.0	5.2	-5.2
10	400 kV	NAUBATPUR-BALIA	2	242	240	0.0	1.5	-1.5
11	400 kV	BIHARSHARIFF-BALIA	2	387	171	2.4	0.0	2.4
12	400 kV	MOTIHARI-GORAKHPUR	2	196	406	0.0	3.3	-3.3
13	400 kV	BIHARSARIFF-SAHUPURI	2	185	100	1.2	0.0	1.2
14	220 kV	SAHUPURI-KARAMNASA	1	0	97	0.0	2.1	-2.1
15	132 kV	NAGAR UNTARI-RIHAND	1	0	0	0.0	0.0	0.0
16	132 kV	GARWAH-RIHAND	1	30	0	0.6	0.0	0.6
17	132 kV	KARMANASA-SAHUPURI	1	0	0	0.0	0.0	0.0
18	132 kV	KARMANASA-CHANDAULI	1	0	0	0.0	0.0	0.0
					ER-NR	**13.0**	**30.9**	**-17.9**
Import/Export of ER (With WR)								
1	765 kV	JHARSUGUDA-DHARAMJAIGARH	4	451	790	0.0	3.3	-3.3
2	765 kV	NEW RANCHI-DHARAMJAIGARH	2	2244	0	32.8	0.0	32.8
3	765 kV	JHARSUGUDA-DURG	2	2	499	0.0	6.7	-6.7
4	400 kV	JHARSUGUDA-RAIGARH	4	133	442	0.0	4.1	-4.1
5	400 kV	RANCHI-SIPAT	2	551	0	5.6	0.0	5.6
6	220 kV	BUDHIPADAR-RAIGARH	1	100	50	0.1	0.0	0.1
7	220 kV	BUDHIPADAR-KORBA	2	84	30	0.5	0.0	0.5
					ER-WR	**39.1**	**14.1**	**25.0**
Import/Export of ER (With SR)								
1	HVDC	JEYPORE-GAZUWAKA B/B	2	110	116	0.0	0.6	-0.6
2	HVDC	TALCHER-KOLAR BIPOLE	2	0	1768	0.0	44.0	-44.0
3	765 kV	ANGUL-SRIKAKULAM	2	0	2697	0.0	44.7	-44.7
4	400 kV	TALCHER-I/C	2	614	967	0.0	5.2	-5.2
5	220 kV	BALIMELA-UPPER-SILERRU	1	0	0	0.0	0.0	0.0
					ER-SR	**0.0**	**89.3**	**-89.3**
Import/Export of ER (With NER)								
1	400 kV	BINAGURI-BONGAIGAON	2	466	0	7.0	0.0	7.0
2	400 kV	ALIPURDUAR-BONGAIGAON	2	510	90	5.5	0.0	5.5
3	220 kV	ALIPURDUAR-SALAKATI	2	109	0	1.5	0.0	1.5
					ER-NER	**14.0**	**0.0**	**14.0**
Import/Export of NER (With NR)								
1	HVDC	BISWANATH CHARIALI-AGRA	2	754	0	14.3	0.0	14.3
					NER-NR	**14.3**	**0.0**	**14.3**
Import/Export of WR (With NR)								
1	HVDC	CHAMPA-KURUKSHETRA	2	0	4039	0.0	93.3	-93.3
2	HVDC	VINDHYACHAL B/B	-	0	407	0.0	8.5	-8.5
3	HVDC	MUNDRA-MOHINDERGARH	2	0	1452	0.0	36.3	-36.3
4	765 kV	GWALIOR-AGRA	2	0	1992	0.0	27.5	-27.5
5	765 kV	GWALIOR-PHAGI	2	1131	1152	6.0	9.5	-3.5
6	765 kV	JABALPUR-ORAI	2	58	900	0.0	19.9	-19.9
7	765 kV	GWALIOR-ORAI	1	524	0	7.9	0.0	7.9
8	765 kV	SATNA-ORAI	1	0	984	0.0	16.6	-16.6
9	765 kV	BANASKANTHA-CHITORGARH	2	548	770	1.4	6.2	-4.9
10	765 kV	VINDHYACHAL-VARANASI	2	0	3301	0.0	60.9	-60.9
11	400 kV	ZERDA-KANKROLI	1	138	127	1.2	0.6	0.6
12	400 kV	ZERDA -BHINMAL	1	183	243	0.0	3.3	-3.3
13	400 kV	VINDHYACHAL -RIHAND	1	975	0	18.8	0.0	18.8
14	400 kV	RAPP-SHUJALPUR	2	590	267	5.2	1.2	4.0
15	400 kV	NEEMUCH-Chittorgarh	2	563	292	4.1	1.8	2.3
16	220 kV	BHANPURA-RANPUR	1	0	168	0.0	3.3	-3.3
17	220 kV	BHANPURA-MORAK	1	0	30	0.0	2.1	-2.1
18	220 kV	MEHGAON-AURAIYA	1	90	0	1.3	0.0	1.3
19	220 kV	MALANPUR-AURAIYA	1	65	0	0.8	0.0	0.8
20	132 kV	GWALIOR-SAWAI MADHOPUR	1	0	0	0.0	0.0	0.0
21	132 kV	RAJGHAT-LALITPUR	2	0	0	0.0	0.0	0.0
					WR-NR	**46.6**	**291.0**	**-244.3**
Import/Export of WR (With SR)								
1	HVDC	BHADRAWATI B/B	-	0	309	0.0	7.2	-7.2
2	HVDC	RAIGARH-PUGALUR	2	0	1499	0.0	37.4	-37.4
3	765 kV	SOLAPUR-RAICHUR	2	984	1615	5.2	7.9	-2.8
4	765 kV	WARDHA-NIZAMABAD	2	0	2428	0.0	24.4	-24.4
5	765 kV	WARORA-WARANGAL(NEW)	2	0	2463	0.0	30.4	-30.4
6	400 kV	KOLHAPUR-KUDGI	2	1450	0	22.1	0.0	22.1
7	220 kV	KOLHAPUR-CHIKODI	2	0	0	0.0	0.0	0.0
8	220 kV	PONDA-AMBEWADI	1	0	0	0.0	0.0	0.0
9	220 kV	XELDEM-AMBEWADI	1	1	125	2.5	0.0	2.5
					WR-SR	**29.7**	**107.4**	**-77.7**

INTERNATIONAL EXCHANGES

Import(+ve)/Export(-ve)

State	Region	Line Name	Max (MW)	Min (MW)	Avg (MW)	Energy Exchange (MU)
BHUTAN	ER	400kV MANGDECHHU-ALIPURDUAR 1,2&3 i.e. ALIPURDUAR RECEIPT (from MANGDECHU HEP 4*180MW)	1131	670	868	20.82
	ER	400kV TALA-BINAGURI 1,2,4 (& 400kV MALBASE - BINAGURI) i.e. BINAGURI RECEIPT (from TALA HEP 6*170MW)	611	106	351	8.41
	ER	220kV CHUKHA-BIRPARA 1&2 (& 220kV MALBASE - BIRPARA) i.e. BIRPARA RECEIPT (from CHUKHA HEP 4*84MW)	-155	6	-45	-1.09
	NER	132kV GELEPHU-SALAKATI	-67	16	-1	-0.02
	NER	132kV MOTANGA-RANGIA	41	2	29	0.69
NEPAL	NR	NEPAL IMPORT (FROM UP)	-73	0	-44	-1.06
	NR	132kV MAHENDRANAGAR-TANAKPUR(NHPC)	-73	0	-47	-1.13
	ER	NEPAL IMPORT (FROM BIHAR)	-272	0	-116	-2.79
	ER	400kV DHALKEBAR-MUZAFFARPUR 1&2	-410	257	-23	-0.56
BANGLADESH	ER	BHERAMARA B/B HVDC (B'DESH)	-941	-882	-926	-22.22
	ER (Isolated from Indian Grid)	400kV GODDA_TPS-RAHANPUR (B'DESH) D/C	-1468	-1000	-1285	-30.85
	NER	132kV COMILLA-SURAJMANI NAGAR 1&2	-42	0	-38	-0.90

CROSS BORDER EXCHANGE SCHEDULE **Date of Reporting: 17-May-2025**

Export From India (in MU)

Country	GNA (ISGS/PPA)	T-GNA							TOTAL
		BILATERAL TOTAL	COLLECTIVE						
			IDAM			RTM			
			IEX	PXIL	HPX	IEX	PXIL	HPX	
Bhutan	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Nepal	2.88	0.00	3.91	0.00	0.00	0.08	0.00	0.00	6.87
Bangladesh	23.09	0.00	0.00	0.00	0.00	0.00	0.00	0.00	23.09
Myanmar	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total Export	25.97	0.00	3.91	0.00	0.00	0.08	0.00	0.00	29.96

Import by India(in MU)

Country	GNA (ISGA/PPA)	T-GNA							TOTAL
		BILATERAL TOTAL	COLLECTIVE						
			IDAM			RTM			
			IEX	PXIL	HPX	IEX	PXIL	HPX	
Bhutan	28.77	0.00	0.00	0.00	0.00	0.00	0.00	0.00	28.77
Nepal	0.00	0.00	0.00	0.00	0.00	2.22	0.00	0.00	2.22
Bangladesh	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Myanmar	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total Import	28.77	0.00	0.00	0.00	0.00	2.22	0.00	0.00	30.99

Net from India(in MU) **-ve : Export / +ve : Import**

Country	GNA (ISGS/PPA)	T-GNA							TOTAL
		BILATERAL TOTAL	COLLECTIVE						
			IDAM			RTM			
			IEX	PXIL	HPX	IEX	PXIL	HPX	
Bhutan	28.77	0.00	0.00	0.00	0.00	0.00	0.00	0.00	28.77
Nepal	-2.88	0.00	-3.91	0.00	0.00	2.14	0.00	0.00	-4.65
Bangladesh	-23.09	0.00	0.00	0.00	0.00	0.00	0.00	0.00	-23.09
Myanmar	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total Net	2.80	0.00	-3.91	0.00	0.00	2.14	0.00	0.00	1.03

Date of Reporting: 17-May-2025

15 Min (INSTANTANEOUS) ALL INDIA GRID FREQUENCY, GENERATION & DEMAND MET (SCADA DATA)

TIME	FREQUENCY (Hz)	DEMAND MET (MW)	NUCLEAR (MW)	WIND (MW)	SOLAR (MW)	HYDRO** (MW)	GAS (MW)	THERMAL (MW)	OTHERS* (MW)	NET DEMAND MET (MW)	TOTAL GENERATION (MW)	NET TRANSNATIONAL EXCHANGE (MW) (+ve) Import, (-ve) Export
		(A)	(B)	(C)	(D)	(E)	(F)	(G)	(H)	(I=A-(C+D))	(J=B+C+D+E+F+G+H)	(K)
0:00	50.02	219357	6222	8412	69	24828	9022	170925	1910	210876	221388	-18
0:15	50.07	217720	6235	8453	68	24232	8472	170600	1852	209199	219912	-82
0:30	50.07	216413	6238	8739	53	23762	7838	170040	1901	207621	218571	-46
0:45	50.07	215422	6237	8997	53	23460	7571	169375	1880	206372	217573	-75
1:00	50.07	214289	6232	9009	53	23425	7282	168487	1876	205227	216364	-41
1:15	50.07	212576	6236	8911	53	22358	7061	168150	1918	203612	214687	-52
1:30	50.02	211766	6222	8699	53	22067	6809	168125	1903	203014	213878	-98
1:45	49.97	210633	6243	8679	52	22440	6244	167256	1872	201902	212786	-126
2:00	50.02	209284	6222	8695	52	22402	6086	166308	1896	200537	211661	-160
2:15	49.97	208388	6237	8564	52	21941	5813	165960	1889	199772	210456	-30
2:30	49.97	206608	6246	8313	52	21002	5752	165503	1893	198243	208761	-70
2:45	49.97	205645	6237	8244	52	20199	5734	165391	1890	197349	207747	-108
3:00	50.02	204052	6239	8437	52	19635	5723	164274	1875	195563	206235	-92
3:15	49.97	202954	6237	8506	52	19262	5636	163887	1879	194396	205459	-314
3:30	50.02	201931	6252	8544	52	18985	5564	162766	1892	193335	204055	-60
3:45	49.97	201101	6246	8277	52	18769	5188	162814	1882	192772	203228	9
4:00	50.02	199698	6248	8072	52	18504	5173	161753	1949	191574	201751	-9
4:15	49.97	199500	6260	8107	52	18227	5149	161828	1901	191341	201524	90
4:30	50.02	199626	6257	8054	52	18127	5176	162068	1919	191520	201653	201
4:45	49.97	199792	6256	7963	118	18403	5201	161884	1898	191711	201723	212
5:00	50.02	199296	6266	8032	51	17962	5060	161954	1883	191213	201208	288
5:15	50.02	199681	6270	8259	53	17683	5066	162033	1984	191369	201348	411
5:30	50.02	199489	6277	8310	55	18052	5064	161569	1901	191124	201228	273
5:45	49.97	199713	6274	8349	81	18557	5092	161508	1898	191283	201759	31
6:00	50.02	198796	6277	8400	154	18473	5096	160167	1934	190242	200501	41
6:15	49.92	198621	6283	8398	1364	18465	5051	159039	1940	188859	200540	88
6:30	50.02	198121	6274	8429	2861	18170	5015	157172	1930	186831	199851	121
6:45	50.02	196248	6275	8566	5156	18093	4990	153220	1862	182526	198162	84
7:00	49.97	196260	6279	8522	8648	17814	5047	149890	1943	179090	198143	73
7:15	49.92	196465	6290	8103	12627	17111	5040	147121	1961	175735	198253	76
7:30	49.97	195286	6270	7859	17340	16636	5033	142136	1970	170087	197244	121
7:45	49.97	195786	6266	7688	22423	15903	5039	138419	1981	165675	197719	167
8:00	49.97	194910	6263	7957	26472	15303	5055	134088	1967	160481	197105	47
8:15	49.97	197003	6254	7991	31006	15241	5043	131587	1993	158006	199115	216
8:30	49.97	198675	6262	7813	34827	14894	5060	130058	2006	156035	200920	64
8:45	49.97	201321	6259	7640	38320	14797	5049	129150	2039	155361	203254	90
9:00	49.97	203639	6272	7402	41731	14922	5072	128370	2012	154506	205781	110
9:15	49.82	209060	6253	7237	44647	14934	5110	130762	2036	157176	210979	62
9:30	49.97	211324	6247	7195	47377	14609	5064	130776	2054	156752	213322	35
9:45	49.97	213020	6246	7307	50486	13280	5081	130685	2046	155227	215131	33
10:00	49.97	214885	6239	7268	52869	12602	5052	130836	2029	154748	216895	59
10:15	49.97	216331	6218	7225	54879	12119	5039	130723	2049	154227	218252	-6
10:30	49.97	216891	6230	7381	55877	12232	5056	130214	2052	153633	219042	50
10:45	49.97	217911	6243	7454	56419	12752	5070	130059	2080	154038	220077	64
11:00	50.02	218012	6221	7589	57099	12774	5040	129779	2064	153324	220566	28
11:15	50.02	218967	6230	7598	57871	13068	5065	129324	2074	153498	221230	-194
11:30	49.97	219766	6227	7597	58688	13260	5074	129336	2106	153481	222288	-127
11:45	49.97	221104	6216	7569	59590	13306	5062	129503	2083	153945	223329	-150
12:00	50.02	220666	6223	7692	59833	13287	5050	128848	2088	153141	223021	-190
12:15	49.97	221547	6217	7995	59629	13348	5047	128991	2104	153923	223331	-163
12:30	50.02	221912	6200	7948	60166	13553	5068	128825	2113	153798	223873	-76
12:45	49.97	221327	6222	8146	59323	13777	5045	128803	2080	153858	223396	-137
13:00	50.07	220644	6208	8409	59293	14013	5042	127618	2100	152942	222683	-59
13:15	50.07	218253	6221	8619	58596	13749	5054	125937	2092	151038	220268	-200
13:30	50.02	219516	6193	8770	58264	14001	5062	127149	2038	152482	221477	-195
13:45	49.97	221608	6202	9069	57901	14255	5064	128785	2040	154638	223316	-209
14:00	49.97	222577	6186	9223	56390	14231	5092	131210	2006	156964	224338	-202
14:15	49.92	223640	6185	9399	55275	14088	5086	133305	2024	158966	225362	-198
14:30	49.92	225691	6179	9390	54041	14297	5094	136617	2058	162260	227676	-179
14:45	49.97	227672	6203	9817	52738	14176	5066	139618	2021	165117	229639	-96
15:00	50.02	228757	6200	9532	50713	14364	5081	143014	2018	168512	230922	-196
15:15	50.02	227961	6210	9371	48483	14196	5226	144505	2046	170107	230037	-17
15:30	50.02	228019	6211	9517	45534	14926	5286	146620	1959	172968	230053	-72
15:45	50.07	226447	6231	9774	42871	15067	5378	146414	1946	173802	227681	-7
16:00	50.12	224882	6230	10337	40331	14747	5389	147927	1917	174214	226878	-4
16:15	50.07	222814	6218	10759	36569	15452	5938	148343	1894	175486	225173	-180
16:30	50.07	222145	6223	11177	33055	16181	6076	149627	1928	177913	224267	-143
16:45	50.02	220362	6241	11362	29560	16777	6259	150120	1859	179440	222178	110
17:00	50.07	217504	6228	11736	26121	17078	6723	149726	1850	179647	219462	126
17:15	50.12	212884	6260	12174	22421	15945	6698	149174	1885	178289	214557	330
17:30	50.22	209744	6257	12679	18835	15994	6849	148737	1916	178230	211267	255
17:45	49.99	208314	6252	12606	15300	17455	6720	148494	1815	180408	208642	169
18:00	49.99	205975	6236	12706	11717	17586	6391	149705	1795	181552	206136	177
18:15	49.99	204285	6231	12680	8500	17692	6451	150525	1821	183105	203900	281
18:30	50.04	205708	6230	12728	5937	20314	6574	152820	1840	187043	206443	282
18:45	50.04	207519	6242	12999	3108	22195	6857	156555	1833	191412	209789	238
19:00	50.04	209873	6235	12771	1789	23258	7067	159302	1851	195313	212273	169
19:15	50.04	212900	6231	12399	969	24171	7166	162308	1930	199532	215174	97
19:30	50.04	215364	6250	12308	691	24766	7062	164448	1848	202365	217373	313
19:45	50.04	216041	6239	11768	669	24947	7207	165502	1868	203604	218200	344
20:00	50.04	215987	6244	11701	686	25009	7193	165556	1890	203600	218279	315
20:15	49.99	215981	6238	11921	480	24150	7056	166286	1851	203580	217982	321
20:30	50.04	216409	6241	12612	481	23975	7075	166279	1930	203316	218593	310
20:45	49.99	216890	6221	13120	480	23050	7085	166845	1907	203290	218708	300
21:00	50.04	217152	6213	13917	481	22325	7198	166820	1919	202754	218873	342
21:15	49.99	217686	6209	14321	481	22867	7246	166223	1914	202884	219261	487
21:30	49.94	217917	6209	14017	478	23844	7567	165763	1859	203422	219737	492
21:45	49.89	219499	6171	13800	478	24106	7586	167289	1865	205221	221295	521
22:00	49.99	220347	6145	13357	438	24331	7727	168520	1823	206552	222341	541
22:15	49.89	222199	6152	12899	444	25576	7632	169547	1867	208856	224117	507
22:30	49.99	223329	6169	12717	444	26646	7616	169783	1855	210168	225230	489
22:45	49.99	224030	6152	12815	447	26218	7627	170931	1871	210768	226061	474
23:00	49.94	223925	6161	13173	446	26336	7765	170227	1912	210306	226020	500
23:15	49.99	223304	6164	13280	446	26046	7764	169802	1919	209578	225421	561
23:30	49.99	221899	6161	13568	446	25218	7652	168884	1883	207885	223812	532
23:45	49.99	220993	6161	13900	445	24430	7741	168556	1898	206648	223131	509

*Others include (i) Biomass from Punjab (ii) Some of the state sector IPP & non-conventional generation in SR (small capacity) (iii) Solar generation in Odisha(manually punched).
** Hydro generation is excluding Bhutan hydro.
***Bhutan hydro is accounted for in net transnational exchange.

Disclaimer:
1. The information provided is for general informational purposes only.
2. The data is provided "as is" without any guarantees or warranties.
3. All Data is operational SCADA data telemetered and reporting at NLDC through RLDC/SLDC.
4. Data is subject to errors due to telemetry loss/freeze/garbage value etc.
5. Demand met and RE generation data is incident on transmission system. Resources in distribution system plus behind the meter (BTM) generation excluded.
6. Users are advised to ensure its accuracy, completeness and relevance for their purposes, and, in this respect, GRID-INDIA shall not be responsible for any errors or omissions.