



National Load Despatch Centre
राष्ट्रीय भार प्रेषण केंद्र
GRID CONTROLLER OF INDIA LIMITED
ग्रिड कंट्रोलर ऑफ इंडिया लिमिटेड

(Government of India Enterprise/ भारत सरकार का उद्यम)
B-9, QUTUB INSTITUTIONAL AREA, KATWARIA SARAI, NEW DELHI -110016
बी-9, कुतुब इन्स्टीट्यूशनल एरिया, कटवारिया सराये, न्यू दिल्ली-110016

Ref: GRID-INDIA/NLDC/SO/Daily PSP Report

दिनांक: 10.12.2025

To,

- कार्यकारी निदेशक, पू.क्षे.भा.प्रे.के., 14, गोल्फ क्लब रोड, कोलकाता - 700033
Executive Director, ERLDC, 14 Golf Club Road, Tollygunge, Kolkata, 700033
- कार्यकारी निदेशक, ऊ.क्षे.भा.प्रे.के., 18/ए, शाहीद जीत सिंह सनसनवाल मार्ग, नई दिल्ली - 110016
Executive Director, NRLDC, 18-A, Shaheed Jeet Singh Marg, Katwaria Sarai, New Delhi - 110016
- कार्यकारी निदेशक, प.क्षे.भा.प्रे.के., एफ3, एम आई डी सी क्षेत्र, अंधेरी, मुंबई -400093
Executive Director, WRLDC, F-3, M.I.D.C. Area, Marol, Andheri (East), Mumbai-400093
- कार्यकारी निदेशक, ऊ.पू.क्षे.भा.प्रे.के., डोंगतेह, लोअर नोंग्रह, लापालंग, शिलोंग - 793006
Executive Director, NERLDC, Dongteih, Lower Nongrah, Lapalang, Shillong - 793006, Meghalaya
- कार्यकारी निदेशक, द.क्षे.भा.प्रे.के., 29, रेस कोर्स क्रॉस रोड, बंगलुरु -560009
Executive Director, SRLDC, 29, Race Course Cross Road, Bangalore-560009

Sub: Daily PSP Report for the date 09.12.2025.

महोदय/Sir,

आईईजीसी-2023 की धारा स.-38(1) के प्रावधान के अनुसार, दिनांक 9-दिसंबर-2025 की अखिल भारतीय प्रणाली की दैनिक ग्रिड निष्पादन रिपोर्ट रांभांप्रेके की वेबसाइट पर उपलब्ध है।

As per article 38(1) of the Indian Electricity Grid Code, the daily report pertaining power supply position of All India Power System for the date 09.12.2025, is available at the NLDC website.

धन्यवाद,
Thanks

Report for previous day

Date of Reporting: 10-Dec-2025

A. Power Supply Position at All India and Regional level

	NR	WR	SR	ER	NER	TOTAL
Demand Met during Evening Peak hrs(MW) (at 19:00 hrs; from RLDCs)	57966	65253	47282	22949	2786	196236
Peak Shortage (MW)	0	0	0	0	0	0
Energy Met (MU)	1267	1521	1115	470	51	4424
Hydro Gen (MU)	115	40	105	23	12	296
Wind Gen (MU)	3	118	85	-	-	205
Solar Gen (MU)*	188.63	168.22	139.45	3.11	1.06	500
Energy Shortage (MU)	0.00	0.00	0.00	0.00	0.00	0.00
Maximum Demand Met During the Day (MW) (From NLDC SCADA)	68547	74761	54574	23725	3028	220397
Time Of Maximum Demand Met	10:25	09:44	11:52	17:43	17:03	10:23

B. Frequency Profile (%)

Region	FVI	< 49.7	49.7 - 49.8	49.8 - 49.9	< 49.9	49.9 - 50.05	> 50.05
All India	0.038	0.00	0.42	3.73	4.14	77.86	18.00

C. Power Supply Position in States

Region	States	Max.Demand Met during the day (MW)	Shortage during maximum Demand (MW)	Energy Met (MU)	Drawal Schedule (MU)	OD(+)/UD(-) (MU)	Max OD (MW)	Energy Shortage (MU)
NR	Punjab	9464	0	167.1	81.1	-0.5	559	0.00
	Haryana	9344	0	171.9	130.4	-0.3	368	0.00
	Rajasthan	18013	0	336.6	112.9	-2.7	917	0.00
	Delhi	4369	0	78.9	73.8	-0.8	444	0.00
	UP	19426	0	357.5	98.1	-0.3	999	0.00
	Uttarakhand	2435	0	44.2	33.1	0.1	128	0.00
	HP	2161	0	37.5	29.1	-0.4	100	0.00
	J&K(UT) & Ladakh(UT)	3140	0	65.7	64.7	-0.4	211	0.00
	Chandigarh	239	0	4.0	3.9	0.0	17	0.00
	Railways_NR ISTS	197	0	3.9	3.8	0.2	36	0.00
WR	Chhattisgarh	4816	0	94.6	32.8	0.0	564	0.00
	Gujarat	22210	0	431.0	163.2	-8.5	876	0.00
	MP	18971	0	343.8	221.2	0.0	600	0.00
	Maharashtra	27095	0	568.5	179.5	-6.2	513	0.00
	Goa	713	0	14.1	11.9	2.0	36	0.00
	DNHDDPDCL	1338	0	30.6	30.7	-0.1	41	0.00
	AMNSIL	836	0	19.0	11.6	0.3	293	0.00
	BALCO	567	0	13.5	13.7	-0.2	10	0.00
	RIL JAMNAGAR	262	0	5.9	6.0	-0.1	0	0.00
	Andhra Pradesh	10013	0	199.1	53.1	-1.7	437	0.00
SR	Telangana	12731	0	222.1	93.3	-1.0	829	0.00
	Karnataka	15374	0	279.9	88.5	-0.6	636	0.00
	Kerala	4320	0	81.1	61.4	-1.6	419	0.00
	Tamil Nadu	16752	0	324.1	186.1	-2.1	901	0.00
	Puducherry	430	0	9.0	8.6	-0.2	31	0.00
	Bihar	5290	0	95.8	83.3	-2.4	150	0.00
ER	DVC	3114	0	66.0	-39.4	0.4	346	0.00
	Jharkhand	2169	0	40.6	29.0	-2.0	189	0.00
	Odisha	5712	0	112.5	33.4	-3.4	413	0.00
	West Bengal	7677	0	152.7	27.5	-2.4	150	0.00
	Sikkim	112	0	1.9	1.7	0.2	37	0.00
	Railways_ER ISTS	19	0	0.1	0.1	-0.1	0	0.00
NER	Arunachal Pradesh	176	0	3.1	2.9	-0.1	16	0.00
	Assam	1704	0	28.5	22.2	0.4	161	0.00
	Manipur	275	0	3.9	3.8	0.1	35	0.00
	Meghalaya	343	0	6.1	5.4	-0.1	41	0.00
	Mizoram	158	0	2.3	1.9	-0.3	11	0.00
	Nagaland	171	0	2.8	2.7	0.0	6	0.00
	Tripura	236	0	4.8	4.8	0.4	33	0.00

D. Transnational Exchanges (MU) - Import(+ve)/Export(-ve)

	Bhutan	Nepal	Bangladesh	Godda -> Bangladesh
Actual (MU)	-7.0	7.3	-21.4	-24.0
Day Peak (MW)	-666.0	562.4	-984.9	-1436.0

E. Import/Export by Regions (in MU) - Import(+ve)/Export(-ve); OD(+)/UD(-)

	NR	WR	SR	ER	NER	TOTAL
Schedule(MU)	259.7	-236.0	110.2	-143.0	9.0	0.0
Actual(MU)	247.0	-230.2	105.7	-143.1	8.2	-12.4
O/D/U/D(MU)	-12.7	5.8	-4.5	-0.2	-0.9	-12.4

F. Generation Outage(MW)

	NR	WR	SR	ER	NER	TOTAL	% Share
Central Sector	5827	12585	6518	6430	240	31600	49
State Sector	11469	10264	8634	2577	205	33148	51
Total	17296	22848	15152	9007	445	64748	100

G. Sourcewise generation (Gross) (MU)

	NR	WR	SR	ER	NER	All India	% Share
Coal	703	1451	641	660	13	3467	72
Lignite	23	14	53	0	0	90	2
Hydro	115	40	105	23	12	296	6
Nuclear	37	53	46	0	0	136	3
Gas, Naptha & Diesel	9	24	4	0	22	59	1
RES (Wind, Solar, Biomass & Others)	216	288	253	7	1	764	16
Total	1103	1870	1102	690	48	4812	100

Share of RES in total generation (%)	19.58	15.40	22.93	0.96	2.19	15.88
Share of Non-fossil fuel (Hydro,Nuclear and RES) in total generation(%)	33.41	20.36	36.64	4.32	27.64	24.85

H. All India Demand Diversity Factor

Based on Regional Max Demands	1.019
Based on State Max Demands	1.054

I. All India Peak Demand and shortage at Solar and Non-Solar Hour

	Max Demand Met(MW)	Time	Shortage(MW)
Solar hr	220397	10:23	0
Non-Solar hr	208011	17:59	0

Diversity factor = Sum of regional or state maximum demands / All India maximum demand

**Note: All generation MU figures are gross

***Godda (Jharkhand) -> Bangladesh power exchange is through the radial connection (isolated from Indian Grid)

Solar Hours -> 06:00 to 18:00hrs and rest are Non-Solar Hours

*Source: RLDCs for solar connected to ISTS; SLDCs for embedded solar. Limited visibility of embedded solar data.

Executive Director-NLDC

INTER-REGIONAL EXCHANGES

Import=(+ve) /Export =(-ve) for NET (MU)
Date of Reporting: 10-Dec-2025

Sl No	Voltage Level	Line Details	No. of Circuit	Max Import (MW)	Max Export (MW)	Import (MU)	Export (MU)	NET (MU)
Import/Export of ER (With NR)								
1	HVDC	ALIPURDUAR-AGRA	2	0	0	0.0	0.0	0.0
2	HVDC	PUSAULI B/B	-	0	47	0.0	2.5	-2.5
3	765 kV	GAYA-VARANASI	2	120	1215	0.0	13.3	-13.3
4	765 kV	SASARAM-FATEHPUR	1	57	502	0.0	7.8	-7.8
5	765 kV	GAYA-BALIA	1	0	884	0.0	12.0	-12.0
6	400 kV	PUSAULI-VARANASI	1	30	71	0.0	0.4	-0.4
7	400 kV	PUSAULI -ALLAHABAD	1	0	124	0.0	2.0	-2.0
8	400 kV	MUZAFFARPUR-GORAKHPUR	2	231	745	0.0	7.2	-7.2
9	400 kV	PATNA-BALIA	2	31	900	0.0	12.2	-12.2
10	400 kV	NAUBATPUR-BALIA	2	164	235	0.0	4.4	-4.4
11	400 kV	BIHARSHARIFF-BALIA	2	157	339	0.0	2.0	-2.0
12	400 kV	MOTIHARI-GORAKHPUR	2	5	523	0.0	7.1	-7.1
13	400 kV	BIHARSARIEF SAHUPURI	2	73	503	0.0	7.1	-7.1
14	220 kV	SAHUPURI-KARMANASA	1	2	0	0.0	2.1	-2.1
15	132 kV	NAGAR UNTARI-RIHAND	1	0	0	0.0	0.0	0.0
16	132 kV	GARWAH-RIHAND	1	30	0	0.6	0.0	0.6
17	132 kV	KARMANASA-SAHUPURI	1	0	41	0.0	0.0	0.0
18	132 kV	KARMANASA-CHANDAULI	1	0	0	0.0	0.1	-0.1
ER-NR						0.6	80.2	-79.6
Import/Export of ER (With WR)								
1	765 kV	JHARSUGUDA-DHARAMJAIGARH	4	93	823	0.0	9.8	-9.8
2	765 kV	NEW RANCHI-DHARAMJAIGARH	2	715	785	0.0	2.1	-2.1
3	765 kV	JHARSUGUDA-DURG	2	0	1161	0.0	20.3	-20.3
4	400 kV	JHARSUGUDA-RAIGARH	4	289	337	0.0	2.0	-2.0
5	400 kV	RANCHI-SIPAT	2	155	253	0.0	1.5	-1.5
6	400 kV	JEYPORE-JAGDALPUR	2	239	359	0.5	0.0	0.5
7	220 kV	BUDHIPADAR-RAIGARH	1	22	107	0.0	1.2	-1.2
8	220 kV	BUDHIPADAR-KORBA	2	92	18	0.7	0.0	0.7
ER-WR						1.3	36.9	-35.7
Import/Export of ER (With SR)								
1	HVDC	JEYPORE-GAZUWAKA B/B	2	0	123	0.0	2.9	-2.9
2	HVDC	TALCHER-KOLAR BIPOLE	2	0	1610	0.0	31.7	-31.7
3	765 kV	ANGUL-SRIKAKULAM	2	0	2671	0.0	43.2	-43.2
4	400 kV	TALCHER-I/C	2	703	192	10.9	0.0	10.9
5	220 kV	BALIMELA-UPPER-SILERRU	1	3	0	0.0	0.0	0.0
ER-SR						0.0	77.8	-77.8
Import/Export of ER (With NER)								
1	400 kV	BINAGURI-BONGAIGAON	2	234	148	1.5	0.3	1.1
2	400 kV	ALIPURDUAR-BONGAIGAON	2	464	91	4.2	0.0	4.2
3	220 kV	ALIPURDUAR-SALAKATI	2	99	4	1.1	0.0	1.1
ER-NER						6.8	0.3	6.4
Import/Export of NER (With NR)								
1	HVDC	BISWANATH CHARIALI-AGRA	2	664	0	16.3	0.0	16.3
NER-NR						16.3	0.0	16.3
Import/Export of WR (With NR)								
1	HVDC	CHAMPA-KURUKSHETRA	2	0	4016	0.0	63.4	-63.4
2	HVDC	VINDHYACHAL B/B	-	769	58	0.0	1.2	-1.2
3	HVDC	MUNDRA-MOHINDERGARH	2	0	1921	0.0	33.7	-33.7
4	765 kV	GWALIOR-AGRA	2	0	2093	0.0	29.1	-29.1
5	765 kV	GWALIOR-PHAGI	2	650	2033	1.3	26.2	-24.9
6	765 kV	JABALPUR-ORAI	2	0	1127	0.0	33.4	-33.4
7	765 kV	GWALIOR-ORAI	1	1017	0	15.6	0.0	15.6
8	765 kV	SATNA-ORAI	1	0	1150	0.0	20.6	-20.6
9	765 kV	BANASKANTHA-CHITORGARH	2	1799	231	15.3	0.2	15.1
10	765 kV	VINDHYACHAL-VARANASI	2	0	2468	0.0	40.1	-40.1
11	400 kV	ZERDA-KANKROLI	1	263	0	2.7	0.0	2.7
12	400 kV	ZERDA -BHINMAL	1	182	0	1.6	0.0	1.6
13	400 kV	VINDHYACHAL -RIHAND	1	981	0	20.8	0.0	20.8
14	400 kV	RAPP-SHUJALPUR	2	611	336	3.1	1.2	1.9
15	400 kV	NEEMUCH-Chittorgarh	2	637	403	3.2	2.7	0.5
16	220 kV	BHANPURA-RANPUR	1	0	130	0.0	2.0	-2.0
17	220 kV	BHANPURA-MORAK	1	0	30	0.0	1.2	-1.2
18	220 kV	MEHGAON-AURAIYA	1	122	15	0.9	0.0	0.9
19	220 kV	MALANPUR-AURAIYA	1	89	27	0.5	0.1	0.4
20	132 kV	RAIGHAT-LALITPUR	2	0	0	0.0	0.0	0.0
WR-NR						64.9	255.1	-190.2
Import/Export of WR (With SR)								
1	HVDC	BHADRAWATI B/B	-	0	1008	0.0	13.8	-13.8
2	HVDC	RAIGARH-PUGALUR	2	0	3007	0.0	43.1	-43.1
3	765 kV	SOLAPUR-RAICHUR	2	1114	1426	5.9	4.6	1.3
4	765 kV	WARDHA-NIZAMABAD	2	0	1989	0.0	20.5	-20.5
5	765 kV	WARORA-WARANGAL(NEW)	2	0	2390	0.0	29.5	-29.5
6	400 kV	KOLHAPUR-KUDGI	2	1619	0	28.1	0.0	28.1
7	220 kV	KOLHAPUR-CHIKODI	2	0	0	0.0	0.0	0.0
8	220 kV	PONDA-AMBEWADI	1	0	0	0.0	0.0	0.0
9	220 kV	XELDEM-AMBEWADI	1	0	115	2.2	0.0	2.2
WR-SR						36.2	111.5	-75.3
INTERNATIONAL EXCHANGES								
State	Region	Line Name	Max (MW)	Min (MW)	Avg (MW)	Energy Exchange (MU)		
BHUTAN	ER	400kV MANGDECHHU-ALIPURDUAR 1,2&3 I.e. ALIPURDUAR RECEIPT (from MANGDECHU HEP 4*180MW)	-158	60	-37	-0.88		
	ER	400kV TALA-BINAGURI 1,2,4 (& 400kV MALBASE - BINAGURI) I.e. BINAGURI RECEIPT (from TALA HEP 6*170MW)	326	-155	102	2.44		
	ER	220kV CHUKHA-BIRPARA 1&2 (& 220kV MALBASE - BIRPARA) I.e. BIRPARA RECEIPT (from CHUKHA HEP 4*84MW)	-324	-262	-289	-6.94		
	NER	132kV GELEPHU-SALAKATI	-60	0	-54	-1.30		
	NER	132kV MOTANGA-RANGIA	-18	0	-13	-0.32		
NEPAL	NR	NEPAL IMPORT (FROM UP)	-7	0	0	0.00		
	NR	132kV MAHENDRANAGAR-TANAKPUR(NHPC)	44	0	25	0.59		
	ER	NEPAL IMPORT (FROM BIHAR)	0	0	0	0.00		
	ER	400kV DHALKEBAR-MUZAFFARPUR 1&2	452	11	280	6.72		
BANGLADESH	ER	BHERAMARA B/B HVDC (B'DESH)	-871	-578	-793	-19.04		
	ER (Isolated from Indian Grid)	400kV GODDA_TPS-RAHANPUR (B'DESH) D/C	-1436	-886	-1000	-24.00		
	NER	132kV COMILLA-SURAJMANI NAGAR 1&2	-118	0	-100	-2.40		

CROSS BORDER EXCHANGE SCHEDULE

Date of Reporting: 10-Dec-2025

Export From India (in MU)

Country	GNA (ISGS/PPA)	T-GNA							TOTAL
		BILATERAL TOTAL	COLLECTIVE						
			IDAM			RTM			
			IEX	PXIL	HPX	IEX	PXIL	HPX	
Bhutan	0.00	0.31	8.32	0.00	0.00	0.00	0.00	0.00	8.63
Nepal	0.03	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.03
Bangladesh	19.80	0.00	0.00	0.00	0.00	0.00	0.00	0.00	19.80
Myanmar	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total Export	19.83	0.31	8.32	0.00	0.00	0.00	0.00	0.00	28.46

Import by India(in MU)

Country	GNA (ISGA/PPA)	T-GNA							TOTAL
		BILATERAL TOTAL	COLLECTIVE						
			IDAM			RTM			
			IEX	PXIL	HPX	IEX	PXIL	HPX	
Bhutan	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Nepal	0.00	0.00	0.85	0.00	0.00	6.84	0.00	0.00	7.69
Bangladesh	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Myanmar	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total Import	0.00	0.00	0.85	0.00	0.00	6.84	0.00	0.00	7.69

Net from India(in MU)

-ve : Export / +ve : Import

Country	GNA (ISGS/PPA)	T-GNA							TOTAL
		BILATERAL TOTAL	COLLECTIVE						
			IDAM			RTM			
			IEX	PXIL	HPX	IEX	PXIL	HPX	
Bhutan	0.00	-0.31	-8.32	0.00	0.00	0.00	0.00	0.00	-8.63
Nepal	-0.03	0.00	0.85	0.00	0.00	6.84	0.00	0.00	7.66
Bangladesh	-19.80	0.00	0.00	0.00	0.00	0.00	0.00	0.00	-19.80
Myanmar	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total Net	-19.83	-0.31	-7.47	0.00	0.00	6.84	0.00	0.00	-20.77

15 Min (INSTANTANEOUS) ALL INDIA GRID FREQUENCY, GENERATION & DEMAND MET (SCADA DATA)												
TIME	FREQUENCY (Hz)	DEMAND MET (MW)	NUCLEAR (MW)	WIND (MW)	SOLAR (MW)	HYDRO** (MW)	GAS (MW)	THERMAL (MW)	OTHERS* (MW)	NET DEMAND (MW)	TOTAL GENERATION (MW)	NET TRANSNATIONAL EXCHANGE (MW)
		(A)	(B)	(C)	(D)	(E)	(F)	(G)	(H)	(I=A-(C+D))	(J=B+C+D+E+F+G+H)	(K)
0:00	50.02	150127	5053	11770	0	6703	2241	123880	3219	138357	152866	-686
0:15	50.02	149572	5058	11508	0	6868	2254	123802	3178	138064	152668	-915
0:30	49.97	148682	5062	11280	0	7361	2251	122509	3157	137402	151620	-876
0:45	49.97	147914	5050	11042	0	7479	2240	121729	3189	136872	150729	-797
1:00	50.02	147204	5078	10844	0	7463	2245	121254	3133	136360	150017	-802
1:15	49.97	146769	5080	10641	0	7076	2241	121172	3185	136128	149395	-803
1:30	49.97	145798	5065	10631	0	6869	2259	120690	3149	135167	148663	-827
1:45	49.97	145512	5070	10643	0	6862	2228	120290	3172	134869	148265	-783
2:00	49.97	144253	5075	10635	0	6847	2234	118966	3216	133618	146973	-779
2:15	49.97	144269	5064	10468	0	6923	2283	119198	3214	133801	147150	-781
2:30	50.02	144168	5081	10335	0	6852	2273	119378	3152	133833	147071	-739
2:45	49.97	144137	5075	10244	0	6813	2270	119089	3193	133893	146684	-635
3:00	50.02	143623	5084	10161	0	6687	2274	119008	3152	133462	146366	-576
3:15	49.92	144484	5082	10186	0	6517	2279	119968	3187	134298	147219	-562
3:30	49.97	144481	5074	10052	0	6795	2265	119826	3203	134429	147215	-557
3:45	49.97	145258	5083	9771	0	7123	2281	120721	3168	135487	148147	-583
4:00	50.07	145465	5084	9471	0	7492	2282	120638	3147	135994	148114	-580
4:15	50.02	147584	5088	9271	0	7497	2189	123095	3166	138313	150306	-672
4:30	50.07	149422	5077	9081	0	7992	2331	124635	3122	140341	152238	-667
4:45	50.02	151367	5085	8913	0	8331	2169	126452	3213	142454	154163	-725
5:00	50.18	153597	5077	8713	138	8463	2143	128113	3153	144746	155800	-740
5:15	50.02	157741	5082	8699	134	8775	2144	132960	3173	148908	160967	-730
5:30	50.08	162594	5089	8562	129	9765	2158	137003	3248	153903	165954	-760
5:45	50.03	168022	5093	8408	127	10424	2202	141996	3179	159487	171429	-779
6:00	50.08	172358	5099	8260	111	12046	2231	144770	3259	163987	175776	-603
6:15	49.98	178397	5099	8124	228	13387	2192	149351	3196	170045	181577	-380
6:30	50.08	185805	5089	8209	262	17103	2179	153191	3248	177334	189281	-405
6:45	49.93	192127	5091	8140	458	19328	2188	157242	3255	183529	195702	-592
7:00	49.93	197702	5093	8049	1122	22199	2210	159621	3205	188531	201499	-586
7:15	49.78	202689	5087	8026	2321	24197	2194	160888	3223	192342	205936	-606
7:30	50.03	205564	5095	8071	4801	24583	2177	160718	3280	192692	208725	-603
7:45	50.08	207033	5103	8090	8637	27758	2193	159827	3281	190306	209889	-685
8:00	50.08	206839	5096	8023	13927	18923	2037	158046	3263	184889	209315	-682
8:15	50.03	209245	5096	7876	20581	16466	2005	156180	3246	180788	211450	-671
8:30	50.03	210476	5096	7653	27578	14341	1951	152530	3206	175245	212355	-651
8:45	50.03	211733	5107	7343	34584	12088	1947	147826	3224	169806	212119	-734
9:00	50.08	211959	5086	6790	39202	10639	1934	144677	3184	165967	211512	-706
9:15	50.03	217147	5080	6424	43081	10404	1927	144785	3151	167642	214852	-705
9:30	50.03	218713	5068	5861	50947	9480	1933	143408	3164	161905	219861	-811
9:45	50.03	220177	5076	5462	54760	9234	1913	141354	3169	159955	220968	-852
10:00	50.08	219422	5078	5082	57504	9015	1898	138590	3147	156836	220314	-1106
10:15	50.03	219862	5075	4946	60789	8088	1920	137795	3125	154127	221738	-1299
10:30	50.03	220191	5057	4953	62475	7549	1938	136710	3170	152763	221852	-1336
10:45	50.03	219146	5077	5035	64024	6490	1955	134850	3192	150087	220623	-1301
11:00	50.03	218004	5075	5105	65392	6279	1947	132574	3119	147507	219491	-1346
11:15	50.03	216108	5069	5212	66392	5976	1972	129819	3101	144504	217541	-1291
11:30	49.98	215156	5076	5432	67392	5860	1993	128165	3072	142332	216990	-1415
11:45	49.98	214416	5051	5504	68350	6199	2006	126211	3016	140562	216337	-1520
12:00	49.98	212212	5045	5882	69122	6395	2003	122647	3075	137208	214169	-1540
12:15	49.98	210924	5039	5894	69094	6171	2004	121296	3104	135936	212602	-1504
12:30	50.08	209880	5034	5952	69754	6480	2001	119249	3032	134174	211502	-1532
12:45	49.99	208290	5047	5905	69748	6411	2038	117670	3076	132637	209895	-1511
13:00	50.09	205109	5029	5680	69362	6254	2028	115524	2984	130067	206861	-1538
13:15	49.93	200983	5043	5659	67583	6082	2036	113359	3005	127741	202767	-1533
13:30	49.93	200796	5038	5676	67651	6356	2068	113204	3058	127469	203051	-1581
13:45	49.88	201462	5038	5530	66585	6752	2065	114166	3026	129347	203162	-1453
14:00	49.99	201470	5028	5529	65541	6930	2067	114947	3048	130400	203090	-1506
14:15	49.93	202035	5034	5479	63540	6753	2079	117782	3096	133016	203763	-1454
14:30	49.95	203148	5030	5393	60852	7067	2078	121886	3038	136903	205344	-1460
14:45	49.95	203181	5036	5073	58419	6988	2081	124896	3104	139689	205597	-1491
15:00	50.10	204748	5039	5191	55839	7105	2099	128327	3054	143718	206654	-1460
15:15	50.15	203753	5058	5125	52651	6985	2103	130432	3102	145977	205456	-1476
15:30	50.05	203088	5043	5180	48502	6946	2172	134579	3047	149406	205469	-1485
15:45	50.00	203981	5036	5325	44333	8209	2458	138742	3160	154323	207263	-1471
16:00	50.00	203971	5036	5326	39565	9134	2696	142167	3136	159080	207060	-1047
16:15	50.00	201347	5019	5335	33427	10529	3086	143242	3117	162585	203755	-923
16:30	50.05	203075	5035	5345	26457	12545	3171	148114	3138	171273	203805	-819
16:45	49.94	201612	5025	5363	19625	14298	3257	152906	3197	176624	203671	-683
17:00	50.04	202741	5019	5462	14205	17968	3271	155828	3233	183074	204986	-620
17:15	50.04	201418	5022	5534	8303	22064	3319	158568	3166	187581	205976	-543
17:30	50.04	203325	5046	5794	4631	26137	3792	160277	3288	192900	208965	-591
17:45	49.84	206155	5054	6108	2225	27564	3972	162882	3233	197822	211038	-576
18:00	50.04	207898	5042	6569	1308	27936	4232	163382	3244	200021	211713	-557
18:15	49.94	206670	5053	7102	1115	27798	3582	162353	3251	198453	210254	-501
18:30	49.94	206355	5077	7696	748	28160	3032	162139	3338	197911	210190	-521
18:45	49.99	205294	5052	8521	696	27707	2473	161607	3302	196077	209358	-519
19:00	50.04	202563	5052	9112	673	26456	2481	159331	3290	192778	206395	-517
19:15	50.04	200448	5068	9569	680	25268	2345	157776	3272	190199	203978	-514
19:30	49.99	197318	5075	9926	0	22595	2311	156575	3339	187392	200003	-523
19:45	50.04	193928	5068	10314	0	20692	2265	154911	3221	183614	196471	-553
20:00	50.04	190073	5066	10698	0	19270	2218	152151	3127	179375	192530	-533
20:15	49.99	185739	5074	10812	0	16324	2229	150551	3213	174927	188203	-584
20:30	50.04	182699	5055	11048	0	14580	2218	148918	3294	171651	185113	-564
20:45	50.09	179741	5077	11163	0	13503	2209	146965	3213	168578	182130	-539
21:00	50.09	177068	5084	11276	0	12916	2220	144592	3241	165792	179329	-501
21:15	50.04	173854	5077	11233	0	12292	2230	141969	3230	162621	176031	-542
21:30	50.04	171287	5067	11363	0	11588	2227	140120	3265	159924	173630	-534
21:45	50.04	168274	5067	11345	0	10437	2228	138189	3249	156929	170515	-525
22:00	50.04	164500	5084	11440	0	9637	2230	135042	3270	153060	166703	-567
22:15	49.99	163804	5079	11274	0	9570	2231	134873	3298	152530	166325	-753
22:30	49.99	162168	5076	11115	0	9606	2240	133				