



National Load Despatch Centre
राष्ट्रीय भार प्रेषण केंद्र
GRID CONTROLLER OF INDIA LIMITED
ग्रिड कंट्रोलर ऑफ इंडिया लिमिटेड

(Government of India Enterprise/ भारत सरकार का उद्यम)
B-9, QUTUB INSTITUTIONAL AREA, KATWARIA SARAI, NEW DELHI -110016
बी-9, कुतुब इंस्टीट्यूशनल एरिया, कटवारिया सराये, न्यू दिल्ली-110016

Ref: POSOCO/NLDC/SO/Daily PSP Report

दिनांक: 17-June-2024

To,

- कार्यकारी निदेशक, पू.क्षे.भा.प्रे.के., 14, गोल्फ क्लब रोड, कोलकाता - 700033
Executive Director, ERLDC, 14 Golf Club Road, Tollygunge, Kolkata, 700033
- कार्यकारी निदेशक, ऊ.क्षे.भा.प्रे.के., 18/ए, शाहीद जीत सिंह सनसनवाल मार्ग, नई दिल्ली - 110016
Executive Director, NRLDC, 18-A, Shaheed Jeet Singh Marg, Katwaria Sarai, New Delhi - 110016
- कार्यकारी निदेशक, प.क्षे.भा.प्रे.के., एफ3, एम आई डी सी क्षेत्र, अंधेरी, मुंबई -400093
Executive Director, WRLDC, F-3, M.I.D.C. Area, Marol, Andheri (East), Mumbai-400093
- कार्यकारी निदेशक, ऊ.पू.क्षे.भा.प्रे.के., डोंगतेह, लोअर नोंग्रह, लापालंग, शिलोंग - 793006
Executive Director, NERLDC, Dongteih, Lower Nongrah, Lapalang, Shillong - 793006, Meghalaya
- कार्यकारी निदेशक, द.क्षे.भा.प्रे.के., 29, रेस कोर्स क्रॉस रोड, बंगलुरु -560009
Executive Director, SRLDC, 29, Race Course Cross Road, Bangalore-560009

Sub: Daily PSP Report for the date 16.06.2024.

महोदय/Dear Sir,

आईईजीसी-2010 की धारा स.-5.5.1 के प्रावधान के अनुसार, दिनांक 16-जून-2024 की अखिल भारतीय प्रणाली की दैनिक ग्रिड निष्पादन रिपोर्ट रांभांप्रेके की वेबसाइट पर उपलब्ध है।

As per article 5.5.1 of the Indian Electricity Grid Code, the daily report pertaining power supply position of All India Power System for the date 16-June-2024, is available at the NLDC website.

धन्यवाद,
Thanks

Report for previous day Date of Reporting: 17-Jun-2024

A. Power Supply Position at All India and Regional level

	NR	WR	SR	ER	NER	TOTAL
Demand Met during Evening Peak hrs(MW) (at 20:00 hrs; from RLDCs)	79099	60740	43127	28182	2894	214042
Peak Shortage (MW)	509	0	0	0	0	509
Energy Met (MU)	1927	1466	1060	637	55	5144
Hydro Gen (MU)	350	52	61	53	31	546
Wind Gen (MU)	29	95	155	-	-	278
Solar Gen (MU)*	173.10	84.49	131.31	2.94	0.42	392
Energy Shortage (MU)	21.80	0.00	0.00	0.00	0.00	21.80
Maximum Demand Met During the Day (MW) (From NLDC SCADA)	85961	65691	48211	31162	2892	231161
Time Of Maximum Demand Met	14:58	15:06	14:31	23:31	19:53	14:56

B. Frequency Profile (%)

Region	FVI	< 49.7	49.7 - 49.8	49.8 - 49.9	< 49.9	49.9 - 50.05	> 50.05
All India	0.039	0.36	1.15	6.40	7.90	83.66	8.44

C. Power Supply Position in States

Region	States	Max.Demand Met during the day (MW)	Shortage during maximum Demand (MW)	Energy Met (MU)	Drawal Schedule (MU)	OD(+)/UD(-) (MU)	Max OD (MW)	Energy Shortage (MU)
NR	Punjab	15030	0	325.7	194.6	-3.6	234	0.00
	Haryana	12164	0	268.0	198.0	-0.5	437	0.00
	Rajasthan	17055	0	361.6	120.7	1.9	496	13.68
	Delhi	7786	0	154.8	134.2	-0.4	332	0.00
	UP	29616	163	650.5	330.9	0.4	457	6.63
	Uttarakhand	2616	0	57.6	30.5	0.6	240	0.97
	HP	1729	0	37.9	3.2	-0.5	65	0.00
	J&K(UT) & Ladakh(UT)	2770	112	58.4	26.9	5.1	584	0.52
	Chandigarh	407	0	8.1	7.9	0.2	89	0.00
WR	Railways_NR ISTS	205	0	4.3	3.3	1.0	98	0.00
	Chhattisgarh	5260	0	115.8	58.9	0.2	270	0.00
	Gujarat	22917	0	481.2	174.8	-1.0	643	0.00
	MP	12292	0	270.8	141.7	-3.8	355	0.00
	Maharashtra	22750	0	524.9	181.0	-5.3	647	0.00
	Goa	613	0	13.0	12.3	0.2	92	0.00
	DNHDDPDCL	1295	0	29.6	29.5	0.1	57	0.00
	AMNSIL	835	0	17.8	7.8	0.5	267	0.00
	BALCO	523	0	12.5	12.5	0.0	6	0.00
SR	Andhra Pradesh	10838	0	214.4	62.5	-0.4	891	0.00
	Telangana	9622	0	201.0	93.3	0.3	713	0.00
	Karnataka	10257	0	200.1	40.2	-1.6	570	0.00
	Kerala	4105	0	80.7	51.0	1.5	420	0.00
	Tamil Nadu	15799	0	353.3	152.1	0.6	1069	0.00
	Puducherry	478	0	10.5	10.0	-0.1	48	0.00
	Railways_SR ISTS	21	0	0.2	0.2	0.0	4	0.00
ER	Bihar	7111	0	155.2	146.7	-3.1	158	0.00
	DVC	3563	0	76.1	-45.6	-0.6	277	0.00
	Jharkhand	2260	0	47.4	42.0	-0.3	220	0.00
	Odisha	6322	0	125.0	51.4	-0.1	706	0.00
	West Bengal	11848	0	231.6	89.7	-1.8	431	0.00
	Sikkim	66	0	1.1	1.4	-0.2	5	0.00
	Railways_ER ISTS	21	0	0.2	0.2	0.0	4	0.00
NER	Arunachal Pradesh	151	0	2.7	3.0	-0.6	8	0.00
	Assam	1885	0	34.3	25.6	0.4	147	0.00
	Manipur	198	0	3.2	3.2	0.0	39	0.00
	Meghalaya	290	0	5.1	-0.5	0.0	85	0.00
	Mizoram	104	0	1.6	1.2	-0.4	9	0.00
	Nagaland	161	0	2.7	2.9	-0.2	14	0.00
	Tripura	273	0	5.1	4.6	0.2	73	0.00

D. Transnational Exchanges (MU) - Import(+ve)/Export(-ve)

	Bhutan	Nepal	Bangladesh	Godda -> Bangladesh
Actual (MU)	21.7	5.2	-23.0	-24.0
Day Peak (MW)	1587.0	381.0	-1027.0	-1376.0

E. Import/Export by Regions (in MU) - Import(+ve)/Export(-ve); OD(+)/UD(-)

	NR	WR	SR	ER	NER	TOTAL
Schedule(MU)	479.3	-388.4	-7.3	-75.2	-8.4	0.0
Actual(MU)	454.6	-369.6	-10.3	-74.6	-11.5	-11.4
O/D/U/D(MU)	-24.7	18.8	-3.0	0.6	-3.0	-11.4

F. Generation Outage(MW)

	NR	WR	SR	ER	NER	TOTAL	% Share
Central Sector	2936	5729	5408	3446	180	17698	44
State Sector	3751	9980	6258	2224	119	22331	56
Total	6686	15708	11666	5670	299	40029	100

G. Sourcewise generation (Gross) (MU)

	NR	WR	SR	ER	NER	All India	% Share
Coal	900	1620	666	727	16	3928	71
Lignite	23	16	49	0	0	88	2
Hydro	350	52	61	53	31	546	10
Nuclear	29	60	51	0	0	140	3
Gas, Naptha & Diesel	54	53	6	0	24	137	2
RES (Wind, Solar, Biomass & Others)	210	182	309	4	0	705	13
Total	1566	1982	1141	784	71	5545	100

Share of RES in total generation (%)	13.41	9.18	27.06	0.48	0.62	12.72
Share of Non-fossil fuel (Hydro,Nuclear and RES) in total generation(%)	37.60	14.83	36.86	7.23	43.99	25.10

H. All India Demand Diversity Factor

Based on Regional Max Demands	1.011
Based on State Max Demands	1.043

I. All India Peak Demand and shortage at Solar and Non-Solar Hour

	Max Demand Met(MW)	Time	Shortage(MW)
Solar hr	231161	14:56	0
Non-Solar hr	221339	0:06	2909

Diversity factor = Sum of regional or state maximum demands / All India maximum demand

**Note: All generation MU figures are gross

***Godda (Jharkhand) -> Bangladesh power exchange is through the radial connection (isolated from Indian Grid)

Solar Hours -> 07:00 to 17:00hrs and rest are Non-Solar Hours

*Source: RLDCs for solar connected to ISTS; SLDCs for embedded solar. Limited visibility of embedded solar data.

Executive Director-NLDC

INTER-REGIONAL EXCHANGES

Import=(+ve) /Export =(-ve) for NET (MU)

Date of Reporting: 17-Jun-2024

Sl No	Voltage Level	Line Details	No. of Circuit	Max Import (MW)	Max Export (MW)	Import (MU)	Export (MU)	NET (MU)
Import/Export of ER (With NR)								
1	HVDC	ALIPURDUAR-AGRA	2	0	0	0.0	0.0	0.0
2	HVDC	PUSAULI B/B	-	3	0	3.2	0.0	3.2
3	765 kV	GAYA-VARANASI	2	285	1009	0.0	10.3	-10.3
4	765 kV	SASARAM-FATEHPUR	1	0	499	0.0	8.0	-8.0
5	765 kV	GAYA-BALIA	1	0	705	0.0	13.2	-13.2
6	400 kV	PUSAULI-VARANASI	1	40	99	0.0	1.0	-1.0
7	400 kV	PUSAULI -ALLAHABAD	1	66	134	0.0	1.1	-1.1
8	400 kV	MUZAFFARPUR-GORAKHPUR	2	0	976	0.0	17.4	-17.4
9	400 kV	PATNA-BALIA	2	0	921	0.0	17.1	-17.1
10	400 kV	NAUBATPUR-BALIA	2	0	282	0.0	4.7	-4.7
11	400 kV	BIHARSHARIEFF-BALIA	2	98	217	1.9	0.0	1.9
12	400 kV	MOTIHARI-GORAKHPUR	2	0	634	0.0	11.9	-11.9
13	400 kV	BIHARSHARIEFF-VARANASI	2	0	0	0.0	0.0	0.0
14	220 kV	SAHUPURI-KARAMNASA	1	4	65	0.0	0.9	-0.9
15	132 kV	NAGAR UNTARI-RIHAND	1	0	0	0.1	0.0	0.1
16	132 kV	GARWAH-RIHAND	1	30	0	0.5	0.0	0.5
17	132 kV	KARMANASA-SAHUPURI	1	0	0	0.0	0.0	0.0
18	132 kV	KARMANASA-CHANDAULI	1	0	0	0.0	0.0	0.0
ER-NR						5.7	85.5	-79.8
Import/Export of ER (With WR)								
1	765 kV	JHARSUGUDA-DHARAMJAIGARH	4	1	1095	0.0	12.4	-12.4
2	765 kV	NEW RANCHI-DHARAMJAIGARH	2	1977	0	32.5	0.0	32.5
3	765 kV	JHARSUGUDA-DURG	2	0	639	0.0	6.8	-6.8
4	400 kV	JHARSUGUDA-RAIGARH	4	489	139	4.8	0.0	4.8
5	400 kV	RANCHI-SIPAT	2	527	0	9.6	0.0	9.6
6	220 kV	BUDHIPADAR-RAIGARH	1	0	210	0.0	2.6	-2.6
7	220 kV	BUDHIPADAR-KORBA	2	101	144	0.0	0.4	-0.4
ER-WR						47.0	22.1	24.9
Import/Export of ER (With SR)								
1	HVDC	JEYPORE-GAZUWAKA B/B	2	503	0	11.0	0.0	11.0
2	HVDC	TALCHER-KOLAR BIPOLE	2	0	1702	0.0	41.0	-41.0
3	765 kV	ANGUL-SRIKAKULAM	2	0	2253	0.0	40.3	-40.3
4	400 kV	TALCHER-I/C	2	36	477	0.0	6.4	-6.4
5	220 kV	BALIMELA-UPPER-SILERRU	1	0	0	0.0	0.0	0.0
ER-SR						11.0	81.3	-70.3
Import/Export of ER (With NER)								
1	400 kV	BINAGURI-BONGAIGAON	2	629	0	10.1	0.0	10.1
2	400 kV	ALIPURDUAR-BONGAIGAON	2	841	0	12.6	0.0	12.6
3	220 kV	ALIPURDUAR-SALAKATI	2	146	0	2.1	0.0	2.1
ER-NER						24.8	0.0	24.8
Import/Export of NER (With NR)								
1	HVDC	BISWANATH CHARIALI-AGRA	2	605	0	14.4	0.0	14.4
NER-NR						14.4	0.0	14.4
Import/Export of WR (With NR)								
1	HVDC	CHAMPA-KURUKSHETRA	2	0	6030	0.0	120.3	-120.3
2	HVDC	VINDHYACHAL B/B	-	0	254	0.0	9.8	-9.8
3	HVDC	MUNDRA-MOHINDERGARH	2	0	1616	0.0	27.0	-27.0
4	765 kV	GWALIOR-AGRA	2	0	3155	0.0	60.0	-60.0
5	765 kV	GWALIOR-PHAGI	2	236	1982	0.4	24.6	-24.2
6	765 kV	JABALPUR-ORAI	2	0	1399	0.0	50.0	-50.0
7	765 kV	GWALIOR-ORAI	1	747	0	11.0	0.0	11.0
8	765 kV	SATNA-ORAI	1	0	1261	0.0	25.6	-25.6
9	765 kV	BANASKANTHA-CHITORGARH	2	430	1332	1.2	13.6	-12.5
10	765 kV	VINDHYACHAL-VARANASI	2	0	3543	0.0	68.5	-68.5
11	400 kV	ZERDA-KANKROLI	1	138	213	0.6	1.9	-1.2
12	400 kV	ZERDA -BHINMAL	1	139	213	0.6	1.8	-1.2
13	400 kV	VINDHYACHAL -RIHAND	1	962	0	22.2	0.0	22.2
14	400 kV	RAPP-SHUJALPUR	2	88	627	0.2	8.1	-7.9
15	400 kV	NEEMUCH-Chittorgarh	2	194	688	0.5	8.2	-7.7
16	220 kV	BHANPURA-RANPUR	1	0	108	0.0	2.0	-2.0
17	220 kV	BHANPURA-MORAK	1	0	30	0.0	2.7	-2.7
18	220 kV	MEHGAON-AURAIYA	1	65	23	0.5	0.0	0.5
19	220 kV	MALANPUR-AURAIYA	1	37	34	0.2	0.2	0.1
20	132 kV	GWALIOR-SAWAI MADHOPUR	1	0	0	0.0	0.0	0.0
21	132 kV	RAJGHAT-LALITPUR	2	0	0	0.0	0.0	0.0
WR-NR						37.5	424.4	-386.9
Import/Export of WR (With SR)								
1	HVDC	BHADRAWATI B/B	-	999	0	24.0	0.0	24.0
2	HVDC	RAIGARH-PUGALUR	2	0	1202	0.0	18.8	-18.8
3	765 kV	SOLAPUR-RAICHUR	2	2315	0	29.7	0.0	29.7
4	765 kV	WARDHA-NIZAMABAD	2	37	1554	0.0	15.9	-15.9
5	765 kV	WARORA-WARANGAL(NEW)	2	28	1647	0.0	18.2	-18.2
6	400 kV	KOLHAPUR-KUDGI	2	2114	0	38.7	0.0	38.7
7	220 kV	KOLHAPUR-CHIKODI	2	0	0	0.0	0.0	0.0
8	220 kV	PONDA-AMBEWADI	1	0	59	1.4	0.0	1.4
9	220 kV	XELDEM-AMBEWADI	1	0	112	2.1	0.0	2.1
WR-SR						96.0	53.0	43.0

INTERNATIONAL EXCHANGES						
State	Region	Line Name	Max (MW)	Min (MW)	Avg (MW)	Import(+ve)/Export(-ve) Energy Exchange (MU)
BHUTAN	ER	400kV MANGDECHHU-ALIPURDUAR 1,2&3 i.e. ALIPURDUAR RECEIPT (from MANGDECHU HEP 4*180MW)	680	347	397	9.53
	ER	400kV TALA-BINAGURI 1,2,4 (& 400kV MALBASE - BINAGURI) i.e. BINAGURI RECEIPT (from TALA HEP 6*170MW)	850	218	463	11.10
	ER	220kV CHUKHA-BIRPARA 1&2 (& 220kV MALBASE - BIRPARA) i.e. BIRPARA RECEIPT (from CHUKHA HEP 4*84MW)	49	-40	9	0.21
	NER	132kV GELEPHU-SALAKATI	12	0	3	0.06
	NER	132kV MOTANGA-RANGIA	48	0	33	0.79
NEPAL	NR	NEPAL IMPORT (FROM UP)	-74	0	0	0.00
	NR	132kV MAHENDRANAGAR-TANAKPUR(NHPC)	-74	0	-40	-0.96
	ER	NEPAL IMPORT (FROM BIHAR)	0	0	0	0.00
	ER	400kV DHALKEBAR-MUZAFFARPUR 1&2	381	26	258	6.18
BANGLADESH	ER	BHERAMARA B/B HVDC (B'DESH)	-939	-784	-889	-21.33
	ER (Isolated from Indian Grid)	400kV GODDA_TPS-RAHANPUR (B'DESH) D/C	-1376	-813	-1001	-24.02
	NER	132kV COMILLA-SURAJMANI NAGAR 1&2	-88	0	-70	-1.68

Export From India (in MU)

Country	GNA (ISGS/PPA)	T-GNA							TOTAL
		BILATERAL TOTAL	COLLECTIVE						
			IDAM			RTM			
			IEX	PXIL	HPX	IEX	PXIL	HPX	
Bhutan	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Nepal	0.19	0.00	0.63	0.00	0.00	0.00	0.00	0.00	0.82
Bangladesh	21.31	0.00	0.00	0.00	0.00	0.00	0.00	0.00	21.31
Myanmar	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total Export	21.50	0.00	0.63	0.00	0.00	0.00	0.00	0.00	22.13

Import by India(in MU)

Country	GNA (ISGA/PPA)	T-GNA							TOTAL
		BILATERAL TOTAL	COLLECTIVE						
			IDAM			RTM			
			IEX	PXIL	HPX	IEX	PXIL	HPX	
Bhutan	19.92	0.00	0.56	0.00	0.00	0.26	0.00	0.00	20.74
Nepal	2.63	0.00	1.62	0.00	0.00	1.30	0.00	0.00	5.55
Bangladesh	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Myanmar	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total Import	22.55	0.00	2.18	0.00	0.00	1.56	0.00	0.00	26.29

Net from India(in MU)

-ve : Export / +ve : Import

Country	GNA (ISGS/PPA)	T-GNA							TOTAL
		BILATERAL TOTAL	COLLECTIVE						
			IDAM			RTM			
			IEX	PXIL	HPX	IEX	PXIL	HPX	
Bhutan	19.92	0.00	0.56	0.00	0.00	0.26	0.00	0.00	20.74
Nepal	2.44	0.00	0.99	0.00	0.00	1.30	0.00	0.00	4.73
Bangladesh	-21.31	0.00	0.00	0.00	0.00	0.00	0.00	0.00	-21.31
Myanmar	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total Net	1.05	0.00	1.55	0.00	0.00	1.56	0.00	0.00	4.16