



National Load Despatch Centre
राष्ट्रीय भार प्रेषण केंद्र
GRID CONTROLLER OF INDIA LIMITED
ग्रिड कंट्रोलर ऑफ इंडिया लिमिटेड

(Government of India Enterprise/ भारत सरकार का उद्यम)
B-9, QUTUB INSTITUTIONAL AREA, KATWARIA SARAI, NEW DELHI -110016
बी-9, कुतुब इन्स्टीट्यूशनल एरिया, कटवारिया सराये, न्यू दिल्ली-110016

Ref: GRID-INDIA/NLDC/SO/Daily PSP Report

दिनांक: 05.11.2025

To,

- कार्यकारी निदेशक, पू.क्षे.भा.प्रे.के., 14, गोल्फ क्लब रोड, कोलकाता - 700033
Executive Director, ERLDC, 14 Golf Club Road, Tollygunge, Kolkata, 700033
- कार्यकारी निदेशक, ऊ.क्षे.भा.प्रे.के., 18/ए, शाहीद जीत सिंह सनसनवाल मार्ग, नई दिल्ली - 110016
Executive Director, NRLDC, 18-A, Shaheed Jeet Singh Marg, Katwaria Sarai, New Delhi - 110016
- कार्यकारी निदेशक, प.क्षे.भा.प्रे.के., एफ3, एम आई डी सी क्षेत्र, अंधेरी, मुंबई - 400093
Executive Director, WRLDC, F-3, M.I.D.C. Area, Marol, Andheri (East), Mumbai-400093
- कार्यकारी निदेशक, ऊ.पू.क्षे.भा.प्रे.के., डोंगतेह, लोअर नोंग्रह, लापलंग, शिलोंग - 793006
Executive Director, NERLDC, Dongteih, Lower Nongrah, Lapalang, Shillong - 793006, Meghalaya
- कार्यकारी निदेशक, द.क्षे.भा.प्रे.के., 29, रेस कोर्स क्रॉस रोड, बंगलुरु - 560009
Executive Director, SRLDC, 29, Race Course Cross Road, Bangalore-560009

Sub: Daily PSP Report for the date 04.11.2025.

महोदय/Sir,

आईईजीसी-2023 की धारा स.-38(1) के प्रावधान के अनुसार, दिनांक 4-नवंबर-2025 की अखिल भारतीय प्रणाली की दैनिक ग्रिड निष्पादन रिपोर्ट रांभांप्रेके की वेबसाइट पर उपलब्ध है।

As per article 38(1) of the Indian Electricity Grid Code, the daily report pertaining power supply position of All India Power System for the date 04.11.2025, is available at the NLDC website.

धन्यवाद,
Thanks

Report for previous day

Date of Reporting: 05-Nov-2025

A. Power Supply Position at All India and Regional level

	NR	WR	SR	ER	NER	TOTAL
Demand Met during Evening Peak hrs(MW) (at 19:00 hrs; from RLDCs)	50995	59581	50223	23284	3012	187095
Peak Shortage (MW)	0	0	0	0	0	0
Energy Met (MU)	1120	1295	1118	479	56	4068
Hydro Gen (MU)	157	51	178	63	23	472
Wind Gen (MU)	27	101	73	-	-	201
Solar Gen (MU)*	167.22	137.14	97.60	3.07	1.04	406
Energy Shortage (MU)	0.00	0.00	0.00	0.00	0.00	0.00
Maximum Demand Met During the Day (MW) (From NLDC SCADA)	56100	62202	52153	24022	3244	195965
Time Of Maximum Demand Met	18:21	18:32	09:34	18:16	17:15	18:31

B. Frequency Profile (%)

Region	FV1	< 49.7	49.7 - 49.8	49.8 - 49.9	< 49.9	49.9 - 50.05	> 50.05
All India	0.052	0.00	0.00	3.97	3.97	75.98	20.06

C. Power Supply Position in States

Region	States	Max.Demand Met during the day (MW)	Shortage during maximum Demand (MW)	Energy Met (MU)	Drawal Schedule (MU)	OD(+)/UD(-) (MU)	Max OD (MW)	Energy Shortage (MU)
NR	Punjab	7183	0	143.9	68.3	-1.4	314	0.00
	Haryana	7592	0	158.0	133.5	-1.1	295	0.00
	Rajasthan	13526	0	270.6	63.9	-5.7	973	0.00
	Delhi	4195	0	81.5	79.2	0.4	317	0.00
	UP	17484	0	333.3	116.3	0.6	650	0.00
	Uttarakhand	2137	0	40.7	27.5	1.0	173	0.00
	HP	1900	0	32.6	17.9	-0.6	153	0.00
	J&K(UT) & Ladakh(UT)	2689	0	51.2	44.9	-2.8	138	0.00
	Chandigarh	209	0	3.7	3.7	0.0	10	0.00
	Railways_NR ISTS	224	0	4.4	4.0	0.4	55	0.00
WR	Chhattisgarh	4668	0	97.8	44.4	-0.5	529	0.00
	Gujarat	18384	0	371.3	202.9	-7.2	907	0.00
	MP	11416	0	222.1	138.4	0.0	353	0.00
	Maharashtra	25821	0	520.3	180.9	-1.0	808	0.00
	Goa	734	0	15.0	12.4	2.2	53	0.00
	DNHDDPDCL	1373	0	31.1	31.0	0.1	56	0.00
	AMNSIL	833	0	18.7	11.4	0.3	292	0.00
	BALCO	536	0	12.8	12.9	-0.1	6	0.00
	RIL JAMNAGAR	254	0	5.8	5.8	0.0	0	0.00
	Andhra Pradesh	9388	0	206.8	82.9	0.1	756	0.00
SR	Telangana	9279	0	184.7	69.5	0.6	785	0.00
	Karnataka	13626	0	255.0	95.4	3.0	1165	0.00
	Kerala	4523	0	86.9	53.2	-1.3	447	0.00
	Tamil Nadu	18020	0	374.9	192.1	-0.5	756	0.00
	Puducherry	457	0	10.1	9.5	-0.1	43	0.00
	Bihar	5384	0	101.0	82.1	-3.5	104	0.00
ER	DVC	3134	0	64.1	-29.9	-0.5	316	0.00
	Jharkhand	1971	0	37.6	29.0	-0.4	327	0.00
	Odisha	5202	0	105.1	37.4	-3.3	521	0.00
	West Bengal	8541	0	169.8	49.2	-2.2	187	0.00
	Sikkim	84	0	1.2	1.3	-0.1	10	0.00
	Railways_ER ISTS	17	0	0.2	0.2	0.0	3	0.00
NER	Arunachal Pradesh	167	0	2.9	3.0	-0.3	38	0.00
	Assam	1981	0	34.2	26.6	0.3	91	0.00
	Manipur	229	0	3.1	3.2	-0.1	40	0.00
	Meghalaya	321	0	5.3	3.8	-0.2	47	0.00
	Mizoram	134	0	2.1	1.0	-0.1	33	0.00
	Nagaland	160	0	2.6	2.3	0.0	20	0.00
	Tripura	310	0	5.6	4.9	0.3	49	0.00

D. Transnational Exchanges (MU) - Import(+ve)/Export(-ve)

	Bhutan	Nepal	Bangladesh	Godda -> Bangladesh
Actual (MU)	28.4	19.9	-24.5	-27.6
Day Peak (MW)	1433.1	943.7	-1045.1	-1460.6

E. Import/Export by Regions (in MU) - Import(+ve)/Export(-ve); OD(+)/UD(-)

	NR	WR	SR	ER	NER	TOTAL
Schedule(MU)	196.9	-202.8	148.4	-148.0	5.5	0.0
Actual(MU)	204.0	-206.2	159.8	-170.9	4.3	-9.0
O/D/U/D(MU)	7.1	-3.3	11.4	-22.9	-1.3	-9.0

F. Generation Outage(MW)

	NR	WR	SR	ER	NER	TOTAL	% Share
Central Sector	7022	12702	5678	3370	607	29379	41
State Sector	11359	18742	10158	2287	205	42750	59
Total	18381	31444	15836	5657	812	72129	100

G. Sourcewise generation (Gross) (MU)

	NR	WR	SR	ER	NER	All India	% Share
Coal	570	1203	582	649	11	3016	68
Lignite	28	11	51	0	0	89	2
Hydro	157	51	178	63	23	472	11
Nuclear	31	63	41	0	0	135	3
Gas, Naptha & Diesel	3	29	5	0	21	58	1
RES (Wind, Solar, Biomass & Others)	204	241	191	5	1	642	15
Total	993	1598	1047	717	56	4412	100

Share of RES in total generation (%)	20.53	15.09	18.22	0.74	1.84	14.56
Share of Non-fossil fuel (Hydro,Nuclear and RES) in total generation(%)	39.50	22.23	39.11	9.51	43.45	28.33

H. All India Demand Diversity Factor

Based on Regional Max Demands	1.008
Based on State Max Demands	1.041

I. All India Peak Demand and shortage at Solar and Non-Solar Hour

	Max Demand Met(MW)	Time	Shortage(MW)
Solar hr	184156	9:29	0
Non-Solar hr	195965	18:31	0

Diversity factor = Sum of regional or state maximum demands / All India maximum demand

**Note: All generation MU figures are gross

***Godda (Jharkhand) -> Bangladesh power exchange is through the radial connection (isolated from Indian Grid)

Solar Hours -> 06:00 to 18:00hrs and rest are Non-Solar Hours

*Source: RLDCs for solar connected to ISTS; SLDCs for embedded solar. Limited visibility of embedded solar data.

Executive Director-NLDC

INTER-REGIONAL EXCHANGES

Import=(+ve) /Export =(-ve) for NET (MU)
Date of Reporting: 05-Nov-2025

Sl No	Voltage Level	Line Details	No. of Circuit	Max Import (MW)	Max Export (MW)	Import (MU)	Export (MU)	NET (MU)
Import/Export of ER (With NR)								
1	HVDC	ALIPURDUAR-AGRA	2	0	313	0.0	7.4	-7.4
2	HVDC	PUSAULI B/B	-	0	47	0.0	2.5	-2.5
3	765 kV	GAYA-VARANASI	2	342	1102	0.0	10.7	-10.7
4	765 kV	SASARAM-FATEHPUR	1	36	561	0.0	6.8	-6.8
5	765 kV	GAYA-BALIA	1	0	586	0.0	9.4	-9.4
6	400 kV	PUSAULI-VARANASI	1	0	92	0.0	1.4	-1.4
7	400 kV	PUSAULI-ALLAHABAD	1	0	87	0.0	1.0	-1.0
8	400 kV	MUZAFFARPUR-GORAKHPUR	2	0	676	0.0	9.8	-9.8
9	400 kV	PATNA-BALIA	2	0	926	0.0	12.5	-12.5
10	400 kV	NAUBATPUR-BALIA	2	288	76	0.0	4.8	-4.8
11	400 kV	BIHARSHARIFF-BALIA	2	140	163	0.0	0.5	-0.5
12	400 kV	MOTIHARI-GORAKHPUR	2	0	566	0.0	8.1	-8.1
13	400 kV	BIHARSARIFF-SAHUPURI	2	172	417	0.0	4.0	-4.0
14	220 kV	SAHUPURI-KARMANASA	1	34	3	0.0	1.9	-1.9
15	132 kV	NAGAR UNTARI-RIHAND	1	0	0	0.0	0.0	0.0
16	132 kV	GARWAH-RIHAND	1	30	0	0.5	0.0	0.5
17	132 kV	KARMANASA-SAHUPURI	1	0	0	0.0	0.0	0.0
18	132 kV	KARMANASA-CHANDAULI	1	0	0	0.0	0.3	-0.3
ER-NR						0.5	80.9	-80.4
Import/Export of ER (With WR)								
1	765 kV	JHARSUGUDA-DHARAMJAIGARH	4	583	1342	0.0	7.7	-7.7
2	765 kV	NEW RANCHI-DHARAMJAIGARH	2	839	365	6.9	0.0	6.9
3	765 kV	JHARSUGUDA-DURG	2	0	749	0.0	11.5	-11.5
4	400 kV	JHARSUGUDA-RAIGARH	4	504	145	2.9	0.0	2.9
5	400 kV	RANCHI-SIPAT	2	215	205	1.9	0.0	1.9
6	400 kV	JEYPORE-JACDALPUR	2	474	182	5.0	0.0	5.0
7	220 kV	BUDHIPADAR-RAIGARH	1	75	94	0.0	0.5	-0.5
8	220 kV	BUDHIPADAR-KORBA	2	120	96	0.1	0.0	0.1
ER-WR						16.7	19.7	-3.0
Import/Export of ER (With SR)								
1	HVDC	JEYPORE-GAZUWAKA B/B	2	0	414	0.0	9.8	-9.8
2	HVDC	TALCHER-KOLAR BIPOLE	2	0	1623	0.0	38.1	-38.1
3	765 kV	ANGUL-SRIKAKULAM	2	0	2911	0.0	50.3	-50.3
4	400 kV	TALCHER/JC	2	28	1188	0.0	0.0	-9.0
5	220 kV	BALIMELA-UPPER-SILERRU	1	27	0	0.5	0.0	0.5
ER-SR						0.5	98.3	-97.8
Import/Export of ER (With NER)								
1	400 kV	BINAGURI-BONGAIGAON	2	0	512	0.0	7.3	-7.3
2	400 kV	ALIPURDUAR-BONGAIGAON	2	0	796	0.0	11.9	-11.9
3	220 kV	ALIPURDUAR-SALAKATI	2	0	161	0.0	2.6	-2.6
ER-NER						0.0	21.8	-21.8
Import/Export of NER (With NR)								
1	HVDC	BISWANATH CHARIALI-AGRA	2	0	705	0.0	17.0	-17.0
NER-NR						0.0	17.0	-17.0
Import/Export of WR (With NR)								
1	HVDC	CHAMPA-KURUKSHETRA	2	0	3033	0.0	46.6	-46.6
2	HVDC	VINDHYACHAL B/B	-	194	0	4.9	0.0	4.9
3	HVDC	MUNDRA-MOHINDERGARH	2	0	979	0.0	14.2	-14.2
4	765 kV	GWALIOR-AGRA	2	327	1782	0.2	20.0	-19.7
5	765 kV	GWALIOR-PHAGI	2	1020	1896	0.0	19.5	-19.5
6	765 kV	JABALPUR-ORAI	2	301	803	0.0	22.7	-22.7
7	765 kV	GWALIOR-ORAI	1	962	0	12.1	0.0	12.1
8	765 kV	SATNA-ORAI	1	0	865	0.0	15.2	-15.2
9	765 kV	BANASKANTHA-CHITORGARH	2	2928	765	24.4	1.6	22.8
10	765 kV	VINDHYACHAL-VARANASI	2	0	1835	0.0	26.4	-26.4
11	400 kV	ZERDA-KANKROLI	1	520	0	5.7	0.0	5.7
12	400 kV	ZERDA -BHINMAL	1	359	0	4.0	0.0	4.0
13	400 kV	VINDHYACHAL -RIHAND	1	0	1	0.0	0.0	0.0
14	400 kV	RAPP-SHUJALPUR	2	688	288	2.0	0.0	2.0
15	400 kV	NEEMUCH-Chittorgarh	2	739	245	3.8	1.8	2.0
16	220 kV	BHANPURA-RANPUR	1	0	104	0.0	1.8	-1.8
17	220 kV	BHANPURA-MORAK	1	0	30	0.0	1.2	-1.2
18	220 kV	MEHGAON-AURAIYA	1	62	18	0.5	0.1	0.4
19	220 kV	MALANPUR-AURAIYA	1	42	23	0.3	0.1	0.1
20	132 kV	RAIGHAT-LALITPUR	2	0	0	0.0	0.0	0.0
WR-NR						57.8	171.2	-113.4
Import/Export of WR (With SR)								
1	HVDC	BHADRAWATI B/B	-	305	492	4.8	4.0	0.8
2	HVDC	RAIGARH-PUGALUR	2	0	4010	0.0	53.3	-53.3
3	765 kV	SOLAPUR-RAICHUR	2	891	1421	2.8	5.7	-3.0
4	765 kV	WARDHA-NIZAMABAD	2	0	2342	0.0	29.5	-29.5
5	765 kV	WARORA-WARANGAL(NEW)	2	0	2412	0.0	33.0	-33.0
6	400 kV	KOLHAPUR-KUDGI	2	1319	0	20.6	0.0	20.6
7	220 kV	KOLHAPUR-CHIKODI	2	0	0	0.0	0.0	0.0
8	220 kV	PONDA-AMBEWADI	1	0	0	0.0	0.0	0.0
9	220 kV	XELDEM-AMBEWADI	1	0	113	0.0	2.2	-2.2
WR-SR						30.3	125.4	-95.1

INTERNATIONAL EXCHANGES					Import(+ve)/Export(-ve)		
State	Region	Line Name	Max (MW)	Min (MW)	Avg (MW)	Energy Exchange (MU)	
BHUTAN	ER	400kV MANGDECHHU-ALIPURDUAR 1,2&3 I.e. ALIPURDUAR RECEIPT (from MANGDECHU HEP 4*180MW)	599	422	525	12.60	
	ER	400kV TALA-BINAGURI 1,2,4 (& 400kV MALBASE - BINAGURI) I.e. BINAGURI RECEIPT (from TALA HEP 6*170MW)	835	525	693	16.64	
	ER	220kV CHUKHA-BIRPARA 1&2 (& 220kV MALBASE - BIRPARA) I.e. BIRPARA RECEIPT (from CHUKHA HEP 4*84MW)	-69	25	-18	-0.44	
	NER	132kV GELEPHU-SALAKATI	-36	0	-28	-0.66	
	NER	132kV MOTANGA-RANGIA	28	-5	10	0.25	
NEPAL	NR	NEPAL IMPORT (FROM UP)	0	0	0	0.00	
	NR	132kV MAHENDRANAGAR-TANAKPUR(NHPC)	68	0	64	1.53	
	ER	NEPAL IMPORT (FROM BIHAR)	0	0	0	0.00	
	ER	400kV DHALKEBAR-MUZAFFARPUR 1&2	857	707	766	18.39	
BANGLADESH	ER	BHERAMARA B/B HVDC (B'DESH)	-966	-934	-955	-22.91	
	ER (Isolated from Indian Grid)	400kV GODDA_TPS-RAHANPUR (B'DESH) D/C	-1461	-832	-1149	-27.57	
	NER	132kV COMILLA-SURAJMANI NAGAR 1&2	-78	0	-65	-1.56	

CROSS BORDER EXCHANGE SCHEDULE

Date of Reporting: 05-Nov-2025

Export From India (in MU)

Country	GNA (ISGS/PPA)	T-GNA							TOTAL
		BILATERAL TOTAL	COLLECTIVE						
			IDAM			RTM			
			IEX	PXIL	HPX	IEX	PXIL	HPX	
Bhutan	0.00	0.33	0.00	0.00	0.00	0.00	0.00	0.00	0.33
Nepal	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Bangladesh	23.51	0.17	0.00	0.00	0.00	0.00	0.00	0.00	23.68
Myanmar	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total Export	23.51	0.50	0.00	0.00	0.00	0.00	0.00	0.00	24.01

Import by India(in MU)

Country	GNA (ISGA/PPA)	T-GNA							TOTAL
		BILATERAL TOTAL	COLLECTIVE						
			IDAM			RTM			
			IEX	PXIL	HPX	IEX	PXIL	HPX	
Bhutan	17.03	0.00	0.00	0.00	0.00	0.00	0.00	0.00	17.03
Nepal	0.76	0.16	12.69	0.00	0.00	3.69	0.00	0.00	17.30
Bangladesh	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Myanmar	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total Import	17.79	0.16	12.69	0.00	0.00	3.69	0.00	0.00	34.33

Net from India(in MU)

-ve : Export / +ve : Import

Country	GNA (ISGS/PPA)	T-GNA							TOTAL	
		BILATERAL TOTAL	COLLECTIVE							
			IDAM			RTM				
			IEX	PXIL	HPX	IEX	PXIL	HPX		
Bhutan	17.03	-0.33	0.00	0.00	0.00	0.00	0.00	0.00	16.70	
Nepal	0.76	0.16	12.69	0.00	0.00	0.00	3.69	0.00	0.00	17.30
Bangladesh	-23.51	-0.17	0.00	0.00	0.00	0.00	0.00	0.00	0.00	-23.68
Myanmar	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total Net	-5.72	-0.34	12.69	0.00	0.00	0.00	3.69	0.00	0.00	10.32

15 Min (INSTANTANEOUS) ALL INDIA GRID FREQUENCY, GENERATION & DEMAND MET (SCADA DATA)												
TIME	FREQUENCY (Hz)	DEMAND MET (MW)	NUCLEAR (MW)	WIND (MW)	SOLAR (MW)	HYDRO** (MW)	GAS (MW)	THERMAL (MW)	OTHERS* (MW)	NET DEMAND (MW)	TOTAL GENERATION (MW)	NET TRANSNATIONAL EXCHANGE (MW)
		(A)	(B)	(C)	(D)	(E)	(F)	(G)	(H)	(I=A-(C+D))	(J=B+C+D+E+F+G+H)	(K)
0:00	50.05	157530	5104	13433	0	16084	2294	118711	1902	144097	157528	1282
0:15	49.95	156393	5110	13659	0	14344	2268	119101	1837	142734	156319	1292
0:30	49.95	155265	5115	13704	0	14811	2185	117431	1816	141561	155062	1286
0:45	49.95	154040	5112	13831	0	14822	2265	115968	1889	140209	153887	1311
1:00	49.90	152903	5109	13744	0	15222	2176	114493	1840	139159	152584	1340
1:15	49.90	151592	5115	13693	0	14913	2271	113487	1844	137899	151323	1358
1:30	49.95	151042	5106	13658	0	14831	2276	112795	1868	137384	150534	1348
1:45	49.95	150267	5121	13610	0	14514	2182	112480	1866	136657	149773	1325
2:00	50.00	149206	5105	13552	0	14700	2269	111538	1813	135654	148977	1324
2:15	50.00	148345	5116	13586	0	14406	2260	111096	1853	134759	148317	1291
2:30	50.00	147986	5113	13684	0	14380	2262	110789	1832	134302	148060	1283
2:45	50.00	147625	5109	13489	0	14501	2268	110601	1851	134136	147819	1084
3:00	50.00	147023	5113	13380	0	14211	2259	110437	1866	133643	147266	1076
3:15	50.01	146549	5113	13362	0	14165	2179	110209	1855	133187	146883	1090
3:30	50.01	146545	5114	13189	0	14204	2311	110117	1844	133356	146779	1078
3:45	50.06	146480	5104	12931	0	14305	2305	110313	1859	133549	146817	1076
4:00	50.06	146198	5099	12916	0	14106	2301	110237	1829	133282	146488	1084
4:15	50.01	147710	5122	12997	0	14604	2325	111196	1861	134713	148105	1083
4:30	50.01	149044	5115	13002	0	15009	2154	112029	1824	136042	149133	1079
4:45	50.01	150393	5126	12915	0	14670	2165	113863	1822	137478	150561	1067
5:00	50.01	152403	5116	12735	-8	15310	2164	115419	1877	139676	152613	1101
5:15	49.96	155473	5116	12475	-14	16045	2183	118028	1876	143012	155709	1073
5:30	50.01	158505	5115	12204	-16	16855	2185	120758	1829	146317	158930	1067
5:45	50.01	161637	5118	11829	-15	18533	2171	122773	1831	149823	162240	1045
6:00	50.06	163945	5095	11504	-22	19679	2331	124754	1887	152463	165228	911
6:15	50.00	166460	5095	10988	-31	22000	2170	125515	1802	155503	167539	990
6:30	49.95	170398	5100	10647	170	23419	2099	128238	1869	159581	171542	1065
6:45	49.95	173580	5100	10223	799	23898	2121	130807	1877	162558	174825	1033
7:00	49.95	175073	5100	9898	1930	23921	2112	132009	1835	163245	176805	1049
7:15	49.95	177028	5097	9667	3806	24748	2119	131605	1855	162555	178897	1012
7:30	50.00	177497	5107	9428	6730	24541	2114	129570	1860	161339	179350	1016
7:45	50.05	177237	5100	8985	10721	22221	2108	127488	1927	157531	178550	1071
8:00	50.05	176355	5116	8553	15357	20532	2070	123594	1979	152445	177201	1078
8:15	50.00	175728	5106	8152	20723	18587	2106	121186	1989	148653	177849	1199
8:30	50.05	179113	5110	7756	26419	17911	2089	117681	1989	144938	178955	1255
8:45	50.05	179374	5102	7475	31902	16913	2085	113187	1976	139997	178640	1219
9:00	50.30	180477	5105	7379	37799	15653	2082	110194	1995	135299	180207	1167
9:15	50.10	182801	5097	7781	42527	15106	2094	108199	2031	132493	182835	1249
9:30	50.10	184010	5083	7887	46259	15287	2107	104915	2059	129864	183597	1236
9:45	50.15	183230	5070	7923	48753	14765	2141	102533	2088	126554	183273	1224
10:00	49.95	181501	5069	7675	49254	14265	2196	101257	2070	124572	181786	1190
10:15	50.00	181103	5062	7220	50477	13505	2185	100815	2070	123406	181334	1115
10:30	50.00	180460	5056	6763	52305	13533	2182	99423	2084	121392	181346	1112
10:45	50.10	180395	5057	6489	54602	13049	2149	97169	2190	119304	180705	1180
11:00	50.20	179058	5068	6076	55614	12685	2129	96015	2076	117368	179663	1096
11:15	50.10	177008	5080	5901	54657	12315	2136	95572	2069	116450	177730	1175
11:30	50.00	175497	5068	5758	52734	12044	2173	96526	2136	117005	176439	1157
11:45	49.95	175247	5075	5616	51228	12072	2193	97770	2036	118403	175990	1173
12:00	49.95	173286	5080	5502	50087	11100	2190	97665	2088	117697	173712	1250
12:15	49.90	172619	5075	5385	48679	11385	2227	97806	2094	118555	172651	1097
12:30	49.95	172857	5078	5249	49233	11614	2304	97789	1982	118375	173249	1113
12:45	50.00	172819	5076	5274	49595	11977	2265	97025	1968	117950	173180	1083
13:00	50.15	171810	5078	5249	50471	11027	2218	95250	2863	116090	172156	1050
13:15	50.20	169594	5085	5204	49013	10773	2220	95301	2786	115377	170382	854
13:30	50.25	169309	5069	5185	48455	10758	2211	95304	2840	115669	169822	874
13:45	50.05	170408	5077	5257	48414	11195	2315	96003	2854	116737	171115	929
14:00	50.00	170732	5071	5170	47803	11784	2320	96358	2793	117759	171299	942
14:15	49.95	171970	5066	5114	46478	12485	2344	97977	2811	120378	172275	946
14:30	50.00	174220	5064	4979	49398	12561	2240	97568	2887	119843	174697	915
14:45	50.00	175045	5063	4965	48567	13199	2239	99043	2807	121513	175883	929
15:00	50.00	175684	5065	4853	46981	14089	2326	100137	2793	123850	176244	958
15:15	50.00	175968	5069	5035	45124	14486	2349	101721	2776	125809	176560	903
15:30	50.05	177103	5082	5208	41863	14791	2367	105062	2830	130032	177203	911
15:45	50.00	176423	5078	5253	38084	14865	2429	109321	1913	133086	176943	907
16:00	50.00	177918	5064	5496	33851	15550	2437	114256	1909	138571	178563	900
16:15	50.00	177291	5068	5637	28927	15052	2433	118952	1863	142727	177932	950
16:30	50.00	179197	5082	5556	23683	16009	2467	125148	1804	149958	179749	936
16:45	50.05	179248	5081	5527	18791	17425	2494	128826	1793	154930	179937	902
17:00	50.05	181204	5096	5467	13050	19669	2605	134513	1802	162687	182202	860
17:15	50.00	183686	5093	5519	8546	21063	2583	140227	1788	169621	184819	852
17:30	50.05	187744	5111	5597	4416	24014	2602	145537	1765	177731	189042	804
17:45	50.00	190919	5104	5492	1670	27030	2714	148839	1726	183757	192575	866
18:00	49.96	193904	5119	5544	687	29980	2932	150055	1740	187673	196057	852
18:15	50.01	195048	5133	5572	363	31734	3065	149677	1749	189113	197293	880
18:30	50.06	195605	5133	5677	315	32083	3192	149477	1749	189613	197626	891
18:45	50.06	194215	5131	5880	147	32174	2926	148468	1763	188188	196489	918
19:00	50.06	191611	5123	6172	72	31338	2708	146283	1790	185367	193486	948
19:15	50.01	188518	5130	6384	87	29696	2582	144744	1786	182047	190409	982
19:30	50.01	186067	5126	6419	0	29091	2376	142932	1789	179648	187733	898
19:45	49.96	183387	5121	6451	0	27650	2236	141664	1726	176936	184848	944
20:00	50.01	180800	5111	6430	0	25849	2225	140396	1730	174370	181741	967
20:15	50.01	178066	5125	6357	0	23887	2255	139786	1822	171709	179232	951
20:30	50.06	176554	5124	6368	0	23664	2225	138600	1861	170186	177842	936
20:45	49.99	174435	5124	6268	0	23091	2161	137478	1811	168167	175933	991
21:00	49.99	172819	5095	6187	0	22081	2199	137251	1842	166632	174655	972
21:15	49.99	171309	4956	6120	0	21322	2175	136760	1813	165189	173146	1013
21:30	50.04	170096	4969	6390	0	20900	2192	136069	1801	163706	172321	977
21:45	49.99	168877	4981	6232	0	20739	2202	134775	1794	162645	170723	1008
22:00	50.04	166733	4823	6211	0	20784	2184	132734	1768	160522	168504	973
22:15	49.94	166844	4591	6222	0	20484	2163	133261	1776	160622	168497	1017
22:30	49.94	166015	4595	6213	0	20233	2190	132602	1782	159802	167615	