



National Load Despatch Centre
राष्ट्रीय भार प्रेषण केंद्र
GRID CONTROLLER OF INDIA LIMITED
ग्रिड कंट्रोलर ऑफ इंडिया लिमिटेड

(Government of India Enterprise/ भारत सरकार का उद्यम)
B-9, QUTUB INSTITUTIONAL AREA, KATWARIA SARAI, NEW DELHI -110016
बी-9, कुतुब इन्स्टीट्यूशनल एरिया, कटवारिया सराये, न्यू दिल्ली-110016

Ref: GRID-INDIA/NLDC/SO/Daily PSP Report

दिनांक: 29.01.2026

To,

- कार्यकारी निदेशक, पू.क्षे.भा.प्रे.के., 14, गोल्फ क्लब रोड, कोलकाता - 700033
Executive Director, ERLDC, 14 Golf Club Road, Tollygunge, Kolkata, 700033
- कार्यकारी निदेशक, ऊ.क्षे.भा.प्रे.के., 18/ए, शाहीद जीत सिंह सनसनवाल मार्ग, नई दिल्ली - 110016
Executive Director, NRLDC, 18-A, Shaheed Jeet Singh Marg, Katwaria Sarai, New Delhi - 110016
- कार्यकारी निदेशक, प.क्षे.भा.प्रे.के., एफ3, एम आई डी सी क्षेत्र, अंधेरी, मुंबई -400093
Executive Director, WRLDC, F-3, M.I.D.C. Area, Marol, Andheri (East), Mumbai-400093
- कार्यकारी निदेशक, ऊ.पू.क्षे.भा.प्रे.के., डोंगतेह, लोअर नोंग्रह, लापालंग, शिलोंग - 793006
Executive Director, NERLDC, Dongteih, Lower Nongrah, Lapalang, Shillong - 793006, Meghalaya
- कार्यकारी निदेशक, द.क्षे.भा.प्रे.के., 29, रेस कोर्स क्रॉस रोड, बंगलुरु -560009
Executive Director, SRLDC, 29, Race Course Cross Road, Bangalore-560009

Sub: Daily PSP Report for the date 28.01.2026.

महोदय/Sir,

आईईजीसी-2023 की धारा स.-38(1) के प्रावधान के अनुसार, दिनांक 28-जनवरी-2026 की अखिल भारतीय प्रणाली की दैनिक ग्रिड निष्पादन रिपोर्ट रांभांप्रेके की वेबसाइट पर उपलब्ध है।

As per article 38(1) of the Indian Electricity Grid Code, the daily report pertaining power supply position of All India Power System for the date 28.01.2026, is available at the NLDC website.

धन्यवाद,
Thanks

Report for previous day

Date of Reporting: 29-Jan-2026

A. Power Supply Position at All India and Regional level

	NR	WR	SR	ER	NER	TOTAL
Demand Met during Evening Peak hrs(MW) (at 19:00 hrs; from RLDCs)	62345	65430	51097	24421	2829	206122
Peak Shortage (MW)	0	0	0	0	0	0
Energy Met (MU)	1234	1505	1271	497	52	4558
Hydro Gen (MU)	110	36	89	25	14	274
Wind Gen (MU)	20	136	74	-	-	230
Solar Gen (MU)*	201.13	173.30	155.05	3.05	1.07	534
Energy Shortage (MU)	0.00	0.00	0.00	0.00	0.00	0.00
Maximum Demand Met During the Day (MW) (From NLDC SCADA)	64504	76126	63510	25124	2984	230023
Time Of Maximum Demand Met	09:57	09:58	09:25	18:08	17:54	09:43

B. Frequency Profile (%)

Region	FVI	< 49.7	49.7 - 49.8	49.8 - 49.9	< 49.9	49.9 - 50.05	> 50.05
All India	0.044	0.27	0.52	2.34	3.12	70.34	26.54

C. Power Supply Position in States

Region	States	Max.Demand Met during the day (MW)	Shortage during maximum Demand (MW)	Energy Met (MU)	Drawal Schedule (MU)	OD(+)/UD(-) (MU)	Max OD (MW)	Energy Shortage (MU)
NR	Punjab	8740	0	163.2	79.9	-1.4	453	0.00
	Haryana	8211	0	162.3	117.4	-0.5	260	0.00
	Rajasthan	17837	0	319.0	112.5	-6.5	1398	0.00
	Delhi	5440	0	93.0	85.3	-1.1	555	0.00
	UP	20064	0	342.4	73.2	1.6	404	0.00
	Uttarakhand	2459	0	44.7	36.5	-0.3	216	0.00
	HP	1977	0	37.1	29.6	-0.9	140	0.00
	J&K(UT) & Ladakh(UT)	3130	0	63.3	60.7	-2.5	198	0.00
	Chandigarh	297	0	5.0	4.9	0.0	22	0.00
	Railways_NR ISTS	191	0	4.0	3.8	0.2	24	0.00
WR	Chhattisgarh	5832	0	116.6	65.9	0.1	289	0.00
	Gujarat	23350	0	425.6	167.7	-12.6	589	0.00
	MP	15269	0	275.6	157.6	0.0	686	0.00
	Maharashtra	29337	0	603.9	179.5	-10.8	1430	0.00
	Goa	734	0	14.9	12.6	2.1	41	0.00
	DNHDDPDCL	1367	0	31.2	31.1	0.1	43	0.00
	AMNSIL	938	0	21.2	13.3	0.8	298	0.00
	BALCO	601	0	14.3	14.5	-0.2	33	0.00
	RIL JAMNAGAR	110	0	1.4	1.5	-0.1	0	0.00
	Andhra Pradesh	12500	0	233.3	72.8	-1.1	495	0.00
SR	Telangana	15887	0	281.7	146.1	-0.4	851	0.00
	Karnataka	17681	0	322.1	118.3	0.8	1131	0.00
	Kerala	4797	0	91.1	72.0	2.0	399	0.00
	Tamil Nadu	17129	0	334.5	188.2	-2.4	656	0.00
	Puducherry	408	0	8.7	8.4	-0.2	16	0.00
	Bihar	5862	0	105.5	85.5	-0.5	219	0.00
ER	DVC	3184	0	69.0	-13.4	0.5	407	0.00
	Jharkhand	2120	0	38.8	28.3	-1.3	247	0.00
	Odisha	5354	0	110.7	20.1	-0.9	322	0.00
	West Bengal	8282	0	170.4	62.5	-2.7	235	0.00
	Sikkim	121	0	2.1	2.0	0.1	25	0.00
	Railways_ER ISTS	28	0	0.2	0.1	0.1	5	0.00
NER	Arunachal Pradesh	192	0	3.2	3.2	-0.1	24	0.00
	Assam	1651	0	29.2	24.9	0.1	115	0.00
	Manipur	258	0	4.0	4.1	-0.1	17	0.00
	Meghalaya	386	0	6.4	5.7	-0.1	34	0.00
	Mizoram	153	0	2.5	2.2	-0.1	20	0.00
	Nagaland	167	0	2.6	2.6	-0.1	10	0.00
	Tripura	233	0	4.0	6.5	-0.1	46	0.00

D. Transnational Exchanges (MU) - Import(+ve)/Export(-ve)

	Bhutan	Nepal	Bangladesh	Godda -> Bangladesh
Actual (MU)	-17.9	-8.5	-24.6	-17.5
Day Peak (MW)	-1000.1	-663.7	-1054.9	-775.0

E. Import/Export by Regions (in MU) - Import(+ve)/Export(-ve); OD(+)/UD(-)

	NR	WR	SR	ER	NER	TOTAL
Schedule(MU)	201.6	-260.3	166.3	-119.8	12.3	0.0
Actual(MU)	184.7	-255.7	154.8	-109.3	10.4	-15.1
O/D/U/D(MU)	-16.9	4.6	-11.5	10.6	-1.9	-15.1

F. Generation Outage(MW)

	NR	WR	SR	ER	NER	TOTAL	% Share
Central Sector	5480	12605	3008	2994	469	24555	44
State Sector	10504	11198	5050	4183	205	31139	56
Total	15984	23803	8058	7176	674	55694	100

G. Sourcewise generation (Gross) (MU)

	NR	WR	SR	ER	NER	All India	% Share
Coal	693	1436	720	683	12	3544	71
Lignite	28	22	55	0	0	105	2
Hydro	110	36	89	25	14	274	5
Nuclear	53	60	71	0	0	184	4
Gas, Naptha & Diesel	10	19	10	0	20	59	1
RES (Wind, Solar, Biomass & Others)	246	313	259	7	1	826	17
Total	1139	1888	1203	714	48	4991	100

Share of RES in total generation (%)	21.62	16.60	21.51	0.92	2.25	16.55
Share of Non-fossil fuel (Hydro,Nuclear and RES) in total generation(%)	35.91	21.72	34.77	4.37	31.66	25.72

H. All India Demand Diversity Factor

Based on Regional Max Demands	1.009
Based on State Max Demands	1.053

I. All India Peak Demand and shortage at Solar and Non-Solar Hour

	Max Demand Met(MW)	Time	Shortage(MW)
Solar hr	230023	9:43	0
Non-Solar hr	209636	18:44	0

Diversity factor = Sum of regional or state maximum demands / All India maximum demand

**Note: All generation MU figures are gross

***Godda (Jharkhand) -> Bangladesh power exchange is through the radial connection (isolated from Indian Grid)

Solar Hours -> 06:00 to 18:00hrs and rest are Non-Solar Hours

*Source: RLDCs for solar connected to ISTS; SLDCs for embedded solar. Limited visibility of embedded solar data.

Executive Director-NLDC

INTER-REGIONAL EXCHANGES

Import=(+ve)/Export =(-ve) for NET (MU)
Date of Reporting: 29-Jan-2026

Sl No	Voltage Level	Line Details	No. of Circuit	Max Import (MW)	Max Export (MW)	Import (MU)	Export (MU)	NET (MU)
Import/Export of ER (With NR)								
1	HVDC	ALIPURDUAR-AGRA	2	0	0	0.0	0.0	0.0
2	HVDC	PUSAULI B/B	-	0	47	0.0	2.4	-2.4
3	765 kV	GAYA-VARANASI	2	438	1415	0.0	12.1	-12.1
4	765 kV	SASARAM-FAITEHPUR	1	137	679	0.0	5.8	-5.8
5	765 kV	GAYA-BALIA	1	0	912	0.0	9.6	-9.6
6	400 kV	PUSAULI-VARANASI	1	5	114	0.0	1.2	-1.2
7	400 kV	PUSAULI-ALLAHABAD	1	23	99	0.0	1.0	-1.0
8	400 kV	MUZAFFARPUR-GORAKHPUR	2	537	638	0.0	1.0	-1.0
9	400 kV	PATNA-BALIA	2	163	1032	0.0	8.9	-8.9
10	400 kV	NAUBATPUR-BALIA	2	231	218	0.0	3.1	-3.1
11	400 kV	BIHARSHARIFF-BALIA	2	525	224	4.4	0.0	4.4
12	400 kV	MOTIHARI-GORAKHPUR	2	89	586	0.0	5.6	-5.6
13	400 kV	BIHARSARIFF-SAHUPURI	2	238	469	0.0	4.0	-4.0
14	220 kV	SAHUPURI-KARAMNANA	1	23	13	0.0	1.7	-1.7
15	132 kV	NAGAR UNTARI-RIHAND	1	0	0	0.0	0.0	0.0
16	132 kV	GARWAH-RIHAND	1	0	0	0.7	0.0	0.7
17	132 kV	KARMANASA-CHANDAUJI	1	0	0	0.0	0.0	0.0
ER-NR						5.1	56.4	-51.3
Import/Export of ER (With WR)								
1	765 kV	JHARSUGUDA-DHARAMJAIGARH	4	190	1404	0.0	15.2	-15.2
2	765 kV	NEW RANCHI-DHARAMJAIGARH	2	1149	496	12.2	0.0	12.2
3	765 kV	JHARSUGUDA-DURG	2	0	1455	0.0	23.5	-23.5
4	400 kV	JHARSUGUDA-RAIGARH	4	119	381	0.0	3.1	-3.1
5	400 kV	RANCHI-SIPAT	2	174	300	0.6	0.0	0.6
6	400 kV	JEYPORE-JAGDALPUR	2	288	174	2.3	0.0	2.3
7	220 kV	BUDHIPADAR-RAIGARH	1	0	119	0.0	1.2	-1.2
8	220 kV	BUDHIPADAR-KORBA	2	37	169	0.0	1.5	-1.5
ER-WR						15.1	44.4	-29.3
Import/Export of ER (With SR)								
1	HVDC	JEYPORE-GAZUWAKA B/B	2	0	524	0.0	12.4	-12.4
2	HVDC	TALCHER-KOLAR BIPOLE	2	0	1445	0.0	39.7	-39.7
3	765 kV	ANGUL-SRIKAKULAM	2	0	1806	0.0	26.3	-26.3
4	400 kV	TALCHER-I/C	2	226	99	4.1	0.0	4.1
5	220 kV	BALIMELA-UPPER-SILERRU	1	1	0	0.0	0.0	0.0
ER-SR						0.0	78.4	-78.4
Import/Export of ER (With NER)								
1	400 kV	BINAGURI-BONGAIGAOIN	2	171	190	0.5	1.6	-1.1
2	400 kV	ALIPURDUAR-BONGAIGAOIN	2	317	100	2.4	0.0	2.4
3	220 kV	ALIPURDUAR-SALAKATI	2	47	37	0.1	0.0	0.1
ER-NER						3.0	1.6	1.4
Import/Export of NER (With NR)								
1	HVDC	BISWANATH CHARIALI-AGRA	2	562	0	13.8	0.0	13.8
NER-NR						13.8	0.0	13.8
Import/Export of WR (With NR)								
1	HVDC	CHAMPA-KURUKSHETRA	2	0	3032	0.0	27.9	-27.9
2	HVDC	VINDHYACHAL B/B	-	0	519	0.0	9.9	-9.9
3	HVDC	MUNDRA-MOHINDERGARH	2	0	1926	0.0	33.3	-33.3
4	765 kV	GWALIOR-AGRA	2	395	2385	0.3	24.8	-24.5
5	765 kV	GWALIOR-PHAGI	2	880	2373	3.6	25.0	-21.4
6	765 kV	JABALPUR-ORAI	2	261	1396	0.0	26.5	-26.5
7	765 kV	GWALIOR-ORAI	1	907	0	11.9	0.0	11.9
8	765 kV	SATNA-ORAI	1	0	1130	0.0	17.0	-17.0
9	765 kV	BANASKANTHA-CHITTOORGARH	2	1584	901	8.6	2.5	6.1
10	765 kV	VINDHYACHAL VARANASI	2	48	2324	0.0	28.3	-28.3
11	400 kV	ZERDA-KANKROLI	1	271	0	2.5	0.0	2.5
12	400 kV	ZERDA BHINMAL	1	187	1	1.7	0.0	1.7
13	400 kV	VINDHYACHAL -RIHAND	1	485	0	0.0	9.6	-9.6
14	400 kV	RAPP-SHUJALPUR	2	930	415	6.2	1.5	4.7
15	400 kV	NEEMUCH-Chittorgarh	2	836	654	4.7	3.1	1.6
16	220 kV	BHANPURA-RANPUR	1	0	121	0.0	2.0	-2.0
17	220 kV	BHANPURA-MORAK	1	0	30	0.0	1.6	-1.6
18	220 kV	MEHGAON-AURAIYA	1	54	29	0.4	0.2	0.2
19	220 kV	MALANPUR-AURAIYA	1	40	36	0.2	0.1	0.1
20	132 kV	RAJGHAT-LALITPUR	2	0	0	0.0	0.0	0.0
WR-NR						40.0	213.2	-173.2
Import/Export of WR (With SR)								
1	HVDC	BHADRAWATI B/B	-	0	1013	0.0	21.4	-21.4
2	HVDC	RAIGARH-PUGALUR	2	0	4019	0.0	83.4	-83.4
3	765 kV	SOLAPUR-RAICHUR	2	2316	1755	14.6	7.6	7.0
4	765 kV	WARDHA-NIZAMABAD	2	931	2968	2.1	31.9	-29.8
5	765 kV	WARORA-WARANGAL(NEW)	2	642	3173	1.1	35.4	-34.4
6	400 kV	KOLHAPUR-KUDGI	2	2012	0	28.7	0.0	28.7
7	220 kV	KOLHAPUR-CHIKODI	2	0	0	0.0	0.0	0.0
8	220 kV	PONDA-AMBEWADI	1	0	0	0.0	0.0	0.0
9	220 kV	XELDEM-AMBEWADI	1	0	124	2.2	0.0	2.2
WR-SR						48.7	179.7	-131.0

INTERNATIONAL EXCHANGES

					Import(+ve)/Export(-ve)		
State	Region	Line Name	Max (MW)	Min (MW)	Avg (MW)	Energy Exchange (MU)	
BHUTAN	ER	400kV MANGDECHHU-ALIPURDUAR 1,2&3 I.e. ALIPURDUAR RECEIPT (from MANGDECHU HEP 4*180MW)	-292	66	-192	-4.61	
	ER	400kV TALA-BINAGURI 1,2,4 (& 400kV MALBASE - BINAGURI) I.e. BINAGURI RECEIPT (from TALA HEP 6*170MW)	-339	157	-200	-4.80	
	ER	220kV CHUKHA-BIRPARA 1&2 (& 220kV MALBASE - BIRPARA) I.e. BIRPARA RECEIPT (from CHUKHA HEP 4*84MW)	-307	-203	-268	-6.43	
	NER	132kV GELEPHU-SALAKATI	-73	-39	-61	-1.46	
	NER	132kV MOTANGA-RANGIA	-46	-5	-25	-0.59	
NEPAL	NR	NEPAL IMPORT (FROM UP)	-64	0	-27	-0.64	
	NR	132kV MAHENDRANAGAR-TANAKPUR(NHPC)	-64	0	-31	-0.74	
	ER	NEPAL IMPORT (FROM BIHAR)	-134	-91	-120	-2.89	
	ER	400kV DHALKEBAR-MUZAFFARPUR 1&2	-390	-58	-176	-4.22	
BANGLADESH	ER	BHERAMARA B/B HVDC (B'DESH)	-913	-908	-910	-21.85	
	ER (Isolated from Indian Grid)	400kV GODDA_TPS-RAHANPUR (B'DESH) D/C	-775	-509	-730	-17.51	
	NER	132kV COMILLA-SURAJMANI NAGAR 1&2	-141	0	-116	-2.78	

CROSS BORDER EXCHANGE SCHEDULE

Date of Reporting: 29-Jan-2026

Export From India (in MU)

Country	GNA (ISGS/PPA)	T-GNA							TOTAL
		BILATERAL TOTAL	COLLECTIVE						
			IDAM			RTM			
			IEX	PXIL	HPX	IEX	PXIL	HPX	
Bhutan	0.00	0.00	20.24	0.00	0.00	0.00	0.00	0.00	20.24
Nepal	3.07	1.75	1.39	0.00	0.00	1.99	0.00	0.00	8.20
Bangladesh	22.90	0.00	0.00	0.00	0.00	0.00	0.00	0.00	22.90
Myanmar	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total Export	25.97	1.75	21.63	0.00	0.00	1.99	0.00	0.00	51.34

Import by India(in MU)

Country	GNA (ISGA/PPA)	T-GNA							TOTAL
		BILATERAL TOTAL	COLLECTIVE						
			IDAM			RTM			
			IEX	PXIL	HPX	IEX	PXIL	HPX	
Bhutan	0.39	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.39
Nepal	0.00	0.00	0.00	0.00	0.00	0.26	0.00	0.00	0.26
Bangladesh	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Myanmar	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total Import	0.39	0.00	0.00	0.00	0.00	0.26	0.00	0.00	0.65

Net from India(in MU)

-ve : Export / +ve : Import

Country	GNA (ISGS/PPA)	T-GNA							TOTAL
		BILATERAL TOTAL	COLLECTIVE						
			IDAM			RTM			
			IEX	PXIL	HPX	IEX	PXIL	HPX	
Bhutan	0.39	0.00	-20.24	0.00	0.00	0.00	0.00	0.00	-19.85
Nepal	-3.07	-1.75	-1.39	0.00	0.00	-1.73	0.00	0.00	-7.94
Bangladesh	-22.90	0.00	0.00	0.00	0.00	0.00	0.00	0.00	-22.90
Myanmar	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total Net	-25.58	-1.75	-21.63	0.00	0.00	-1.73	0.00	0.00	-50.69

15 Min (INSTANTANEOUS) ALL INDIA GRID FREQUENCY, GENERATION & DEMAND MET (SCADA DATA)												
TIME	FREQUENCY (Hz)	DEMAND MET (MW)	NUCLEAR (MW)	WIND (MW)	SOLAR (MW)	HYDRO** (MW)	GAS (MW)	THERMAL (MW)	OTHERS* (MW)	NET DEMAND (MW)	TOTAL GENERATION (MW)	NET TRANSNATIONAL EXCHANGE (MW)
		(A)	(B)	(C)	(D)	(E)	(F)	(G)	(H)	(I=A-(C+D))	(J=B+C+D+E+F+G+H)	(K)
0:00	50.06	155042	6718	12913	0	6791	2383	127971	3770	142129	160546	-2065
0:15	49.98	154547	6736	12766	0	7082	2373	127704	3716	141781	160377	-2182
0:30	50.00	153535	6726	12623	0	7130	2372	126637	3731	140912	159219	-2151
0:45	49.96	152868	6742	12544	0	7222	2379	125897	3758	140324	158542	-2160
1:00	49.96	152521	6752	12570	0	7229	2369	125585	3753	139951	158258	-2161
1:15	49.98	151932	6754	12512	0	6789	2366	125555	3721	139420	157697	-2149
1:30	50.03	151449	6752	12685	0	6884	2374	124961	3739	138764	157395	-2137
1:45	50.01	151213	6768	12712	0	6738	2375	124808	3762	138501	157163	-2119
2:00	50.04	149933	6803	12859	0	6794	2369	123469	3686	137074	155980	-2130
2:15	49.97	149890	6827	12840	0	6428	2410	123696	3723	137050	155924	-2116
2:30	50.00	149743	6813	12713	0	6628	2399	123719	3696	137030	155968	-2132
2:45	50.00	150183	6835	12730	0	6473	2399	123894	3788	137453	156119	-2105
3:00	50.04	149468	6852	12440	0	6424	2371	123650	3780	137028	155517	-2079
3:15	50.02	149436	6853	12400	0	6198	2382	123732	3786	137036	155351	-2069
3:30	50.05	149452	6881	12466	0	6335	2385	123617	3816	136986	155500	-2034
3:45	50.05	150017	6889	12371	0	6554	2372	123735	3917	137646	155838	-2019
4:00	50.13	150068	6900	12302	0	6532	2361	123902	3871	137766	155868	-2039
4:15	50.01	152455	6896	12167	0	6860	2374	126008	3878	140288	158183	-2035
4:30	50.02	153829	6901	11969	0	6899	2372	127671	3898	141860	159710	-2055
4:45	49.97	156093	6896	11842	0	6890	2395	130174	3814	144251	162011	-2036
5:00	50.10	157971	6898	11608	368	6956	2380	132174	3853	145995	164237	-2055
5:15	50.08	161986	6855	11593	379	6937	2373	136425	3762	150014	168324	-2023
5:30	50.07	165928	6871	11447	384	7740	2371	139543	3877	154097	172233	-2029
5:45	50.01	170433	6885	11327	383	8467	2372	143515	3837	158723	176786	-2090
6:00	50.08	174571	6887	11324	379	9935	2383	146285	3871	162868	181064	-2101
6:15	50.00	180475	6864	11112	389	10529	2371	152028	3842	168974	187135	-2186
6:30	50.02	187496	6834	10773	383	12047	2366	157999	3876	176340	194278	-2236
6:45	50.08	194917	6830	10575	380	14513	2375	162720	3890	183962	201283	-1788
7:00	50.10	199808	6835	10426	695	16067	2387	165025	3885	188687	205320	-1209
7:15	50.04	205573	6811	10259	1348	18945	2399	167748	3821	192966	211341	-1210
7:30	50.00	210103	6809	10179	2577	20257	2390	169084	3897	197347	215193	-1132
7:45	50.04	213350	6796	9977	4921	20406	2410	169840	3865	198452	218215	-1123
8:00	50.08	214475	6780	9677	8740	20251	2395	167410	3771	196058	219024	-1171
8:15	50.07	218377	6823	9232	14084	20554	2407	166281	3787	195061	223168	-1174
8:30	50.13	220578	6865	8721	20661	19976	2386	162808	3675	191196	225092	-1188
8:45	50.16	222578	6896	8003	27633	18772	2396	159640	3768	186942	227108	-1399
9:00	50.19	223696	6927	7224	35143	14973	2379	157968	3790	181329	228404	-1896
9:15	50.04	227470	6945	6295	41854	14132	2389	157363	3727	179321	232705	-2213
9:30	49.99	229296	6968	5439	47668	12903	2391	154699	3695	176189	233763	-2280
9:45	50.02	229799	6951	5039	53270	12195	2378	150859	3720	171490	234412	-2299
10:00	50.07	229166	6960	5019	57855	11195	2384	146379	3642	166292	233434	-2224
10:15	50.05	228193	6994	5108	61782	9279	2381	142865	3684	161303	232093	-2258
10:30	50.02	227201	6979	5381	65957	8381	2376	139081	3754	155863	231909	-2385
10:45	49.98	225832	7027	5496	68688	7808	2396	135299	3672	151648	230386	-2443
11:00	50.03	223124	6973	5707	70380	7190	2364	131201	3658	147037	227473	-2526
11:15	50.01	220945	6999	5874	71308	6903	2360	128120	3640	143763	225204	-2465
11:30	50.05	219988	7005	6104	72466	6445	2386	126702	3602	141418	224710	-2512
11:45	50.03	218888	6996	6245	73079	6459	2356	124809	3579	139564	223523	-2514
12:00	50.10	216645	7014	6205	73314	6350	2361	122224	3574	137126	221042	-2556
12:15	50.00	215163	7014	6392	72879	6287	2354	121061	3446	135892	219433	-2538
12:30	49.99	213214	7017	6348	72898	6132	2355	119113	3615	133968	217478	-2520
12:45	49.98	211531	7017	6204	72487	5962	2351	118374	3668	132840	216063	-2480
13:00	50.08	207693	7031	6002	71408	5879	2352	116273	3598	130283	212543	-2456
13:15	50.00	203233	7022	5857	68850	5472	2332	114712	3628	128526	207873	-2490
13:30	50.01	202025	7019	5729	68736	5463	2331	113919	3552	127560	206749	-2500
13:45	49.99	203214	7024	5550	69149	5620	2328	114652	3518	128515	207841	-2471
14:00	50.03	203814	7006	5676	67899	5978	2334	116075	3480	130239	208448	-2512
14:15	49.87	204536	6998	5521	66159	5945	2335	118595	3479	132856	209032	-2503
14:30	49.88	205788	6982	5439	66169	6597	2337	119358	3572	134180	210454	-2459
14:45	49.66	206246	6984	5500	64338	6786	2355	121079	3511	136408	210553	-2502
15:00	49.91	207351	6966	5464	64172	6747	2336	122489	3545	137715	211719	-2558
15:15	50.06	207548	7011	5388	62860	6553	2340	124440	3546	139300	212138	-2554
15:30	50.07	208818	7019	5391	59920	6960	2336	128614	3448	143507	213688	-2545
15:45	50.05	209212	7001	5357	55854	7311	2356	132615	3499	148001	213993	-2527
16:00	50.04	209976	6962	5327	51427	7923	2346	137337	3458	153222	214780	-2543
16:15	49.98	207375	6956	5483	46352	8589	2330	139281	3490	155540	212481	-2568
16:30	50.08	208820	6911	5454	40839	10606	2348	144044	3520	162527	213722	-2513
16:45	50.05	207736	6896	5483	34306	12132	2350	147806	3537	167947	212510	-2358
17:00	50.11	208417	6846	5715	28547	13551	2315	152701	3533	174155	213208	-2383
17:15	50.08	206725	6797	5967	20675	16058	2350	156414	3595	180083	211856	-2392
17:30	50.11	206991	6777	5957	13573	19163	2384	160683	3548	187461	212085	-2293
17:45	49.95	207576	6738	6150	12028	20402	2449	165369	3519	189398	216655	-1910
18:00	50.11	207350	6714	6351	9670	21278	2428	167358	3517	191329	217316	-1363
18:15	49.94	206054	6710	6627	7996	21196	2442	167951	3587	191431	216509	-1324
18:30	50.01	207393	6710	6719	3738	22635	2489	169075	3538	196936	214904	-1291
18:45	50.01	209473	6692	7213	646	23100	2481	170270	3577	201614	213979	-1291
19:00	50.03	208462	6696	7724	654	22606	2474	169143	3572	200084	212869	-1314
19:15	49.94	206718	6701	8313	634	19623	2488	169727	3614	197771	211100	-1286
19:30	50.05	203882	6701	8841	0	18190	2435	168030	3609	195041	207806	-1291
19:45	50.03	202285	6710	9331	0	17205	2398	167102	3625	192954	206371	-1332
20:00	50.09	199075	6688	9691	0	16127	2370	164944	3678	189384	203498	-1761
20:15	49.95	196255	6727	10107	0	14489	2379	163875	3729	186148	201306	-2164
20:30	50.00	193721	6732	7107	0	13642	2354	161966	3754	186614	195555	-2183
20:45	50.06	191342	6736	10878	0	12153	2349	160515	3787	180464	196418	-2172
21:00	50.04	187974	6775	11362	0	11185	2363	157567	3789	176612	193041	-2104
21:15	49.96	185548	6809	11836	0	10753	2368	155157	3783	173712	190706	-2161
21:30	50.01	182665	6805	12165	0	9925	2363	152942	3755	170500	187955	-2136
21:45	50.06	179256	6803	12517	0	8883	2374	150295	3765	166739	184637	-2078
22:00	50.13	175597	6834	12898	0	8441	2369	146502	3700	162699	180744	-2038
22:15	50.00	174920	6827	13100	0	8223	2366	145782	3707	161820	180005	-2020
22:30	50.07	173005	6813	13284	0	8060	2367	144144	3770</			