



National Load Despatch Centre
राष्ट्रीय भार प्रेषण केंद्र
GRID CONTROLLER OF INDIA LIMITED
ग्रिड कंट्रोलर ऑफ इंडिया लिमिटेड

(Government of India Enterprise/ भारत सरकार का उद्यम)
B-9, QUTUB INSTITUTIONAL AREA, KATWARIA SARAI, NEW DELHI -110016
बी-9, कुतुब इन्स्टीट्यूशनल एरिया, कटवारिया सराये, न्यू दिल्ली-110016

Ref: GRID-INDIA/NLDC/SO/Daily PSP Report

दिनांक: 19.12.2024

To,

- कार्यकारी निदेशक, पू.क्षे.भा.प्रे.के., 14, गोल्फ क्लब रोड, कोलकाता - 700033
Executive Director, ERLDC, 14 Golf Club Road, Tollygunge, Kolkata, 700033
- कार्यकारी निदेशक, ऊ.क्षे.भा.प्रे.के., 18/ए, शाहीद जीत सिंह सनसनवाल मार्ग, नई दिल्ली - 110016
Executive Director, NRLDC, 18-A, Shaheed Jeet Singh Marg, Katwaria Sarai, New Delhi - 110016
- कार्यकारी निदेशक, प.क्षे.भा.प्रे.के., एफ3, एम आई डी सी क्षेत्र, अंधेरी, मुंबई - 400093
Executive Director, WRLDC, F-3, M.I.D.C. Area, Marol, Andheri (East), Mumbai-400093
- कार्यकारी निदेशक, ऊ.पू.क्षे.भा.प्रे.के., डोंगतेह, लोअर नोंग्रह, लापलंग, शिलोंग - 793006
Executive Director, NERLDC, Dongteih, Lower Nongrah, Lapalang, Shillong - 793006, Meghalaya
- कार्यकारी निदेशक, द.क्षे.भा.प्रे.के., 29, रेस कोर्स क्रॉस रोड, बंगलुरु - 560009
Executive Director, SRLDC, 29, Race Course Cross Road, Bangalore-560009

Sub: Daily PSP Report for the date 18.12.2024.

महोदय/Dear Sir,

आईईजीसी-2023 की धारा स.-38(1) के प्रावधान के अनुसार, दिनांक 18-दिसंबर-2024 की अखिल भारतीय प्रणाली की दैनिक ग्रिड निष्पादन रिपोर्ट रांभांप्रेके की वेबसाइट पर उपलब्ध है।

As per article 38(1) of the Indian Electricity Grid Code, the daily report pertaining power supply position of All India Power System for the date 18.12.2024, is available at the NLDC website.

धन्यवाद,
Thanks

Report for previous day Date of Reporting: 19-Dec-2024

A. Power Supply Position at All India and Regional level

	NR	WR	SR	ER	NER	TOTAL
Demand Met during Evening Peak hrs(MW) (at 19:00 hrs; from RLDCs)	59401	63825	43436	20989	2675	190326
Peak Shortage (MW)	60	0	0	426	0	486
Energy Met (MU)	1268	1507	1097	427	49	4347
Hydro Gen (MU)	117	60	96	19	14	305
Wind Gen (MU)	26	154	14	-	-	194
Solar Gen (MU)*	148.55	94.66	99.28	3.10	0.90	346
Energy Shortage (MU)	2.29	0.00	0.00	1.42	0.00	3.71
Maximum Demand Met During the Day (MW) (From NLDC SCADA)	68373	75288	54292	21346	2791	217753
Time Of Maximum Demand Met	10:34	10:04	09:37	17:41	17:21	10:18

B. Frequency Profile (%)

Region	FVI	< 49.7	49.7 - 49.8	49.8 - 49.9	< 49.9	49.9 - 50.05	> 50.05
All India	0.044	0.28	1.16	5.03	6.47	79.97	13.56

C. Power Supply Position in States

Region	States	Max.Demand Met during the day (MW)	Shortage during maximum Demand (MW)	Energy Met (MU)	Drawal Schedule (MU)	OD(+)/UD(-) (MU)	Max OD (MW)	Energy Shortage (MU)
NR	Punjab	9531	0	166.4	66.5	0.6	520	0.00
	Haryana	9248	0	169.2	111.2	-1.6	984	0.00
	Rajasthan	18371	0	338.7	109.6	-1.6	494	0.00
	Delhi	4701	0	81.6	79.9	-0.4	413	0.00
	UP	19247	0	353.3	107.1	-0.8	434	1.19
	Uttarakhand	2488	0	45.8	34.8	0.7	177	0.00
	HP	2206	0	40.6	33.8	-2.5	178	0.00
	J&K(UT) & Ladakh(UT)	3142	60	64.7	58.4	1.2	977	1.10
	Chandigarh	262	0	4.3	4.4	-0.1	42	0.00
WR	Railways_NR ISTS	206	0	4.0	3.7	0.3	39	0.00
	Chhattisgarh	4830	0	100.0	40.4	0.6	295	0.00
	Gujarat	21425	0	405.6	194.2	-52.6	847	0.00
	MP	18759	0	346.6	209.1	-1.6	573	0.00
	Maharashtra	28305	0	578.8	210.9	3.5	829	0.00
	Goa	669	0	13.7	13.2	0.2	58	0.00
	DNHDDPDCL	1324	0	30.3	30.2	0.1	72	0.00
	AMNSIL	748	0	17.1	7.9	0.0	255	0.00
	BALCO	530	0	12.6	12.7	-0.1	11	0.00
SR	RIL JAMNAGAR	101	0	2.2	2.2	0.0	0	0.00
	Andhra Pradesh	10048	0	192.2	55.5	0.6	569	0.00
	Telangana	13778	0	256.4	149.1	-0.1	1050	0.00
	Karnataka	13845	0	250.8	68.3	0.8	862	0.00
	Kerala	4291	0	82.0	63.3	1.2	333	0.00
	Tamil Nadu	15334	0	306.5	185.1	1.2	787	0.00
	Puducherry	404	0	8.7	8.5	-0.2	39	0.00
	Bihar	4804	0	89.3	79.6	-0.2	324	1.28
	DVC	3329	0	68.6	-42.5	0.1	690	0.00
ER	Jharkhand	2090	144	38.7	28.1	-0.8	189	0.14
	Odisha	4559	0	86.2	15.6	0.0	467	0.00
	West Bengal	7116	0	142.3	9.7	-1.3	234	0.00
	Sikkim	120	0	2.0	1.8	0.1	43	0.00
	Railways_ER ISTS	16	0	0.2	0.2	0.0	8	0.00
	Arunachal Pradesh	174	0	3.0	2.8	0.1	52	0.00
NER	Assam	1538	0	26.9	19.4	0.6	83	0.00
	Manipur	233	0	3.6	3.7	-0.1	41	0.00
	Meghalaya	369	0	6.5	5.6	-0.1	56	0.00
	Mizoram	146	0	2.1	1.7	-0.2	8	0.00
	Nagaland	154	0	2.5	2.4	0.0	25	0.00
	Tripura	228	0	4.2	3.4	0.1	31	0.00

D. Transnational Exchanges (MU) - Import(+ve)/Export(-ve)

	Bhutan	Nepal	Bangladesh	Godda -> Bangladesh
Actual (MU)	-6.3	2.5	-21.7	-12.3
Day Peak (MW)	-497.0	292.0	-984.0	-769.0

E. Import/Export by Regions (in MU) - Import(+ve)/Export(-ve); OD(+)/UD(-)

	NR	WR	SR	ER	NER	TOTAL
Schedule(MU)	224.3	-247.2	183.4	-164.9	4.4	0.0
Actual(MU)	214.9	-263.5	198.4	-162.5	3.4	-9.2
O/D/U/D(MU)	-9.4	-16.2	15.0	2.4	-1.0	-9.2

F. Generation Outage(MW)

	NR	WR	SR	ER	NER	TOTAL	% Share
Central Sector	4895	7974	8138	5523	518	27048	47
State Sector	6893	13729	7164	2169	191	30145	53
Total	11788	21952	15302	7692	709	57193	100

G. Sourcewise generation (Gross) (MU)

	NR	WR	SR	ER	NER	All India	% Share
Coal	757	1519	622	649	10	3557	19
Lignite	28	8	37	0	0	72	0
Hydro	117	60	96	19	14	305	77
Nuclear	32	67	70	0	0	169	1
Gas, Naptha & Diesel	12	33	5	0	25	75	0
RES (Wind, Solar, Biomass & Others)	201	252	139	6	1	599	3
Total	1146	1940	970	673	50	4778	100

Share of RES in total generation (%)	17.55	1.55	14.35	0.82	1.81	3.14
Share of Non-fossil fuel (Hydro,Nuclear and RES) in total generation(%)	30.49	19.53	31.52	3.58	29.20	22.45

H. All India Demand Diversity Factor

Based on Regional Max Demands	1.019
Based on State Max Demands	1.050

I. All India Peak Demand and shortage at Solar and Non-Solar Hour

	Max Demand Met(MW)	Time	Shortage(MW)
Solar hr	217753	10:18	178
Non-Solar hr	197501	18:24	621

Diversity factor = Sum of regional or state maximum demands / All India maximum demand

**Note: All generation MU figures are gross

***Godda (Jharkhand) -> Bangladesh power exchange is through the radial connection (isolated from Indian Grid)

Solar Hours -> 06:00 to 18:00hrs and rest are Non-Solar Hours

*Source: RLDCs for solar connected to ISTS; SLDCs for embedded solar. Limited visibility of embedded solar data.

Executive Director-NLDC

INTER-REGIONAL EXCHANGES

Import=(+ve) /Export =(-ve) for NET (MU)
Date of Reporting: 19-Dec-2024

Sl No	Voltage Level	Line Details	No. of Circuit	Max Import (MW)	Max Export (MW)	Import (MU)	Export (MU)	NET (MU)
Import/Export of ER (With NR)								
1	HVDC	ALIPURDUAR-AGRA	2	0	0	0.0	0.0	0.0
2	HVDC	PUSAULI B/B	-	0	249	0.0	5.9	-5.9
3	765 kV	GAYA-VARANASI	2	0	724	0.0	11.6	-11.6
4	765 kV	SASARAM-FATEHPUR	1	0	470	0.0	7.9	-7.9
5	765 kV	GAYA-BALIA	1	0	602	0.0	10.2	-10.2
6	400 kV	PUSAULI-VARANASI	1	0	192	0.0	3.8	-3.8
7	400 kV	PUSAULI -ALLAHABAD	1	0	117	0.0	2.1	-2.1
8	400 kV	MUZAFFARPUR-GORAKHPUR	2	0	615	0.0	7.0	-7.0
9	400 kV	PATNA-BALIA	2	0	869	0.0	12.0	-12.0
10	400 kV	NAUBATPUR-BALIA	2	0	292	0.0	3.8	-3.8
11	400 kV	BIHARSHARIFF-BALIA	2	0	200	0.0	3.6	-3.6
12	400 kV	MOTIHARI-GORAKHPUR	2	0	482	0.0	8.3	-8.3
13	400 kV	BIHARSHARIFF-VARANASI	2	0	0	0.0	0.0	0.0
14	220 kV	SAHUPURI-KARAMNESA	1	0	65	0.0	0.8	-0.8
15	132 kV	NAGAR UNTARI-RIHAND	1	0	0	0.1	0.0	0.1
16	132 kV	GARWAH-RIHAND	1	30	0	0.6	0.0	0.6
17	132 kV	KARMANASA-SAHUPURI	1	0	0	0.0	0.0	0.0
18	132 kV	KARMANASA-CHANDAULI	1	0	0	0.0	0.0	0.0
ER-NR						0.6	77.0	-76.3
Import/Export of ER (With WR)								
1	765 kV	JHARSUGUDA-DHARAMJAIGARH	4	323	678	0.0	9.4	-9.4
2	765 kV	NEW RANCHI-DHARAMJAIGARH	2	503	648	0.0	1.6	-1.6
3	765 kV	JHARSUGUDA-DURG	2	0	681	0.0	12.9	-12.9
4	400 kV	JHARSUGUDA-RAIGARH	4	0	713	0.0	9.9	-9.9
5	400 kV	RANCHI-SIPAT	2	0	0	0.0	0.0	0.0
6	220 kV	BUDHIPADAR-RAIGARH	1	0	113	0.0	1.6	-1.6
7	220 kV	BUDHIPADAR-KORBA	2	79	98	0.1	0.0	0.1
ER-WR						0.1	35.3	-35.2
Import/Export of ER (With SR)								
1	HVDC	JEYPORE-GAZUWAKA B/B	2	0	530	0.0	12.6	-12.6
2	HVDC	TALCHER-KOLAR BIPOLE	2	0	1648	0.0	39.7	-39.7
3	765 kV	ANGUL-SRIKAKULAM	2	0	3009	0.0	55.0	-55.0
4	400 kV	TALCHER-I/C	2	223	538	3.1	0.0	3.1
5	220 kV	BALIMELA-UPPER-SILERRU	1	0	0	0.0	0.0	0.0
ER-SR						0.0	107.3	-107.3
Import/Export of ER (With NER)								
1	400 kV	BINAGURI-BONGAIGAON	2	289	0	3.5	0.0	3.5
2	400 kV	ALIPURDUAR-BONGAIGAON	2	417	0	7.4	0.0	7.4
3	220 kV	ALIPURDUAR-SALAKATI	2	86	0	1.6	0.0	1.6
ER-NER						12.5	0.0	12.5
Import/Export of NER (With NR)								
1	HVDC	BISWANATH CHARIALI-AGRA	2	667	0	16.3	0.0	16.3
NER-NR						16.3	0.0	16.3
Import/Export of WR (With NR)								
1	HVDC	CHAMPA-KURUKSHETRA	2	0	2512	0.0	61.9	-61.9
2	HVDC	VINDHYACHAL B/B	-	0	55	0.0	1.2	-1.2
3	HVDC	MUNDRA-MOHINDERGARH	2	0	1457	0.0	28.7	-28.7
4	765 kV	GWALIOR-AGRA	2	0	1804	0.0	23.4	-23.4
5	765 kV	GWALIOR-PHAGI	2	20	1568	0.0	20.4	-20.4
6	765 kV	JABALPUR-ORAI	2	0	873	0.0	23.4	-23.4
7	765 kV	GWALIOR-ORAI	1	796	0	14.1	0.0	14.1
8	765 kV	SATNA-ORAI	1	0	967	0.0	18.8	-18.8
9	765 kV	BANASKANTHA-CHITORGARH	2	1541	622	10.1	3.5	6.6
10	765 kV	VINDHYACHAL-VARANASI	2	0	2364	0.0	33.8	-33.8
11	400 kV	ZERDA-KANKROLI	1	291	80	2.3	0.2	2.1
12	400 kV	ZERDA -BHINMAL	1	201	56	1.1	0.1	1.0
13	400 kV	VINDHYACHAL -RIHAND	1	967	0	22.4	0.0	22.4
14	400 kV	RAPP-SHUJALPUR	2	555	232	3.9	0.7	3.2
15	400 kV	NEEMUCH-Chittorgarh	2	577	284	4.4	0.7	3.7
16	220 kV	BHANPURA-RANPUR	1	0	203	0.0	3.4	-3.4
17	220 kV	BHANPURA-MORAK	1	0	30	0.0	2.0	-2.0
18	220 kV	MEHGAON-AURAIYA	1	163	0	1.9	0.0	1.9
19	220 kV	MALANPUR-AURAIYA	1	126	4	1.2	0.0	1.2
20	132 kV	GWALIOR-SAWAI MADHOPUR	1	0	0	0.0	0.0	0.0
21	132 kV	RAJGHAT-LALITPUR	2	0	0	0.0	0.0	0.0
WR-NR						61.3	222.1	-160.8
Import/Export of WR (With SR)								
1	HVDC	BHADRAWATI B/B	-	0	1007	0.0	24.0	-24.0
2	HVDC	RAIGARH-PUGALUR	2	0	2003	0.0	40.9	-40.9
3	765 kV	SOLAPUR-RAICHUR	2	624	1961	1.0	14.1	-13.1
4	765 kV	WARDHA-NIZAMABAD	2	0	2669	0.0	36.7	-36.7
5	765 kV	WARORA-WARANGAL(NEW)	2	0	2819	0.0	41.2	-41.2
6	400 kV	KOLHAPUR-KUDGI	2	1335	27	16.1	0.0	16.1
7	220 kV	KOLHAPUR-CHIKODI	2	0	0	0.0	0.0	0.0
8	220 kV	PONDA-AMBEWADI	1	0	0	0.0	0.0	0.0
9	220 kV	XELDEM-AMBEWADI	1	0	126	2.3	0.0	2.3
WR-SR						19.3	156.8	-137.5

INTERNATIONAL EXCHANGES					Import(+ve)/Export(-ve)		
State	Region	Line Name	Max (MW)	Min (MW)	Avg (MW)	Energy Exchange (MU)	
BHUTAN	ER	400kV MANGDECHHU-ALIPURDUAR 1,2&3 i.e. ALIPURDUAR RECEIPT (from MANGDECHU HEP 4*180MW)	-122	96	-30	-0.72	
	ER	400kV TALA-BINAGURI 1,2,4 (& 400kV MALBASE - BINAGURI) i.e. BINAGURI RECEIPT (from TALA HEP 6*170MW)	-189	162	-23	-0.56	
	ER	220kV CHUKHA-BIRPARA 1&2 (& 220kV MALBASE - BIRPARA) i.e. BIRPARA RECEIPT (from CHUKHA HEP 4*84MW)	-248	-127	-189	-4.55	
	NER	132kV GELEPHU-SALAKATI	-32	0	-23	-0.55	
	NER	132kV MOTANGA-RANGIA	18	0	4	0.10	
NEPAL	NR	NEPAL IMPORT (FROM UP)	-67	0	0	0.00	
	NR	132kV MAHENDRANAGAR-TANAKPUR(NHPC)	-67	0	-39	-0.93	
	ER	NEPAL IMPORT (FROM BIHAR)	0	0	0	0.00	
	ER	400kV DHALKEBAR-MUZAFFARPUR 1&2	292	24	143	3.42	
BANGLADESH	ER	BHERAMARA B/B HVDC (B'DESH)	-920	-642	-855	-20.51	
	ER (Isolated from Indian Grid)	400kV GODDA_TPS-RAHANPUR (B'DESH) D/C	-769	-404	-512	-12.30	
	NER	132kV COMILLA-SURAJMANI NAGAR 1&2	-64	0	-50	-1.20	

Export From India (in MU)

Country	GNA (ISGS/PPA)	T-GNA							TOTAL	
		BILATERAL TOTAL	COLLECTIVE							
			IDAM			RTM				
			IEX	PXIL	HPX	IEX	PXIL	HPX		
Bhutan	0.00	0.00	7.74	0.00	0.00	0.00	0.00	0.00	7.74	
Nepal	0.32	0.00	1.38	0.00	0.00	0.00	1.93	0.00	0.00	3.63
Bangladesh	21.31	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	21.31
Myanmar	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total Export	21.63	0.00	9.12	0.00	0.00	0.00	1.93	0.00	0.00	32.68

Import by India(in MU)

Country	GNA (ISGA/PPA)	T-GNA							TOTAL
		BILATERAL TOTAL	COLLECTIVE						
			IDAM			RTM			
			IEX	PXIL	HPX	IEX	PXIL	HPX	
Bhutan	0.91	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.91
Nepal	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Bangladesh	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Myanmar	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total Import	0.91	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.91

Net from India(in MU)

-ve : Export / +ve : Import

Country	GNA (ISGS/PPA)	T-GNA							TOTAL
		BILATERAL TOTAL	COLLECTIVE						
			IDAM			RTM			
			IEX	PXIL	HPX	IEX	PXIL	HPX	
Bhutan	0.91	0.00	-7.74	0.00	0.00	0.00	0.00	0.00	-6.83
Nepal	-0.32	0.00	-1.38	0.00	0.00	-1.93	0.00	0.00	-3.63
Bangladesh	-21.31	0.00	0.00	0.00	0.00	0.00	0.00	0.00	-21.31
Myanmar	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total Net	-20.72	0.00	-9.12	0.00	0.00	-1.93	0.00	0.00	-31.77

Date of Reporting: 19-Dec-2024												
15 Min (INSTANTANEOUS) ALL INDIA GRID FREQUENCY, GENERATION & DEMAND MET (SCADA DATA)												
TIME	FREQUENCY (Hz)	DEMAND MET (MW)	NUCLEAR (MW)	WIND (MW)	SOLAR (MW)	HYDRO** (MW)	GAS (MW)	THERMAL (MW)	OTHERS* (MW)	NET DEMAND MET (MW)	TOTAL GENERATION (MW)	NET TRANSNATIONAL EXCHANGE (MW) (+ve) Import, (-ve) Export
		(A)	(B)	(C)	(D)	(E)	(F)	(G)	(H)	(I=A-(C+D))	(J=B+C+D+E+F+G+H)	(K)
0:00	50.02	147015	6616	11081	45	7178	3113	122114	3113	135889	153260	-1563
0:15	49.97	146709	6628	10800	45	7083	2969	122332	3095	135864	152952	-1603
0:30	49.92	145998	6625	10637	45	7200	2978	121590	3116	135316	152191	-1544
0:45	49.97	144837	6632	10535	43	7203	3108	120649	3105	134259	151275	-1495
1:00	49.92	144183	6635	10532	45	6985	3128	120139	3094	133606	150558	-1498
1:15	49.97	143134	6651	10496	43	6958	3107	119087	3139	132595	149481	-1501
1:30	49.97	142325	6634	10438	43	6710	2969	118572	3145	131844	148511	-1462
1:45	49.97	142172	6633	10372	43	6597	3108	118552	3155	131757	148460	-1470
2:00	49.97	141217	6619	10255	47	6552	3112	117810	3155	130915	147550	-1441
2:15	49.97	140296	6637	10107	42	6210	3109	117398	3142	130147	146645	-1453
2:30	49.92	140538	6632	10011	42	6196	3121	117839	3134	130485	146975	-1439
2:45	49.97	140321	6628	9808	41	6278	3102	117873	3098	130472	146828	-1356
3:00	49.92	140177	6632	9381	42	6359	3111	117960	3114	130754	146599	-1338
3:15	49.97	140113	6636	9086	43	6167	3174	118352	3110	130984	146568	-1290
3:30	50.02	140337	6644	8834	41	6262	3274	118585	3073	131462	146713	-1301
3:45	49.97	140504	6628	8639	39	6380	3250	118952	3143	131826	147031	-1292
4:00	50.02	140791	6632	8544	40	6117	3213	119750	3133	132207	147429	-1303
4:15	49.92	143109	6630	8423	39	6707	3257	121636	2909	134647	149601	-1323
4:30	50.02	144701	6651	8307	39	7143	3290	123104	2896	136355	151430	-1332
4:45	50.02	146634	6648	8175	39	7570	3288	124635	2912	138420	153267	-1298
5:00	50.07	149580	6645	8028	38	8115	3312	127148	2986	141514	156272	-1398
5:15	50.02	154200	6640	7954	39	9174	3384	130987	2948	146207	161126	-1396
5:30	50.02	158488	6630	7984	41	10065	3427	133899	2942	150463	164988	-1285
5:45	49.97	162147	6641	7996	44	10970	3585	136669	2933	154107	168838	-1271
6:00	50.07	166926	6632	7939	36	12360	4207	139540	2914	158951	173628	-1225
6:15	50.01	172371	6618	7909	307	14166	4509	143077	2993	164155	179579	-1204
6:30	50.07	180216	6620	7685	316	17977	4307	147295	2987	172215	187187	-1124
6:45	49.92	185659	6644	7608	388	20508	4328	149899	2995	177663	192370	-1133
7:00	49.87	190396	6632	7501	738	22510	4537	152473	3007	182157	197398	-1100
7:15	49.77	195334	6634	7609	1506	24691	4610	153957	2997	186219	202004	-1081
7:30	49.92	198239	6620	7572	2811	25124	4689	154870	3003	187856	204689	-1107
7:45	49.92	201266	6638	7444	4690	25154	4748	155926	3036	189132	207636	-1064
8:00	50.02	202958	6626	7358	7598	23406	4750	156289	3013	188002	209040	-1046
8:15	49.97	205510	6646	7391	11661	21859	4513	155962	3093	186458	211125	-1024
8:30	50.07	207412	6641	7257	15768	20595	4345	154961	3065	184387	212632	-997
8:45	50.07	209231	6634	7074	20543	19275	3848	153814	3119	181614	214307	-953
9:00	50.02	209985	6635	6576	24902	16557	2793	154385	3139	178507	214987	-923
9:15	49.87	214575	6629	5967	29057	16414	2294	156005	3190	179551	219556	-935
9:30	49.87	216242	6609	5242	33016	14617	2520	156058	3147	177984	221209	-945
9:45	49.97	217178	6629	4476	35957	13511	2638	155690	3137	176745	222038	-1017
10:00	49.92	217374	6613	3990	38906	12010	2603	155399	3141	174478	222662	-1242
10:15	49.92	217484	6621	3487	41657	10371	2632	154537	3191	172340	222496	-1242
10:30	49.92	217169	6623	3302	43550	9516	2597	153309	3248	170317	222145	-1205
10:45	49.97	216752	6608	3133	45140	9215	2292	152838	3166	168479	222392	-1310
11:00	50.02	215373	6619	3054	46676	9420	2155	150319	3207	165643	221450	-1550
11:15	49.97	213316	6611	2995	47821	8840	2055	148281	3165	162500	219768	-1698
11:30	49.97	212665	6606	3044	49026	8164	2200	146763	3180	160595	218983	-1803
11:45	49.97	212269	6613	3051	50237	8333	2204	145494	3172	158981	219104	-1828
12:00	50.02	210743	6607	3094	49979	8192	2065	144109	3201	157670	217247	-1832
12:15	50.02	209913	6605	3170	51413	8177	2180	141603	3254	155330	216402	-1834
12:30	50.02	208852	6594	3254	51639	8153	2185	140357	3223	153959	215405	-1863
12:45	49.97	207789	6596	3339	51245	8098	2187	139491	3245	153205	214201	-1800
13:00	49.97	205355	6601	3358	51108	7917	2070	137523	3248	150889	211825	-1820
13:15	50.02	201618	6607	3335	50054	7012	2060	135154	3258	148229	207480	-1733
13:30	50.12	200369	6595	3203	49116	7320	2067	134796	3236	148050	206333	-1763
13:45	50.02	199537	6606	3239	48066	7272	2082	135094	3170	148232	205529	-1810
14:00	50.02	198307	6590	3261	45866	7306	2082	136088	3180	149180	204373	-1806
14:15	49.97	198306	6584	3281	44105	7607	2059	137612	3158	150920	204406	-1796
14:30	49.97	198857	6587	3228	42814	7379	2066	139890	3129	152815	205093	-1797
14:45	49.97	199200	6585	3154	40169	7694	2089	142393	3150	155877	205234	-1754
15:00	50.02	199814	6590	3131	38020	8869	2188	144052	3128	158663	205978	-1773
15:15	50.07	199061	6583	3114	35458	9484	2394	145078	3107	160489	205218	-1828
15:30	50.02	199120	6596	3163	31864	10428	2741	147266	3093	164093	205151	-1834
15:45	50.02	198232	6594	3164	28427	11138	2869	148964	3091	166641	204247	-1827
16:00	50.07	196793	6587	3062	24735	11732	2881	150708	3076	168996	202781	-1777
16:15	50.07	195469	6602	3132	21009	12380	2948	151844	3039	171328	200954	-1457
16:30	49.92	195302	6586	3198	16756	13655	3320	154370	3073	175348	200958	-1326
16:45	50.02	194774	6592	3251	12440	16231	3811	154883	2918	179083	200126	-1135
17:00	49.92	194384	6589	3431	8256	18494	4044	155917	2979	182697	199710	-1200
17:15	49.97	193141	6590	3377	5000	20599	4190	155966	2960	184764	198682	-1243
17:30	49.92	193602	6578	3553	2904	22308	4180	156784	2776	187145	199083	-1356
17:45	49.92	194185	6579	3720	1297	24398	4204	156782	2901	189168	199881	-1411
18:00	49.97	196461	6583	3971	660	26943	4236	156851	2914	191830	202158	-1387
18:15	50.02	196404	6592	4295	496	27773	4297	155762	2856	191613	202071	-1359
18:30	50.02	196889	6597	4640	380	27657	4329	156252	2877	191869	202732	-1332
18:45	50.02	196774	6590	5057	381	27740	4034	155713	2844	191336	202359	-1304
19:00	50.07	194917	6602	5377	316	27498	2708	154909	2882	189224	200292	-1284
19:15	50.02	194203	6593	5633	325	25659	2684	155724	2862	188245	199480	-1267
19:30	50.07	191508	6603	6036	282	23541	2569	154640	2928	185190	196599	-1264
19:45	50.07	188231	6595	6317	282	20620	2413	154144	2950	181632	193321	-1201
20:00	50.07	184505	6596	6620	283	17423	2259	153667	2896	177602	189744	-1174
20:15	50.02	182004	6612	6829	51	15182	2158	153257	2904	175124	186993	-1182
20:30	50.07	179437	6604	7031	43	14548	2142	151247	2903	172363	184518	-1187
20:45	49.97	176962	6619	6994	7	14018	2139	149527	2897	169961	182201	-1206
21:00	50.02	174004	6606	7236	6	13434	2149	147060	2913	166762	179404	-1266
21:15	50.02	171423	6609	7404	8	13229	2145	144655	2962	164011	177012	-1538
21:30	50.02	168723	6614	7667	7	12609	2149	142792	2854	161049	174692	-1709
21:45	49.97	166345	6608	7803	7	11900	2146	141368	2922	158535	172754	-1817
22:00	50.07	162723	6609	7979	9	10768	2139	138662	2867	154735	169033	-1822
22:15	49.97	162172	6614	8086	10	10354	2145	138256	2916	154076	168381	-1778
22:30	49.97	160428	6630	8175	11	10176	2135	1				