



National Load Despatch Centre
राष्ट्रीय भार प्रेषण केंद्र
GRID CONTROLLER OF INDIA LIMITED
ग्रिड कंट्रोलर ऑफ इंडिया लिमिटेड

(Government of India Enterprise/ भारत सरकार का उद्यम)
B-9, QUTUB INSTITUTIONAL AREA, KATWARIA SARAI, NEW DELHI -110016
बी-9, कुतुब इंस्टीट्यूशनल एरिया, कटवारिया सराये, न्यू दिल्ली-110016

Ref: GRID-INDIA/NLDC/SO/Daily PSP Report

दिनांक: 12.01.2025

To,

- कार्यकारी निदेशक, पू.क्षे.भा.प्रे.के., 14, गोल्फ क्लब रोड, कोलकाता - 700033
Executive Director, ERLDC, 14 Golf Club Road, Tollygunge, Kolkata, 700033
- कार्यकारी निदेशक, ऊ.क्षे.भा.प्रे.के., 18/ए, शाहीद जीत सिंह सनसनवाल मार्ग, नई दिल्ली - 110016
Executive Director, NRLDC, 18-A, Shaheed Jeet Singh Marg, Katwaria Sarai, New Delhi - 110016
- कार्यकारी निदेशक, प.क्षे.भा.प्रे.के., एफ3, एम आई डी सी क्षेत्र, अंधेरी, मुंबई - 400093
Executive Director, WRLDC, F-3, M.I.D.C. Area, Marol, Andheri (East), Mumbai-400093
- कार्यकारी निदेशक, ऊ.पू.क्षे.भा.प्रे.के., डोंगतेह, लोअर नोंग्रह, लापालंग, शिलोंग - 793006
Executive Director, NERLDC, Dongteih, Lower Nongrah, Lapalang, Shillong - 793006, Meghalaya
- कार्यकारी निदेशक, द.क्षे.भा.प्रे.के., 29, रेस कोर्स क्रॉस रोड, बंगलुरु - 560009
Executive Director, SRLDC, 29, Race Course Cross Road, Bangalore-560009

Sub: Daily PSP Report for the date 11.01.2025.

महोदय/Dear Sir,

आईईजीसी-2023 की धारा स.-38(1) के प्रावधान के अनुसार, दिनांक 11-जनवरी-2025 की अखिल भारतीय प्रणाली की दैनिक ग्रिड निष्पादन रिपोर्ट रांभांप्रेके की वेबसाइट पर उपलब्ध है।

As per article 38(1) of the Indian Electricity Grid Code, the daily report pertaining power supply position of All India Power System for the date 11.01.2025, is available at the NLDC website.

धन्यवाद,
Thanks

Report for previous day

Date of Reporting: 12-Jan-2025

A. Power Supply Position at All India and Regional level

	NR	WR	SR	ER	NER	TOTAL
Demand Met during Evening Peak hrs(MW) (at 19:00 hrs; from RLDCs)	57713	64884	43540	22640	2705	191482
Peak Shortage (MW)	182	592	0	531	0	1305
Energy Met (MU)	1224	1549	1178	473	50	4474
Hydro Gen (MU)	90	57	108	20	11	286
Wind Gen (MU)	20	60	69	-	-	149
Solar Gen (MU)*	126.67	85.81	84.28	3.25	1.12	301
Energy Shortage (MU)	2.52	1.30	0.00	1.29	0.00	5.11
Maximum Demand Met During the Day (MW) (From NLDC SCADA)	65377	77613	59204	23940	2794	226006
Time Of Maximum Demand Met	10:18	10:20	12:57	17:53	17:47	10:19

B. Frequency Profile (%)

Region	FVI	< 49.7	49.7 - 49.8	49.8 - 49.9	< 49.9	49.9 - 50.05	> 50.05
All India	0.072	1.13	2.65	10.84	14.63	74.01	11.36

C. Power Supply Position in States

Region	States	Max.Demand Met during the day (MW)	Shortage during maximum Demand (MW)	Energy Met (MU)	Drawal Schedule (MU)	OD(+)/UD(-) (MU)	Max OD (MW)	Energy Shortage (MU)
NR	Punjab	8584	0	156.2	61.3	-0.2	417	0.00
	Haryana	7935	0	152.6	97.3	-1.6	634	0.00
	Rajasthan	16469	0	309.4	91.7	-4.9	279	0.00
	Delhi	5104	0	86.3	84.4	-0.4	411	0.00
	UP	19504	0	358.7	128.1	-3.0	1031	1.44
	Uttarakhand	2446	0	45.9	38.1	-0.7	167	0.00
	HP	2120	0	38.4	32.4	-0.5	212	0.00
	J&K(UT) & Ladakh(UT)	3118	210	67.5	64.5	-0.2	701	1.08
	Chandigarh	271	0	4.7	4.7	0.0	39	0.00
WR	Railways_NR ISTS	218	0	4.1	3.5	0.6	58	0.00
	Chhattisgarh	5451	0	111.1	59.2	0.7	374	0.00
	Gujarat	22924	0	427.2	217.9	-2.7	739	0.00
	MP	18197	0	335.6	201.7	-0.1	1269	1.30
	Maharashtra	29390	0	597.9	185.4	6.6	992	0.00
	Goa	705	0	14.3	13.5	0.2	81	0.00
	DNHDDPDCL	1315	0	30.7	30.7	0.0	46	0.00
	AMNSIL	756	0	16.4	7.0	0.3	279	0.00
	BALCO	531	0	12.7	12.7	0.0	8	0.00
SR	RIL JAMNAGAR	111	0	2.6	2.6	0.0	0	0.00
	Andhra Pradesh	10510	0	203.5	53.3	1.8	769	0.00
	Telangana	14389	0	261.4	137.1	0.8	1563	0.00
	Karnataka	16310	0	285.1	94.1	2.2	996	0.00
	Kerala	4244	0	84.5	60.5	1.3	455	0.00
	Tamil Nadu	16437	0	335.1	192.3	1.8	707	0.00
ER	Puducherry	392	0	8.7	8.3	-0.2	30	0.00
	Bihar	5363	0	102.2	93.6	-3.4	310	1.29
	DVC	3459	0	72.6	-42.9	-1.1	425	0.00
	Jharkhand	2112	0	39.3	28.4	-0.7	305	0.00
	Odisha	5468	0	106.0	35.4	0.2	434	0.00
	West Bengal	7689	0	151.1	23.6	-1.5	280	0.00
	Sikkim	116	0	1.9	1.7	0.2	40	0.00
	Railways_ER ISTS	12	0	0.2	0.2	0.0	10	0.00
NER	Arunachal Pradesh	170	0	3.0	2.9	0.0	27	0.00
	Assam	1549	0	27.6	20.7	0.3	107	0.00
	Manipur	243	0	3.9	3.8	0.1	47	0.00
	Meghalaya	377	0	6.8	5.5	-0.2	115	0.00
	Mizoram	154	0	2.4	2.0	-0.1	14	0.00
	Nagaland	148	0	2.4	2.3	0.0	22	0.00
	Tripura	231	0	4.0	3.4	-0.1	47	0.00

D. Transnational Exchanges (MU) - Import(+ve)/Export(-ve)

	Bhutan	Nepal	Bangladesh	Godda -> Bangladesh
Actual (MU)	-4.8	-7.1	-21.2	-13.4
Day Peak (MW)	-381.0	-449.0	-991.0	-762.0

E. Import/Export by Regions (in MU) - Import(+ve)/Export(-ve); OD(+)/UD(-)

	NR	WR	SR	ER	NER	TOTAL
Schedule(MU)	239.3	-239.2	133.7	-137.6	3.8	0.0
Actual(MU)	226.7	-235.8	141.1	-143.1	2.1	-8.9
O/D/U/D(MU)	-12.5	3.4	7.4	-5.5	-1.7	-8.9

F. Generation Outage(MW)

	NR	WR	SR	ER	NER	TOTAL	% Share
Central Sector	5143	9336	4758	5693	698	25627	44
State Sector	9553	12460	6943	3849	221	33025	56
Total	14696	21795	11701	9542	918	58652	100

G. Sourcewise generation (Gross) (MU)

	NR	WR	SR	ER	NER	All India	% Share
Coal	764	1610	667	672	16	3729	77
Lignite	23	17	62	0	0	103	2
Hydro	90	57	108	20	11	286	6
Nuclear	32	54	71	0	0	157	3
Gas, Naptha & Diesel	6	20	14	0	25	64	1
RES (Wind, Solar, Biomass & Others)	173	149	185	6	1	515	11
Total	1087	1908	1108	698	53	4854	100

Share of RES in total generation (%)	15.92	7.84	16.74	0.83	2.12	10.61
Share of Non-fossil fuel (Hydro,Nuclear and RES) in total generation(%)	27.10	13.67	32.92	3.75	23.19	19.75

H. All India Demand Diversity Factor

Based on Regional Max Demands	1.012
Based on State Max Demands	1.037

I. All India Peak Demand and shortage at Solar and Non-Solar Hour

	Max Demand Met(MW)	Time	Shortage(MW)
Solar hr	226006	10:19	78
Non-Solar hr	199568	17:53	736

Diversity factor = Sum of regional or state maximum demands / All India maximum demand

**Note: All generation MU figures are gross

***Godda (Jharkhand) -> Bangladesh power exchange is through the radial connection (isolated from Indian Grid)

Solar Hours -> 06:00 to 18:00hrs and rest are Non-Solar Hours

*Source: RLDCs for solar connected to ISTS; SLDCs for embedded solar. Limited visibility of embedded solar data.

Executive Director-NLDC

INTER-REGIONAL EXCHANGES								
Import=(+ve) /Export =(-ve) for NET (MU)								
Date of Reporting: 12-Jan-2025								
Sl No	Voltage Level	Line Details	No. of Circuit	Max Import (MW)	Max Export (MW)	Import (MU)	Export (MU)	NET (MU)
Import/Export of ER (With NR)								
1	HVDC	ALIPURDUAR-AGRA	2	0	0	0.0	0.0	0.0
2	HVDC	PUSAULI B/B	-	3	0	0.0	3.2	-3.2
3	765 kV	GAYA-VARANASI	2	0	789	0.0	13.0	-13.0
4	765 kV	SASARAM-FATEHPUR	1	0	469	0.0	8.2	-8.2
5	765 kV	GAYA-BALIA	1	0	772	0.0	13.1	-13.1
6	400 kV	PUSAULI-VARANASI	1	0	180	0.0	2.7	-2.7
7	400 kV	PUSAULI -ALLAHABAD	1	58	106	0.0	0.6	-0.6
8	400 kV	MUZAFFARPUR-GORAKHPUR	2	15	517	0.0	6.5	-6.5
9	400 kV	PATNA-BALIA	2	0	699	0.0	12.4	-12.4
10	400 kV	NAUBATPUR-BALIA	2	0	479	0.0	3.8	-3.8
11	400 kV	BIHARSHARIFF-BALIA	2	0	336	0.0	5.4	-5.4
12	400 kV	MOTIHARI-GORAKHPUR	2	0	387	0.0	6.0	-6.0
13	400 kV	BIHARSHARIFF-VARANASI	2	0	0	0.0	0.0	0.0
14	220 kV	SAHUPURI-KARAMNASA	1	0	104	0.0	3.3	-3.3
15	132 kV	NAGAR UNTARI-RIHAND	1	0	0	0.1	0.0	0.1
16	132 kV	GARWAH-RIHAND	1	0	0	0.5	0.0	0.5
17	132 kV	KARMANASA-SAHUPURI	1	0	0	0.0	0.0	0.0
18	132 kV	KARMANASA-CHANDAULI	1	0	0	0.0	0.0	0.0
ER-NR						0.6	78.2	-77.6
Import/Export of ER (With WR)								
1	765 kV	JHARSUGUDA-DHARAMJAIGARH	4	452	642	0.0	0.0	0.0
2	765 kV	NEW RANCHI-DHARAMJAIGARH	2	964	702	1.9	0.0	1.9
3	765 kV	JHARSUGUDA-DURG	2	0	1009	0.0	16.2	-16.2
4	400 kV	JHARSUGUDA-RAIGARH	4	0	567	0.0	8.8	-8.8
5	400 kV	RANCHI-SIPAT	2	219	282	0.0	0.8	-0.8
6	220 kV	BUDHIPADAR-RAIGARH	1	22	130	0.0	1.6	-1.6
7	220 kV	BUDHIPADAR-KORBA	2	126	30	1.4	0.0	1.4
ER-WR						3.4	27.5	-24.1
Import/Export of ER (With SR)								
1	HVDC	JEYPORE-GAZUWAKA B/B	2	0	214	0.0	5.1	-5.1
2	HVDC	TALCHER-KOLAR BIPOLE	2	0	1643	0.0	34.3	-34.3
3	765 kV	ANGUL-SRIKAKULAM	2	0	2946	0.0	49.7	-49.7
4	400 kV	TALCHER-I/C	2	94	424	0.0	3.5	-3.5
5	220 kV	BALIMELA-UPPER-SILERRU	1	0	0	0.0	0.0	0.0
ER-SR						0.0	89.1	-89.1
Import/Export of ER (With NER)								
1	400 kV	BINAGURI-BONGAIGAON	2	291	0	4.0	0.0	4.0
2	400 kV	ALIPURDUAR-BONGAIGAON	2	474	0	7.6	0.0	7.6
3	220 kV	ALIPURDUAR-SALAKATI	2	92	0	1.6	0.0	1.6
ER-NER						13.1	0.0	13.1
Import/Export of NER (With NR)								
1	HVDC	BISWANATH CHARIALI-AGRA	2	663	0	16.2	0.0	16.2
NER-NR						16.2	0.0	16.2
Import/Export of WR (With NR)								
1	HVDC	CHAMPA-KURUKSHETRA	2	0	2522	0.0	62.8	-62.8
2	HVDC	VINDHYACHAL B/B	-	227	103	0.0	1.3	-1.3
3	HVDC	MUNDRA-MOHINDERGARH	2	0	1453	0.0	30.1	-30.1
4	765 kV	GWALIOR-AGRA	2	286	2320	0.3	26.8	-26.6
5	765 kV	GWALIOR-PHAGI	2	346	1649	0.3	20.5	-20.2
6	765 kV	JABALPUR-ORAI	2	26	1132	0.0	28.3	-28.3
7	765 kV	GWALIOR-ORAI	1	801	0	14.1	0.0	14.1
8	765 kV	SATNA-ORAI	1	0	949	0.0	18.2	-18.2
9	765 kV	BANASKANTHA-CHITORGARH	2	1635	367	14.4	0.7	13.8
10	765 kV	VINDHYACHAL-VARANASI	2	0	2874	0.0	36.0	-36.0
11	400 kV	ZERDA-KANKROLI	1	334	36	3.4	0.0	3.4
12	400 kV	ZERDA -BHINMAL	1	231	25	2.3	0.0	2.3
13	400 kV	VINDHYACHAL -RIHAND	1	926	0	10.9	0.0	10.9
14	400 kV	RAPP-SHUJALPUR	2	700	213	4.0	0.9	3.1
15	400 kV	NEEMUCH-Chittorgarh	2	762	263	4.2	1.1	3.1
16	220 kV	BHANPURA-RANPUR	1	0	176	0.0	2.9	-2.9
17	220 kV	BHANPURA-MORAK	1	0	30	0.0	1.7	-1.7
18	220 kV	MEHGAON-AURAIYA	1	122	0	1.4	0.0	1.4
19	220 kV	MALANPUR-AURAIYA	1	89	15	0.9	0.0	0.8
20	132 kV	GWALIOR-SAWAI MADHOPUR	1	0	0	0.0	0.0	0.0
21	132 kV	RAJGHAT-LALITPUR	2	0	0	0.0	0.0	0.0
WR-NR						56.2	231.3	-175.0
Import/Export of WR (With SR)								
1	HVDC	BHADRAWATI B/B	-	0	510	0.0	12.0	-12.0
2	HVDC	RAIGARH-PUGALUR	2	0	2002	0.0	30.8	-30.8
3	765 kV	SOLAPUR-RAICHUR	2	1236	1403	6.4	10.3	-3.8
4	765 kV	WARDHA-NIZAMABAD	2	151	2513	0.1	32.4	-32.4
5	765 kV	WARORA-WARANGAL(NEW)	2	0	2635	0.0	34.0	-34.0
6	400 kV	KOLHAPUR-KUDGI	2	1631	0	26.1	0.0	26.1
7	220 kV	KOLHAPUR-CHIKODI	2	0	0	0.0	0.0	0.0
8	220 kV	PONDA-AMBEWADI	1	0	0	0.0	0.0	0.0
9	220 kV	XELDEM-AMBEWADI	1	0	113	2.2	0.0	2.2
WR-SR						34.8	119.4	-84.6
INTERNATIONAL EXCHANGES								
State	Region		Line Name	Max (MW)	Min (MW)	Avg (MW)	Import(+ve)/Export(-ve) Energy Exchange (MU)	
BHUTAN	ER		400kV MANGDECHHU-ALIPURDUAR 1,2&3 i.e. ALIPURDUAR RECEIPT (from MANGDECHU HEP 4*180MW)	197	2	75	1.81	
	ER		400kV TALA-BINAGURI 1,2,4 (& 400kV MALBASE - BINAGURI) i.e. BINAGURI RECEIPT (from TALA HEP 6*170MW)	-202	93	-53	-1.28	
	ER		220kV CHUKHA-BIRPARA 1&2 (& 220kV MALBASE - BIRPARA) i.e. BIRPARA RECEIPT (from CHUKHA HEP 4*84MW)	-240	-105	-175	-4.21	
	NER		132kV GELEPHU-SALAKATI	-27	-15	-22	-0.52	
	NER		132kV MOTANGA-RANGIA	-11	0	-2	-0.04	
NEPAL	NR		NEPAL IMPORT (FROM UP)	-66	0	-49	-1.18	
	NR		132kV MAHENDRANAGAR-TANAKPUR(NHPC)	-66	0	-36	-0.86	
	ER		NEPAL IMPORT (FROM BIHAR)	-181	-23	-78	-1.88	
	ER		400kV DHALKEBAR-MUZAFFARPUR 1&2	-268	-8	-133	-3.20	
BANGLADESH	ER		BHERAMARA B/B HVDC (B'DESH)	-927	-544	-832	-19.98	
	ER (Isolated from Indian Grid)		400kV GODDA_TPS-RAHANPUR (B'DESH) D/C	-762	-404	-559	-13.43	
	NER		132kV COMILLA-SURAJMANI NAGAR 1&2	-64	0	-50	-1.20	

Export From India (in MU)

Country	GNA (ISGS/PPA)	T-GNA							TOTAL	
		BILATERAL TOTAL	COLLECTIVE							
			IDAM			RTM				
			IEX	PXIL	HPX	IEX	PXIL	HPX		
Bhutan	0.00	0.30	5.63	0.00	0.00	0.00	0.00	0.00	5.93	
Nepal	2.07	0.00	2.61	0.00	0.00	0.00	0.70	0.00	0.00	5.38
Bangladesh	20.86	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	20.86
Myanmar	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total Export	22.93	0.30	8.24	0.00	0.00	0.00	0.70	0.00	0.00	32.17

Import by India(in MU)

Country	GNA (ISGA/PPA)	T-GNA							TOTAL
		BILATERAL TOTAL	COLLECTIVE						
			IDAM			RTM			
			IEX	PXIL	HPX	IEX	PXIL	HPX	
Bhutan	1.18	0.00	0.00	0.00	0.00	0.00	0.00	0.00	1.18
Nepal	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Bangladesh	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Myanmar	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total Import	1.18	0.00	0.00	0.00	0.00	0.00	0.00	0.00	1.18

Net from India(in MU)

-ve : Export / +ve : Import

Country	GNA (ISGS/PPA)	T-GNA							TOTAL
		BILATERAL TOTAL	COLLECTIVE						
			IDAM			RTM			
			IEX	PXIL	HPX	IEX	PXIL	HPX	
Bhutan	1.18	-0.30	-5.63	0.00	0.00	0.00	0.00	0.00	-4.75
Nepal	-2.07	0.00	-2.61	0.00	0.00	-0.70	0.00	0.00	-5.38
Bangladesh	-20.86	0.00	0.00	0.00	0.00	0.00	0.00	0.00	-20.86
Myanmar	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total Net	-21.75	-0.30	-8.24	0.00	0.00	-0.70	0.00	0.00	-30.99

