



National Load Despatch Centre
राष्ट्रीय भार प्रेषण केंद्र
GRID CONTROLLER OF INDIA LIMITED
ग्रिड कंट्रोलर ऑफ इंडिया लिमिटेड

(Government of India Enterprise/ भारत सरकार का उद्यम)
B-9, QUTUB INSTITUTIONAL AREA, KATWARIA SARAI, NEW DELHI -110016
बी-9, कुतुब इन्स्टीट्यूशनल एरिया, कटवारिया सराये, न्यू दिल्ली-110016

Ref: GRID-INDIA/NLDC/SO/Daily PSP Report

दिनांक: 18.01.2025

To,

- कार्यकारी निदेशक, पू.क्षे.भा.प्रे.के., 14, गोल्फ क्लब रोड, कोलकाता - 700033
Executive Director, ERLDC, 14 Golf Club Road, Tollygunge, Kolkata, 700033
- कार्यकारी निदेशक, ऊ.क्षे.भा.प्रे.के., 18/ए, शहीद जीत सिंह सनसनवाल मार्ग, नई दिल्ली - 110016
Executive Director, NRLDC, 18-A, Shaheed Jeet Singh Marg, Katwaria Sarai, New Delhi - 110016
- कार्यकारी निदेशक, प.क्षे.भा.प्रे.के., एफ3, एम आई डी सी क्षेत्र, अंधेरी, मुंबई - 400093
Executive Director, WRLDC, F-3, M.I.D.C. Area, Marol, Andheri (East), Mumbai-400093
- कार्यकारी निदेशक, ऊ.पू.क्षे.भा.प्रे.के., डोंगतेह, लोअर नोंग्रह, लापालंग, शिलोंग - 793006
Executive Director, NERLDC, Dongteih, Lower Nongrah, Lapalang, Shillong - 793006, Meghalaya
- कार्यकारी निदेशक, द.क्षे.भा.प्रे.के., 29, रेस कोर्स क्रॉस रोड, बंगलुरु - 560009
Executive Director, SRLDC, 29, Race Course Cross Road, Bangalore-560009

Sub: Daily PSP Report for the date 17.01.2025.

महोदय/Dear Sir,

आईईजीसी-2023 की धारा स.-38(1) के प्रावधान के अनुसार, दिनांक 17-जनवरी-2025 की अखिल भारतीय प्रणाली की दैनिक ग्रिड निष्पादन रिपोर्ट रांभांप्रेके की वेबसाइट पर उपलब्ध है।

As per article 38(1) of the Indian Electricity Grid Code, the daily report pertaining power supply position of All India Power System for the date 17.01.2025, is available at the NLDC website.

धन्यवाद,
Thanks

Report for previous day

Date of Reporting: 18-Jan-2025

A. Power Supply Position at All India and Regional level

	NR	WR	SR	ER	NER	TOTAL
Demand Met during Evening Peak hrs(MW) (at 19:00 hrs; from RLDCs)	61452	65127	43568	22625	2674	195446
Peak Shortage (MW)	0	104	0	0	0	104
Energy Met (MU)	1245	1537	1143	463	49	4436
Hydro Gen (MU)	91	50	76	24	11	252
Wind Gen (MU)	38	153	116	-	-	307
Solar Gen (MU)*	149.50	100.38	122.89	2.68	1.11	377
Energy Shortage (MU)	0.24	0.29	0.00	0.21	0.00	0.74
Maximum Demand Met During the Day (MW) (From NLDC SCADA)	66397	77797	59663	23261	2866	227245
Time Of Maximum Demand Met	10:27	10:30	10:47	18:47	17:31	10:30

B. Frequency Profile (%)

Region	FVI	< 49.7	49.7 - 49.8	49.8 - 49.9	< 49.9	49.9 - 50.05	> 50.05
All India	0.035	0.00	0.21	4.51	4.72	72.90	22.38

C. Power Supply Position in States

Region	States	Max.Demand Met during the day (MW)	Shortage during maximum Demand (MW)	Energy Met (MU)	Drawal Schedule (MU)	OD(+)/UD(-) (MU)	Max OD (MW)	Energy Shortage (MU)
NR	Punjab	8361	0	152.4	70.9	-0.5	497	0.00
	Haryana	8184	0	156.2	110.8	-2.2	250	0.00
	Rajasthan	17306	0	318.7	92.6	-7.4	780	0.00
	Delhi	5496	0	91.3	90.4	-1.4	479	0.00
	UP	20400	0	364.2	138.3	-2.9	747	0.00
	Uttarakhand	2540	0	45.5	37.0	0.2	136	0.00
	HP	2273	0	40.2	33.4	-0.6	170	0.00
	J&K(UT) & Ladakh(UT)	3103	0	68.4	64.8	-0.3	1006	0.24
	Chandigarh	307	0	4.9	4.7	0.2	79	0.00
WR	Railways_NR ISTS	194	0	3.8	3.7	0.2	47	0.00
	Chhattisgarh	5449	0	111.5	58.6	1.1	323	0.00
	Gujarat	22841	0	420.7	166.5	-6.0	620	0.00
	MP	18372	22	332.8	220.3	-2.6	540	0.29
	Maharashtra	28983	0	593.4	213.5	0.0	876	0.00
	Goa	733	0	15.5	14.7	0.2	102	0.00
	DNHDDPDCL	1332	0	30.4	30.5	-0.1	100	0.00
	AMNSIL	791	0	16.9	7.1	0.9	293	0.00
	BALCO	535	0	12.7	12.7	0.0	41	0.00
SR	RIL JAMNAGAR	125	0	2.8	2.9	-0.1	0	0.00
	Andhra Pradesh	11243	0	202.0	57.9	0.0	761	0.00
	Telangana	14237	0	261.2	150.2	-1.7	583	0.00
	Karnataka	16309	0	287.1	88.5	-1.0	391	0.00
	Kerala	4339	0	86.2	66.1	1.2	258	0.00
	Tamil Nadu	15098	0	298.5	153.6	-4.5	678	0.00
ER	Puducherry	359	0	7.6	7.2	-0.1	65	0.00
	Bihar	5534	0	103.4	92.1	-0.6	507	0.21
	DVC	3203	0	69.5	-27.5	0.6	566	0.00
	Jharkhand	2100	0	40.2	30.0	0.5	176	0.00
	Odisha	4767	0	92.7	22.7	-1.7	455	0.00
	West Bengal	7518	0	154.8	28.7	-2.2	176	0.00
	Sikkim	123	0	2.1	2.1	0.0	20	0.00
	Railways_ER ISTS	15	0	0.1	0.1	0.0	3	0.00
NER	Arunachal Pradesh	185	0	3.0	2.9	-0.1	22	0.00
	Assam	1517	0	27.1	19.9	0.4	134	0.00
	Manipur	271	0	3.8	3.9	-0.1	46	0.00
	Meghalaya	367	0	6.5	4.7	0.0	193	0.00
	Mizoram	150	0	2.4	1.8	-0.1	21	0.00
	Nagaland	155	0	2.3	2.4	-0.2	22	0.00
	Tripura	228	0	4.2	3.4	0.0	35	0.00

D. Transnational Exchanges (MU) - Import(+ve)/Export(-ve)

	Bhutan	Nepal	Bangladesh	Godda -> Bangladesh
Actual (MU)	-4.5	-8.2	-21.2	-11.1
Day Peak (MW)	-335.0	-482.2	-1001.0	-659.8

E. Import/Export by Regions (in MU) - Import(+ve)/Export(-ve); OD(+)/UD(-)

	NR	WR	SR	ER	NER	TOTAL
Schedule(MU)	278.0	-274.9	142.2	-150.2	4.9	0.0
Actual(MU)	258.2	-264.2	136.5	-141.6	4.4	-6.7
O/D/U/D(MU)	-19.8	10.7	-5.7	8.6	-0.5	-6.7

F. Generation Outage(MW)

	NR	WR	SR	ER	NER	TOTAL	% Share
Central Sector	4970	6919	5808	3405	948	22049	41
State Sector	8413	12550	6494	3779	221	31456	59
Total	13383	19468	12302	7184	1168	53505	100

G. Sourcewise generation (Gross) (MU)

	NR	WR	SR	ER	NER	All India	% Share
Coal	710	1533	620	661	14	3539	74
Lignite	29	20	41	0	0	90	2
Hydro	91	50	76	24	11	252	5
Nuclear	27	54	56	0	0	137	3
Gas, Naptha & Diesel	3	12	11	0	24	49	1
RES (Wind, Solar, Biomass & Others)	214	255	266	6	1	743	15
Total	1073	1924	1071	691	50	4810	100

Share of RES in total generation (%)	19.92	13.27	24.89	0.87	2.23	15.44
Share of Non-fossil fuel (Hydro,Nuclear and RES) in total generation(%)	30.87	18.67	37.23	4.34	25.29	23.53

H. All India Demand Diversity Factor

Based on Regional Max Demands	1.012
Based on State Max Demands	1.034

I. All India Peak Demand and shortage at Solar and Non-Solar Hour

	Max Demand Met(MW)	Time	Shortage(MW)
Solar hr	227245	10:30	22
Non-Solar hr	202194	18:40	0

Diversity factor = Sum of regional or state maximum demands / All India maximum demand

**Note: All generation MU figures are gross

***Godda (Jharkhand) -> Bangladesh power exchange is through the radial connection (isolated from Indian Grid)

Solar Hours -> 06:00 to 18:00hrs and rest are Non-Solar Hours

*Source: RLDCs for solar connected to ISTS; SLDCs for embedded solar. Limited visibility of embedded solar data.

Executive Director-NLDC

INTER-REGIONAL EXCHANGES								
Import=(+ve) /Export =(-ve) for NET (MU)								
Date of Reporting: 18-Jan-2025								
Sl No	Voltage Level	Line Details	No. of Circuit	Max Import (MW)	Max Export (MW)	Import (MU)	Export (MU)	NET (MU)
Import/Export of ER (With NR)								
1	HVDC	ALIPURDUAR-AGRA	2	0	0	0.0	0.0	0.0
2	HVDC	PUSAULI B/B	-	0	49	0.0	0.5	-0.5
3	765 kV	GAYA-VARANASI	2	342	813	0.0	9.2	-9.2
4	765 kV	SASARAM-FATEHPUR	1	33	567	0.0	8.1	-8.1
5	765 kV	GAYA-BALIA	1	0	923	0.0	12.7	-12.7
6	400 kV	PUSAULI-VARANASI	1	0	123	0.0	1.2	-1.2
7	400 kV	PUSAULI -ALLAHABAD	1	99	33	0.8	0.0	0.8
8	400 kV	MUZAFFARPUR-GORAKHPUR	2	96	722	0.0	6.8	-6.8
9	400 kV	PATNA-BALIA	2	0	917	0.0	13.6	-13.6
10	400 kV	NAUBATPUR-BALIA	2	0	623	0.0	4.2	-4.2
11	400 kV	BIHARSHARIFF-BALIA	2	63	285	0.0	4.0	-4.0
12	400 kV	MOTIHARI-GORAKHPUR	2	0	568	0.0	7.7	-7.7
13	400 kV	BIHARSHARIFF-VARANASI	2	0	0	0.0	0.0	0.0
14	220 kV	SAHUPURI-KARAMNASA	1	0	71	0.0	0.7	-0.7
15	132 kV	NAGAR UNTARI-RIHAND	1	0	0	0.1	0.0	0.1
16	132 kV	GARWAH-RIHAND	1	30	0	0.7	0.0	0.7
17	132 kV	KARMANASA-SAHUPURI	1	0	0	0.0	0.0	0.0
18	132 kV	KARMANASA-CHANDAULI	1	0	0	0.0	0.0	0.0
ER-NR						1.5	68.9	-67.3
Import/Export of ER (With WR)								
1	765 kV	JHARSUGUDA-DHARAMJAIGARH	4	636	792	0.0	1.6	-1.6
2	765 kV	NEW RANCHI-DHARAMJAIGARH	2	909	492	6.3	0.0	6.3
3	765 kV	JHARSUGUDA-DURG	2	0	1063	0.0	19.7	-19.7
4	400 kV	JHARSUGUDA-RAIGARH	4	0	705	0.0	10.6	-10.6
5	400 kV	RANCHI-SIPAT	2	202	172	0.8	0.0	0.8
6	220 kV	BUDHIPADAR-RAIGARH	1	6	109	0.0	1.3	-1.3
7	220 kV	BUDHIPADAR-KORBA	2	116	54	1.0	0.0	1.0
ER-WR						8.1	33.2	-25.1
Import/Export of ER (With SR)								
1	HVDC	JEYPORE-GAZUWAKA B/B	2	0	215	0.0	5.1	-5.1
2	HVDC	TALCHER-KOLAR BIPOLE	2	0	1995	0.0	31.5	-31.5
3	765 kV	ANGUL-SRIKAKULAM	2	0	3148	0.0	52.4	-52.4
4	400 kV	TALCHER-I/C	2	194	720	0.0	0.4	-0.4
5	220 kV	BALIMELA-UPPER-SILERRU	1	0	0	0.0	0.0	0.0
ER-SR						0.0	89.1	-89.1
Import/Export of ER (With NER)								
1	400 kV	BINAGURI-BONGAIGAON	2	269	33	3.4	0.0	3.4
2	400 kV	ALIPURDUAR-BONGAIGAON	2	438	0	6.4	0.0	6.4
3	220 kV	ALIPURDUAR-SALAKATI	2	95	0	1.5	0.0	1.5
ER-NER						11.2	0.0	11.2
Import/Export of NER (With NR)								
1	HVDC	BISWANATH CHARIALI-AGRA	2	666	0	16.2	0.0	16.2
NER-NR						16.2	0.0	16.2
Import/Export of WR (With NR)								
1	HVDC	CHAMPA-KURUKSHETRA	2	0	3536	0.0	57.1	-57.1
2	HVDC	VINDHYACHAL B/B	-	0	311	0.0	7.2	-7.2
3	HVDC	MUNDRA-MOHINDERGARH	2	0	1919	0.0	38.5	-38.5
4	765 kV	GWALIOR-AGRA	2	13	3226	0.0	33.2	-33.2
5	765 kV	GWALIOR-PHAGI	2	576	1741	1.2	18.0	-16.7
6	765 kV	JABALPUR-ORAI	2	77	1422	0.0	27.9	-27.9
7	765 kV	GWALIOR-ORAI	1	865	0	13.2	0.0	13.2
8	765 kV	SATNA-ORAI	1	0	1242	0.0	19.5	-19.5
9	765 kV	BANASKANTHA-CHITORGARH	2	1154	992	3.5	4.6	-1.1
10	765 kV	VINDHYACHAL-VARANASI	2	0	3472	0.0	49.6	-49.6
11	400 kV	ZERDA-KANKROLI	1	260	132	1.7	0.2	1.5
12	400 kV	ZERDA -BHINMAL	1	179	91	1.2	0.2	1.0
13	400 kV	VINDHYACHAL -RIHAND	1	974	0	21.4	0.0	21.4
14	400 kV	RAPP-SHUJALPUR	2	747	459	5.1	1.3	3.8
15	400 kV	NEEMUCH-Chittorgarh	2	777	467	5.9	1.3	4.6
16	220 kV	BHANPURA-RANPUR	1	0	177	0.0	3.0	-3.0
17	220 kV	BHANPURA-MORAK	1	0	30	0.0	1.8	-1.8
18	220 kV	MEHGAON-AURAIYA	1	90	18	0.9	0.0	0.9
19	220 kV	MALANPUR-AURAIYA	1	60	43	0.5	0.1	0.3
20	132 kV	GWALIOR-SAWAI MADHOPUR	1	0	0	0.0	0.0	0.0
21	132 kV	RAJGHAT-LALITPUR	2	0	0	0.0	0.0	0.0
WR-NR						54.6	263.4	-208.8
Import/Export of WR (With SR)								
1	HVDC	BHADRAWATI B/B	-	0	1003	0.0	12.2	-12.2
2	HVDC	RAIGARH-PUGALUR	2	0	2001	0.0	23.8	-23.8
3	765 kV	SOLAPUR-RAICHUR	2	1204	1086	3.6	9.5	-5.9
4	765 kV	WARDHA-NIZAMABAD	2	5	2394	0.0	32.8	-32.8
5	765 kV	WARORA-WARANGAL(NEW)	2	0	2510	0.0	35.3	-35.3
6	400 kV	KOLHAPUR-KUDGI	2	1893	0	27.6	0.0	27.6
7	220 kV	KOLHAPUR-CHIKODI	2	0	0	0.0	0.0	0.0
8	220 kV	PONDA-AMBEWADI	1	0	0	0.0	0.0	0.0
9	220 kV	XELDEM-AMBEWADI	1	0	107	2.0	0.0	2.0
WR-SR						33.2	113.4	-80.3
INTERNATIONAL EXCHANGES								
State	Region	Line Name	Max (MW)	Min (MW)	Avg (MW)	Import(+ve)/Export(-ve) Energy Exchange (MU)		
BHUTAN	ER	400kV MANGDECHHU-ALIPURDUAR 1,2&3 i.e. ALIPURDUAR RECEIPT (from MANGDECHU HEP 4*180MW)	230	19	81	1.95		
	ER	400kV TALA-BINAGURI 1,2,4 (& 400kV MALBASE - BINAGURI) i.e. BINAGURI RECEIPT (from TALA HEP 6*170MW)	-192	95	-74	-1.77		
	ER	220kV CHUKHA-BIRPARA 1&2 (& 220kV MALBASE - BIRPARA) i.e. BIRPARA RECEIPT (from CHUKHA HEP 4*84MW)	-247	-100	-173	-4.15		
	NER	132kV GELEPHU-SALAKATI	-24	-12	-16	-0.38		
	NER	132kV MOTANGA-RANGIA	-30	-2	-8	-0.18		
NEPAL	NR	NEPAL IMPORT (FROM UP)	-60	0	-38	-0.90		
	NR	132kV MAHENDRANAGAR-TANAKPUR(NHPC)	-60	0	-39	-0.93		
	ER	NEPAL IMPORT (FROM BIHAR)	-192	-41	-88	-2.11		
	ER	400kV DHALKEBAR-MUZAFFARPUR 1&2	-290	-16	-175	-4.21		
BANGLADESH	ER	BHERAMARA B/B HVDC (B'DESH)	-941	-652	-834	-20.02		
	ER (Isolated from Indian Grid)	400kV GODDA_TPS-RAHANPUR (B'DESH) D/C	-660	-333	-462	-11.10		
	NER	132kV COMILLA-SURAJMANI NAGAR 1&2	-60	0	-48	-1.14		

Export From India (in MU)

Country	GNA (ISGS/PPA)	T-GNA							TOTAL	
		BILATERAL TOTAL	COLLECTIVE							
			IDAM			RTM				
			IEX	PXIL	HPX	IEX	PXIL	HPX		
Bhutan	0.00	0.30	5.43	0.00	0.00	0.00	0.00	0.00	5.73	
Nepal	2.16	0.00	3.57	0.00	0.00	0.00	0.61	0.00	0.00	6.34
Bangladesh	20.83	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	20.83
Myanmar	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total Export	22.99	0.30	9.00	0.00	0.00	0.00	0.61	0.00	0.00	32.90

Import by India(in MU)

Country	GNA (ISGA/PPA)	T-GNA							TOTAL
		BILATERAL TOTAL	COLLECTIVE						
			IDAM			RTM			
			IEX	PXIL	HPX	IEX	PXIL	HPX	
Bhutan	0.79	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.79
Nepal	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Bangladesh	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Myanmar	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total Import	0.79	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.79

Net from India(in MU)

-ve : Export / +ve : Import

Country	GNA (ISGS/PPA)	T-GNA							TOTAL
		BILATERAL TOTAL	COLLECTIVE						
			IDAM			RTM			
			IEX	PXIL	HPX	IEX	PXIL	HPX	
Bhutan	0.79	-0.30	-5.43	0.00	0.00	0.00	0.00	0.00	-4.94
Nepal	-2.16	0.00	-3.57	0.00	0.00	-0.61	0.00	0.00	-6.34
Bangladesh	-20.83	0.00	0.00	0.00	0.00	0.00	0.00	0.00	-20.83
Myanmar	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total Net	-22.20	-0.30	-9.00	0.00	0.00	-0.61	0.00	0.00	-32.11

Date of Reporting: 18-Jan-2025												
15 Min (INSTANTANEOUS) ALL INDIA GRID FREQUENCY, GENERATION & DEMAND MET (SCADA DATA)												
TIME	FREQUENCY (Hz)	DEMAND MET (MW)	NUCLEAR (MW)	WIND (MW)	SOLAR (MW)	HYDRO** (MW)	GAS (MW)	THERMAL (MW)	OTHERS* (MW)	NET DEMAND MET (MW)	TOTAL GENERATION (MW)	NET TRANSNATIONAL EXCHANGE (MW) (+ve) Import, (-ve) Export
		(A)	(B)	(C)	(D)	(E)	(F)	(G)	(H)	(I=A-(C+D))	(J=B+C+D+E+F+G+H)	(K)
0:00	50.02	151420	5242	12938	761	5889	1928	127033	2915	137721	156706	-1638
0:15	49.97	150916	5246	12950	761	5709	1929	126431	2938	137205	155964	-1706
0:30	50.02	149940	5252	13112	763	5867	1929	125156	2924	136065	155003	-1703
0:45	50.02	149036	5275	13209	764	5674	1933	124067	3026	135063	153948	-1675
1:00	50.02	147689	5267	13359	766	5377	1934	123049	2985	133564	152737	-1676
1:15	50.03	146801	5273	13569	762	5211	1935	122020	2994	132470	151764	-1594
1:30	50.03	145959	5254	13802	762	5050	2091	121077	3020	131395	151056	-1479
1:45	50.02	145108	5275	14058	763	5193	1925	119783	2955	130287	149952	-1521
2:00	50.13	143933	5265	14124	766	5083	2083	118852	2960	129043	149133	-1502
2:15	50.07	143134	5317	14149	766	4442	2083	118457	2990	128219	148204	-1482
2:30	50.02	143152	5344	14139	764	4327	2098	118799	2943	128249	148414	-1481
2:45	50.02	142878	5399	14149	763	4214	2092	118369	3004	127966	147990	-1467
3:00	50.08	142050	5403	14203	759	4295	2088	117392	2971	127088	147111	-1476
3:15	50.03	142523	5414	14166	755	4330	2098	117731	2973	127602	147467	-1462
3:30	49.97	142309	5413	14003	752	4301	2091	117881	2984	127554	147425	-1475
3:45	49.97	142783	5422	13767	752	4354	2099	118502	2969	128264	147865	-1355
4:00	50.03	142727	5417	13630	748	4492	2092	118595	2965	128349	147939	-1378
4:15	49.97	144736	5419	13536	747	4614	2093	120410	2958	130453	149777	-1352
4:30	49.98	146327	5423	13524	749	4740	2100	122107	2963	132054	151606	-1383
4:45	49.98	148253	5439	13508	750	4881	2087	123895	3053	133995	153613	-1390
5:00	50.03	150525	5440	13580	752	5433	2083	125277	3007	136193	155572	-1413
5:15	49.98	154197	5448	13657	756	5642	2095	129078	2957	139784	159633	-1451
5:30	49.98	158178	5370	13654	756	5853	2095	132503	3008	143768	163239	-1352
5:45	49.88	162529	5457	13409	765	6949	2095	135794	2988	148355	167457	-1219
6:00	50.03	166772	5455	13207	774	8332	2096	138734	3002	152791	171600	-1127
6:15	49.98	171602	5457	13072	907	8944	2067	142931	3020	157623	176398	-1156
6:30	49.93	178391	5451	12944	949	11287	2147	147485	3039	164498	183302	-1186
6:45	50.03	184517	5476	12845	962	13655	2162	151851	3008	170710	189959	-1124
7:00	49.93	189742	5466	12921	1111	15397	2168	154591	3018	175710	194672	-1115
7:15	49.93	196052	5495	12996	1723	19031	2197	156988	3032	181333	201462	-1112
7:30	49.93	200014	5528	13142	2603	21414	2199	158393	3077	184269	206356	-1037
7:45	49.93	204107	5567	13008	3976	22697	2198	159691	3114	187123	210251	-1035
8:00	49.93	206222	5539	12704	6148	22716	2206	159972	3128	187370	212413	-990
8:15	49.93	210307	5544	12071	8812	23342	2210	160474	3158	189424	215611	-1049
8:30	49.93	214133	5579	11538	12544	23017	2202	160365	3194	190051	218439	-1046
8:45	49.93	216789	5598	10816	16127	22133	1946	161012	3181	189846	220813	-999
9:00	49.93	217851	5609	10413	20096	19739	1948	160303	3278	187342	221386	-933
9:15	49.93	221169	5631	10081	23943	18618	1969	161560	3278	187145	225080	-1052
9:30	49.93	223340	5628	9636	27698	17622	1957	161089	3221	186006	226851	-976
9:45	49.93	224158	5560	9537	31230	15602	1959	160826	3278	183391	227992	-1158
10:00	49.93	225094	5586	9571	34732	14398	1951	158819	3319	180791	228376	-1222
10:15	49.93	226570	5590	9628	37827	13194	2165	159094	3306	179115	230804	-1377
10:30	49.93	227245	5579	9835	41449	11877	2144	156859	3333	175961	231076	-1495
10:45	49.93	225808	5547	10161	45693	8704	2087	154506	3316	169954	230014	-1506
11:00	49.93	226052	5584	10510	49760	7993	2089	150868	3307	165782	230111	-1508
11:15	49.93	224013	5542	10822	51536	7302	2069	147571	3297	161655	228139	-1430
11:30	49.93	222941	5571	11312	53460	7097	2047	144741	3395	158169	227623	-1771
11:45	49.93	221036	5557	11551	54539	7011	2041	141493	3362	154946	225554	-1770
12:00	49.93	219556	5528	11609	55168	6768	1992	139300	3379	152779	223744	-1748
12:15	49.93	217125	5517	11726	55567	6281	1941	137256	3340	149832	221628	-1756
12:30	49.93	215746	5532	11843	56327	6185	1885	134996	3337	147576	220105	-1763
12:45	49.93	213831	5538	11867	55941	6492	1905	132941	3333	146023	218017	-1770
13:00	49.93	211078	5547	12135	55144	6129	1899	130849	3352	143799	215055	-1737
13:15	49.93	205957	5529	12002	53726	6090	1909	127348	3379	140229	209983	-1785
13:30	49.93	203871	5537	11867	53736	5611	1906	125723	3403	138268	207783	-1738
13:45	49.93	202879	5546	11678	53414	5588	1901	125783	3334	137787	207244	-1694
14:00	49.93	202406	5643	11543	53132	5628	1926	125065	3500	137731	206437	-1584
14:15	49.93	201193	5654	11463	52439	5204	1932	125210	3514	137291	205416	-1621
14:30	49.93	200955	5648	11479	51108	5513	1915	126192	3510	138368	205365	-1591
14:45	49.93	200685	5526	11550	48711	5544	1920	128265	3509	140424	205025	-1579
15:00	49.93	200128	5524	11426	45039	6213	1921	130483	3479	143663	204085	-1556
15:15	49.98	199797	5553	11408	42829	6309	1930	131840	3456	145560	203325	-1458
15:30	50.03	199080	5558	11605	39906	6987	1955	133683	3482	147569	203176	-1494
15:45	50.03	198889	5562	11620	36942	7876	1928	135658	3511	150327	203097	-1405
16:00	50.03	198892	5581	11780	32990	8226	1948	139187	3440	154122	203152	-1379
16:15	50.03	197193	5569	11640	28308	8156	1951	142334	3482	157245	201440	-1389
16:30	50.03	198416	5594	11452	24243	9555	1962	146415	3405	162721	202626	-1208
16:45	50.03	197677	5537	11324	19148	10360	1935	150022	3388	167205	201714	-1091
17:00	50.03	198331	5627	10995	14623	13563	1924	152575	3580	172713	202887	-1208
17:15	49.98	195396	5649	10696	10201	15173	1821	153230	3488	174499	200258	-1075
17:30	50.08	196844	5672	10393	6565	18462	1846	155180	3422	179886	201540	-1067
17:45	49.98	199561	5702	9931	3956	20093	1918	159253	3475	185674	204328	-1047
18:00	50.03	200513	5715	9616	2179	21214	1924	161016	3448	188718	205112	-1051
18:15	49.93	200916	5737	9410	1267	22446	1921	161604	3470	190239	205855	-1043
18:30	49.98	202088	5755	9600	1102	22944	1936	162679	3409	191386	207425	-1029
18:45	50.03	201798	5749	10270	1045	21866	1931	162600	3426	190483	206887	-1018
19:00	50.03	200278	5800	11074	875	20581	1937	161629	3444	188329	205340	-994
19:15	50.03	199263	5829	11841	876	19073	1934	161439	3374	186546	204366	-991
19:30	50.08	197584	5863	12632	873	17733	1839	159619	3381	184079	201940	-990
19:45	50.08	194895	5845	13188	870	15739	1841	158326	3427	180837	199236	-988
20:00	50.08	190877	5861	13424	877	13017	1845	156602	3398	176576	195024	-990
20:15	50.03	187289	5846	13857	832	11035	1847	154253	3379	172600	191049	-1044
20:30	49.93	184540	5827	14387	832	10037	1857	153129	3354	169321	189423	-1001
20:45	49.93	182270	5855	14481	827	9569	1851	151513	3304	166962	187400	-1045
21:00	50.03	178465	5857	14697	786	9146	1844	148156	3351	162982	183837	-1100
21:15	49.98	176413	5855	15227	787	8692	1839	146376	3347	160399	182123	-1357
21:30	50.03	174158	5865	15396	791	8306	1839	144165	3346	157971	179708	-1433
21:45	49.98	172121	5880	15491	796	7825	1841	142387	3356	155834	177576	-1480
22:00	50.03	168581	5871	15237	798	7191	1828	139803	3374	152546	174102	-1480
22:15	49.93	167994	5877	15259	804	7646	1835	138846	3349	151931	173616	