



National Load Despatch Centre
राष्ट्रीय भार प्रेषण केंद्र
GRID CONTROLLER OF INDIA LIMITED
ग्रिड कंट्रोलर ऑफ इंडिया लिमिटेड

(Government of India Enterprise/ भारत सरकार का उद्यम)
B-9, QUTUB INSTITUTIONAL AREA, KATWARIA SARAI, NEW DELHI -110016
बी-9, कुतुब इन्स्टीट्यूशनल एरिया, कटवारिया सराये, न्यू दिल्ली-110016

Ref: GRID-INDIA/NLDC/SO/Daily PSP Report

दिनांक: 02.05.2025

To,

- कार्यकारी निदेशक, पू.क्षे.भा.प्रे.के., 14, गोल्फ क्लब रोड, कोलकाता - 700033
Executive Director, ERLDC, 14 Golf Club Road, Tollygunge, Kolkata, 700033
- कार्यकारी निदेशक, ऊ.क्षे.भा.प्रे.के., 18/ए, शाहीद जीत सिंह सनसनवाल मार्ग, नई दिल्ली - 110016
Executive Director, NRLDC, 18-A, Shaheed Jeet Singh Marg, Katwaria Sarai, New Delhi - 110016
- कार्यकारी निदेशक, प.क्षे.भा.प्रे.के., एफ3, एम आई डी सी क्षेत्र, अंधेरी, मुंबई -400093
Executive Director, WRLDC, F-3, M.I.D.C. Area, Marol, Andheri (East), Mumbai-400093
- कार्यकारी निदेशक, ऊ.पू.क्षे.भा.प्रे.के., डोंगतेह, लोअर नोंग्रह, लापालंग, शिलोंग - 793006
Executive Director, NERLDC, Dongteih, Lower Nongrah, Lapalang, Shillong - 793006, Meghalaya
- कार्यकारी निदेशक, द.क्षे.भा.प्रे.के., 29, रेस कोर्स क्रॉस रोड, बंगलुरु -560009
Executive Director, SRLDC, 29, Race Course Cross Road, Bangalore-560009

Sub: Daily PSP Report for the date 01.05.2025.

महोदय/Sir,

आईईजीसी-2023 की धारा स.-38(1) के प्रावधान के अनुसार, दिनांक 1-मई-2025 की अखिल भारतीय प्रणाली की दैनिक ग्रिड निष्पादन रिपोर्ट रांभांप्रेके की वेबसाइट पर उपलब्ध है।

As per article 38(1) of the Indian Electricity Grid Code, the daily report pertaining power supply position of All India Power System for the date 01.05.2025, is available at the NLDC website.

धन्यवाद,
Thanks

Report for previous day

Date of Reporting: 02-May-2025

A. Power Supply Position at All India and Regional level

	NR	WR	SR	ER	NER	TOTAL
Demand Met during Evening Peak hrs(MW) (at 20:00 hrs; from RLDCs)	66594	63775	46744	20526	2499	200138
Peak Shortage (MW)	0	0	0	0	0	0
Energy Met (MU)	1502	1605	1181	503	50	4841
Hydro Gen (MU)	258	21	69	31	14	393
Wind Gen (MU)	24	189	68	-	-	281
Solar Gen (MU)*	191.77	154.88	140.42	3.82	0.45	491
Energy Shortage (MU)	0.19	0.00	0.00	0.00	0.00	0.19
Maximum Demand Met During the Day (MW) (From NLDC SCADA)	68969	72275	54485	24317	2616	215096
Time Of Maximum Demand Met	00:00	15:46	15:35	00:02	18:33	00:00

B. Frequency Profile (%)

Region	FVI	< 49.7	49.7 - 49.8	49.8 - 49.9	< 49.9	49.9 - 50.05	> 50.05
All India	0.070	0.00	0.00	1.77	1.77	66.93	31.30

C. Power Supply Position in States

Region	States	Max.Demand Met during the day (MW)	Shortage during maximum Demand (MW)	Energy Met (MU)	Drawal Schedule (MU)	OD(+)/UD(-) (MU)	Max OD (MW)	Energy Shortage (MU)
NR	Punjab	11225	0	202.2	101.5	-5.0	755	0.00
	Haryana	9909	0	214.4	169.8	1.3	292	0.19
	Rajasthan	15818	0	323.9	123.4	-1.5	799	0.00
	Delhi	5956	0	123.3	113.5	-2.7	194	0.00
	UP	25186	0	492.0	182.5	0.1	489	0.00
	Uttarakhand	2215	0	48.1	27.8	-0.3	109	0.00
	HP	1690	0	33.0	5.1	-0.6	199	0.00
	J&K(UT) & Ladakh(UT)	2777	0	55.1	38.7	-1.1	526	0.00
	Chandigarh	315	0	6.1	6.4	-0.3	10	0.00
	Railways_NR ISTS	214	0	4.1	4.0	0.1	45	0.00
WR	Chhattisgarh	5395	0	107.6	60.6	-6.9	458	0.00
	Gujarat	25443	0	507.3	167.7	-5.0	666	0.00
	MP	13397	0	297.0	182.1	-3.1	954	0.00
	Maharashtra	28573	0	616.9	220.4	2.5	849	0.00
	Goa	767	0	16.4	15.9	0.3	55	0.00
	DNHDDPDCL	1287	0	27.4	27.5	-0.1	47	0.00
	AMNSIL	798	0	17.5	8.5	0.1	239	0.00
	BALCO	529	0	12.6	12.7	-0.1	7	0.00
	RIL JAMNAGAR	159	0	2.3	2.4	-0.1	0	0.00
	Andhra Pradesh	10505	0	226.8	78.9	-1.3	522	0.00
SR	Telangana	10169	0	211.0	94.7	1.6	688	0.00
	Karnataka	12317	0	253.6	89.8	-0.8	1028	0.00
	Kerala	4858	0	93.2	65.7	0.4	498	0.00
	Tamil Nadu	17148	0	386.0	236.4	0.2	631	0.00
	Puducherry	500	0	10.1	10.2	-0.2	69	0.00
ER	Bihar	6148	0	122.3	112.3	-0.9	505	0.00
	DVC	3006	0	60.5	-32.2	0.0	441	0.00
	Jharkhand	1933	0	37.2	33.3	-3.5	229	0.00
	Odisha	5528	0	111.1	28.2	-0.9	434	0.00
	West Bengal	8064	0	170.0	48.7	-3.0	266	0.00
	Sikkim	102	0	1.5	1.2	0.3	47	0.00
	Railways_ER ISTS	28	0	0.2	0.1	0.1	3	0.00
NER	Arunachal Pradesh	169	0	2.8	2.9	-0.2	35	0.00
	Assam	1506	0	29.3	23.6	-0.2	169	0.00
	Manipur	212	0	2.8	3.0	-0.1	33	0.00
	Meghalaya	335	0	5.6	1.9	0.0	86	0.00
	Mizoram	121	0	2.3	1.8	-0.1	16	0.00
	Nagaland	139	0	2.4	2.5	-0.2	10	0.00
	Tripura	264	0	5.2	4.3	-0.1	36	0.00

D. Transnational Exchanges (MU) - Import(+ve)/Export(-ve)

	Bhutan	Nepal	Bangladesh	Godda -> Bangladesh
Actual (MU)	8.9	-8.5	-23.0	-21.1
Day Peak (MW)	631.0	-549.2	-977.0	-1378.4

E. Import/Export by Regions (in MU) - Import(+ve)/Export(-ve); OD(+)/UD(-)

	NR	WR	SR	ER	NER	TOTAL
Schedule(MU)	251.5	-309.4	169.2	-118.2	6.8	0.0
Actual(MU)	248.2	-300.0	159.2	-120.4	5.4	-7.7
OD/UD(MU)	-3.3	9.4	-10.0	-2.3	-1.5	-7.7

F. Generation Outage(MW)

	NR	WR	SR	ER	NER	TOTAL	% Share
Central Sector	4283	7922	3878	3110	318	19510	49
State Sector	6054	5946	6876	1469	169	20514	51
Total	10337	13868	10754	4579	487	40024	100

G. Sourcewise generation (Gross) (MU)

	NR	WR	SR	ER	NER	All India	% Share
Coal	791	1560	653	671	12	3687	70
Lignite	23	15	44	0	0	83	2
Hydro	258	21	69	31	14	393	8
Nuclear	33	65	71	0	0	169	3
Gas, Naptha & Diesel	19	36	9	0	23	87	2
RES (Wind, Solar, Biomass & Others)	227	349	235	5	0	817	16
Total	1351	2046	1081	708	49	5236	100

Share of RES in total generation (%)	16.77	17.06	21.78	0.77	0.91	15.60
Share of Non-fossil fuel (Hydro,Nuclear and RES) in total generation(%)	38.35	21.28	34.70	5.16	28.43	26.35

H. All India Demand Diversity Factor

Based on Regional Max Demands	1.035
Based on State Max Demands	1.091

I. All India Peak Demand and shortage at Solar and Non-Solar Hour

	Max Demand Met(MW)	Time	Shortage(MW)
Solar hr	212075	14:57	0
Non-Solar hr	215096	0:00	0

Diversity factor = Sum of regional or state maximum demands / All India maximum demand

**Note: All generation MU figures are gross

***Godda (Jharkhand) -> Bangladesh power exchange is through the radial connection (isolated from Indian Grid)

Solar Hours -> 06:00 to 18:00hrs and rest are Non-Solar Hours

*Source: RLDCs for solar connected to ISTS; SLDCs for embedded solar. Limited visibility of embedded solar data.

Executive Director-NLDC

INTER-REGIONAL EXCHANGES

Import=(+ve) /Export =(-ve) for NET (MU)

Date of Reporting: 02-May-2025

Sl No	Voltage Level	Line Details	No. of Circuit	Max Import (MW)	Max Export (MW)	Import (MU)	Export (MU)	NET (MU)
Import/Export of ER (With NR)								
1	HVDC	ALIPURDUAR-AGRA	2	0	0	0.0	0.0	0.0
2	HVDC	PUSAULI B/B	-	0	47	0.0	2.4	-2.4
3	765 kV	GAYA-VARANASI	2	706	1048	0.0	8.5	-8.5
4	765 kV	SASARAM-FATEHPUR	1	293	490	0.0	5.0	-5.0
5	765 kV	GAYA-BALIA	1	1	776	0.0	10.8	-10.8
6	400 kV	PUSAULI-VARANASI	1	0	97	0.0	1.0	-1.0
7	400 kV	PUSAULI-JALLAHABAD	1	0	98	0.0	1.4	-1.4
8	400 kV	MUZAFFARPUR-GORAKHPUR	2	491	712	0.0	5.0	-5.0
9	400 kV	PATNA-BALIA	2	226	892	0.0	11.2	-11.2
10	400 kV	NAUBATPUR-BALIA	2	141	285	0.0	3.1	-3.1
11	400 kV	BIHARSHARIEF-BALIA	2	427	327	0.0	0.5	-0.5
12	400 kV	MOTIHARI-GORAKHPUR	2	218	467	0.0	5.0	-5.0
13	400 kV	BIHARSARIEF-SAHUPURI	2	125	222	0.0	4.0	-4.0
14	220 kV	SAHUPURI-KARMANASA	1	0	60	0.0	0.2	-0.2
15	132 kV	NAGAR UNTARI-RIHAND	1	0	0	0.0	0.0	0.0
16	132 kV	GARWAH-RIHAND	1	0	0	0.0	0.0	0.0
17	132 kV	KARMANASA-SAHUPURI	1	0	0	0.0	0.0	0.0
18	132 kV	KARMANASA-CHANDAULI	1	0	0	0.0	0.0	0.0
ER-NR						0.0	58.1	-58.1
Import/Export of ER (With WR)								
1	765 kV	JHARSUGUDA-DHARAMJAIGARH	4	975	1033	0.0	1.9	-1.9
2	765 kV	NEW RANCHI-DHARAMJAIGARH	2	1356	647	3.6	0.0	3.6
3	765 kV	JHARSUGUDA-DURG	2	0	1124	0.0	17.4	-17.4
4	400 kV	JHARSUGUDA-RAIGARH	4	9	611	0.0	7.1	-7.1
5	400 kV	RANCHI-SIPAT	2	294	216	0.1	0.0	0.1
6	220 kV	BUDHIPADAR-RAIGARH	1	11	126	0.0	1.7	-1.7
7	220 kV	BUDHIPADAR-KORBA	2	277	114	0.1	0.0	0.1
ER-WR						3.8	28.0	-24.2
Import/Export of ER (With SR)								
1	HVDC	JEYPORE-GAZUWAKA B/B	2	202	0	4.8	0.0	4.8
2	HVDC	TALCHER-KOLAR BIPOLE	2	0	1764	0.0	38.0	-38.0
3	765 kV	ANGUL-SRIKAKULAM	2	0	3122	0.0	52.7	-52.7
4	400 kV	TALCHER-I/C	2	736	474	1.3	0.0	1.3
5	220 kV	BALIMELA-UPPER-SILERRU	1	0	0	0.0	0.0	0.0
ER-SR						4.8	90.8	-86.0
Import/Export of ER (With NER)								
1	400 kV	BINAGURI-BONGAIGAON	2	396	60	2.8	0.2	2.6
2	400 kV	ALIPURDUAR-BONGAIGAON	2	615	180	2.5	0.0	2.5
3	220 kV	ALIPURDUAR-SALAKATI	2	122	13	0.9	0.0	0.9
ER-NER						6.2	0.2	6.0
Import/Export of NER (With NR)								
1	HVDC	BISWANATH CHARIALI-AGRA	2	474	0	11.7	0.0	11.7
NER-NR						11.7	0.0	11.7
Import/Export of WR (With NR)								
1	HVDC	CHAMPA-KURUKSHETRA	2	0	3521	0.0	70.4	-70.4
2	HVDC	VINDHYACHAL B/B	-	98	104	2.3	0.1	2.2
3	HVDC	MUNDRA-MOHINDERGARH	2	0	1453	0.0	36.3	-36.3
4	765 kV	GWALIOR-AGRA	2	0	1743	0.0	25.2	-25.2
5	765 kV	GWALIOR-PHAGI	2	1123	1558	5.5	17.8	-12.3
6	765 kV	JABALPUR-ORAI	2	123	902	0.0	23.7	-23.7
7	765 kV	GWALIOR-ORAI	1	732	0	11.2	0.0	11.2
8	765 kV	SATNA-ORAI	1	0	1093	0.0	18.6	-18.6
9	765 kV	BANASKANTHA-CHITORGARH	2	0	1011	0.0	11.4	-11.4
10	765 kV	VINDHYACHAL-VARANASI	2	0	2369	0.0	44.8	-44.8
11	400 kV	ZERDA-KANKROLI	1	100	89	0.4	0.0	0.4
12	400 kV	ZERDA-BHIMMAL	1	74	68	0.3	0.3	0.0
13	400 kV	VINDHYACHAL-BIHAND	1	973	0	19.1	0.0	19.1
14	400 kV	RAPP-SHUJALPUR	2	570	293	3.9	1.7	2.1
15	400 kV	NEEMUCH-Chittorgarh	2	627	299	3.6	1.7	1.9
16	220 kV	BHANPURA-RANPUR	1	0	83	0.0	1.4	-1.4
17	220 kV	BHANPURA-MORAR	1	0	30	0.0	2.2	-2.2
18	220 kV	MEHGAON-AURAIYA	1	58	0	0.9	0.0	0.9
19	220 kV	MALANPUR-AURAIYA	1	39	0	0.4	0.0	0.4
20	132 kV	GWALIOR-SAWAI MADHOPUR	1	0	0	0.0	0.0	0.0
21	132 kV	RAIGHAT-LALITPUR	2	0	0	0.0	0.0	0.0
WR-NR						47.6	256.0	-208.4
Import/Export of WR (With SR)								
1	HVDC	BHADRAWATI B/B	-	0	1008	0.0	19.0	-19.0
2	HVDC	RAIGARH-PUGALUR	2	0	4003	0.0	56.6	-56.6
3	765 kV	SOLAPUR-RAICHUR	2	711	1416	4.5	4.5	0.0
4	765 kV	WARDHA-NIZAMABAD	2	0	2472	0.0	29.7	-29.7
5	765 kV	WARORA-WARANGAL(NEW)	2	0	2787	0.0	35.5	-35.5
6	400 kV	KOLHAPUR-KUDGI	2	1376	0	22.8	0.0	22.8
7	220 kV	KOLHAPUR-CHIKODI	2	0	0	0.0	0.0	0.0
8	220 kV	PONDA-AMBEWADI	1	0	0	0.0	0.0	0.0
9	220 kV	XELDEM-AMBEWADI	1	0	128	2.6	0.0	2.6
WR-SR						29.9	145.3	-115.4

INTERNATIONAL EXCHANGES						Import(+ve)/Export(-ve)	
State	Region	Line Name	Max (MW)	Min (MW)	Avg (MW)	Energy Exchange (MU)	
BHUTAN	ER	400kV MANGDECHHU-ALIPURDUAR 1,2&3 I.e. ALIPURDUAR RECEIPT (from MANGDECHHU HEP 4*180MW)	549	237	367	8.81	
	ER	400kV TALA-BINAGURI 1,2,4 (& 400kV MALBASE - BINAGURI) I.e. BINAGURI RECEIPT (from TALA HEP 6*170MW)	238	-11	123	2.95	
	ER	220kV CHUKHA-BIRPARA 1&2 (& 220kV MALBASE - BIRPARA) I.e. BIRPARA RECEIPT (from CHUKHA HEP 4*84MW)	-150	-76	-115	-2.77	
	NER	132kV GELEPHU-SALAKATI	-20	0	-12	-0.28	
	NER	132kV MOTANGA-RANGIA	19	-8	7	0.17	
NEPAL	NR	NEPAL IMPORT (FROM UP)	-67	0	0	0.00	
	NR	132kV MAHENDRANAGAR-TANAKPUR(NHPC)	-67	0	-45	-1.09	
	ER	NEPAL IMPORT (FROM BIHAR)	-217	0	-138	-3.32	
BANGLADESH	ER	400kV DHALKEBAR-MUZAFFARPUR 1&2	-332	22	-170	-4.07	
	ER	BHERAMARA B/B HVDC (B'DESH)	-937	-743	-924	-22.18	
	ER (Isolated from Indian Grid)	400kV GODDA_TPS-RAHANPUR (B'DESH) D/C	-1378	-808	-880	-21.12	
	NER	132kV COMILLA-SURAJMANI NAGAR 1&2	-40	0	-33	-0.80	

CROSS BORDER EXCHANGE SCHEDULE

Date of Reporting: 02-May-2025

Export From India (in MU)

Export From India (in M\$)									
Country	GNA (ISGS/PPA)	T-GNA							TOTAL
		BILATERAL TOTAL	COLLECTIVE						
			IDAM			RTM			
			IEX	PXIL	HPX	IEX	PXIL	HPX	
Bhutan	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Nepal	3.51	0.00	4.02	0.00	0.00	0.62	0.00	0.00	8.15
Bangladesh	23.02	0.00	0.00	0.00	0.00	0.00	0.00	0.00	23.02
Myanmar	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total Export	26.53	0.00	4.02	0.00	0.00	0.62	0.00	0.00	31.17

Import by India(in MU)

import by mode (in M\$)		T-GNA							TOTAL
Country	GNA (ISGA/PPA)	BILATERAL TOTAL	COLLECTIVE						
			IDAM			RTM			
			IEX	PXIL	HPX	IEX	PXIL	HPX	
Bhutan	8.40	0.00	0.00	0.00	0.00	0.00	0.00	0.00	8.40
Nepal	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Bangladesh	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Myanmar	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total Import	8.40	0.00	0.00	0.00	0.00	0.00	0.00	0.00	8.40

Net from India(in MU)

-ve : Export / +ve : Import

Net from India (in MU)		T-GNA							-ve : Export / +ve : Import
Country	GNA (ISGS/PPA)	BILATERAL TOTAL	COLLECTIVE						TOTAL
			IDAM			RTM			
			IEX	PXIL	HPX	IEX	PXIL	HPX	
Bhutan	8.40	0.00	0.00	0.00	0.00	0.00	0.00	0.00	8.40
Nepal	-3.51	0.00	-4.02	0.00	0.00	-0.62	0.00	0.00	-8.15
Bangladesh	-23.02	0.00	0.00	0.00	0.00	0.00	0.00	0.00	-23.02
Myanmar	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total Net	-18.13	0.00	-4.02	0.00	0.00	-0.62	0.00	0.00	-22.77

Date of Reporting: 02-May-2025

15 Min (INSTANTANEOUS) ALL INDIA GRID FREQUENCY, GENERATION & DEMAND MET (SCADA DATA)												
TIME	FREQUENCY (Hz)	DEMAND MET (MW)	NUCLEAR (MW)	WIND (MW)	SOLAR (MW)	HYDRO** (MW)	GAS (MW)	THERMAL (MW)	OTHERS* (MW)	NET DEMAND MET (MW)	TOTAL GENERATION (MW)	NET TRANSNATIONAL EXCHANGE (MW) (+ve) Import, (-ve) Export
		(A)	(B)	(C)	(D)	(E)	(F)	(G)	(H)	(I=A-(C+D))	(J=B+C+D+E+F+G+H)	(K)
0:00	50.00	215096	6306	14160	24	20344	5687	169968	1869	200912	218358	-1126
0:15	50.00	214567	6323	14075	29	20844	5163	169217	1826	200463	217477	-829
0:30	50.05	213267	6316	14024	29	20878	4620	168552	1849	199214	216268	-836
0:45	50.00	211265	6359	13788	34	20825	4447	166868	1822	197443	214143	-847
1:00	50.00	210098	6332	13715	35	20516	4378	166113	1814	196348	212903	-828
1:15	49.95	208110	6351	13775	35	20071	4332	164756	1807	194300	211127	-815
1:30	50.00	206690	6359	13748	39	19449	4258	163936	1822	192903	209611	-784
1:45	50.00	205236	6345	13911	36	18392	4152	163655	1814	191289	208305	-765
2:00	50.00	203717	6329	14198	37	17216	4010	162994	1837	189482	206621	-794
2:15	50.00	202642	6335	14305	32	16810	3914	162371	1808	188305	205575	-840
2:30	50.00	201437	6332	14300	32	16735	3833	161326	1847	187105	204405	-888
2:45	50.00	200442	6329	14387	40	16312	3814	160681	1836	186015	203399	-842
3:00	50.00	199042	6355	14287	42	15796	3708	160180	1813	184713	202181	-812
3:15	50.00	198585	6329	14247	42	15037	3710	160215	1855	184296	201435	-669
3:30	50.00	197493	6361	13980	36	14972	3675	159488	1863	183477	200375	-690
3:45	50.00	196616	6388	13644	19	14910	3654	159077	1799	182953	199491	-735
4:00	50.05	195506	6364	13265	24	14806	3613	158575	1842	182217	198489	-706
4:15	50.00	196252	6329	13091	32	15127	3567	158936	1828	183129	198910	-581
4:30	50.00	196894	6333	12954	32	15143	3342	159822	1876	183908	199502	-621
4:45	50.00	197264	6338	12832	35	15127	3312	160388	1869	184397	199901	-550
5:00	50.05	196885	6370	12849	35	15078	3305	160151	1888	184001	199676	-560
5:15	49.95	197909	6304	12665	31	15334	3300	161000	1879	185213	200513	-512
5:30	50.00	199087	6346	12591	29	15466	3334	162171	1829	186467	201766	-485
5:45	50.00	199011	6319	12210	44	15720	3351	162088	1825	186757	201557	-459
6:00	50.05	198184	6375	11748	79	15500	3385	161999	1853	186357	200939	-478
6:15	50.00	198710	6325	11255	996	15705	3387	162084	1810	186459	201562	-699
6:30	50.00	197695	6369	11013	2249	15462	3384	160484	1897	184433	200858	-842
6:45	50.06	196266	6347	10594	4363	15507	3346	157367	1876	181309	199400	-967
7:00	50.00	194861	6363	10311	7309	15058	3275	153855	1846	177241	198017	-1147
7:15	50.00	193404	6339	9666	10946	14768	3216	149491	1908	172792	196334	-1076
7:30	50.00	192591	6379	8939	15291	14559	3196	145067	1906	168361	195337	-861
7:45	50.00	191634	6382	8156	20261	14216	3202	140399	1938	163217	194554	-1029
8:00	50.05	189960	6373	7592	24913	13703	3186	135375	1952	157455	193094	-1027
8:15	50.00	190919	6349	7176	29551	13498	3201	131993	1942	154192	193710	-1111
8:30	50.05	191612	6370	7060	33954	13021	3224	129254	1953	150598	194836	-1112
8:45	50.00	192589	6357	7108	38252	12764	3213	126073	2093	147229	195860	-1168
9:00	50.05	193946	6370	7155	41856	12451	3180	124523	2010	144935	197545	-1140
9:15	50.05	197000	6315	7418	45046	11806	3152	124559	2006	144536	200302	-994
9:30	50.05	199219	6397	7588	48211	11746	3151	123465	1989	143420	202547	-996
9:45	50.05	200598	6349	7590	51350	11907	3161	121406	2054	141658	203817	-909
10:0	50.10	201316	6359	7599	53994	11754	3155	119404	2074	139723	204339	-915
10:1	50.05	201877	6382	7613	56292	11025	3182	118223	2071	137972	204788	-871
10:3	50.10	202482	6354	7488	57896	10619	3174	117237	2076	137098	204844	-895
10:4	50.05	203542	6347	7313	59276	10443	3175	117129	2120	136953	205803	-843
11:0	50.10	203714	6333	7488	60369	9971	3169	116638	2108	135857	206076	-831
11:1	50.20	205213	6381	7791	62448	9435	3208	116448	2055	134974	207766	-870
11:3	50.15	205110	6389	7850	62880	9404	3197	116020	2111	134380	207851	-886
11:4	50.20	205722	6332	8286	63140	9237	3192	116102	2127	134296	208416	-892
12:0	50.25	205391	6324	8668	63288	9047	2996	115817	2091	133435	208231	-908
12:1	50.20	205054	6387	8823	63069	9036	3008	115618	2076	133162	208017	-939
12:3	50.05	205281	6352	9131	62966	9065	3007	115358	2077	133184	207956	-916
12:4	50.10	204994	6346	9269	62615	9213	3035	114928	2114	133110	207520	-849
13:0	50.10	204363	6314	9388	62106	9358	3009	114652	2184	132869	207011	-915
13:1	50.26	203081	6319	9546	61451	9099	3015	114195	2084	132084	205709	-897
13:3	50.16	203309	6329	9606	61128	9677	3019	114129	2070	132575	205958	-930
13:4	49.95	204467	6289	9852	59624	10603	3030	115373	2114	134991	206885	-921
14:0	50.05	205747	6295	10205	58770	11258	3021	116650	2059	136772	208258	-977
14:1	49.90	206679	6308	10481	57581	11340	3043	118692	2064	138617	209509	-1041
14:3	49.95	209071	6291	10593	55406	12160	3045	122152	2012	143072	211659	-1021
14:4	49.95	211033	6309	10588	53646	12757	3040	125129	1968	146799	213437	-1015
15:0	50.05	212016	6302	10746	51129	13138	2969	128356	2031	150141	214671	-1007
15:1	50.05	211214	6333	10844	48829	12195	3036	131226	1991	151541	214454	-1025
15:3	50.00	211035	6297	11061	43838	12996	3036	134685	1985	156136	213898	-1004
15:4	49.95	211095	6263	11232	40040	13736	3023	138207	2010	159823	214511	-967
16:0	49.95	210205	6287	11493	36171	14033	3025	140514	1968	162541	213491	-959
16:1	49.85	208027	6285	11813	31213	14410	3096	142754	1921	165001	211492	-921
16:3	49.90	207428	6270	12253	27369	14840	3087	145097	1911	167806	210827	-1034
16:4	49.90	205148	6310	12649	23977	15052	3089	145469	1879	168522	208425	-987
17:0	50.05	201881	6322	12739	20920	15631	3080	145092	1879	168222	205663	-1086
17:1	50.06	199261	6343	13275	17305	15777	3075	145736	1815	168681	203326	-1066
17:3	0.00	197345	6298	13735	14064	15547	3088	147154	1798	169546	201684	-1127
17:4	50.16	194259	6323	14085	10634	15765	3102	146587	1783	169540	198279	-1118
18:0	50.11	192288	6304	14073	7750	16419	3135	146618	1789	170465	196088	-1029
18:1	50.11	189360	6296	13813	4953	16588	3128	146498	1734	170594	193010	-816
18:3	50.11	189545	6305	13605	2828	17734	3212	147810	1744	173112	193238	-809
19:0	50.06	192243	6321	13419	1355	19829	3286	149969	1756	177469	195935	-813
19:1	50.11	194965	6289	13091	629	21644	3305	151747	1756	181245	198461	-808
19:3	50.00	198604	6295	12714	380	21698	3367	156028	1774	185510	202256	-786
19:4	50.06	200219	6324	12685	319	22151	3357	157204	1779	187215	203819	-782
20:0	50.06	200621	6358	12550	342	21691	3369	158004	1808	187729	204122	-766
20:1	50.06	199960	6322	12998	350	21087	3413	157434	1723	186612	203327	-772
20:3	50.01	198833	6339	13531	40	20542	3466	156412	1753	185262	202083	-767
20:4	50.01	198400	6315	13738	45	20095	3489	156220	1737	184617	201639	-853
21:0	50.00	198017	6327	13654	49	18978	3529	156928	1727	184314	201192	-817
21:1	50.00	197274	6352	14003	70	19215	3581	155468	1715	183201	200404	-820
21:3	50.05	196497	6339	14326	78	20081	3657	153739	1744	182093	199964	-808
21:4	50.00	197216	6348	14393	40	21082	3785	153388	1764	182783	200800	-795
22:0	50.00	198029	6351	13724	60	21288	3809	154498	1741	184245	201471	-801
22:1	50.05	197422	6337	13054	54	21398	3815	154738	1735	184314	201131	-805
22:3	50.00	199860	6314	12240	67	21839	3874	157158	1804	187553	203296	-744
22:4	50.00	201067	6331	11665	67	21774	3964	158788	1762	18		

*Others include (i) Biomass from Punjab (ii) Some of the state sector IPP & non-conventional generation in SR (small capacity) (iii) Solar generation in Odisha(manually punched).

** Hydro generation is excluding Bhutan hydro.

***Bhutan hydro is accounted for in net transnational exchange.

Disclaimer:

1. The information provided is for general informational purposes only.

2. The data is provided "as is" without any guarantees or warranties.

3. All Data is operational SCADA data telemetered and reporting at NLDC through RLDC/SLDC.

4. Data is subject to errors due to telemetry loss/freeze/garbage value etc.

5. Demand met and RE generation data is incident on transmission system. Resources in distribution system plus behind the meter (BTM) generation excluded.

6. Users are advised to ensure its accuracy, completeness and relevance for their purposes, and, in this respect, GRID-INDIA shall not be responsible for any errors or omissions.