



National Load Despatch Centre
राष्ट्रीय भार प्रेषण केंद्र
GRID CONTROLLER OF INDIA LIMITED
ग्रिड कंट्रोलर ऑफ इंडिया लिमिटेड

(Government of India Enterprise/ भारत सरकार का उद्यम)
B-9, QUTUB INSTITUTIONAL AREA, KATWARIA SARAI, NEW DELHI -110016
बी-9, कुतुब इन्स्टीट्यूशनल एरिया, कटवारिया सराये, न्यू दिल्ली-110016

Ref: GRID-INDIA/NLDC/SO/Daily PSP Report

दिनांक: 07.01.2025

To,

- कार्यकारी निदेशक, पू.क्षे.भा.प्रे.के., 14, गोल्फ क्लब रोड, कोलकाता - 700033
Executive Director, ERLDC, 14 Golf Club Road, Tollygunge, Kolkata, 700033
- कार्यकारी निदेशक, ऊ.क्षे.भा.प्रे.के., 18/ए, शाहीद जीत सिंह सनसनवाल मार्ग, नई दिल्ली - 110016
Executive Director, NRLDC, 18-A, Shaheed Jeet Singh Marg, Katwaria Sarai, New Delhi - 110016
- कार्यकारी निदेशक, प.क्षे.भा.प्रे.के., एफ3, एम आई डी सी क्षेत्र, अंधेरी, मुंबई - 400093
Executive Director, WRLDC, F-3, M.I.D.C. Area, Marol, Andheri (East), Mumbai-400093
- कार्यकारी निदेशक, ऊ.पू.क्षे.भा.प्रे.के., डोंगतेह, लोअर नोंग्रह, लापालंग, शिलोंग - 793006
Executive Director, NERLDC, Dongteih, Lower Nongrah, Lapalang, Shillong - 793006, Meghalaya
- कार्यकारी निदेशक, द.क्षे.भा.प्रे.के., 29, रेस कोर्स क्रॉस रोड, बंगलुरु - 560009
Executive Director, SRLDC, 29, Race Course Cross Road, Bangalore-560009

Sub: Daily PSP Report for the date 06.01.2025.

महोदय/Dear Sir,

आईईजीसी-2023 की धारा स.-38(1) के प्रावधान के अनुसार, दिनांक 6-जनवरी-2025 की अखिल भारतीय प्रणाली की दैनिक ग्रिड निष्पादन रिपोर्ट रांभांप्रेके की वेबसाइट पर उपलब्ध है।

As per article 38(1) of the Indian Electricity Grid Code, the daily report pertaining power supply position of All India Power System for the date 06.01.2025, is available at the NLDC website.

धन्यवाद,
Thanks

Report for previous day Date of Reporting: 07-Jan-2025

A. Power Supply Position at All India and Regional level

	NR	WR	SR	ER	NER	TOTAL
Demand Met during Evening Peak hrs(MW) (at 19:00 hrs; from RLDCs)	61296	63599	44997	22446	2685	195023
Peak Shortage (MW)	0	0	0	439	0	439
Energy Met (MU)	1248	1479	1161	456	49	4394
Hydro Gen (MU)	92	33	97	19	13	253
Wind Gen (MU)	22	143	46	-	-	211
Solar Gen (MU)*	147.12	95.96	138.00	2.71	1.04	385
Energy Shortage (MU)	0.00	0.00	0.00	3.41	0.00	3.41
Maximum Demand Met During the Day (MW) (From NLDC SCADA)	66048	74247	60056	23032	2765	223964
Time Of Maximum Demand Met	10:32	10:41	10:23	19:05	17:17	10:32

B. Frequency Profile (%)

Region	FVI	< 49.7	49.7 - 49.8	49.8 - 49.9	< 49.9	49.9 - 50.05	> 50.05
All India	0.040	0.00	0.00	1.24	1.24	68.93	29.83

C. Power Supply Position in States

Region	States	Max.Demand Met during the day (MW)	Shortage during maximum Demand (MW)	Energy Met (MU)	Drawal Schedule (MU)	OD(+)/UD(-) (MU)	Max OD (MW)	Energy Shortage (MU)
NR	Punjab	7887	0	147.8	65.7	0.9	668	0.00
	Haryana	8213	0	152.6	108.9	-1.2	410	0.00
	Rajasthan	18188	0	330.8	112.2	-1.4	581	0.00
	Delhi	5211	0	87.7	81.3	-0.8	478	0.00
	UP	21047	0	379.6	125.9	-0.4	337	0.00
	Uttarakhand	2410	0	44.2	36.8	-0.2	133	0.00
	HP	2034	0	36.6	29.9	-0.4	197	0.00
	J&K(UT) & Ladakh(UT)	3053	0	60.9	59.1	-2.2	317	0.00
	Chandigarh	256	0	4.3	4.3	0.0	35	0.00
WR	Railways_NR ISTS	199	0	3.9	3.4	0.5	70	0.00
	Chhattisgarh	5427	0	109.5	60.5	-0.3	374	0.00
	Gujarat	21892	0	409.7	164.9	-11.3	2231	0.00
	MP	16620	0	303.9	185.4	-3.4	997	0.00
	Maharashtra	28071	0	579.4	195.4	-0.2	987	0.00
	Goa	703	0	14.2	12.9	0.8	29	0.00
	DNHDDPDCL	1318	0	29.9	30.0	-0.1	32	0.00
	AMNSIL	786	0	17.4	7.0	1.0	314	0.00
	BALCO	534	0	12.6	12.7	-0.1	581	0.00
SR	RIL JAMNAGAR	101	0	2.4	2.4	0.0	0	0.00
	Andhra Pradesh	10964	0	199.1	53.0	-0.3	499	0.00
	Telangana	14433	0	264.8	145.4	-1.1	929	0.00
	Karnataka	16100	0	279.4	89.2	2.9	832	0.00
	Kerala	4251	0	80.5	62.2	1.3	379	0.00
	Tamil Nadu	16417	0	329.3	188.8	0.5	937	0.00
	Puducherry	390	0	8.4	8.2	-0.3	17	0.00
ER	Bihar	5270	402	100.5	91.4	-2.7	682	3.41
	DVC	3287	0	68.8	-43.4	-1.1	233	0.00
	Jharkhand	2059	0	38.0	27.6	-0.9	190	0.00
	Odisha	5598	0	102.9	34.1	-1.3	582	0.00
	West Bengal	7262	0	144.3	4.3	-0.5	216	0.00
	Sikkim	112	0	1.7	1.8	-0.1	25	0.00
	Railways_ER ISTS	18	0	0.2	0.1	0.1	0	0.00
NER	Arunachal Pradesh	180	0	3.2	2.8	0.2	34	0.00
	Assam	1535	0	27.1	20.3	0.4	140	0.00
	Manipur	254	0	3.8	4.0	-0.1	40	0.00
	Meghalaya	363	0	6.7	5.2	0.0	146	0.00
	Mizoram	154	0	2.2	1.8	-0.2	14	0.00
	Nagaland	153	0	2.4	2.3	0.0	33	0.00
	Tripura	217	0	3.9	3.2	-0.1	12	0.00

D. Transnational Exchanges (MU) - Import(+ve)/Export(-ve)

	Bhutan	Nepal	Bangladesh	Godda -> Bangladesh
Actual (MU)	-4.2	-6.3	-20.7	-13.7
Day Peak (MW)	-442.0	-481.2	-1003.0	-768.0

E. Import/Export by Regions (in MU) - Import(+ve)/Export(-ve); OD(+)/UD(-)

	NR	WR	SR	ER	NER	TOTAL
Schedule(MU)	263.2	-299.5	148.6	-118.9	6.8	0.0
Actual(MU)	250.2	-308.3	153.2	-107.6	7.0	-5.6
O/D/U/D(MU)	-13.0	-8.8	4.6	11.3	0.2	-5.6

F. Generation Outage(MW)

	NR	WR	SR	ER	NER	TOTAL	% Share
Central Sector	5071	6886	4948	6978	593	24476	46
State Sector	7508	10730	7874	2249	191	28551	54
Total	12579	17615	12822	9227	784	53027	100

G. Sourcewise generation (Gross) (MU)

	NR	WR	SR	ER	NER	All India	% Share
Coal	733	1554	623	624	9	3543	74
Lignite	27	16	55	0	0	98	2
Hydro	92	33	97	19	13	253	5
Nuclear	32	54	71	0	0	157	3
Gas, Naptha & Diesel	12	15	6	0	25	58	1
RES (Wind, Solar, Biomass & Others)	195	243	223	6	1	668	14
Total	1091	1915	1075	648	48	4777	100

Share of RES in total generation (%)	17.86	12.70	20.77	0.93	2.18	13.99
Share of Non-fossil fuel (Hydro,Nuclear and RES) in total generation(%)	29.18	17.24	36.38	3.81	29.24	22.57

H. All India Demand Diversity Factor

Based on Regional Max Demands	1.009
Based on State Max Demands	1.040

I. All India Peak Demand and shortage at Solar and Non-Solar Hour

	Max Demand Met(MW)	Time	Shortage(MW)
Solar hr	223964	10:32	0
Non-Solar hr	202787	18:44	945

Diversity factor = Sum of regional or state maximum demands / All India maximum demand

**Note: All generation MU figures are gross

***Godda (Jharkhand) -> Bangladesh power exchange is through the radial connection (isolated from Indian Grid)

Solar Hours -> 06:00 to 18:00hrs and rest are Non-Solar Hours

*Source: RLDCs for solar connected to ISTS; SLDCs for embedded solar. Limited visibility of embedded solar data.

Executive Director-NLDC

INTER-REGIONAL EXCHANGES

Import=(+ve) /Export =(-ve) for NET (MU)

Date of Reporting: 07-Jan-2025

Sl No	Voltage Level	Line Details	No. of Circuit	Max Import (MW)	Max Export (MW)	Import (MU)	Export (MU)	NET (MU)
Import/Export of ER (With NR)								
1	HVDC	ALIPURDUAR-AGRA	2	0	0	0.0	0.0	0.0
2	HVDC	PUSAULI B/B	-	1	0	0.0	6.0	-6.0
3	765 kV	GAYA-VARANASI	2	401	627	0.0	5.1	-5.1
4	765 kV	SASARAM-FATEHPUR	1	84	459	0.0	4.7	-4.7
5	765 kV	GAYA-BALIA	1	0	826	0.0	12.6	-12.6
6	400 kV	PUSAULI-VARANASI	1	0	244	0.0	5.0	-5.0
7	400 kV	PUSAULI -ALLAHABAD	1	0	111	0.0	1.0	-1.0
8	400 kV	MUZAFFARPUR-GORAKHPUR	2	55	662	0.0	6.0	-6.0
9	400 kV	PATNA-BALIA	2	0	678	0.0	8.4	-8.4
10	400 kV	NAUBATPUR-BALIA	2	9	371	0.0	2.4	-2.4
11	400 kV	BIHARSHARIFF-BALIA	2	68	271	0.0	3.3	-3.3
12	400 kV	MOTIHARI-GORAKHPUR	2	0	472	0.0	5.4	-5.4
13	400 kV	BIHARSHARIFF-VARANASI	2	121	223	0.0	0.0	0.0
14	220 kV	SAHUPURI-KARAMNASA	1	0	95	0.0	2.3	-2.3
15	132 kV	NAGAR UNTARI-RIHAND	1	0	0	0.1	0.0	0.1
16	132 kV	GARWAH-RIHAND	1	30	0	0.5	0.0	0.5
17	132 kV	KARMANASA-SAHUPURI	1	0	0	0.0	0.0	0.0
18	132 kV	KARMANASA-CHANDAULI	1	0	0	0.0	0.0	0.0
ER-NR						0.6	62.3	-61.7
Import/Export of ER (With WR)								
1	765 kV	JHARSUGUDA-DHARAMJAIGARH	4	1182	290	6.9	0.0	6.9
2	765 kV	NEW RANCHI-DHARAMJAIGARH	2	1164	329	8.6	0.0	8.6
3	765 kV	JHARSUGUDA-DURG	2	0	866	0.0	14.5	-14.5
4	400 kV	JHARSUGUDA-RAIGARH	4	0	598	0.0	8.4	-8.4
5	400 kV	RANCHI-SIPAT	2	317	173	1.5	0.0	1.5
6	220 kV	BUDHIPADAR-RAIGARH	1	0	113	0.0	1.3	-1.3
7	220 kV	BUDHIPADAR-KORBA	2	123	29	1.4	0.0	1.4
ER-WR						18.3	24.2	-5.9
Import/Export of ER (With SR)								
1	HVDC	JEYPORE-GAZUWAKA B/B	2	0	215	0.0	5.1	-5.1
2	HVDC	TALCHER-KOLAR BIPOLE	2	0	1990	0.0	40.1	-40.1
3	765 kV	ANGUL-SRIKAKULAM	2	0	2659	0.0	45.4	-45.4
4	400 kV	TALCHER-I/C	2	646	478	0.9	0.0	0.9
5	220 kV	BALIMELA-UPPER-SILERRU	1	0	0	0.0	0.0	0.0
ER-SR						0.0	90.6	-90.6
Import/Export of ER (With NER)								
1	400 kV	BINAGURI-BONGAIGAON	2	267	72	1.6	0.3	1.3
2	400 kV	ALIPURDUAR-BONGAIGAON	2	450	61	3.0	0.0	3.0
3	220 kV	ALIPURDUAR-SALAKATI	2	85	2	0.7	0.0	0.7
ER-NER						5.3	0.3	5.0
Import/Export of NER (With NR)								
1	HVDC	BISWANATH CHARIALI-AGRA	2	644	0	12.6	0.0	12.6
NER-NR						12.6	0.0	12.6
Import/Export of WR (With NR)								
1	HVDC	CHAMPA-KURUKSHETRA	2	0	1513	0.0	36.0	-36.0
2	HVDC	VINDHYACHAL B/B	-	300	105	0.0	1.2	-1.2
3	HVDC	MUNDRA-MOHINDERGARH	2	0	1455	0.0	36.2	-36.2
4	765 kV	GWALIOR-AGRA	2	0	2819	0.0	35.0	-35.0
5	765 kV	GWALIOR-PHAGI	2	210	1796	0.0	20.6	-20.6
6	765 kV	JABALPUR-ORAI	2	0	1368	0.0	31.3	-31.3
7	765 kV	GWALIOR-ORAI	1	842	0	12.1	0.0	12.1
8	765 kV	SATNA-ORAI	1	0	1443	0.0	21.5	-21.5
9	765 kV	BANASKANTHA-CHITORGARH	2	791	1477	1.7	10.5	-8.9
10	765 kV	VINDHYACHAL-VARANASI	2	0	3348	0.0	53.1	-53.1
11	400 kV	ZERDA-KANKROLI	1	173	178	0.7	0.9	-0.2
12	400 kV	ZERDA -BHINMAL	1	119	123	0.5	0.6	-0.2
13	400 kV	VINDHYACHAL -RIHAND	1	964	0	21.2	0.0	21.2
14	400 kV	RAPP-SHUJALPUR	2	332	488	2.6	2.2	0.4
15	400 kV	NEEMUCH-Chittorgarh	2	427	506	3.5	1.5	2.1
16	220 kV	BHANPURA-RANPUR	1	0	152	0.0	2.6	-2.6
17	220 kV	BHANPURA-MORAK	1	0	30	0.0	1.3	-1.3
18	220 kV	MEHGAON-AURAIYA	1	117	12	1.1	0.0	1.1
19	220 kV	MALANPUR-AURAIYA	1	79	30	0.6	0.1	0.5
20	132 kV	GWALIOR-SAWAI MADHOPUR	1	0	0	0.0	0.0	0.0
21	132 kV	RAJGHAT-LALITPUR	2	0	0	0.0	0.0	0.0
WR-NR						43.9	254.7	-210.8
Import/Export of WR (With SR)								
1	HVDC	BHADRAWATI B/B	-	0	713	0.0	8.4	-8.4
2	HVDC	RAIGARH-PUGALUR	2	0	3004	0.0	46.0	-46.0
3	765 kV	SOLAPUR-RAICHUR	2	2011	1464	7.6	11.2	-3.5
4	765 kV	WARDHA-NIZAMABAD	2	81	2655	0.0	37.2	-37.1
5	765 kV	WARORA-WARANGAL(NEW)	2	41	2597	0.0	37.8	-37.8
6	400 kV	KOLHAPUR-KUDGI	2	1515	0	27.5	0.0	27.5
7	220 kV	KOLHAPUR-CHIKODI	2	0	0	0.0	0.0	0.0
8	220 kV	PONDA-AMBEWADI	1	0	0	0.0	0.0	0.0
9	220 kV	XELDEM-AMBEWADI	1	0	110	2.1	0.0	2.1
WR-SR						37.2	140.5	-103.2

INTERNATIONAL EXCHANGES					Import(+ve)/Export(-ve)	
State	Region	Line Name	Max (MW)	Min (MW)	Avg (MW)	Energy Exchange (MU)
BHUTAN	ER	400kV MANGDECHHU-ALIPURDUAR 1,2&3 i.e. ALIPURDUAR RECEIPT (from MANGDECHU HEP 4*180MW)	183	11	97	2.34
	ER	400kV TALA-BINAGURI 1,2,4 (& 400kV MALBASE - BINAGURI) i.e. BINAGURI RECEIPT (from TALA HEP 6*170MW)	-219	84	-67	-1.62
	ER	220kV CHUKHA-BIRPARA 1&2 (& 220kV MALBASE - BIRPARA) i.e. BIRPARA RECEIPT (from CHUKHA HEP 4*84MW)	-242	-139	-191	-4.59
	NER	132kV GELEPHU-SALAKATI	-25	0	-1	-0.03
	NER	132kV MOTANGA-RANGIA	-50	10	-11	-0.26
NEPAL	NR	NEPAL IMPORT (FROM UP)	-68	0	-39	-0.94
	NR	132kV MAHENDRANAGAR-TANAKPUR(NHPC)	-68	0	-39	-0.94
	ER	NEPAL IMPORT (FROM BIHAR)	-197	-35	-80	-1.91
	ER	400kV DHALKEBAR-MUZAFFARPUR 1&2	-284	-2	-105	-2.53
BANGLADESH	ER	BHERAMARA B/B HVDC (B'DESH)	-939	-644	-812	-19.48
	ER (Isolated from Indian Grid)	400kV GODDA_TPS-RAHANPUR (B'DESH) D/C	-768	-408	-573	-13.74
	NER	132kV COMILLA-SURAJMANI NAGAR 1&2	-64	0	-53	-1.26

Export From India (in MU)

Country	GNA (ISGS/PPA)	T-GNA							TOTAL	
		BILATERAL TOTAL	COLLECTIVE							
			IDAM			RTM				
			IEX	PXIL	HPX	IEX	PXIL	HPX		
Bhutan	0.00	0.30	5.45	0.00	0.00	0.00	0.00	0.00	5.75	
Nepal	2.01	0.00	1.64	0.00	0.00	0.00	1.20	0.00	0.00	4.85
Bangladesh	20.35	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	20.35
Myanmar	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total Export	22.36	0.30	7.09	0.00	0.00	0.00	1.20	0.00	0.00	30.95

Import by India(in MU)

Country	GNA (ISGA/PPA)	T-GNA							TOTAL
		BILATERAL TOTAL	COLLECTIVE						
			IDAM			RTM			
			IEX	PXIL	HPX	IEX	PXIL	HPX	
Bhutan	0.90	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.90
Nepal	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Bangladesh	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Myanmar	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total Import	0.90	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.90

Net from India(in MU)

-ve : Export / +ve : Import

Country	GNA (ISGS/PPA)	T-GNA							TOTAL
		BILATERAL TOTAL	COLLECTIVE						
			IDAM			RTM			
			IEX	PXIL	HPX	IEX	PXIL	HPX	
Bhutan	0.90	-0.30	-5.45	0.00	0.00	0.00	0.00	0.00	-4.85
Nepal	-2.01	0.00	-1.64	0.00	0.00	-1.20	0.00	0.00	-4.85
Bangladesh	-20.35	0.00	0.00	0.00	0.00	0.00	0.00	0.00	-20.35
Myanmar	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total Net	-21.46	-0.30	-7.09	0.00	0.00	-1.20	0.00	0.00	-30.05

15 Min (INSTANTANEOUS) ALL INDIA GRID FREQUENCY, GENERATION & DEMAND MET (SCADA DATA)												Date of Reporting: 07-Jan-2025
TIME	FREQUENCY (Hz)	DEMAND MET (MW)	NUCLEAR (MW)	WIND (MW)	SOLAR (MW)	HYDRO** (MW)	GAS (MW)	THERMAL (MW)	OTHERS* (MW)	NET DEMAND MET (MW)	TOTAL GENERATION (MW)	NET TRANSNATIONAL EXCHANGE (MW)
		(A)	(B)	(C)	(D)	(E)	(F)	(G)	(H)	(I=A-(C+D))	(J=B+C+D+E+F+G+H)	(K)
0:00	50.09	145679	6157	9173	92	6315	1917	121856	3251	136414	148761	-1295
0:15	50.04	144446	6176	9320	95	6066	1704	120895	3221	135031	147477	-1365
0:30	49.98	143965	6183	9511	92	5976	1714	120217	3243	134362	146936	-1383
0:45	49.99	143430	6180	9813	95	6119	1712	119191	3227	133522	146337	-1162
1:00	50.04	142078	6175	9975	94	6178	1724	118080	3274	132009	145500	-1176
1:15	49.98	141194	6191	10096	136	5755	1741	117587	3291	130962	144797	-1179
1:30	50.04	140266	6187	10205	95	5499	1859	116885	3272	129966	144002	-1182
1:45	50.04	139601	6189	10337	92	5304	1723	116427	3205	129172	143277	-1164
2:00	50.19	138745	6173	10412	96	5177	1710	115532	3217	128237	142317	-1160
2:15	50.09	138167	6185	10482	97	4872	1716	115335	3225	127588	141912	-1179
2:30	49.98	137971	6197	10477	100	4861	1732	115241	3241	127394	141849	-1158
2:45	50.04	137627	6191	10462	102	4929	1728	114955	3170	127063	141537	-1112
3:00	50.09	136921	6178	10384	98	4878	1712	114450	3221	126439	140921	-1108
3:15	49.98	137210	6192	10310	105	4862	1716	114604	3224	126795	141013	-1104
3:30	50.08	137244	6205	10337	104	4923	1709	114278	3278	126803	140834	-1110
3:45	49.98	137346	6183	10267	103	5393	1705	114410	3223	126976	141284	-1063
4:00	50.08	137773	6182	10155	101	5397	1717	114698	3273	127517	141523	-1079
4:15	50.03	140613	6190	10206	100	5730	1732	116865	3227	130307	144050	-1141
4:30	50.13	142325	6191	10309	103	5673	1710	118139	3216	131913	145341	-1141
4:45	49.98	143837	6194	10206	105	5873	1914	119530	3270	133526	147092	-1180
5:00	50.03	146523	6189	10206	108	5924	1903	121948	3207	136209	149485	-1121
5:15	49.98	150294	6184	10254	113	6142	1901	125367	3219	139927	153180	-1172
5:30	50.03	154523	6176	10276	110	6252	2034	129123	3255	144137	157226	-1168
5:45	49.98	159138	6186	10312	106	7148	2046	133126	3293	148720	162217	-1283
6:00	50.09	163673	6192	10362	103	8126	2193	136449	3295	153208	166720	-1296
6:15	50.04	169138	6180	10565	633	9133	2388	140464	3283	157940	172646	-1412
6:30	50.09	176308	6191	10601	638	11016	2843	145331	3306	165069	179926	-1348
6:45	50.09	183125	6196	10630	652	13015	2886	149642	3296	171843	186317	-1271
7:00	50.04	189004	6189	10375	906	15544	2918	153089	3299	177723	192320	-1343
7:15	49.99	195519	6189	10351	1530	17603	2956	156677	3342	183638	198648	-1181
7:30	50.04	200139	6187	10324	2702	19831	3195	157342	3334	187113	202915	-1161
7:45	50.04	203827	6191	10115	4349	20427	3565	158723	3359	189363	206729	-1105
8:00	50.09	205589	6185	9778	6861	20211	3824	158203	3386	188950	208448	-1142
8:15	50.07	208923	6198	9567	9994	19871	3811	158898	3386	189362	211725	-1006
8:30	50.07	211027	6189	9119	13774	18734	3740	158462	3431	188134	213449	-836
8:45	50.02	213343	6193	8595	17345	17234	3073	159620	3389	187403	215449	-808
9:00	50.02	215645	6198	7998	21356	15788	2873	160087	3520	186291	217820	-830
9:15	49.97	219588	6193	7525	25093	15085	2905	161891	3415	186970	222107	-842
9:30	49.97	221075	6178	6794	29156	13639	3093	161622	3441	185125	223923	-951
9:45	49.97	222534	6186	5889	32941	12895	3084	161204	3449	183704	225648	-1070
10:00	50.07	222113	6160	5209	35983	11117	3036	160156	3492	180921	225153	-1074
10:15	50.07	223134	6165	5032	39229	9693	2700	159179	3655	178873	225653	-1055
10:30	50.17	223758	6172	5125	44145	8907	1939	156337	3578	174488	226203	-1157
10:45	50.12	223148	6200	5165	47522	8193	1943	152736	3600	170461	225359	-1321
11:00	50.11	221828	6200	5280	49872	7969	1940	148793	3653	166676	223707	-1303
11:15	50.06	220733	6193	5475	51643	6852	1935	147284	3618	163615	223000	-1373
11:30	50.01	219994	6182	5662	52795	6719	2035	145648	3569	161537	222610	-1420
11:45	50.01	218975	6179	6002	53556	6403	2040	143886	3645	159417	221711	-1447
12:00	50.06	217648	6177	6148	54330	6263	2020	141857	3654	157170	220449	-1499
12:15	50.01	216277	6178	6434	55006	5889	2020	139178	3560	154837	218265	-1600
12:30	49.96	215116	6163	6386	55096	6141	2023	137649	3687	153634	217145	-1678
12:45	49.96	212858	6169	6039	55616	6349	2033	135634	3577	151203	215417	-1670
13:00	50.01	210245	6177	5844	55827	5981	1933	133534	3600	148574	212896	-1731
13:15	49.96	206094	6170	5664	55586	5909	1928	129904	3618	144844	208779	-1743
13:30	50.02	205151	6176	5559	55233	5776	1928	129623	3556	144359	207851	-1700
13:45	49.96	204707	6153	5343	54557	6034	2032	130210	3570	144807	207899	-1735
14:00	50.01	204277	6142	5195	53655	6029	2022	130616	3612	145427	207271	-1738
14:15	49.91	203799	6145	5176	52449	6339	2018	131144	3580	146174	206851	-1837
14:30	49.86	204196	6139	5131	50703	6661	2033	132842	3636	148362	207145	-1830
14:45	49.91	204208	6154	4949	48832	6722	2042	135097	3538	150427	207334	-1859
15:00	49.96	204273	6155	4949	46519	6909	2048	136999	3557	152805	207136	-1874
15:15	49.97	203472	6162	4929	43924	6881	2025	138551	3549	154619	206021	-1843
15:30	50.02	203056	6149	4854	41151	7533	2060	141449	3524	157051	206720	-1819
15:45	50.02	202492	6153	4893	37664	7839	2056	143720	3505	159935	205830	-1674
16:00	50.07	202149	6163	4949	33809	8084	2130	146774	3548	163391	205457	-1694
16:15	50.01	199760	6146	4965	29437	8315	2374	148452	3444	165358	203133	-1512
16:30	50.06	201133	6145	5018	24398	10688	2691	152064	3463	171717	204467	-1295
16:45	50.06	201560	6154	5028	19096	12638	3123	155310	3419	177436	204768	-1303
17:00	50.01	200515	6156	5165	13479	14993	3166	157236	3400	181871	203595	-1196
17:15	50.01	199665	6157	5236	8871	17164	3189	157721	3382	185558	201720	-876
17:30	50.01	200887	6140	5285	5130	20558	3174	159340	3386	190472	203013	-741
17:45	49.96	201193	6144	5353	2584	22618	3190	160321	3355	193256	203565	-764
18:00	49.96	200960	6149	5567	952	23479	3180	160433	3452	194441	203212	-757
18:15	49.91	201696	6153	6076	455	23443	3524	160773	3438	195165	203862	-746
18:30	50.06	201992	6166	6558	322	23949	3966	160083	3420	195112	204464	-720
18:45	50.06	202593	6161	7193	255	23906	3988	159945	3418	195145	204866	-684
19:00	50.06	200647	6185	7869	244	21851	3980	159012	3366	192534	202507	-665
19:15	50.06	200702	6171	8399	229	20774	3220	160117	3392	192074	202302	-698
19:30	50.06	197860	6160	9004	199	18358	2351	159998	3379	188657	199449	-687
19:45	50.06	194859	6177	9473	203	16394	2356	158712	3390	185183	196705	-685
20:00	50.11	191647	6187	9791	199	15076	2240	156784	3430	181657	193707	-693
20:15	50.06	187995	6186	10173	135	12751	2233	155247	3384	177687	190109	-867
20:30	50.01	185557	6175	10495	137	11898	2168	153878	3384	174925	188135	-1091
20:45	50.01	182871	6180	10760	101	10938	2151	151688	3395	172010	185213	-1029
21:00	50.01	179059	6185	11068	101	10060	2147	148590	3335	167890	181486	-1141
21:15	49.96	176472	6193	11393	99	9377	2136	146636	3278	164980	179112	-1398
21:30	49.96	174304	6197	11709	104	9249	2138	144428	3263	162491	177088	-1426
21:45	50.07	171574	6201	11916	113	8748	2261	142077	3255	159545	174571	-1459
22:00	50.17	167565	6197	12083	115	7578	2239	139316	3251	155367	170779	-1566
22:15	49.96	166475	6205	12145	121	7608	2231	138606	3253	154209	170169	-1524
22:30	49.97	164817	6216	12212	123	7447	2257	136585	3319	152482	168159	-1546
22:45	49.97	162409	6206									