



National Load Despatch Centre
राष्ट्रीय भार प्रेषण केंद्र
GRID CONTROLLER OF INDIA LIMITED
ग्रिड कंट्रोलर ऑफ इंडिया लिमिटेड

(Government of India Enterprise/ भारत सरकार का उद्यम)
B-9, QUTUB INSTITUTIONAL AREA, KATWARIA SARAI, NEW DELHI -110016
बी-9, कुतुब इन्स्टीट्यूशनल एरिया, कटवारिया सराये, न्यू दिल्ली-110016

Ref: GRID-INDIA/NLDC/SO/Daily PSP Report

दिनांक: 29.10.2025

To,

- कार्यकारी निदेशक, पू.क्षे.भा.प्रे.के., 14, गोल्फ क्लब रोड, कोलकाता - 700033
Executive Director, ERLDC, 14 Golf Club Road, Tollygunge, Kolkata, 700033
- कार्यकारी निदेशक, ऊ.क्षे.भा.प्रे.के., 18/ए, शाहीद जीत सिंह सनसनवाल मार्ग, नई दिल्ली - 110016
Executive Director, NRLDC, 18-A, Shaheed Jeet Singh Marg, Katwaria Sarai, New Delhi - 110016
- कार्यकारी निदेशक, प.क्षे.भा.प्रे.के., एफ3, एम आई डी सी क्षेत्र, अंधेरी, मुंबई - 400093
Executive Director, WRLDC, F-3, M.I.D.C. Area, Marol, Andheri (East), Mumbai-400093
- कार्यकारी निदेशक, ऊ.पू.क्षे.भा.प्रे.के., डोंगतेह, लोअर नोंग्रह, लापालंग, शिलोंग - 793006
Executive Director, NERLDC, Dongteih, Lower Nongrah, Lapalang, Shillong - 793006, Meghalaya
- कार्यकारी निदेशक, द.क्षे.भा.प्रे.के., 29, रेस कोर्स क्रॉस रोड, बंगलुरु - 560009
Executive Director, SRLDC, 29, Race Course Cross Road, Bangalore-560009

Sub: Daily PSP Report for the date 28.10.2025.

महोदय/Sir,

आईईजीसी-2023 की धारा स.-38(1) के प्रावधान के अनुसार, दिनांक 28-अक्टूबर-2025 की अखिल भारतीय प्रणाली की दैनिक ग्रिड निष्पादन रिपोर्ट रांभांप्रेके की वेबसाइट पर उपलब्ध है।

As per article 38(1) of the Indian Electricity Grid Code, the daily report pertaining power supply position of All India Power System for the date 28.10.2025, is available at the NLDC website.

धन्यवाद,
Thanks

Report for previous day

Date of Reporting: 29-Oct-2025

A. Power Supply Position at All India and Regional level

	NR	WR	SR	ER	NER	TOTAL
Demand Met during Evening Peak hrs(MW) (at 19:00 hrs; from RLDCs)	51128	57113	41314	24631	3310	177496
Peak Shortage (MW)	0	0	0	0	0	0
Energy Met (MU)	1139	1266	946	550	63	3963
Hydro Gen (MU)	173	78	162	62	26	500
Wind Gen (MU)	55	177	201	-	-	433
Solar Gen (MU)*	147.66	76.19	66.26	1.92	1.08	293
Energy Shortage (MU)	0.00	0.00	0.00	0.00	0.00	0.00
Maximum Demand Met During the Day (MW) (From NLDC SCADA)	55400	60692	45283	25625	3528	188905
Time Of Maximum Demand Met	18:30	18:26	07:44	18:05	17:46	18:29

B. Frequency Profile (%)

Region	FVI	< 49.7	49.7 - 49.8	49.8 - 49.9	< 49.9	49.9 - 50.05	> 50.05
All India	0.056	0.25	0.75	6.76	7.77	65.87	26.36

C. Power Supply Position in States

Region	States	Max.Demand Met during the day (MW)	Shortage during maximum Demand (MW)	Energy Met (MU)	Drawal Schedule (MU)	OD(+)/UD(-) (MU)	Max OD (MW)	Energy Shortage (MU)
NR	Punjab	7987	0	154.6	86.8	-0.3	347	0.00
	Haryana	7774	0	162.3	135.2	-1.5	257	0.00
	Rajasthan	13044	0	264.4	67.7	-7.4	1085	0.00
	Delhi	4047	0	80.7	78.8	-0.2	259	0.00
	UP	17127	0	340.2	125.8	-0.9	435	0.00
	Uttarakhand	2094	0	40.3	28.2	-0.2	134	0.00
	HP	1892	0	34.2	16.9	0.1	126	0.00
	J&K(UT) & Ladakh(UT)	2711	0	53.8	44.1	-1.2	160	0.00
	Chandigarh	216	0	3.9	3.9	0.1	12	0.00
	Railways_NR ISTS	206	0	4.3	4.0	0.3	36	0.00
WR	Chhattisgarh	4875	0	106.5	52.6	1.2	304	0.00
	Gujarat	16767	0	354.2	188.8	-10.8	959	0.00
	MP	10505	0	209.5	114.0	0.0	447	0.00
	Maharashtra	25297	0	513.7	205.2	-2.7	644	0.00
	Goa	709	0	14.3	12.2	1.7	70	0.00
	DNHDDPDCL	1322	0	29.9	30.0	-0.1	38	0.00
	AMNSIL	843	0	18.8	12.2	0.7	331	0.00
	BALCO	534	0	12.7	12.9	-0.2	4	0.00
	RIL JAMNAGAR	254	0	5.9	6.0	-0.1	0	0.00
	Andhra Pradesh	6978	0	151.2	23.9	-2.3	691	0.00
SR	Telangana	9657	0	186.3	77.1	3.8	691	0.00
	Karnataka	10779	0	206.5	51.1	-1.2	572	0.00
	Kerala	4222	0	82.2	48.3	-1.4	389	0.00
	Tamil Nadu	16120	0	310.2	117.9	-4.1	1385	0.00
	Puducherry	411	0	9.1	8.8	-0.4	29	0.00
	Bihar	6301	0	123.4	117.8	-4.7	302	0.00
ER	DVC	2985	0	64.6	-20.9	1.1	440	0.00
	Jharkhand	1883	0	39.3	30.6	-3.4	197	0.00
	Odisha	5430	0	108.0	35.7	-2.4	501	0.00
	West Bengal	9699	0	213.7	88.5	-3.5	208	0.00
	Sikkim	91	0	1.3	1.3	0.0	12	0.00
	Railways_ER ISTS	15	0	0.1	0.1	0.0	3	0.00
NER	Arunachal Pradesh	182	0	3.1	3.0	-0.1	41	0.00
	Assam	2165	0	39.3	31.6	0.7	183	0.00
	Manipur	241	0	3.0	3.2	-0.1	42	0.00
	Meghalaya	329	0	5.7	3.0	-0.2	247	0.00
	Mizoram	146	0	2.0	0.7	-0.2	8	0.00
	Nagaland	175	0	2.9	2.6	-0.1	15	0.00
	Tripura	340	0	6.8	6.2	0.6	41	0.00

D. Transnational Exchanges (MU) - Import(+ve)/Export(-ve)

	Bhutan	Nepal	Bangladesh	Godda -> Bangladesh
Actual (MU)	12.1	23.7	-24.8	27.1
Day Peak (MW)	632.7	1064.6	-1052.8	-1478.0

E. Import/Export by Regions (in MU) - Import(+ve)/Export(-ve); OD(+)/UD(-)

	NR	WR	SR	ER	NER	TOTAL
Schedule(MU)	206.7	-224.8	43.4	-35.7	10.4	0.0
Actual(MU)	211.0	-214.6	30.5	-44.5	9.1	-8.5
O/D/U/D(MU)	4.3	10.2	-12.9	-8.8	-1.4	-8.6

F. Generation Outage(MW)

	NR	WR	SR	ER	NER	TOTAL	% Share
Central Sector	7167	12006	10558	2510	265	32505	42
State Sector	13354	18997	10563	1557	205	44675	58
Total	20521	31002	21121	4067	470	77180	100

G. Sourcewise generation (Gross) (MU)

	NR	WR	SR	ER	NER	All India	% Share
Coal	561	1150	465	585	11	2772	65
Lignite	26	10	37	0	0	72	2
Hydro	173	78	162	62	26	500	12
Nuclear	37	65	41	0	0	142	3
Gas, Naptha & Diesel	3	15	5	0	21	44	1
RES (Wind, Solar, Biomass & Others)	210	251	287	3	1	752	18
Total	1009	1568	997	651	59	4283	100

Share of RES in total generation (%)	20.80	15.97	28.85	0.53	1.86	17.56
Share of Non-fossil fuel (Hydro,Nuclear and RES) in total generation(%)	41.55	25.06	49.19	10.10	45.72	32.57

H. All India Demand Diversity Factor

Based on Regional Max Demands	1.008
Based on State Max Demands	1.039

I. All India Peak Demand and shortage at Solar and Non-Solar Hour

	Max Demand Met(MW)	Time	Shortage(MW)
Solar hr	181710	9:40	0
Non-Solar hr	188905	18:29	0

Diversity factor = Sum of regional or state maximum demands / All India maximum demand

**Note: All generation MU figures are gross

***Godda (Jharkhand) -> Bangladesh power exchange is through the radial connection (isolated from Indian Grid)

Solar Hours -> 06:00 to 18:00hrs and rest are Non-Solar Hours

*Source: RLDCs for solar connected to ISTS; SLDCs for embedded solar. Limited visibility of embedded solar data.

Executive Director-NLDC

INTER-REGIONAL EXCHANGES

Import=(+ve) /Export =(-ve) for NET (MU)
Date of Reporting: 29-Oct-2025

Sl No	Voltage Level	Line Details	No. of Circuit	Max Import (MW)	Max Export (MW)	Import (MU)	Export (MU)	NET (MU)
Import/Export of ER (With NR)								
1	HVDC	ALIPURDUAR-AGRA	2	0	348	0.0	7.4	-7.4
2	HVDC	PUSAULI B/B	-	0	47	0.0	2.5	-2.5
3	765 kV	GAYA-VARANASI	2	568	834	0.1	0.0	-0.1
4	765 kV	SASARAM-FATEHPUR	1	53	207	0.0	0.8	-0.8
5	765 kV	GAYA-BALIA	1	0	649	0.0	7.0	-7.0
6	400 kV	PUSAULI-VARANASI	1	0	90	0.0	1.4	-1.4
7	400 kV	PUSAULI-ALLAHABAD	1	0	80	0.0	1.0	-1.0
8	400 kV	MUZAFFARPUR-GORAKHPUR	2	255	487	0.0	2.8	-2.8
9	400 kV	PATNA-BALIA	2	231	605	0.0	1.7	-1.7
10	400 kV	NAUBATPUR-BALIA	2	60	245	0.4	0.0	0.4
11	400 kV	BIHARSHARIFF-BALIA	2	474	63	6.0	0.0	6.0
12	400 kV	MOTIHARI-GORAKHPUR	2	88	388	0.0	2.9	-2.9
13	400 kV	BIHARSARIFF-SAHUPURI	2	262	328	0.4	0.0	0.4
14	220 kV	SAHUPURI-KARAMNANA	1	0	82	0.0	1.4	-1.4
15	132 kV	NAGAR UNTARI-RIHAND	1	0	0	0.0	0.1	-0.1
16	132 kV	GARWAH-RIHAND	1	30	0	0.4	0.0	0.4
17	132 kV	KARMANASA-SAHUPURI	1	0	0	0.0	0.0	0.0
18	132 kV	KARMANASA-CHANDAULI	1	0	0	0.0	0.0	0.0
ER-NR						7.2	29.0	-21.8
Import/Export of ER (With WR)								
1	765 kV	JHARSUGUDA-DHARAMJAIGARH	4	865	391	4.3	0.0	4.3
2	765 kV	NEW RANCHI-DHARAMJAIGARH	2	1878	0	29.6	0.0	29.6
3	765 kV	JHARSUGUDA-DURG	2	104	559	0.0	6.0	-6.0
4	400 kV	JHARSUGUDA-RAIGARH	4	540	215	4.3	0.0	4.3
5	400 kV	RANCHI-SIPAT	2	449	0	6.4	0.0	6.4
6	400 kV	JEYPORE-JACDALPUR	2	67	450	0.0	4.4	-4.4
7	220 kV	BUDHIPADAR-RAIGARH	1	65	106	0.0	0.6	-0.6
8	220 kV	BUDHIPADAR-KORBA	2	143	101	0.7	0.0	0.7
ER-WR						45.3	11.0	34.4
Import/Export of ER (With SR)								
1	HVDC	JEYPORE-GAZUWAKA B/B	2	155	321	0.0	1.4	-1.4
2	HVDC	TALCHER-KOLAR BIPOLE	2	0	1377	0.0	26.1	-26.1
3	765 kV	ANGUL-SRIKAKULAM	2	0	2507	0.0	34.5	-34.5
4	400 kV	TALCHER/JC	2	565	684	0.0	1.0	-1.0
5	220 kV	BALIMELA-UPPER-SILERRU	1	23	22	0.2	0.0	0.2
ER-SR						0.2	62.0	-61.8
Import/Export of ER (With NER)								
1	400 kV	BINAGURI-BONGAIGAON	2	0	585	0.0	8.6	-8.6
2	400 kV	ALIPURDUAR-BONGAIGAON	2	0	871	0.0	12.5	-12.5
3	220 kV	ALIPURDUAR-SALAKATI	2	0	159	0.0	2.2	-2.2
ER-NER						0.0	23.3	-23.3
Import/Export of NER (With NR)								
1	HVDC	BISWANATH CHARIALI-AGRA	2	0	604	0.0	13.7	-13.7
NER-NR						0.0	13.7	-13.7
Import/Export of WR (With NR)								
1	HVDC	CHAMPA-KURUKSHETRA	2	0	980	0.0	24.0	-24.0
2	HVDC	VINDHYACHAL B/B	-	194	0	4.9	0.0	4.9
3	HVDC	MUNDRA-MOHINDERGARH	2	0	398	0.0	9.8	-9.8
4	765 kV	GWALIOR-AGRA	2	0	2459	0.0	39.3	-39.3
5	765 kV	GWALIOR-PHAGI	2	391	1416	0.9	18.4	-17.5
6	765 kV	JABALPUR-ORAI	2	0	1150	0.0	33.5	-33.5
7	765 kV	GWALIOR-ORAI	1	756	0	9.5	0.0	9.5
8	765 kV	SATNA-ORAI	1	0	1136	0.0	17.9	-17.9
9	765 kV	BANASKANTHA-CHITORGARH	2	946	698	3.0	5.7	-2.8
10	765 kV	VINDHYACHAL-VARANASI	2	0	2859	0.0	50.0	-50.0
11	400 kV	ZERDA-KANKROLI	1	245	48	2.2	0.1	2.2
12	400 kV	ZERDA -BHINMAL	1	169	34	1.5	0.0	1.5
13	400 kV	VINDHYACHAL -RIHAND	1	0	1	0.0	0.0	0.0
14	400 kV	RAPP-SHUJALPUR	2	498	434	2.0	3.1	-1.1
15	400 kV	NEEMUCH-Chittorgarh	2	566	450	2.2	3.4	-1.2
16	220 kV	BHANPURA-RANPUR	1	0	79	0.0	1.4	-1.4
17	220 kV	BHANPURA-MORAK	1	0	30	0.0	1.2	-1.2
18	220 kV	MEHGAON-AURAIYA	1	32	51	0.1	0.5	-0.5
19	220 kV	MALANPUR-AURAIYA	1	21	50	0.0	0.7	-0.7
20	132 kV	RAIGHAT-LALITPUR	2	0	0	0.0	0.0	0.0
WR-NR						26.2	209.1	-182.9
Import/Export of WR (With SR)								
1	HVDC	BHADRAWATI B/B	-	0	310	0.0	7.2	-7.2
2	HVDC	RAIGARH-PUGALUR	2	0	751	0.0	15.1	-15.1
3	765 kV	SOLAPUR-RAICHUR	2	1859	436	22.2	0.3	21.9
4	765 kV	WARDHA-NIZAMABAD	2	281	1884	0.3	14.7	-14.4
5	765 kV	WARORA-WARANGAL(NEW)	2	270	1963	0.3	16.0	-15.6
6	400 kV	KOLHAPUR-KUDGI	2	1759	0	31.2	0.0	31.2
7	220 kV	KOLHAPUR-CHIKODI	2	0	0	0.0	0.0	0.0
8	220 kV	PONDA-AMBEWADI	1	0	0	0.0	0.0	0.0
9	220 kV	XELDEM-AMBEWADI	1	0	107	0.0	2.2	-2.2
WR-SR						56.1	53.2	2.9

INTERNATIONAL EXCHANGES					Import(+ve)/Export(-ve)	
State	Region	Line Name	Max (MW)	Min (MW)	Avg (MW)	Energy Exchange (MU)
BHUTAN	ER	400kV MANGDECHHU-ALIPURDUAR 1,2&3 I.e. ALIPURDUAR RECEIPT (from MANGDECHU HEP 4*180MW)	441	160	380	9.13
	ER	400kV TALA-BINAGURI 1,2,4 (& 400kV MALBASE - BINAGURI) I.e. BINAGURI RECEIPT (from TALA HEP 6*170MW)	283	144	221	5.30
	ER	220kV CHUKHA-BIRPARA 1&2 (& 220kV MALBASE - BIRPARA) I.e. BIRPARA RECEIPT (from CHUKHA HEP 4*84MW)	-120	-56	-77	-1.85
	NER	132kV GELEPHU-SALAKATI	-26	0	-15	-0.35
	NER	132kV MOTANGA-RANGIA	-29	0	-7	-0.17
NEPAL	NR	NEPAL IMPORT (FROM UP)	-35	0	0	0.00
	NR	132kV MAHENDRANAGAR-TANAKPUR(NHPC)	43	0	17	0.41
	ER	NEPAL IMPORT (FROM BIHAR)	206	157	174	4.17
	ER	400kV DHALKEBAR-MUZAFFARPUR 1&2	840	750	796	19.12
BANGLADESH	ER	BHERAMARA B/B HVDC (B'DESH)	-964	-960	-962	-23.09
	ER (Isolated from Indian Grid)	400kV GODDA_TPS-RAHANPUR (B'DESH) D/C	-1478	-986	1127	27.06
	NER	132kV COMILLA-SURAJMANI NAGAR 1&2	-86	0	-70	-1.68

CROSS BORDER EXCHANGE SCHEDULE

Date of Reporting: 29-Oct-2025

Export From India (in MU)

Country	GNA (ISGS/PPA)	T-GNA							TOTAL
		BILATERAL TOTAL	COLLECTIVE						
			IDAM			RTM			
			IEX	PXIL	HPX	IEX	PXIL	HPX	
Bhutan	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Nepal	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Bangladesh	23.79	0.13	0.00	0.00	0.00	0.00	0.00	0.00	23.92
Myanmar	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total Export	23.79	0.13	0.00	0.00	0.00	0.00	0.00	0.00	23.92

Import by India(in MU)

Country	GNA (ISGA/PPA)	T-GNA							TOTAL	
		BILATERAL TOTAL	COLLECTIVE							
			IDAM			RTM				
			IEX	PXIL	HPX	IEX	PXIL	HPX		
Bhutan	1.14	0.00	0.21	0.00	0.00	0.00	0.00	0.00	1.35	
Nepal	9.16	4.74	5.01	0.00	0.00	0.00	3.67	0.00	0.00	22.58
Bangladesh	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Myanmar	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total Import	10.30	4.74	5.22	0.00	0.00	0.00	3.67	0.00	0.00	23.93

Net from India(in MU)

-ve : Export / +ve : Import

Country	GNA (ISGS/PPA)	T-GNA							TOTAL	
		BILATERAL TOTAL	COLLECTIVE							
			IDAM			RTM				
			IEX	PXIL	HPX	IEX	PXIL	HPX		
Bhutan	1.14	0.00	0.21	0.00	0.00	0.00	0.00	0.00	1.35	
Nepal	9.16	4.74	5.01	0.00	0.00	0.00	3.67	0.00	0.00	22.58
Bangladesh	-23.79	-0.13	0.00	0.00	0.00	0.00	0.00	0.00	0.00	-23.92
Myanmar	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total Net	-13.49	4.61	5.22	0.00	0.00	0.00	3.67	0.00	0.00	0.01

15 Min (INSTANTANEOUS) ALL INDIA GRID FREQUENCY, GENERATION & DEMAND MET (SCADA DATA)												
TIME	FREQUENCY (Hz)	DEMAND MET (MW)	NUCLEAR (MW)	WIND (MW)	SOLAR (MW)	HYDRO** (MW)	GAS (MW)	THERMAL (MW)	OTHERS* (MW)	NET DEMAND MET (MW)	TOTAL GENERATION N (MW)	NET TRANSNATIONAL EXCHANGE (MW)
		(A)	(B)	(C)	(D)	(E)	(F)	(G)	(H)	(I=A-(C+D))	(J=B+C+D+E+H)	(K)
0:00	50.03	153542	5326	16650	0	16786	1877	112748	1741	136892	155128	355
0:15	50.03	152412	5341	17050	0	16396	1843	112006	1730	135362	154366	347
0:30	50.08	151012	5331	17195	0	16321	1860	110105	1651	133817	152463	369
0:45	50.03	150078	5343	17168	0	16346	1876	109295	1687	132910	151715	329
1:00	50.03	149220	5336	17593	0	15982	1895	108379	1691	131627	150876	345
1:15	50.03	147962	5350	17882	0	15566	1881	107030	1724	130080	149433	383
1:30	50.08	147073	5344	18182	0	15081	1902	106470	1644	128891	148623	370
1:45	50.03	146475	5327	18686	0	14531	1895	106037	1654	127789	148130	390
2:00	50.03	145953	5361	18735	0	14625	1886	105128	1674	127218	147409	396
2:15	49.98	145044	5345	18533	0	14354	1856	104790	1657	126511	146535	417
2:30	49.93	144892	5341	18162	0	14425	1861	104779	1683	126730	146251	429
2:45	49.93	143792	5339	17807	0	14509	1862	103973	1668	125985	145158	379
3:00	49.93	143547	5330	17386	0	14454	1829	104145	1683	126161	144827	388
3:15	49.93	143124	5334	17012	0	14496	1885	104181	1713	126112	144621	391
3:30	49.93	143226	5332	16440	0	14794	1879	104418	1663	126786	144526	402
3:45	49.98	143275	5330	16099	0	14682	1881	105205	1623	127176	144820	387
4:00	50.03	142804	5338	16019	0	14216	1879	105403	1643	126785	144498	391
4:15	50.03	143214	5338	15447	0	14544	1888	106336	1657	127767	145210	414
4:30	50.03	143496	5342	15550	0	14484	1874	106469	1644	127946	145363	440
4:45	50.03	143645	5325	15602	0	14598	1884	106391	1630	128043	145430	427
5:00	50.08	144769	5332	15568	227	15785	1874	106535	1648	128974	146969	401
5:15	50.03	147226	5317	15850	230	17042	1941	107268	1647	131146	149295	365
5:30	50.08	149206	5335	16100	229	18391	1940	107912	1680	132877	151587	239
5:45	50.08	150954	5334	16200	222	19484	1926	108190	1675	134532	153031	321
6:00	50.13	152440	5332	16071	204	20994	1939	108656	1642	136165	154838	262
6:15	50.03	155051	5328	15626	873	22779	1873	109764	1670	138552	157913	279
6:30	49.93	158904	5323	15606	958	24741	1791	111488	1663	142340	161570	296
6:45	49.88	162154	5329	15339	1227	25452	1797	113840	1653	145588	164637	267
7:00	49.88	164771	5322	15231	1796	26135	1801	115457	1647	147744	167389	298
7:15	49.88	167149	5331	14961	3023	26199	1810	116690	1705	149165	169719	346
7:30	49.93	169156	5330	14734	4971	25960	1807	117348	1652	149451	171802	341
7:45	50.03	170233	5330	14784	6824	24116	1796	117979	1719	148625	172548	333
8:00	50.08	171152	5251	14977	9315	22225	1798	117745	1772	146860	173083	335
8:15	49.98	173206	5242	14952	12202	21461	1794	117603	1749	146052	175003	281
8:30	50.03	175152	5258	14994	15443	20692	1796	116491	1741	144715	176415	289
8:45	50.03	176283	5246	14931	18980	19647	1794	115226	1752	142372	175756	262
9:00	50.13	177490	5266	14820	21752	19141	1747	114270	1781	140918	178777	272
9:15	50.03	180046	5260	15133	26507	18275	1712	112557	1867	138406	181311	327
9:30	50.08	180872	5256	15375	29910	17289	1703	110326	1822	135587	181681	317
9:45	50.03	180989	5241	15701	32477	16721	1707	108224	1800	132811	181871	312
10:00	50.03	180769	5233	15920	32982	16446	1719	107578	1830	131867	181708	312
10:15	50.03	180111	5214	16181	36438	14995	1660	104861	1830	127492	181179	283
10:30	50.03	180040	5224	16079	38254	14755	1655	102846	1824	125707	180637	292
10:45	49.98	179257	5289	16023	37783	15171	1662	102497	1822	125451	180247	302
11:00	49.93	179174	5223	16382	39130	15142	1657	100762	1870	123662	180166	298
11:15	49.98	178273	5290	16507	39778	14714	1652	99780	1836	121988	179557	292
11:30	49.98	177404	5224	16730	40512	14424	1655	98157	1829	120162	178531	294
11:45	50.03	177049	5225	17117	41137	14279	1682	96888	1828	118795	178156	276
12:00	50.08	176049	5295	17216	41100	13956	1667	96197	1795	117733	177226	312
12:15	50.08	175622	5296	17457	41215	13470	1674	95822	1780	116950	176714	289
12:30	50.08	174824	5292	17510	40711	13930	1664	95194	1771	116603	176072	254
12:45	50.03	173910	5295	18035	40132	13664	1659	94787	1790	115743	175362	239
13:00	50.23	172059	5306	18234	39546	12987	1655	93903	1819	114279	173450	265
13:15	50.08	169069	5313	18316	36939	12618	1671	93870	1842	113814	170569	294
13:30	50.03	168772	5297	18224	36490	12781	1661	93574	1825	114058	169852	302
13:45	49.93	169216	5287	18143	35422	13177	1664	94871	1787	115651	170351	308
14:00	50.03	169480	5278	18274	35742	13759	1664	94109	1822	115464	170648	283
14:15	49.98	170021	5294	18211	35676	14258	1657	93955	1869	116134	170920	249
14:30	49.98	172039	5274	18350	35930	14746	1684	95400	1745	117759	173129	275
14:45	49.98	172570	5286	18001	35322	15137	1660	96421	1746	119247	173573	283
15:00	50.09	173238	5282	17958	35670	14800	1657	97056	1805	119610	174228	266
15:15	49.99	171967	5289	17478	33720	14378	1694	98921	1752	120769	173232	269
15:30	49.99	173062	5289	17844	31276	14933	1687	101234	1747	123942	174010	266
15:45	49.99	172948	5281	18541	27746	15166	1749	104136	1767	126661	174386	261
16:00	50.04	172740	5288	18501	24889	15515	1708	106798	1727	129350	174426	290
16:15	49.99	171023	5305	19057	21119	15322	1700	108765	1753	130847	173021	250
16:30	49.99	171927	5305	18186	17124	16556	1760	112655	1790	136617	173376	228
16:45	49.99	173283	5312	18842	14039	17169	1705	116431	1710	140402	175208	196
17:00	49.99	175388	5307	18744	10268	18480	1760	121105	1658	146376	177322	179
17:15	49.94	176735	5319	18680	7249	19906	1767	123692	1644	150806	178257	83
17:30	50.04	178577	5314	18072	3888	21335	1739	128818	1673	156617	180839	78
17:45	50.04	183372	5311	18904	2498	22676	1742	132764	1718	161970	185613	84
18:00	50.14	186465	5322	19125	1748	24214	1734	135056	1702	165592	188901	89
18:15	50.04	188399	5333	18955	1559	24668	1740	137023	1710	167885	190988	101
18:30	50.14	188834	5337	18930	1520	26697	1732	135557	1744	168384	191517	42
18:45	50.09	186535	5334	18983	1350	26696	1800	133516	1704	166202	189383	57
19:00	50.09	184065	5332	19220	1303	26870	1740	130507	1759	163542	186731	63
19:15	50.04	181076	5327	19451	1159	26972	1795	127438	1736	160466	183878	79
19:30	49.98	179304	5333	19596	0	27586	1742	124588	1727	159708	180572	168
19:45	49.98	176735	5338	19760	0	27860	1751	121474	1715	156975	177898	208
20:00	50.03	173484	5329	19946	0	27646	1751	118038	1734	153538	174444	240
20:15	50.03	170907	5338	20272	0	26974	1798	115848	1753	150635	171983	257
20:30	50.03	170039	5321	20268	0	24550	1790	117342	1714	149771	170985	276
20:45	50.08	169200	5327	20285	0	23449	1796	117640	1716	148915	170213	332
21:00	50.13	167364	5355	20131	0	22200	1751	117130	1728	147233	168295	381
21:15	50.08	165061	5348	20054	0	22089	1741	115016	1738	145007	165986	337
21:30	50.03	163492	5345	19938	0	21858	1798	113985	1725	143554	164649	406
21:45	49.98	161845	5337	19587	0	20766	1750	113743	1748	142258	162931	367
22:00	49.98	160283	5338	19293	0	20557	1740	112634	1737	140990	161299	401
22:15	49.82	159193	5311	19581	0	19273	1754	112574	1718	139612	160211	423
22:30	49.88	158360	5323	19857	0	19253	1754</					