



National Load Despatch Centre
राष्ट्रीय भार प्रेषण केंद्र
GRID CONTROLLER OF INDIA LIMITED
ग्रिड कंट्रोलर ऑफ इंडिया लिमिटेड

(Government of India Enterprise/ भारत सरकार का उद्यम)
B-9, QUTUB INSTITUTIONAL AREA, KATWARIA SARAI, NEW DELHI -110016
बी-9, कुतुब इन्स्टीट्यूशनल एरिया, कटवारिया सराये, न्यू दिल्ली-110016

Ref: GRID-INDIA/NLDC/SO/Daily PSP Report

दिनांक: 21.10.2025

To,

- कार्यकारी निदेशक, पू.क्षे.भा.प्रे.के., 14, गोल्फ क्लब रोड, कोलकाता - 700033
Executive Director, ERLDC, 14 Golf Club Road, Tollygunge, Kolkata, 700033
- कार्यकारी निदेशक, ऊ.क्षे.भा.प्रे.के., 18/ए, शाहीद जीत सिंह सनसनवाल मार्ग, नई दिल्ली - 110016
Executive Director, NRLDC, 18-A, Shaheed Jeet Singh Marg, Katwaria Sarai, New Delhi - 110016
- कार्यकारी निदेशक, प.क्षे.भा.प्रे.के., एफ3, एम आई डी सी क्षेत्र, अंधेरी, मुंबई -400093
Executive Director, WRLDC, F-3, M.I.D.C. Area, Marol, Andheri (East), Mumbai-400093
- कार्यकारी निदेशक, ऊ.पू.क्षे.भा.प्रे.के., डोंगतेह, लोअर नोंग्रह, लापालंग, शिलोंग - 793006
Executive Director, NERLDC, Dongteih, Lower Nongrah, Lapalang, Shillong - 793006, Meghalaya
- कार्यकारी निदेशक, द.क्षे.भा.प्रे.के., 29, रेस कोर्स क्रॉस रोड, बंगलुरु -560009
Executive Director, SRLDC, 29, Race Course Cross Road, Bangalore-560009

Sub: Daily PSP Report for the date 20.10.2025.

महोदय/Sir,

आईईजीसी-2023 की धारा स.-38(1) के प्रावधान के अनुसार, दिनांक 20-अक्टूबर-2025 की अखिल भारतीय प्रणाली की दैनिक ग्रिड निष्पादन रिपोर्ट रांभांप्रेके की वेबसाइट पर उपलब्ध है।

As per article 38(1) of the Indian Electricity Grid Code, the daily report pertaining power supply position of All India Power System for the date 20.10.2025, is available at the NLDC website.

धन्यवाद,
Thanks

Report for previous day

Date of Reporting: 21-Oct-2025

A. Power Supply Position at All India and Regional level

	NR	WR	SR	ER	NER	TOTAL
Demand Met during Evening Peak hrs(MW) (at 19:00 hrs; from RLDCs)	47860	52742	36368	25837	3166	165973
Peak Shortage (MW)	0	0	0	0	0	0
Energy Met (MU)	1120	1287	924	573	61	3965
Hydro Gen (MU)	197	40	139	71	28	476
Wind Gen (MU)	7	59	49	-	-	115
Solar Gen (MU)*	173.30	143.64	95.40	2.72	1.19	416
Energy Shortage (MU)	0.00	0.00	0.00	0.00	0.00	0.00
Maximum Demand Met During the Day (MW) (From NLDC SCADA)	53030	57254	43996	26692	3335	180140
Time Of Maximum Demand Met	09:50	10:08	10:03	18:31	17:31	10:14

B. Frequency Profile (%)

Region	FVI	< 49.7	49.7 - 49.8	49.8 - 49.9	< 49.9	49.9 - 50.05	> 50.05
All India	0.034	0.00	0.20	5.58	5.77	78.24	15.98

C. Power Supply Position in States

Region	States	Max.Demand Met during the day (MW)	Shortage during maximum Demand (MW)	Energy Met (MU)	Drawal Schedule (MU)	OD(+)/UD(-) (MU)	Max OD (MW)	Energy Shortage (MU)
NR	Punjab	7962	0	153.4	78.4	0.2	337	0.00
	Haryana	6795	0	144.3	119.4	-1.6	211	0.00
	Rajasthan	11723	0	237.2	56.8	0.2	621	0.00
	Delhi	3828	0	80.2	77.9	-0.2	180	0.00
	UP	18228	0	394.6	140.9	-1.1	608	0.00
	Uttarakhand	1611	0	30.8	15.8	-0.3	78	0.00
	HP	1237	0	22.1	1.5	-0.6	97	0.00
	J&K(UT) & Ladakh(UT)	2610	0	49.3	41.0	-1.9	261	0.00
	Chandigarh	183	0	3.4	3.4	0.0	17	0.00
	Railways_NR ISTS	226	0	4.7	3.9	0.8	58	0.00
WR	Chhattisgarh	4853	0	101.5	48.4	1.0	416	0.00
	Gujarat	15512	0	329.9	195.9	-0.6	1483	0.00
	MP	12457	0	246.2	144.8	0.0	355	0.00
	Maharashtra	24344	0	540.0	167.7	-1.9	639	0.00
	Goa	576	0	12.4	10.3	1.6	27	0.00
	DNHDDPDCL	1201	0	20.4	20.6	-0.2	107	0.00
	AMNSIL	852	0	18.7	11.7	0.4	296	0.00
	BALCO	535	0	12.8	12.8	0.0	6	0.00
	RIL JAMNAGAR	255	0	4.8	5.5	-0.7	0	0.00
	Andhra Pradesh	8427	0	185.2	43.4	-1.9	825	0.00
SR	Telangana	11764	0	221.2	84.8	1.4	824	0.00
	Karnataka	11097	0	212.1	65.0	-0.8	422	0.00
	Kerala	3996	0	79.2	43.6	-0.9	313	0.00
	Tamil Nadu	10756	0	219.9	111.8	-2.4	910	0.00
	Puducherry	329	0	6.6	6.2	-0.2	42	0.00
	Bihar	6514	0	136.8	125.2	0.7	342	0.00
ER	DVC	3170	0	66.1	-29.3	-0.6	420	0.00
	Jharkhand	2161	0	43.2	30.5	0.5	208	0.00
	Odisha	5772	0	114.1	42.6	-1.5	269	0.00
	West Bengal	9793	0	211.5	78.1	-2.3	174	0.00
	Sikkim	63	0	0.8	1.0	-0.2	7	0.00
	Railways_ER ISTS	14	0	0.2	0.1	0.0	0	0.00
NER	Arunachal Pradesh	170	0	2.9	3.0	-0.4	4	0.00
	Assam	2000	0	38.2	29.9	0.7	47	0.00
	Manipur	219	0	3.2	3.2	0.0	8	0.00
	Meghalaya	322	0	5.5	3.9	-0.1	3	0.00
	Mizoram	131	0	1.9	0.7	-0.4	3	0.00
	Nagaland	192	0	2.9	2.8	-0.1	2	0.00
	Tripura	327	0	6.4	6.4	0.2	24	0.00

D. Transnational Exchanges (MU) - Import(+ve)/Export(-ve)

	Bhutan	Nepal	Bangladesh	Godda -> Bangladesh
Actual (MU)	23.8	24.4	-24.8	-34.7
Day Peak (MW)	1172.0	1135.0	-1064.0	-1483.3

E. Import/Export by Regions (in MU) - Import(+ve)/Export(-ve); OD(+)/UD(-)

	NR	WR	SR	ER	NER	TOTAL
Schedule(MU)	127.0	-124.9	86.3	-94.7	6.3	0.0
Actual(MU)	133.2	-118.1	81.6	-109.0	4.4	-7.9
O/D/U/D(MU)	6.2	6.8	-4.8	-14.3	-1.9	-7.9

F. Generation Outage(MW)

	NR	WR	SR	ER	NER	TOTAL	% Share
Central Sector	7187	15054	11848	3070	265	37423	47
State Sector	12314	18314	9303	2767	179	42877	53
Total	19501	33368	21151	5837	444	80300	100

G. Sourcewise generation (Gross) (MU)

	NR	WR	SR	ER	NER	All India	% Share
Coal	617	1167	490	668	11	2952	69
Lignite	28	16	45	0	0	88	2
Hydro	197	40	139	71	28	476	11
Nuclear	29	65	65	0	0	159	4
Gas, Naptha & Diesel	3	11	5	0	22	40	1
RES (Wind, Solar, Biomass & Others)	188	203	164	4	1	561	13
Total	1062	1501	908	743	62	4277	100

Share of RES in total generation (%)	17.71	13.55	18.09	0.56	1.93	13.12
Share of Non-fossil fuel (Hydro,Nuclear and RES) in total generation(%)	39.04	20.52	40.52	10.14	47.92	27.96

H. All India Demand Diversity Factor

Based on Regional Max Demands	1.023
Based on State Max Demands	1.066

I. All India Peak Demand and shortage at Solar and Non-Solar Hour

	Max Demand Met(MW)	Time	Shortage(MW)
Solar hr	180140	10:14	0
Non-Solar hr	173233	18:31	0

Diversity factor = Sum of regional or state maximum demands / All India maximum demand

**Note: All generation MU figures are gross

***Godda (Jharkhand) -> Bangladesh power exchange is through the radial connection (isolated from Indian Grid)

Solar Hours -> 06:00 to 18:00hrs and rest are Non-Solar Hours

*Source: RLDCs for solar connected to ISTS; SLDCs for embedded solar. Limited visibility of embedded solar data.

Executive Director-NLDC

INTER-REGIONAL EXCHANGES

Import=(+ve) /Export =(-ve) for NET (MU)
Date of Reporting: 21-Oct-2025

Sl No	Voltage Level	Line Details	No. of Circuit	Max Import (MW)	Max Export (MW)	Import (MU)	Export (MU)	NET (MU)
Import/Export of ER (With NR)								
1	HVDC	ALIPURDUAR-AGRA	2	0	312	0.0	7.5	-7.5
2	HVDC	PUSAULI B/B	-	0	47	0.0	2.6	-2.6
3	765 kV	GAYA-VARANASI	2	639	1036	0.0	7.8	-7.8
4	765 kV	SASARAM-FATEHPUR	1	287	412	0.0	2.0	-2.0
5	765 kV	GAYA-BALIA	1	0	623	0.0	9.5	-9.5
6	400 kV	PUSAULI-VARANASI	1	0	117	0.0	2.1	-2.1
7	400 kV	PUSAULI-ALLAHABAD	1	21	61	0.0	0.4	-0.4
8	400 kV	MUZAFFARPUR-GORAKHPUR	2	115	717	0.0	8.4	-8.4
9	400 kV	PATNA-BALIA	2	150	683	0.0	7.4	-7.4
10	400 kV	NAUBATPUR-BALIA	2	40	337	0.0	1.6	-1.6
11	400 kV	BIHARSHARIFF-BALIA	2	382	161	2.2	0.0	2.2
12	400 kV	MOTIHARI-GORAKHPUR	2	54	455	0.0	5.7	-5.7
13	400 kV	BIHARSARIFF-SAHUPURI	2	267	299	0.0	1.5	-1.5
14	220 kV	SAHUPURI-KARMANASA	1	0	44	0.0	0.7	-0.7
15	132 kV	NAGAR UNTARI-RIHAND	1	0	0	0.0	0.0	0.0
16	132 kV	GARWAH-RIHAND	1	30	0	0.6	0.0	0.6
17	132 kV	KARMANASA-SAHUPURI	1	0	0	0.0	0.0	0.0
18	132 kV	KARMANASA-CHANDAULI	1	0	0	0.0	0.0	0.0
ER-NR						2.8	57.1	-54.3
Import/Export of ER (With WR)								
1	765 kV	JHARSUGUDA-DHARAMJAIGARH	4	926	672	0.0	2.2	-2.2
2	765 kV	NEW RANCHI-DHARAMJAIGARH	2	1561	532	17.5	0.0	17.5
3	765 kV	JHARSUGUDA-DURG	2	81	789	0.0	10.0	-10.0
4	400 kV	JHARSUGUDA-RAIGARH	4	465	392	0.3	0.0	0.3
5	400 kV	RANCHI-SIPAT	2	361	225	2.7	0.0	2.7
6	400 kV	JEYPORE-JACDALPUR	2	379	360	0.0	1.0	-1.0
7	220 kV	BUDHIPADAR-RAIGARH	1	75	124	0.0	0.7	-0.7
8	220 kV	BUDHIPADAR-KORBA	2	198	79	1.0	0.0	1.0
ER-WR						21.6	13.9	7.7
Import/Export of ER (With SR)								
1	HVDC	JEYPORE-GAZUWAKA B/B	2	0	308	0.0	4.6	-4.6
2	HVDC	TALCHER-KOLAR BIPOLE	2	0	1615	0.0	32.4	-32.4
3	765 kV	ANGUL-SRIKAKULAM	2	0	2832	0.0	42.7	-42.7
4	400 kV	TALCHER I/C	2	183	1187	0.0	3.0	-3.0
5	220 kV	BALIMELA-UPPER-SILERRU	1	0	0	0.0	0.0	0.0
ER-SR						0.0	79.7	-79.7
Import/Export of ER (With NER)								
1	400 kV	BINAGURI-BONGAIGAON	2	0	377	0.0	4.8	-4.8
2	400 kV	ALIPURDUAR-BONGAIGAON	2	0	624	0.0	8.4	-8.4
3	220 kV	ALIPURDUAR-SALAKATI	2	0	112	0.0	1.5	-1.5
ER-NER						0.0	14.7	-14.7
Import/Export of NER (With NR)								
1	HVDC	BISWANATH CHARIALI-AGRA	2	0	403	0.0	9.8	-9.8
NER-NR						0.0	9.8	-9.8
Import/Export of WR (With NR)								
1	HVDC	CHAMPA-KURUKSHETRA	2	0	1997	0.0	30.0	-30.0
2	HVDC	VINDHYACHAL B/B	-	489	0	10.5	0.0	10.5
3	HVDC	MUNDRA-MOHINDERGARH	2	0	500	0.0	12.2	-12.2
4	765 kV	GWALIOR-AGRA	2	71	1662	0.0	18.5	-18.5
5	765 kV	GWALIOR-PHAGI	2	970	1712	4.4	22.6	-18.3
6	765 kV	JABALPUR-ORAI	2	33	836	0.0	23.6	-23.6
7	765 kV	GWALIOR-ORAI	1	972	0	13.6	0.0	13.6
8	765 kV	SATNA-ORAI	1	0	824	0.0	13.0	-13.0
9	765 kV	BANASKANTHA-CHITORGARH	2	2170	218	28.4	0.2	28.2
10	765 kV	VINDHYACHAL-VARANASI	2	161	1846	0.0	25.7	-25.7
11	400 kV	ZERDA-KANKROLI	1	409	0	6.8	0.0	6.8
12	400 kV	ZERDA -BHINMAL	1	282	0	4.7	0.0	4.7
13	400 kV	VINDHYACHAL -RIHAND	1	0	1	0.0	0.0	0.0
14	400 kV	RAPP-SHUJALPUR	2	722	317	4.6	1.9	2.7
15	400 kV	NEEMUCH-Chittorgarh	2	666	424	3.8	3.5	0.3
16	220 kV	BHANPURA-RANPUR	1	0	55	0.0	0.8	-0.8
17	220 kV	BHANPURA-MORAK	1	0	30	0.0	1.2	-1.2
18	220 kV	MEHGAON-AURAIYA	1	78	6	0.8	0.0	0.8
19	220 kV	MALANPUR-AURAIYA	1	55	18	0.4	0.0	0.4
20	132 kV	RAIGHAT-LALITPUR	2	0	0	0.0	0.0	0.0
WR-NR						77.8	153.2	-75.4
Import/Export of WR (With SR)								
1	HVDC	BHADRAWATI B/B	-	0	308	0.0	7.2	-7.2
2	HVDC	RAIGARH-PUGALUR	2	0	2004	0.0	22.0	-22.0
3	765 kV	SOLAPUR-RAICHUR	2	1265	626	10.8	0.9	10.0
4	765 kV	WARDHA-NIZAMABAD	2	35	1846	0.0	19.3	-19.3
5	765 kV	WARORA-WARANGAL(NEW)	2	27	2199	0.0	24.0	-24.0
6	400 kV	KOLHAPUR-KUDGI	2	1373	0	26.0	0.0	26.0
7	220 kV	KOLHAPUR-CHIKODI	2	0	0	0.0	0.0	0.0
8	220 kV	PONDA-AMBEWADI	1	0	0	0.0	0.0	0.0
9	220 kV	XELDEM-AMBEWADI	1	0	84	1.6	0.0	1.6
WR-SR						38.4	73.3	-34.9

INTERNATIONAL EXCHANGES					Import(+ve)/Export(-ve)		
State	Region	Line Name	Max (MW)	Min (MW)	Avg (MW)	Energy Exchange (MU)	
BHUTAN	ER	400kV MANGDECHHU-ALIPURDUAR 1,2&3 I.e. ALIPURDUAR RECEIPT (from MANGDECHU HEP 4*180MW)	748	475	644	15.45	
	ER	400kV TALA-BINAGURI 1,2,4 (& 400kV MALBASE - BINAGURI) I.e. BINAGURI RECEIPT (from TALA HEP 6*170MW)	474	346	397	9.54	
	ER	220kV CHUKHA-BIRPARA 1&2 (& 220kV MALBASE - BIRPARA) I.e. BIRPARA RECEIPT (from CHUKHA HEP 4*84MW)	-77	-14	-37	-0.88	
	NER	132kV GELEPHU-SALAKATI	-37	-24	-30	-0.72	
	NER	132kV MOTANGA-RANGIA	51	2	17	0.41	
NEPAL	NR	NEPAL IMPORT (FROM UP)	0	0	0	0.00	
	NR	132kV MAHENDRANAGAR-TANAKPUR(NHPC)	69	0	62	1.49	
	ER	NEPAL IMPORT (FROM BIHAR)	180	143	161	3.87	
	ER	400kV DHALKEBAR-MUZAFFARPUR 1&2	898	774	792	19.01	
BANGLADESH	ER	BHERAMARA B/B HVDC (B'DESH)	-963	-931	-952	-22.84	
	ER (Isolated from Indian Grid)	400kV GODDA_TPS-RAHANPUR (B'DESH) D/C	-1483	-1313	-1446	-34.70	
	NER	132kV COMILLA-SURAJMANI NAGAR 1&2	-139	0	-83	-1.99	

CROSS BORDER EXCHANGE SCHEDULE

Date of Reporting: 21-Oct-2025

Export From India (in MU)

Country	GNA (ISGS/PPA)	T-GNA							TOTAL
		BILATERAL TOTAL	COLLECTIVE						
			IDAM			RTM			
			IEX	PXIL	HPX	IEX	PXIL	HPX	
Bhutan	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Nepal	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Bangladesh	23.48	0.16	0.00	0.00	0.00	0.00	0.00	0.00	23.64
Myanmar	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total Export	23.48	0.16	0.00	0.00	0.00	0.00	0.00	0.00	23.64

Import by India(in MU)

Country	GNA (ISGA/PPA)	T-GNA							TOTAL	
		BILATERAL TOTAL	COLLECTIVE							
			IDAM			RTM				
			IEX	PXIL	HPX	IEX	PXIL	HPX		
Bhutan	7.95	0.00	1.41	0.00	0.00	0.00	0.00	0.00	9.36	
Nepal	9.14	4.77	4.41	0.00	0.00	0.00	5.07	0.00	0.00	23.39
Bangladesh	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Myanmar	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total Import	17.09	4.77	5.82	0.00	0.00	0.00	5.07	0.00	0.00	32.75

Net from India(in MU)

-ve : Export / +ve : Import

Country	GNA (ISGS/PPA)	T-GNA							TOTAL	
		BILATERAL TOTAL	COLLECTIVE							
			IDAM			RTM				
			IEX	PXIL	HPX	IEX	PXIL	HPX		
Bhutan	7.95	0.00	1.41	0.00	0.00	0.00	0.00	0.00	9.36	
Nepal	9.14	4.77	4.41	0.00	0.00	0.00	5.07	0.00	0.00	23.39
Bangladesh	-23.48	-0.16	0.00	0.00	0.00	0.00	0.00	0.00	0.00	-23.64
Myanmar	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total Net	-6.39	4.61	5.82	0.00	0.00	0.00	5.07	0.00	0.00	9.11

15 Min (INSTANTANEOUS) ALL INDIA GRID FREQUENCY, GENERATION & DEMAND MET (SCADA DATA)													Date of Reporting: 21-Oct-2025
TIME	FREQUENCY (Hz)	DEMAND MET (MW)	NUCLEAR (MW)	WIND (MW)	SOLAR (MW)	HYDRO** (MW)	GAS (MW)	THERMAL (MW)	OTHERS* (MW)	NET DEMAND MET (MW)	TOTAL GENERATION N (MW)	NET TRANSNATIONAL EXCHANGE (MW)	
		(A)	(B)	(C)	(D)	(E)	(F)	(G)	(H)	(I=A-C+D)	(J=B+C+D+E+H)	(K)	
0:00	49.98	164620	5948	3804	0	20217	1658	133087	1570	160816	166284	901	
0:15	49.98	163887	5983	3750	0	19561	1644	133157	1519	160137	165614	928	
0:30	49.98	162785	5982	3771	0	18998	1634	132589	1531	159014	164505	899	
0:45	49.87	161054	5976	3740	0	18327	1641	131361	1455	157314	162500	913	
1:00	49.98	160161	5976	3696	0	18118	1636	130774	1427	156465	161627	914	
1:15	49.98	158674	5999	3567	0	17599	1641	129909	1410	155107	160125	920	
1:30	49.98	157697	6000	3466	0	17235	1635	129326	1384	154231	159046	946	
1:45	49.98	157328	5997	3417	0	16727	1637	129505	1417	153911	158700	933	
2:00	50.03	156070	6013	3481	0	16621	1642	128360	1394	152589	157511	949	
2:15	49.98	156025	5985	3530	0	16739	1643	128046	1399	152495	157342	939	
2:30	50.03	155061	5993	3611	0	16567	1643	127176	1413	151450	156403	968	
2:45	49.97	155202	6007	3687	0	16429	1647	127771	1443	151515	156484	899	
3:00	50.03	154340	5992	3836	0	16042	1638	126659	1429	150504	155596	898	
3:15	49.97	153692	5974	3860	0	15995	1686	126039	1442	149832	154996	909	
3:30	50.03	153513	6000	3853	0	16108	1684	125620	1435	149660	154700	911	
3:45	50.02	153421	6038	3974	0	16214	1715	125236	1462	149447	154639	925	
4:00	50.02	153058	6011	4171	0	16373	1687	124806	1427	148887	154475	919	
4:15	49.97	154298	5981	4282	0	16490	1722	125588	1422	150016	155485	921	
4:30	50.02	154953	5993	4275	0	16413	1723	126146	1443	150678	155993	894	
4:45	50.02	155832	6003	4324	0	16530	1553	126643	1439	151508	156492	921	
5:00	50.07	157283	6000	4460	332	17470	1548	127229	1438	152491	158477	916	
5:15	50.02	159836	6001	4603	333	18001	1727	129058	1446	154900	161169	855	
5:30	50.02	162249	5981	4753	338	19023	1534	130308	1436	157158	163373	867	
5:45	50.02	163819	6007	4871	345	20274	1547	130588	1509	158603	165141	885	
6:00	50.07	165011	5995	4998	337	21866	1545	130234	1441	159676	166416	869	
6:15	50.02	166689	6001	4995	454	23036	1552	130839	1411	161240	168288	887	
6:30	50.02	168393	5964	4994	696	24316	1603	131003	1472	162703	170048	892	
6:45	49.97	170125	5972	4819	1297	24523	1605	131816	1467	164009	171499	879	
7:00	49.97	170881	5995	4740	2269	24750	1611	130922	1424	163872	171711	876	
7:15	50.02	172160	6008	4662	3883	25621	1614	128966	1410	163615	172164	864	
7:30	50.02	172373	6041	4503	6167	23993	1609	127280	1473	161703	171066	842	
7:45	50.02	172806	6036	4374	9021	21046	1616	126468	1456	159411	170017	976	
8:00	49.97	172187	6067	4175	12027	20067	1620	122176	1532	155985	167664	952	
8:15	49.97	173706	6039	3998	15525	19578	1583	119353	1572	154183	167648	944	
8:30	49.97	174722	6031	3865	18422	19268	1528	116217	1613	152435	166944	961	
8:45	49.97	176411	6020	3599	21693	18778	1526	113732	1552	151119	166900	1008	
9:00	50.07	176388	6034	3245	24710	18310	1511	110227	1521	148433	165558	994	
9:15	50.02	178274	5999	3015	27218	17530	1517	109069	1553	148041	165901	1019	
9:30	50.12	178398	6001	2926	29828	16816	1519	105819	1567	145644	164476	1012	
9:45	50.12	178514	6008	2929	32016	16451	1517	103212	1565	143569	163698	998	
10:00	50.12	177851	5997	2946	34306	16060	1453	99627	1615	140599	162004	1024	
10:15	49.97	179863	5973	3103	38602	15905	1461	98551	1604	138158	165199	984	
10:30	49.97	179489	5995	3166	39534	15854	1458	97886	1603	136789	165496	971	
10:45	49.97	179023	6013	3240	40752	15374	1462	97290	1614	135031	165745	839	
11:00	50.02	179107	6014	3379	41684	15094	1462	96386	1635	134044	165654	793	
11:15	50.02	178289	6015	3473	41839	14630	1459	95740	1612	132977	164768	799	
11:30	50.02	178345	5980	3652	42283	14592	1454	95555	1601	132410	165117	803	
11:45	50.02	177754	5988	3731	54871	13180	1455	95471	1654	119152	176350	813	
12:00	50.02	175877	5972	3740	55133	13429	1457	94426	1660	117004	175817	751	
12:15	49.97	175671	5974	3797	54864	13066	1467	95318	1633	117010	176119	747	
12:30	49.97	175071	5961	3746	53458	13175	1492	95721	1621	117867	175174	760	
12:45	49.92	174218	5984	3621	52737	13168	1505	95848	1638	117860	174501	775	
13:00	49.97	173218	5960	3570	52276	13223	1502	95201	1665	117372	173397	778	
13:15	49.97	172015	5989	3614	51150	13165	1496	95290	1620	117251	172324	777	
13:30	49.97	171398	5975	3734	50963	12913	1494	94883	1644	116701	171606	747	
13:45	50.02	170512	5995	3587	51332	13140	1496	93854	1616	115593	171020	745	
14:00	50.02	170685	5948	3616	50765	13662	1494	94016	1613	116304	171114	728	
14:15	50.07	169890	6014	3724	50143	13677	1502	93499	1578	116023	170137	697	
14:30	49.97	170493	5971	3684	49389	14165	1499	94606	1551	117420	170865	690	
14:45	49.92	170300	5975	3668	47878	14622	1518	95625	1549	118754	170835	691	
15:00	49.97	170342	5954	3842	45931	14755	1529	97176	1527	120569	170714	741	
15:15	49.92	169573	5979	3972	44122	14889	1612	97929	1540	121479	170043	852	
15:30	49.97	169719	5944	4105	41141	15572	1589	100575	1488	124473	170414	829	
15:45	49.97	169452	5966	4129	37465	15725	1599	103463	1534	127858	169881	876	
16:00	49.97	167530	5928	4140	33100	16113	1581	105380	1555	130290	167797	880	
16:15	50.02	164293	5956	4135	28376	16485	1588	106859	1521	131782	164920	857	
16:30	50.02	163230	5935	4212	24118	16429	1588	110292	1471	134900	164045	870	
16:45	49.92	162431	5912	4329	18702	16325	1595	115177	1414	139400	163454	856	
17:00	49.97	161974	5942	4366	13557	17857	1601	118842	1388	144051	163553	830	
17:15	50.02	162055	5939	4482	9414	19992	1599	121148	1333	148159	163907	760	
17:30	50.02	164562	5955	4613	5720	20840	1590	126699	1372	154229	166789	700	
17:45	50.02	167010	5978	4670	2891	21849	1630	131014	1382	159449	169414	678	
18:00	50.07	169603	6013	4639	1259	23641	1632	133272	1343	163705	171799	692	
18:15	50.07	171738	6038	4989	607	24804	1597	134672	1369	166142	174076	723	
18:30	50.12	173097	5980	5673	516	26366	1603	134210	1356	166908	175704	723	
18:45	50.07	171732	6031	6068	412	26994	1590	131813	1414	165252	174322	693	
19:00	50.12	169951	6019	6447	427	27161	1600	129235	1402	163077	172291	774	
19:15	50.07	168025	6029	6555	178	26763	1604	127118	1381	161292	169628	806	
19:30	50.07	166493	6017	6711	0	26652	1619	125748	1389	159782	168136	811	
19:45	49.97	164677	6033	6756	0	26591	1617	123892	1378	157921	166267	863	
20:00	49.97	163032	6022	6663	0	26778	1631	122270	1426	156369	164790	795	
20:15	49.97	161692	6022	6631	0	26943	1629	121024	1402	155061	163651	796	
20:30	49.97	161243	6023	6451	0	26965	1629	120095	1489	154792	162652	808	
20:45	49.92	160506	6022	6567	0	26168	1613	120113	1396	153939	161879	820	
21:00	49.92	159788	6014	6294	0	25808	1631	119932	1377	153494	161056	836	
21:15	49.97	159326	6029	6084	0	25667	1635	119822	1426	153242	160663	858	
21:30	49.97	157619	6026	5978	0	24170	1629	119656	1382	151641	158841	875	
21:45	49.97	157383	6017	5927	0	23619	1638	119807	1386	151456	158394	910	
22:00	50.02	156454	6042	5785	0	22976	1647	119704	1371	150669	157525	891	
22:15	50.02	157094	6034	5889	0	22564	1667	120571	1378	151205	158103	880	
22:30	50.02	156682	6044	5956	0	22106	1678	120562	1396	150726	157742	934	
22:45	49.97	155955	6021	5816	0	21661	1692	120468	1453	150139	157111	892	
23:00	49.97	154926	6038	5709	0	2							