



National Load Despatch Centre
राष्ट्रीय भार प्रेषण केंद्र
GRID CONTROLLER OF INDIA LIMITED
ग्रिड कंट्रोलर ऑफ इंडिया लिमिटेड

(Government of India Enterprise/ भारत सरकार का उद्यम)
B-9, QUTUB INSTITUTIONAL AREA, KATWARIA SARAI, NEW DELHI -110016
बी-9, कुतुब इन्स्टीट्यूशनल एरिया, कटवारिया सराये, न्यू दिल्ली-110016

Ref: GRID-INDIA/NLDC/SO/Daily PSP Report

दिनांक: 12.02.2025

To,

- कार्यकारी निदेशक, पू.क्षे.भा.प्रे.के., 14, गोल्फ क्लब रोड, कोलकाता - 700033
Executive Director, ERLDC, 14 Golf Club Road, Tollygunge, Kolkata, 700033
- कार्यकारी निदेशक, ऊ.क्षे.भा.प्रे.के., 18/ए, शाहीद जीत सिंह सनसनवाल मार्ग, नई दिल्ली - 110016
Executive Director, NRLDC, 18-A, Shaheed Jeet Singh Marg, Katwaria Sarai, New Delhi - 110016
- कार्यकारी निदेशक, प.क्षे.भा.प्रे.के., एफ3, एम आई डी सी क्षेत्र, अंधेरी, मुंबई -400093
Executive Director, WRLDC, F-3, M.I.D.C. Area, Marol, Andheri (East), Mumbai-400093
- कार्यकारी निदेशक, ऊ.पू.क्षे.भा.प्रे.के., डोंगतेह, लोअर नोंग्रह, लापालंग, शिलोंग - 793006
Executive Director, NERLDC, Dongteih, Lower Nongrah, Lapalang, Shillong - 793006, Meghalaya
- कार्यकारी निदेशक, द.क्षे.भा.प्रे.के., 29, रेस कोर्स क्रॉस रोड, बंगलुरु -560009
Executive Director, SRLDC, 29, Race Course Cross Road, Bangalore-560009

Sub: Daily PSP Report for the date 11.02.2025.

महोदय/Dear Sir,

आईईजीसी-2023 की धारा स.-38(1) के प्रावधान के अनुसार, दिनांक 11-फ़रवरी-2025 की अखिल भारतीय प्रणाली की दैनिक ग्रिड निष्पादन रिपोर्ट रांभांप्रेके की वेबसाइट पर उपलब्ध है।

As per article 38(1) of the Indian Electricity Grid Code, the daily report pertaining power supply position of All India Power System for the date 11.02.2025, is available at the NLDC website.

धन्यवाद,
Thanks

Report for previous day

Date of Reporting: 12-Feb-2025

A. Power Supply Position at All India and Regional level

	NR	WR	SR	ER	NER	TOTAL
Demand Met during Evening Peak hrs(MW) (at 19:00 hrs; from RLDCs)	57670	68889	48067	22775	2726	200127
Peak Shortage (MW)	0	204	0	0	35	239
Energy Met (MU)	1261	1645	1318	481	50	4755
Hydro Gen (MU)	95	64	85	26	10	280
Wind Gen (MU)	12	71	51	-	-	134
Solar Gen (MU)*	183.85	117.46	145.89	2.48	0.67	450
Energy Shortage (MU)	0.00	2.61	0.00	0.00	0.20	2.81
Maximum Demand Met During the Day (MW) (From NLDC SCADA)	66714	79200	65541	23556	2757	234858
Time Of Maximum Demand Met	10:36	10:24	09:39	18:23	18:03	09:43

B. Frequency Profile (%)

Region	FVI	< 49.7	49.7 - 49.8	49.8 - 49.9	< 49.9	49.9 - 50.05	> 50.05
All India	0.033	0.00	0.00	4.50	4.50	79.91	15.59

C. Power Supply Position in States

Region	States	Max.Demand Met during the day (MW)	Shortage during maximum Demand (MW)	Energy Met (MU)	Drawal Schedule (MU)	OD(+)/UD(-) (MU)	Max OD (MW)	Energy Shortage (MU)
NR	Punjab	8744	0	162.3	54.0	0.7	368	0.00
	Haryana	9089	0	171.7	107.8	-1.8	243	0.00
	Rajasthan	18520	0	347.5	114.2	-3.1	491	0.00
	Delhi	4170	0	73.7	66.1	-1.7	347	0.00
	UP	19004	0	352.6	93.2	0.8	436	0.00
	Uttarakhand	2372	0	43.6	33.7	0.3	98	0.00
	HP	2108	0	37.6	32.0	-0.6	163	0.00
	J&K(UT) & Ladakh(UT)	2960	0	63.5	61.3	-1.8	181	0.00
	Chandigarh	246	0	3.8	3.9	-0.1	11	0.00
WR	Railways_NR ISTS	207	0	4.5	3.9	0.6	60	0.00
	Chhattisgarh	5973	0	133.1	70.8	1.2	403	0.70
	Gujarat	23234	0	441.8	193.2	-7.4	949	0.00
	MP	17623	239	348.0	229.7	-2.4	1076	1.91
	Maharashtra	29360	0	639.7	239.9	-1.1	889	0.00
	Goa	751	0	15.4	14.5	0.7	69	0.00
	DNHDDPDCL	1337	0	30.7	30.8	0.0	30	0.00
	AMNSIL	828	0	18.9	9.2	0.3	243	0.00
	BALCO	534	0	12.7	12.7	0.0	14	0.00
SR	RIL JAMNAGAR	185	0	4.4	4.5	0.0	0	0.00
	Andhra Pradesh	12450	0	234.8	73.4	0.9	815	0.00
	Telangana	15883	0	306.4	170.3	0.2	1136	0.00
	Karnataka	17367	0	316.4	109.6	0.4	727	0.00
	Kerala	4462	0	87.6	69.0	0.3	534	0.00
	Tamil Nadu	17796	0	363.9	207.3	-2.3	635	0.00
	Puducherry	407	0	8.9	8.6	-0.3	29	0.00
ER	Bihar	5273	0	100.1	85.8	1.8	279	0.00
	DVC	3313	0	67.6	-47.3	-2.0	316	0.00
	Jharkhand	2143	0	40.2	27.2	0.4	245	0.00
	Odisha	5203	0	105.0	33.9	-0.6	487	0.00
	West Bengal	7998	0	166.1	32.8	-0.9	172	0.00
	Sikkim	127	0	2.3	2.0	0.3	47	0.00
	Railways_ER ISTS	19	0	0.2	0.2	0.0	10	0.00
NER	Arunachal Pradesh	191	0	3.5	3.4	0.0	22	0.00
	Assam	1542	0	28.3	22.1	0.5	95	0.00
	Manipur	187	10	3.3	3.2	0.1	53	0.20
	Meghalaya	337	0	5.7	4.3	0.0	76	0.00
	Mizoram	148	0	2.3	1.9	-0.1	18	0.00
	Nagaland	157	0	2.6	2.6	0.0	52	0.00
	Tripura	238	0	4.3	3.3	0.2	29	0.00

D. Transnational Exchanges (MU) - Import(+ve)/Export(-ve)

	Bhutan	Nepal	Bangladesh	Godda -> Bangladesh
Actual (MU)	-7.9	-11.6	-22.6	-15.5
Day Peak (MW)	-557.0	-653.9	-998.0	-766.0

E. Import/Export by Regions (in MU) - Import(+ve)/Export(-ve); OD(+)/UD(-)

	NR	WR	SR	ER	NER	TOTAL
Schedule(MU)	174.2	-220.0	219.3	-176.6	3.0	0.0
Actual(MU)	159.6	-215.2	223.4	-180.5	3.3	-9.4
O/D/U/D(MU)	-14.6	4.8	4.0	-3.9	0.3	-9.4

F. Generation Outage(MW)

	NR	WR	SR	ER	NER	TOTAL	% Share
Central Sector	5108	6969	4388	2736	938	20139	45
State Sector	6758	10321	4932	2299	197	24506	55
Total	11866	17289	9320	5035	1134	44645	100

G. Sourcewise generation (Gross) (MU)

	NR	WR	SR	ER	NER	All India	% Share
Coal	799	1647	726	727	17	3916	76
Lignite	28	13	45	0	0	86	2
Hydro	95	64	85	26	10	280	5
Nuclear	32	55	66	0	0	152	3
Gas, Naptha & Diesel	11	18	10	0	24	64	1
RES (Wind, Solar, Biomass & Others)	222	192	232	5	1	651	13
Total	1187	1988	1164	758	52	5149	100

Share of RES in total generation (%)	18.68	9.65	19.92	0.65	1.32	12.65
Share of Non-fossil fuel (Hydro,Nuclear and RES) in total generation(%)	29.34	15.65	32.82	4.04	21.32	21.04

H. All India Demand Diversity Factor

Based on Regional Max Demands	1.012
Based on State Max Demands	1.032

I. All India Peak Demand and shortage at Solar and Non-Solar Hour

	Max Demand Met(MW)	Time	Shortage(MW)
Solar hr	234858	9:43	409
Non-Solar hr	207024	18:45	73

Diversity factor = Sum of regional or state maximum demands / All India maximum demand

**Note: All generation MU figures are gross

***Godda (Jharkhand) -> Bangladesh power exchange is through the radial connection (isolated from Indian Grid)

Solar Hours -> 06:00 to 18:00hrs and rest are Non-Solar Hours

*Source: RLDCs for solar connected to ISTS; SLDCs for embedded solar. Limited visibility of embedded solar data.

Executive Director-NLDC

INTER-REGIONAL EXCHANGES								
Import=(+ve) /Export =(-ve) for NET (MU)								
Date of Reporting: 12-Feb-2025								
Sl No	Voltage Level	Line Details	No. of Circuit	Max Import (MW)	Max Export (MW)	Import (MU)	Export (MU)	NET (MU)
Import/Export of ER (With NR)								
1	HVDC	ALIPURDUAR-AGRA	2	0	0	0.0	0.0	0.0
2	HVDC	PUSAULI B/B	-	2	1	0.0	0.0	0.0
3	765 kV	GAYA-VARANASI	2	105	1001	0.0	16.2	-16.2
4	765 kV	SASARAM-FATEHPUR	1	0	589	0.0	10.7	-10.7
5	765 kV	GAYA-BALIA	1	0	655	0.0	8.8	-8.8
6	400 kV	PUSAULI-VARANASI	1	6	79	0.0	0.6	-0.6
7	400 kV	PUSAULI -ALLAHABAD	1	80	6	0.7	0.0	0.7
8	400 kV	MUZAFFARPUR-GORAKHPUR	2	293	474	0.0	3.4	-3.4
9	400 kV	PATNA-BALIA	2	0	655	0.0	10.4	-10.4
10	400 kV	NAUBATPUR-BALIA	2	0	216	0.0	3.0	-3.0
11	400 kV	BIHARSHARIFF-BALIA	2	246	247	0.0	1.8	-1.8
12	400 kV	MOTIHARI-GORAKHPUR	2	56	331	0.0	4.1	-4.1
13	400 kV	BIHARSARIFF-SAHUPURI	2	0	0	0.0	6.2	-6.2
14	220 kV	SAHUPURI-KARAMNASA	1	0	126	0.0	1.0	-1.0
15	132 kV	NAGAR UNTARI-RIHAND	1	0	0	0.1	0.0	0.1
16	132 kV	GARWAH-RIHAND	1	30	0	0.6	0.0	0.6
17	132 kV	KARMANASA-SAHUPURI	1	0	0	0.0	0.0	0.0
18	132 kV	KARMANASA-CHANDAUJI	1	0	0	0.0	0.0	0.0
ER-NR						1.4	66.0	-64.7
Import/Export of ER (With WR)								
1	765 kV	JHARSUGUDA-DHARAMJAIGARH	4	468	459	0.2	0.0	0.2
2	765 kV	NEW RANCHI-DHARAMJAIGARH	2	37	1214	0.0	15.8	-15.8
3	765 kV	JHARSUGUDA-DURG	2	0	1081	0.0	20.9	-20.9
4	400 kV	JHARSUGUDA-RAIGARH	4	0	848	0.0	16.0	-16.0
5	400 kV	RANCHI-SIPAT	2	12	329	0.0	3.7	-3.7
6	220 kV	BUDHIPADAR-RAIGARH	1	0	111	0.0	1.4	-1.4
7	220 kV	BUDHIPADAR-KORBA	2	56	117	0.0	0.5	-0.5
ER-WR						0.2	58.4	-58.2
Import/Export of ER (With SR)								
1	HVDC	JEYPORE-GAZUWAKA B/B	2	0	271	0.0	6.3	-6.3
2	HVDC	TALCHER-KOLAR BIPOLE	2	0	1993	0.0	42.7	-42.7
3	765 kV	ANGUL-SRIKAKULAM	2	0	2904	0.0	54.3	-54.3
4	400 kV	TALCHER-I/C	2	166	740	0.0	9.8	-9.8
5	220 kV	BALIMELA-UPPER-SILERRU	1	0	0	0.0	0.0	0.0
ER-SR						0.0	103.4	-103.4
Import/Export of ER (With NER)								
1	400 kV	BINAGURI-BONGAIGAON	2	329	21	3.8	0.0	3.8
2	400 kV	ALIPURDUAR-BONGAIGAON	2	586	0	7.2	0.0	7.2
3	220 kV	ALIPURDUAR-SALAKATI	2	138	0	1.9	0.0	1.9
ER-NER						12.8	0.0	12.8
Import/Export of NER (With NR)								
1	HVDC	BISWANATH CHARIALI-AGRA	2	661	0	16.3	0.0	16.3
NER-NR						16.3	0.0	16.3
Import/Export of WR (With NR)								
1	HVDC	CHAMPA-KURUKSHETRA	2	0	4039	0.0	83.8	-83.8
2	HVDC	VINDHYACHAL B/B	-	194	0	0.0	2.4	-2.4
3	HVDC	MUNDRA-MOHINDERGARH	2	0	1451	0.0	36.2	-36.2
4	765 kV	GWALIOR-AGRA	2	825	1311	2.6	8.3	-5.6
5	765 kV	GWALIOR-PHAGI	2	747	1366	2.4	15.6	-13.3
6	765 kV	JABALPUR-ORAI	2	354	764	0.0	9.7	-9.7
7	765 kV	GWALIOR-ORAI	1	754	0	14.1	0.0	14.1
8	765 kV	SATNA-ORAI	1	0	961	0.0	15.9	-15.9
9	765 kV	BANASKANTHA-CHITORGARH	2	1513	0	16.6	0.0	16.6
10	765 kV	VINDHYACHAL-VARANASI	2	355	1675	0.0	13.7	-13.7
11	400 kV	ZERDA-KANKROLI	1	287	0	3.6	0.0	3.6
12	400 kV	ZERDA -BHINMAL	1	198	0	2.5	0.0	2.5
13	400 kV	VINDHYACHAL -RIHAND	1	483	0	10.6	0.0	10.6
14	400 kV	RAPP-SHUJALPUR	2	759	119	7.6	0.1	7.5
15	400 kV	NEEMUCH-Chittorgarh	2	801	166	7.9	0.3	7.7
16	220 kV	BHANPURA-RANPUR	1	0	209	0.0	3.3	-3.3
17	220 kV	BHANPURA-MORAK	1	0	30	0.0	2.2	-2.2
18	220 kV	MEHGAON-AURAIYA	1	140	0	2.1	0.0	2.1
19	220 kV	MALANPUR-AURAIYA	1	110	0	1.4	0.0	1.4
20	132 kV	GWALIOR-SAWAI MADHOPUR	1	0	0	0.0	0.0	0.0
21	132 kV	RAJGHAT-LALITPUR	2	0	0	0.0	0.0	0.0
WR-NR						71.3	191.4	-120.1
Import/Export of WR (With SR)								
1	HVDC	BHADRAWATI B/B	-	0	1011	0.0	24.0	-24.0
2	HVDC	RAIGARH-PUGALUR	2	0	4013	0.0	80.4	-80.4
3	765 kV	SOLAPUR-RAICHUR	2	1210	982	6.5	6.0	0.6
4	765 kV	WARDHA-NIZAMABAD	2	0	2455	0.0	37.4	-37.4
5	765 kV	WARORA-WARANGAL(NEW)	2	0	2652	0.0	42.5	-42.5
6	400 kV	KOLHAPUR-KUDGI	2	1470	0	25.1	0.0	25.1
7	220 kV	KOLHAPUR-CHIKODI	2	0	0	0.0	0.0	0.0
8	220 kV	PONDA-AMBEWADI	1	0	0	0.0	0.0	0.0
9	220 kV	XELDEM-AMBEWADI	1	0	118	2.2	0.0	2.2
WR-SR						33.8	190.3	-156.5
INTERNATIONAL EXCHANGES								
State	Region		Line Name	Max (MW)	Min (MW)	Avg (MW)	Import(+ve)/Export(-ve) Energy Exchange (MU)	
BHUTAN	ER		400kV MANGDECHHU-ALIPURDUAR 1,2&3 I.e. ALIPURDUAR RECEIPT (from MANGDECHU HEP 4*180MW)	314	63	130	3.13	
	ER		400kV TALA-BINAGURI 1,2,4 (& 400kV MALBASE - BINAGURI) I.e. BINAGURI RECEIPT (from TALA HEP 6*170MW)	-301	103	-142	-3.42	
	ER		220kV CHUKHA-BIRPARA 1&2 (& 220kV MALBASE - BIRPARA) I.e. BIRPARA RECEIPT (from CHUKHA HEP 4*84MW)	-391	-204	-315	-7.56	
	NER		132kV GELEPHU-SALAKATI	0	0	0	0.00	
	NER		132kV MOTANGA-RANGIA	-13	13	0	-0.01	
NEPAL	NR		NEPAL IMPORT (FROM UP)	-68	0	-38	-0.92	
	NR		132kV MAHENDRANAGAR-TANAKPUR(NHPC)	-68	0	-43	-1.03	
	ER		NEPAL IMPORT (FROM BIHAR)	-186	-19	-146	-3.49	
	ER		400kV DHALKEBAR-MUZAFFARPUR 1&2	-468	0	-256	-6.14	
BANGLADESH	ER		BHERAMARA B/B HVDC (B'DESH)	-940	-640	-897	-21.52	
	ER (Isolated from Indian Grid)		400kV GODDA_TPS-RAHANPUR (B'DESH) D/C	-766	-413	-645	-15.47	
	NER		132kV COMILLA-SURAJMANI NAGAR 1&2	-58	0	-44	-1.06	

Export From India (in MU)

Country	GNA (ISGS/PPA)	T-GNA							TOTAL
		BILATERAL TOTAL	COLLECTIVE						
			IDAM			RTM			
			IEX	PXIL	HPX	IEX	PXIL	HPX	
Bhutan	0.00	0.35	8.46	0.00	0.00	0.19	0.00	0.00	9.00
Nepal	3.60	0.00	4.28	0.00	0.00	1.98	0.00	0.00	9.86
Bangladesh	22.33	0.00	0.00	0.00	0.00	0.00	0.00	0.00	22.33
Myanmar	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total Export	25.93	0.35	12.74	0.00	0.00	2.17	0.00	0.00	41.19

Import by India(in MU)

Country	GNA (ISGA/PPA)	T-GNA							TOTAL
		BILATERAL TOTAL	COLLECTIVE						
			IDAM			RTM			
			IEX	PXIL	HPX	IEX	PXIL	HPX	
Bhutan	0.77	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.77
Nepal	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Bangladesh	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Myanmar	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total Import	0.77	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.77

Net from India(in MU)

-ve : Export / +ve : Import

Country	GNA (ISGS/PPA)	T-GNA							TOTAL
		BILATERAL TOTAL	COLLECTIVE						
			IDAM			RTM			
			IEX	PXIL	HPX	IEX	PXIL	HPX	
Bhutan	0.77	-0.35	-8.46	0.00	0.00	-0.19	0.00	0.00	-8.23
Nepal	-3.60	0.00	-4.28	0.00	0.00	-1.98	0.00	0.00	-9.86
Bangladesh	-22.33	0.00	0.00	0.00	0.00	0.00	0.00	0.00	-22.33
Myanmar	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total Net	-25.16	-0.35	-12.74	0.00	0.00	-2.17	0.00	0.00	-40.42

Date of Reporting: 12-Feb-2025												
15 Min (INSTANTANEOUS) ALL INDIA GRID FREQUENCY, GENERATION & DEMAND MET (SCADA DATA)												
TIME	FREQUENCY (Hz)	DEMAND MET (MW)	NUCLEAR (MW)	WIND (MW)	SOLAR (MW)	HYDRO** (MW)	GAS (MW)	THERMAL (MW)	OTHERS* (MW)	NET DEMAND MET (MW)	TOTAL GENERATION (MW)	NET TRANSNATIONAL EXCHANGE (MW) (+ve) Import, (-ve) Export
		(A)	(B)	(C)	(D)	(E)	(F)	(G)	(H)	(I=A-(C+D))	(J=B+C+D+E+F+G+H)	(K)
0:00	50.03	168663	5947	7603	43	8034	2067	146470	3220	161017	173384	-1905
0:15	49.93	168591	5935	7549	44	7702	2098	146762	3228	160998	173318	-1929
0:30	49.98	168518	5950	7348	42	7391	2099	147117	3217	161128	173164	-1901
0:45	49.93	168337	5950	7285	44	7321	2084	147137	3156	161008	172977	-1906
1:00	49.98	167463	5951	7195	44	7293	2094	146270	3167	160224	172014	-1910
1:15	49.98	166407	5963	7111	45	6962	2106	145794	3153	159251	171134	-1898
1:30	49.98	165790	5953	7073	44	6535	2088	145485	3164	158673	170342	-1875
1:45	49.93	165237	5947	7038	42	6360	2100	145327	3177	158157	169991	-1876
2:00	49.98	164260	5939	6984	38	5979	2089	144763	3168	157238	168960	-1892
2:15	49.93	163891	5957	6985	38	5449	2077	144781	3185	156868	168472	-1801
2:30	49.98	163828	5956	6993	36	5308	2079	144809	3175	156799	168356	-1692
2:45	49.98	163453	5963	6943	35	5389	2079	144503	3161	156475	168073	-1693
3:00	50.03	162914	5954	6933	30	5315	2088	144048	3175	155951	167543	-1682
3:15	49.93	162925	5962	7039	31	5374	2075	143829	3179	155855	167489	-1663
3:30	50.03	163001	5966	7138	32	5621	2095	143539	3163	155831	167554	-1679
3:45	49.98	163625	5970	7032	31	5712	2090	143861	3168	156562	167864	-1710
4:00	50.03	162790	5961	6868	32	6086	2107	143290	3161	155890	167505	-1724
4:15	49.93	165442	5949	6817	37	6476	2142	145505	3166	158588	170092	-1752
4:30	49.98	166676	5964	6582	39	6502	2132	147088	3163	160055	171470	-1752
4:45	49.98	168367	5963	6484	41	6586	2111	148835	3169	161842	173189	-1759
5:00	50.03	170026	5957	6186	40	6763	2115	150376	3179	163800	174616	-1687
5:15	49.93	174050	5947	6161	41	7858	2088	153504	3185	167848	178784	-1627
5:30	49.98	177370	5962	5966	55	8791	2089	155947	3156	171349	181966	-1646
5:45	49.93	180313	5954	5855	64	9560	2193	158188	3161	174394	184975	-1719
6:00	50.08	183086	5953	5559	70	10922	2325	159505	3191	177457	187525	-1541
6:15	50.03	187738	5943	5323	272	12549	2447	162528	3168	182143	192230	-1631
6:30	49.98	193187	5943	5185	283	15557	2658	165143	3140	187719	197909	-1477
6:45	49.98	198708	5960	5085	323	19571	2986	166383	3207	193300	203515	-1337
7:00	49.98	203332	5960	4964	636	22230	3529	167512	3203	197732	208034	-1306
7:15	49.83	206939	5973	4822	1403	23719	3750	168178	3236	200714	211081	-1008
7:30	50.03	209807	5976	4580	3104	23971	4516	168292	3241	202123	213680	-978
7:45	50.03	211082	5973	4565	5829	24271	4035	166755	3264	200688	214692	-1008
8:00	50.13	213181	5970	4440	9930	23702	4019	165149	3390	198811	216600	-990
8:15	50.08	217170	5976	4309	15020	23571	3715	164392	3323	197841	220306	-1023
8:30	50.23	220258	5961	4078	20683	21897	3690	163441	3319	195497	223069	-1004
8:45	50.08	224480	5967	3833	26097	20738	3701	163248	3330	194550	226914	-1015
9:00	50.08	225875	5960	3488	31093	19158	3570	162074	3346	191294	228689	-1134
9:15	50.08	231897	5970	3197	36119	17847	3595	164549	3458	192581	234735	-1174
9:30	50.03	233439	5963	2993	40544	16489	3307	164001	3436	189902	236733	-1203
9:45	50.03	234843	5962	2882	44372	15499	2822	163273	3421	187589	238231	-1445
10:00	50.03	234208	5957	3038	48052	13372	2754	161304	3454	183118	237931	-1540
10:15	50.03	234019	5950	3356	50813	11377	2225	160330	3693	179850	237744	-1556
10:30	50.03	233704	5964	3529	53123	11012	2130	158382	3600	177052	237740	-1555
10:45	50.03	233369	5951	3671	55776	9990	2096	156776	3597	173922	237857	-1961
11:00	50.03	232745	5956	3559	57715	9606	2078	154620	3612	171471	237146	-1920
11:15	50.03	231694	5960	3443	59322	8774	2044	152773	3674	168929	235990	-2131
11:30	49.98	231980	5949	3367	60363	8597	2059	152501	3644	168250	236480	-2149
11:45	49.98	231347	5956	3338	61181	8370	2041	151295	3644	166828	235825	-2168
12:00	50.03	229765	5959	3320	61807	7826	2017	149842	3620	164638	234391	-2151
12:15	49.88	228452	5950	3282	62434	6839	2249	148992	3636	162736	233382	-2149
12:30	49.93	228300	5951	3276	62362	6795	2236	148636	3681	162662	232937	-2201
12:45	49.93	226971	5964	3326	62364	6029	2295	148010	3632	161281	231620	-2147
13:00	50.03	223989	5962	3457	62261	5938	2210	144977	3628	158271	228433	-2144
13:15	49.98	220529	5959	3575	62206	5600	2220	141522	3642	154748	224724	-2192
13:30	49.98	219120	5961	3531	61520	5377	2228	141136	3594	154069	223347	-2170
13:45	50.03	219262	5946	3637	61477	5232	2240	141581	3637	154148	223750	-2178
14:00	50.03	217951	5942	3682	60192	5433	2234	141159	3633	154077	222275	-2207
14:15	49.98	218885	5933	3790	59672	5367	2220	142661	3640	155423	223283	-2207
14:30	50.03	219198	5919	3869	58307	5765	2231	144780	3570	157022	224441	-2229
14:45	49.98	219097	5928	3881	56735	6437	2241	145283	3575	158481	224080	-2243
15:00	49.98	219382	5898	3847	54424	6571	2252	147895	3546	161111	224433	-2246
15:15	49.93	218882	5924	3846	51650	7138	2294	149254	3559	163386	223665	-2235
15:30	49.98	218748	5916	3826	48671	8394	2292	151264	3515	166251	223878	-2202
15:45	49.93	217780	5921	3830	45535	9227	2295	152322	3557	168415	222687	-2135
16:00	49.93	217076	5898	3874	41841	9864	2320	154736	3508	171361	222041	-2168
16:15	49.93	214348	5921	3869	37992	9681	2385	155927	3447	172487	219222	-2140
16:30	49.93	215235	5926	4015	33690	10396	2491	160289	3425	177530	220232	-2020
16:45	49.98	215338	5923	4083	28644	12501	2541	162513	3408	182611	219613	-1774
17:00	49.93	212565	5938	4030	23153	14667	2592	163177	3400	185382	216957	-1553
17:15	49.93	209146	5923	4107	18202	15722	2681	163162	3415	186837	213212	-1005
17:30	50.03	207663	5913	4072	12616	18756	2712	164703	3406	190975	212178	-1005
17:45	49.98	207093	5934	4078	7960	21840	2770	165449	3365	195055	211396	-985
18:00	50.08	205883	5916	4200	4397	22878	2747	166809	3395	197286	210342	-1018
18:15	49.93	203836	5937	4466	2174	22309	2832	167161	3381	197196	208260	-978
18:30	50.03	205988	5936	4783	1363	23389	2908	168721	3405	199842	210505	-955
18:45	49.98	207024	5937	5066	1127	23835	2740	169064	3420	200831	211189	-939
19:00	50.03	206196	5937	5544	1027	22865	2636	168857	3467	199625	210333	-914
19:15	50.03	204914	5936	5829	982	21374	2764	168805	3487	198103	209177	-944
19:30	50.03	202676	5951	6091	988	20146	2749	167579	3456	195597	206960	-935
19:45	50.03	200597	5936	6328	821	17753	2698	167716	3440	193448	204692	-934
20:00	50.03	196497	5936	6526	818	15352	2562	166218	3432	189153	200844	-937
20:15	50.03	192315	6148	6699	194	12920	2515	164702	3280	185422	196458	-1024
20:30	50.03	189978	6151	6865	190	11906	2487	163369	3227	182923	194195	-1041
20:45	49.98	187754	5960	6943	178	11105	2457	161967	3240	180633	191850	-1005
21:00	50.01	186062	5968	6997	161	10729	2403	160218	3281	178904	189757	-1185
21:15	49.96	184022	5970	7046	161	10641	2389	158315	3275	176815	187797	-1680
21:30	50.06	182322	5961	7282	149	10310	2389	157005	3274	174891	186370	-1677
21:45	49.96	180721	5982	7612	153	9160	2330	156421	3292	172956	184950	-1815
22:00	50.07	178438	5959	7854	147	8298	2320	154791	3284	170437	182653	-1814
22:15	49.96	179784	5959	8046	99	8757	2379	155464	3354	171639	184058	-1874
22:30	50.02	178677	5962	8174	98	8601	2339	15460				