



National Load Despatch Centre
राष्ट्रीय भार प्रेषण केंद्र
GRID CONTROLLER OF INDIA LIMITED
ग्रिड कंट्रोलर ऑफ इंडिया लिमिटेड

(Government of India Enterprise/ भारत सरकार का उद्यम)
B-9, QUTUB INSTITUTIONAL AREA, KATWARIA SARAI, NEW DELHI -110016
बी-9, कुतुब इन्स्टीट्यूशनल एरिया, कटवारिया सराये, न्यू दिल्ली-110016

Ref: GRID-INDIA/NLDC/SO/Daily PSP Report

दिनांक: 30.01.2026

To,

- कार्यकारी निदेशक, पू.क्षे.भा.प्रे.के., 14, गोल्फ क्लब रोड, कोलकाता - 700033
Executive Director, ERLDC, 14 Golf Club Road, Tollygunge, Kolkata, 700033
- कार्यकारी निदेशक, ऊ.क्षे.भा.प्रे.के., 18/ए, शाहीद जीत सिंह सनसनवाल मार्ग, नई दिल्ली - 110016
Executive Director, NRLDC, 18-A, Shaheed Jeet Singh Marg, Katwaria Sarai, New Delhi - 110016
- कार्यकारी निदेशक, प.क्षे.भा.प्रे.के., एफ3, एम आई डी सी क्षेत्र, अंधेरी, मुंबई - 400093
Executive Director, WRLDC, F-3, M.I.D.C. Area, Marol, Andheri (East), Mumbai-400093
- कार्यकारी निदेशक, ऊ.पू.क्षे.भा.प्रे.के., डोंगतेह, लोअर नोंग्रह, लापालंग, शिलोंग - 793006
Executive Director, NERLDC, Dongteih, Lower Nongrah, Lapalang, Shillong - 793006, Meghalaya
- कार्यकारी निदेशक, द.क्षे.भा.प्रे.के., 29, रेस कोर्स क्रॉस रोड, बंगलुरु - 560009
Executive Director, SRLDC, 29, Race Course Cross Road, Bangalore-560009

Sub: Daily PSP Report for the date 29.01.2026.

महोदय/Sir,

आईईजीसी-2023 की धारा स.-38(1) के प्रावधान के अनुसार, दिनांक 29-जनवरी-2026 की अखिल भारतीय प्रणाली की दैनिक ग्रिड निष्पादन रिपोर्ट रांभांप्रेके की वेबसाइट पर उपलब्ध है।

As per article 38(1) of the Indian Electricity Grid Code, the daily report pertaining power supply position of All India Power System for the date 29.01.2026, is available at the NLDC website.

धन्यवाद,
Thanks

Report for previous day

Date of Reporting: 30-Jan-2026

A. Power Supply Position at All India and Regional level

	NR	WR	SR	ER	NER	TOTAL
Demand Met during Evening Peak hrs(MW) (at 19:00 hrs; from RLDCs)	61221	69466	52045	24334	2883	209949
Peak Shortage (MW)	0	0	0	0	0	0
Energy Met (MU)	1257	1548	1280	500	52	4637
Hydro Gen (MU)	109	37	82	24	14	267
Wind Gen (MU)	30	155	87	-	-	273
Solar Gen (MU)*	199.86	165.75	154.15	2.68	0.92	523
Energy Shortage (MU)	0.00	0.00	0.00	0.00	0.00	0.00
Maximum Demand Met During the Day (MW) (From NLDC SCADA)	66394	79555	63512	25050	2986	235696
Time Of Maximum Demand Met	09:54	09:56	09:44	18:35	17:38	09:52

B. Frequency Profile (%)

Region	FVI	< 49.7	49.7 - 49.8	49.8 - 49.9	< 49.9	49.9 - 50.05	> 50.05
All India	0.047	0.00	1.02	4.93	5.95	72.73	21.32

C. Power Supply Position in States

Region	States	Max.Demand Met during the day (MW)	Shortage during maximum Demand (MW)	Energy Met (MU)	Drawal Schedule (MU)	OD(+)/UD(-) (MU)	Max OD (MW)	Energy Shortage (MU)
NR	Punjab	8312	0	160.7	69.6	-1.9	322	0.00
	Haryana	8537	0	165.0	120.5	-2.3	185	0.00
	Rajasthan	18189	0	327.0	115.9	-9.3	168	0.00
	Delhi	5395	0	92.6	84.5	-0.5	569	0.00
	UP	19299	0	353.5	88.4	2.2	948	0.00
	Uttarakhand	2627	0	46.5	38.1	0.2	134	0.00
	HP	2156	0	38.9	31.8	-0.8	118	0.00
	J&K(UT) & Ladakh(UT)	2992	0	64.2	60.6	-1.7	158	0.00
	Chandigarh	299	0	4.6	4.7	-0.1	23	0.00
WR	Railways_NR ISTS	196	0	4.0	3.7	0.3	43	0.00
	Chhattisgarh	5813	0	115.9	68.5	-1.2	335	0.00
	Gujarat	23845	0	435.9	153.5	-6.1	788	0.00
	MP	16977	0	303.7	185.3	0.0	569	0.00
	Maharashtra	29616	0	608.5	183.7	-12.6	988	0.00
	Goa	738	0	15.1	12.6	2.2	33	0.00
	DNHDDPDCL	1389	0	31.4	31.8	-0.4	71	0.00
	AMNSIL	943	0	21.3	13.7	1.0	333	0.00
	BALCO	602	0	14.3	14.5	-0.2	42	0.00
	RIL JAMNAGAR	107	0	1.7	1.8	-0.1	0	0.00
SR	Andhra Pradesh	12622	0	235.2	68.9	0.5	972	0.00
	Telangana	15817	0	284.1	148.0	-0.3	635	0.00
	Karnataka	17404	0	321.0	116.1	-1.0	685	0.00
	Kerala	4782	0	91.3	72.5	1.2	378	0.00
	Tamil Nadu	17243	0	339.4	190.3	-0.4	774	0.00
	Puducherry	407	0	8.7	8.3	-0.2	19	0.00
ER	Bihar	5837	0	106.9	84.0	1.6	231	0.00
	DVC	3138	0	70.2	-15.0	-0.2	411	0.00
	Jharkhand	2095	0	39.1	28.1	-0.4	186	0.00
	Odisha	5568	0	109.6	17.7	-1.4	439	0.00
	West Bengal	8259	0	172.0	64.8	-2.8	261	0.00
	Sikkim	125	0	2.1	2.0	0.1	31	0.00
	Railways_ER ISTS	25	0	0.3	0.2	0.1	8	0.00
NER	Arunachal Pradesh	183	0	3.2	3.2	0.0	35	0.00
	Assam	1656	0	29.7	25.4	0.3	84	0.00
	Manipur	266	0	3.9	4.0	-0.1	22	0.00
	Meghalaya	389	0	6.4	5.9	-0.1	34	0.00
	Mizoram	155	0	2.3	2.1	-0.1	22	0.00
	Nagaland	167	0	2.7	2.6	0.0	17	0.00
	Tripura	234	0	4.1	6.3	0.3	57	0.00

D. Transnational Exchanges (MU) - Import(+ve)/Export(-ve)

	Bhutan	Nepal	Bangladesh	Godda -> Bangladesh
Actual (MU)	-18.9	-6.8	-24.8	-17.7
Day Peak (MW)	-987.7	-642.6	-1051.9	-770.0

E. Import/Export by Regions (in MU) - Import(+ve)/Export(-ve); OD(+)/UD(-)

	NR	WR	SR	ER	NER	TOTAL
Schedule(MU)	217.8	-275.6	173.4	-128.5	12.9	0.0
Actual(MU)	195.8	-264.8	163.2	-120.9	10.8	-15.9
O/D/U/D(MU)	-22.0	10.8	-10.2	7.6	-2.1	-15.9

F. Generation Outage(MW)

	NR	WR	SR	ER	NER	TOTAL	% Share
Central Sector	6141	10985	3358	2994	469	23946	45
State Sector	10889	10388	4300	3683	205	29464	55
Total	17030	21373	7658	6676	674	53411	100

G. Sourcewise generation (Gross) (MU)

	NR	WR	SR	ER	NER	All India	% Share
Coal	699	1476	723	692	12	3602	71
Lignite	28	21	54	0	0	103	2
Hydro	109	37	82	24	14	267	5
Nuclear	53	62	63	0	0	178	4
Gas, Naptha & Diesel	10	18	9	0	21	58	1
RES (Wind, Solar, Biomass & Others)	262	324	269	6	1	863	17
Total	1160	1939	1202	722	48	5071	100

Share of RES in total generation (%)	22.62	16.73	22.41	0.81	1.97	17.02
Share of Non-fossil fuel (Hydro,Nuclear and RES) in total generation(%)	36.56	21.81	34.55	4.20	32.04	25.79

H. All India Demand Diversity Factor

Based on Regional Max Demands	1.007
Based on State Max Demands	1.036

I. All India Peak Demand and shortage at Solar and Non-Solar Hour

	Max Demand Met(MW)	Time	Shortage(MW)
Solar hr	235696	9:52	0
Non-Solar hr	212234	18:45	0

Diversity factor = Sum of regional or state maximum demands / All India maximum demand

**Note: All generation MU figures are gross

***Godda (Jharkhand) -> Bangladesh power exchange is through the radial connection (isolated from Indian Grid)

Solar Hours -> 06:00 to 18:00hrs and rest are Non-Solar Hours

*Source: RLDCs for solar connected to ISTS; SLDCs for embedded solar. Limited visibility of embedded solar data.

Executive Director-NLDC

INTER-REGIONAL EXCHANGES

Import=(+ve) /Export =(-ve) for NET (MU)

Date of Reporting: 30-Jan-2026

Sl No	Voltage Level	Line Details	No. of Circuit	Max Import (MW)	Max Export (MW)	Import (MU)	Export (MU)	NET (MU)
Import/Export of ER (With NR)								
1	HVDC	ALIPURDUAR-AGRA	2	0	0	0.0	0.0	0.0
2	HVDC	PUSAULI B/B	-	0	47	0.0	2.4	-2.4
3	765 kV	GAYA-VARANASI	2	569	1453	0.0	14.6	-14.6
4	765 kV	SASARAM-FATEHPUR	1	194	647	0.0	6.5	-6.5
5	765 kV	GAYA-BALIA	1	0	940	0.0	11.4	-11.4
6	400 kV	PUSAULI-VARANASI	1	12	120	0.0	1.2	-1.2
7	400 kV	PUSAULI -ALLAHABAD	1	50	111	0.0	1.0	-1.0
8	400 kV	MUZAFFARPUR-GORAKHPUR	2	535	683	0.0	2.5	-2.5
9	400 kV	PATNA-BALIA	2	71	1061	0.0	11.8	-11.8
10	400 kV	NAUBATPUR-BALIA	2	170	233	0.0	3.9	-3.9
11	400 kV	BIHARSHARIFF-BALIA	2	478	310	2.6	0.0	2.5
12	400 kV	MOTIHARI-GORAKHPUR	2	90	592	0.0	6.5	-6.5
13	400 kV	BIHARSARIFF-SAHUPURI	2	229	534	0.0	4.0	-4.0
14	220 kV	SAHUPURI-KARAMNASA	1	14	20	0.0	2.0	-2.0
15	132 kV	NAGAR UNTARI-RIHAND	1	0	0	0.2	0.0	0.2
16	132 kV	GARWAH-RIHAND	1	30	0	0.7	0.0	0.7
17	132 kV	KARMANASA-CHANDAULI	1	0	0	0.0	0.0	0.0
ER-NR						3.5	67.6	-64.1
Import/Export of ER (With WR)								
1	765 kV	JHARSUGUDA-DHARAMJAIGARH	4	0	1173	0.0	15.6	-15.6
2	765 kV	NEW RANCHI-DHARAMJAIGARH	2	1260	356	14.7	0.0	14.7
3	765 kV	JHARSUGUDA-DURG	2	0	1401	0.0	23.7	-23.7
4	400 kV	JHARSUGUDA-RAIGARH	4	146	385	0.0	2.9	-2.9
5	400 kV	RANCHI-SIPAT	2	215	279	0.2	0.0	0.2
6	400 kV	JEYPORE-JAGDALPUR	2	280	131	2.1	0.0	2.1
7	220 kV	BUDHIPADAR-RAIGARH	1	0	119	0.0	1.3	-1.3
8	220 kV	BUDHIPADAR-KORBA	2	13	206	0.0	1.8	-1.8
ER-WR						17.0	45.3	-28.3
Import/Export of ER (With SR)								
1	HVDC	JEYPORE-GAZUWAKA B/B	2	0	524	0.0	12.4	-12.4
2	HVDC	TALCHER-KOLAR BIPOLE	2	0	1446	0.0	39.7	-39.7
3	765 kV	ANGUL-SRIKAKULAM	2	0	1845	0.0	27.7	-27.7
4	400 kV	TALCHER-I/C	2	256	0	4.5	0.0	4.5
5	220 kV	BALIMELA-UPPER-SILERRU	1	2	0	0.0	0.0	0.0
ER-SR						0.0	79.9	-79.9
Import/Export of ER (With NER)								
1	400 kV	BINAGURI-BONGAIGAON	2	261	187	0.8	1.3	-0.5
2	400 kV	ALIPURDUAR-BONGAIGAON	2	478	106	2.9	0.0	2.9
3	220 kV	ALIPURDUAR-SALAKATI	2	60	32	0.2	0.0	0.2
ER-NER						3.9	1.3	2.6
Import/Export of NER (With NR)								
1	HVDC	BISWANATH CHARIALI-AGRA	2	759	0	16.1	0.0	16.1
NER-NR						16.1	0.0	16.1
Import/Export of WR (With NR)								
1	HVDC	CHAMPA-KURUKSHETRA	2	5	3509	0.0	18.3	-18.3
2	HVDC	VINDHYACHAL B/B	-	0	506	0.0	8.4	-8.4
3	HVDC	MUNDRA-MOHINDERGARH	2	0	2378	0.0	37.1	-37.1
4	765 kV	GWALIOR-AGRA	2	151	2688	0.1	27.1	-27.1
5	765 kV	GWALIOR-PHAGI	2	1003	2163	3.2	24.6	-21.4
6	765 kV	JABALPUR-ORAI	2	182	1353	0.0	28.7	-28.7
7	765 kV	GWALIOR-ORAI	1	1015	0	13.5	0.0	13.5
8	765 kV	SATNA-ORAI	1	0	1146	0.0	17.5	-17.5
9	765 kV	BANASKANTHA-CHITORGARH	2	1648	700	7.7	1.6	6.1
10	765 kV	VINDHYACHAL-VARANASI	2	0	2521	0.0	33.8	-33.8
11	400 kV	ZERDA-KANKROLI	1	277	53	2.3	0.0	2.2
12	400 kV	ZERDA -BHINMAL	1	192	37	1.6	0.0	1.5
13	400 kV	VINDHYACHAL -RIHAND	1	483	0	10.1	0.0	10.1
14	400 kV	RAPP-SHUJALPUR	2	883	363	6.3	1.3	5.0
15	400 kV	NEEMUCH-Chittorgarh	2	760	551	5.0	2.7	2.3
16	220 kV	BHANPURA-RANPUR	1	0	117	0.0	2.1	-2.1
17	220 kV	BHANPURA-MORAK	1	0	30	0.0	1.6	-1.6
18	220 kV	MEHGAON-AURAIYA	1	77	31	0.5	0.1	0.4
19	220 kV	MALANPUR-AURAIYA	1	53	41	0.3	0.2	0.1
20	132 kV	RAJGHAT-LALITPUR	2	0	0	0.0	0.0	0.0
WR-NR						50.3	205.0	-154.7
Import/Export of WR (With SR)								
1	HVDC	BHADRAWATI B/B	-	0	986	0.0	23.3	-23.3
2	HVDC	RAIGARH-PUGALUR	2	0	5018	0.0	85.2	-85.2
3	765 kV	SOLAPUR-RAICHUR	2	1826	1174	10.6	5.0	5.6
4	765 kV	WARDHA-NIZAMABAD	2	597	3230	0.4	32.3	-31.9
5	765 kV	WARORA-WARANGAL(NEW)	2	167	3204	0.0	36.1	-36.0
6	400 kV	KOLHAPUR-KUDGI	2	1911	0	30.4	0.0	30.4
7	220 kV	KOLHAPUR-CHIKODI	2	0	0	0.0	0.0	0.0
8	220 kV	PONDA-AMBEWADI	1	0	0	0.0	0.0	0.0
9	220 kV	XELDEM-AMBEWADI	1	0	127	2.3	0.0	2.3
WR-SR						43.8	181.8	-138.1

INTERNATIONAL EXCHANGES					Import(+ve)/Export(-ve)		
State	Region	Line Name	Max (MW)	Min (MW)	Avg (MW)	Energy Exchange (MU)	
BHUTAN	ER	400kV MANGDECHHU-ALIPURDUAR 1,2&3 i.e. ALIPURDUAR RECEIPT (from MANGDECHU HEP 4*180MW)	-280	59	-248	-5.96	
	ER	400kV TALA-BINAGURI 1,2,4 (& 400kV MALBASE - BINAGURI) i.e. BINAGURI RECEIPT (from TALA HEP 6*170MW)	-293	166	-177	-4.24	
	ER	220kV CHUKHA-BIRPARA 1&2 (& 220kV MALBASE - BIRPARA) i.e. BIRPARA RECEIPT (from CHUKHA HEP 4*84MW)	-309	-175	-271	-6.51	
	NER	132kV GELEPHU-SALAKATI	-79	-63	-63	-1.52	
	NER	132kV MOTANGA-RANGIA	-53	-12	-29	-0.69	
NEPAL	NR	NEPAL IMPORT (FROM UP)	0	0	0	-0.72	
	NR	132kV MAHENDRANAGAR-TANAKPUR(NHPC)	0	0	0	0.00	
	ER	NEPAL IMPORT (FROM BIHAR)	-150	-85	-93	-2.23	
	ER	400kV DHALKEBAR-MUZAFFARPUR 1&2	-375	-4	-160	-3.85	
BANGLADESH	ER	BHERAMARA B/B HVDC (B'DESH)	-916	-911	-913	-21.91	
	ER (Isolated from Indian Grid)	400kV GODDA_TPS-RAHANPUR (B'DESH) D/C	-770	-609	-739	-17.73	
	NER	132kV COMILLA-SURAJMANI NAGAR 1&2	-136	0	-119	-2.85	

Export From India (in MU)

Country	GNA (ISGS/PPA)	T-GNA							TOTAL
		BILATERAL TOTAL	COLLECTIVE						
			IDAM			RTM			
			IEX	PXIL	HPX	IEX	PXIL	HPX	
Bhutan	0.00	0.00	19.86	0.00	0.00	0.00	0.00	0.00	19.86
Nepal	2.76	1.75	0.00	0.00	0.00	3.23	0.00	0.00	7.74
Bangladesh	22.95	0.00	0.00	0.00	0.00	0.00	0.00	0.00	22.95
Myanmar	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total Export	25.71	1.75	19.86	0.00	0.00	3.23	0.00	0.00	50.55

Import by India(in MU)

Country	GNA (ISGA/PPA)	T-GNA							TOTAL
		BILATERAL TOTAL	COLLECTIVE						
			IDAM			RTM			
			IEX	PXIL	HPX	IEX	PXIL	HPX	
Bhutan	0.43	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.43
Nepal	0.00	0.00	0.00	0.00	0.00	0.06	0.00	0.00	0.06
Bangladesh	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Myanmar	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total Import	0.43	0.00	0.00	0.00	0.00	0.06	0.00	0.00	0.49

Net from India(in MU)

-ve : Export / +ve : Import

Country	GNA (ISGS/PPA)	T-GNA							TOTAL
		BILATERAL TOTAL	COLLECTIVE						
			IDAM			RTM			
			IEX	PXIL	HPX	IEX	PXIL	HPX	
Bhutan	0.43	0.00	-19.86	0.00	0.00	0.00	0.00	0.00	-19.43
Nepal	-2.76	-1.75	0.00	0.00	0.00	-3.17	0.00	0.00	-7.68
Bangladesh	-22.95	0.00	0.00	0.00	0.00	0.00	0.00	0.00	-22.95
Myanmar	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total Net	-25.28	-1.75	-19.86	0.00	0.00	-3.17	0.00	0.00	-50.06

Date of Reporting: 30-Jan-2026												
15 Min (INSTANTANEOUS) ALL INDIA GRID FREQUENCY, GENERATION & DEMAND MET (SCADA DATA)												
TIME	FREQUENCY (Hz)	DEMAND MET (MW)	NUCLEAR (MW)	WIND (MW)	SOLAR (MW)	HYDRO** (MW)	GAS (MW)	THERMAL (MW)	OTHERS* (MW)	NET DEMAND MET (MW)	TOTAL GENERATIO N (MW)	NET TRANSNATIONAL EXCHANGE (MW)
		(A)	(B)	(C)	(D)	(E)	(F)	(G)	(H)	(I=A-(C+D))	(J=B+C+D+E +F+G+H)	(+ve) Import, (-ve) (K)
0:00	50.05	160536	6891	14062	0	6677	2376	132129	3702	146474	165837	-1981
0:15	50.01	160126	6914	14099	0	7174	2380	131686	3703	146027	165956	-2121
0:30	50.04	160274	6911	14142	0	7599	2389	131203	3711	146132	165955	-2106
0:45	49.96	159303	6911	14010	0	7310	2395	130606	3747	145293	164979	-2113
1:00	50.00	158231	6912	13921	0	6804	2404	129863	3805	144310	163709	-2067
1:15	49.99	156793	6903	13579	0	6629	2370	129138	3721	143214	162340	-2089
1:30	49.96	156033	6928	13358	0	6311	2357	128880	3721	142675	161555	-2090
1:45	49.98	155496	6937	13208	0	6420	2367	128352	3790	142288	161074	-2066
2:00	50.05	154528	6924	13242	0	6491	2403	127269	3743	141286	160072	-2059
2:15	49.99	154327	6937	13125	0	5850	2385	127930	3688	141202	159915	-2034
2:30	49.99	154141	6970	13280	0	5657	2397	127581	3787	140861	159672	-2025
2:45	50.00	154217	6976	13350	0	5700	2410	127595	3737	140867	159768	-2036
3:00	49.99	153871	6967	13408	0	5783	2381	127130	3754	140463	159423	-2030
3:15	49.97	154232	6997	13448	0	5840	2372	127321	3801	140784	159779	-2042
3:30	50.00	154600	6991	13333	0	5895	2373	127840	3808	141267	160240	-2015
3:45	50.00	155266	6974	13174	0	5782	2373	128678	3797	142092	160778	-2002
4:00	50.05	155405	6966	13201	0	5874	2380	128879	3731	142204	161031	-2029
4:15	50.00	157713	6983	13144	0	6071	2368	130895	3711	144569	163172	-2033
4:30	50.12	159254	6966	13201	0	6442	2366	131822	3738	146053	164535	-2017
4:45	50.02	159825	6990	13103	0	6380	2274	132729	3740	146722	165216	-2000
5:00	50.07	161883	6969	13042	524	6583	2224	134923	3730	148317	167995	-2082
5:15	50.02	166315	6934	12922	528	6976	2223	139142	3636	152865	172361	-2091
5:30	50.01	170379	6931	12909	529	7604	2231	142552	3670	156941	176426	-2116
5:45	50.03	174932	6926	12838	541	7999	2220	146932	3673	161553	181129	-2166
6:00	50.13	179973	6914	12712	562	8976	2225	151169	3675	166699	186233	-2123
6:15	50.02	185698	6880	12582	585	9917	2240	156175	3614	172531	191993	-1928
6:30	50.08	193465	6790	12481	577	11792	2227	162165	3651	180407	199683	-1915
6:45	50.07	199784	6748	12423	641	13791	2228	166405	3623	186720	205859	-1726
7:00	50.09	203653	6697	12445	837	15270	2214	167746	3619	190371	208828	-1200
7:15	49.99	209632	6590	12641	1517	18460	2236	170029	3653	195474	215126	-1226
7:30	50.04	214237	6573	12470	2821	20825	2232	170823	3697	198946	219441	-1216
7:45	50.05	217939	6531	12611	5350	21358	2226	171139	3764	199978	222979	-1146
8:00	50.13	219528	6500	12624	9513	21156	2235	168516	3681	197391	224225	-1232
8:15	50.11	223428	6515	12638	14995	20701	2224	167007	3736	195795	227816	-1223
8:30	50.12	225016	6494	12285	21159	19454	2225	164253	3746	191572	229616	-1235
8:45	50.24	227297	6480	11916	28453	17910	2232	160897	3703	186928	231591	-1293
9:00	50.23	228534	6509	11436	35938	14867	2259	158513	3702	181160	233224	-1928
9:15	49.89	232130	6512	10898	41738	14433	2240	158121	3633	179494	237575	-2180
9:30	49.96	234257	6490	10069	47068	13412	2260	156641	3681	177120	239621	-2241
9:45	49.87	235188	6500	9099	51908	12937	2250	154126	3699	174181	240519	-2289
10:00	50.03	234544	6540	8665	57127	11006	2233	150445	3633	168752	239649	-2381
10:15	50.00	234454	6573	8504	61334	9677	2225	147738	3669	164616	239720	-2310
10:30	50.03	233872	6543	8466	64955	8446	2242	144712	3650	160451	239014	-2377
10:45	50.07	231156	6576	8654	67028	7379	2237	140786	3626	155474	236286	-2405
11:00	50.04	228983	6570	8826	68682	6190	2247	137742	3657	151475	233914	-2422
11:15	50.09	227049	6571	9119	70462	6152	2295	133405	3670	147468	231674	-2454
11:30	50.02	225145	6559	9301	71034	6020	2307	131260	3599	144810	230080	-2526
11:45	49.99	223072	6606	9247	72642	6095	2307	127679	3601	141183	228177	-2477
12:00	50.04	220652	6626	8835	73622	6054	2314	124448	3633	138195	225532	-2511
12:15	50.07	217759	6616	8668	73842	5803	2305	122026	3656	135249	222916	-2487
12:30	50.08	216128	6611	8349	73868	5727	2337	120604	3697	133911	221193	-2476
12:45	50.04	214439	6604	8244	72181	5876	2332	120575	3635	134014	219447	-2482
13:00	50.08	210482	6610	7993	71117	5465	2333	118341	3611	131372	215470	-2475
13:15	50.05	205915	6605	7627	68870	5527	2316	116256	3706	129418	210907	-2511
13:30	50.05	205273	6615	7428	69716	5554	2321	114521	3628	128129	209783	-2500
13:45	50.04	204389	6626	7092	69832	5834	2336	113695	3661	127465	209076	-2505
14:00	50.05	203892	6610	6686	69331	6111	2334	114309	3653	127875	209034	-2519
14:15	49.96	204674	6594	6431	68096	6392	2339	116252	3680	130147	209784	-2511
14:30	49.80	205177	6581	6365	65212	6745	2360	119509	3610	133600	210382	-2521
14:45	49.85	207211	6566	6201	63995	7108	2345	122174	3682	137015	212071	-2489
15:00	49.92	207989	6564	6166	61237	7222	2077	126080	3606	140586	212952	-2524
15:15	50.03	207217	6537	5921	58901	6809	2106	128481	3683	142395	212438	-2536
15:30	49.94	207792	6555	5657	55099	6868	2103	132900	3608	147036	212790	-2524
15:45	49.96	208367	6565	5678	51162	7315	2088	136660	3573	151527	213041	-2491
16:00	50.09	208186	6568	5708	47158	7462	2090	140654	3609	155320	213249	-2528
16:15	49.87	205215	6523	5822	41058	7084	2099	144238	3542	158335	210366	-2429
16:30	49.94	206624	6477	5785	35224	8827	2093	149388	3583	165615	211377	-2433
16:45	49.82	206149	6408	5950	28297	10006	2092	154448	3613	171902	210814	-2441
17:00	50.00	208177	6404	6109	23578	12008	2075	158867	3608	178490	212649	-2407
17:15	49.99	205641	6328	6325	16972	14008	2076	161339	3589	182344	210637	-2370
17:30	50.05	207161	6319	6392	12029	16794	2117	164948	3701	188740	212300	-2111
17:45	50.02	208769	6541	6658	7659	18851	2172	168552	3644	194452	214077	-1699
18:00	50.10	209717	6536	6856	4402	20123	2237	170993	3610	198459	214757	-1263
18:15	50.04	208957	6545	7230	2334	20293	2353	171887	3617	199393	214259	-1247
18:30	50.04	210724	6560	7832	1274	20966	2358	172937	3654	201618	215581	-1222
18:45	50.05	212234	6556	8479	1125	21458	2359	173227	3705	202630	216909	-1239
19:00	50.09	210957	6568	9190	989	20499	2369	171982	3697	200778	215294	-1233
19:15	50.04	208427	6557	9993	979	18286	2336	171032	3717	197455	212900	-1240
19:30	50.07	206295	6564	11005	0	17348	2229	169273	3735	195290	210154	-1210
19:45	50.05	203309	6571	11702	0	16397	2164	166918	3783	191607	207535	-1218
20:00	50.08	200366	6563	12257	0	15121	2097	165178	3791	188109	205007	-1770
20:15	50.03	198013	6574	12940	0	14992	2060	163120	3836	185073	203522	-2188
20:30	49.96	195689	6578	13465	0	13663	2081	161316	3792	182224	200895	-2189
20:45	50.01	192875	6574	13966	0	12779	2075	158699	3921	178909	198014	-2194
21:00	50.04	189431	6576	14409	0	11661	2067	155972	3851	175022	194536	-2231
21:15	50.00	186857	6579	15018	0	10992	2083	153592	3878	171839	192142	-2180
21:30	49.96	183637	6585	15266	0	10065	2085	151377	3882	168371	189260	-2214
21:45	50.01	180414	6562	15584	0	9079	2077	148667	3901	164830	185870	-2179
22:00	50.07	176718	6568	15628	0	8406	2088	145723	3832	161090	182245	-2135
22:15	49.95	176112	6570	15696	0	8287	2089	145176	3865	160416	181683	-2125
22:30	49.95	173981	6588	15719	0							