



National Load Despatch Centre
राष्ट्रीय भार प्रेषण केंद्र
GRID CONTROLLER OF INDIA LIMITED
ग्रिड कंट्रोलर ऑफ इंडिया लिमिटेड

(Government of India Enterprise/ भारत सरकार का उद्यम)
B-9, QUTUB INSTITUTIONAL AREA, KATWARIA SARAI, NEW DELHI -110016
बी-9, कुतुब इन्स्टीट्यूशनल एरिया, कटवारिया सराये, न्यू दिल्ली-110016

Ref: GRID-INDIA/NLDC/SO/Daily PSP Report

दिनांक: 23.02.2025

To,

- कार्यकारी निदेशक, पू.क्षे.भा.प्रे.के., 14, गोल्फ क्लब रोड, कोलकाता - 700033
Executive Director, ERLDC, 14 Golf Club Road, Tollygunge, Kolkata, 700033
- कार्यकारी निदेशक, ऊ.क्षे.भा.प्रे.के., 18/ए, शाहीद जीत सिंह सनसनवाल मार्ग, नई दिल्ली - 110016
Executive Director, NRLDC, 18-A, Shaheed Jeet Singh Marg, Katwaria Sarai, New Delhi - 110016
- कार्यकारी निदेशक, प.क्षे.भा.प्रे.के., एफ3, एम आई डी सी क्षेत्र, अंधेरी, मुंबई -400093
Executive Director, WRLDC, F-3, M.I.D.C. Area, Marol, Andheri (East), Mumbai-400093
- कार्यकारी निदेशक, ऊ.पू.क्षे.भा.प्रे.के., डोंगतेह, लोअर नोंग्रह, लापालंग, शिलोंग - 793006
Executive Director, NERLDC, Dongteih, Lower Nongrah, Lapalang, Shillong - 793006, Meghalaya
- कार्यकारी निदेशक, द.क्षे.भा.प्रे.के., 29, रेस कोर्स क्रॉस रोड, बंगलुरु -560009
Executive Director, SRLDC, 29, Race Course Cross Road, Bangalore-560009

Sub: Daily PSP Report for the date 22.02.2025.

महोदय/Sir,

आईईजीसी-2023 की धारा स.-38(1) के प्रावधान के अनुसार, दिनांक 22-फ़रवरी-2025 की अखिल भारतीय प्रणाली की दैनिक ग्रिड निष्पादन रिपोर्ट रांभांप्रेके की वेबसाइट पर उपलब्ध है।

As per article 38(1) of the Indian Electricity Grid Code, the daily report pertaining power supply position of All India Power System for the date 22.02.2025, is available at the NLDC website.

धन्यवाद,
Thanks

Report for previous day

Date of Reporting: 23-Feb-2025

A. Power Supply Position at All India and Regional level

	NR	WR	SR	ER	NER	TOTAL
Demand Met during Evening Peak hrs(MW) (at 19:00 hrs; from RLDCs)	55560	69578	50894	22355	2735	201122
Peak Shortage (MW)	194	533	0	0	49	776
Energy Met (MU)	1202	1659	1373	478	49	4761
Hydro Gen (MU)	96	49	96	26	9	275
Wind Gen (MU)	22	42	31	-	-	95
Solar Gen (MU)*	194.76	131.67	142.44	3.58	0.99	473
Energy Shortage (MU)	0.26	2.16	0.00	0.00	0.27	2.69
Maximum Demand Met During the Day (MW) (From NLDC SCADA)	61105	78398	67801	23052	2776	229826
Time Of Maximum Demand Met	10:10	10:35	09:43	18:33	17:59	09:45

B. Frequency Profile (%)

Region	FVI	< 49.7	49.7 - 49.8	49.8 - 49.9	< 49.9	49.9 - 50.05	> 50.05
All India	0.039	0.00	0.62	7.92	8.54	77.36	14.10

C. Power Supply Position in States

Region	States	Max.Demand Met during the day (MW)	Shortage during maximum Demand (MW)	Energy Met (MU)	Drawal Schedule (MU)	OD(+)/UD(-) (MU)	Max OD (MW)	Energy Shortage (MU)
NR	Punjab	7273	0	138.9	60.2	-1.9	657	0.00
	Haryana	7600	0	152.5	89.6	-1.7	309	0.00
	Rajasthan	17797	0	343.2	112.0	-0.2	724	0.00
	Delhi	3933	0	70.1	58.9	-0.5	275	0.00
	UP	18641	0	345.7	77.7	-3.0	239	0.00
	Uttarakhand	2255	0	43.3	33.6	-0.4	99	0.00
	HP	2144	0	39.2	32.8	-0.8	253	0.00
	J&K(UT) & Ladakh(UT)	2853	0	60.9	57.8	-1.5	664	0.26
	Chandigarh	222	0	3.7	3.7	0.0	25	0.00
	Railways_NR ISTS	206	0	4.2	3.8	0.4	46	0.00
WR	Chhattisgarh	5817	147	133.0	89.4	0.9	541	2.16
	Gujarat	23075	0	453.9	220.3	-1.3	710	0.00
	MP	17180	0	342.5	220.2	-5.5	272	0.00
	Maharashtra	29772	0	648.0	215.7	0.3	818	0.00
	Goa	763	0	16.1	14.4	1.3	48	0.00
	DNHDDPDCL	1352	0	31.0	31.0	0.0	33	0.00
	AMNSIL	759	0	17.4	10.5	-0.2	178	0.00
	BALCO	535	0	12.8	12.7	0.1	11	0.00
	RIL JAMNAGAR	197	0	4.7	4.7	0.0	0	0.00
SR	Andhra Pradesh	12353	0	242.4	61.5	-0.8	510	0.00
	Telangana	16287	0	313.6	189.1	-1.2	435	0.00
	Karnataka	18072	0	335.8	135.6	-0.5	969	0.00
	Kerala	4653	0	94.7	72.9	0.7	421	0.00
	Tamil Nadu	18490	0	377.8	227.8	0.0	906	0.00
	Puducherry	437	0	9.2	9.3	-0.1	48	0.00
ER	Bihar	5123	0	99.8	91.6	-3.7	218	0.00
	DVC	3310	0	68.0	-42.6	-2.0	398	0.00
	Jharkhand	1998	0	37.2	26.5	-1.2	249	0.00
	Odisha	5210	0	106.2	28.5	-1.6	436	0.00
	West Bengal	7728	0	164.4	31.2	-1.6	410	0.00
	Sikkim	108	0	1.8	2.0	-0.2	33	0.00
	Railways_ER ISTS	20	0	0.2	0.2	0.0	4	0.00
NER	Arunachal Pradesh	170	0	3.0	3.3	-0.4	20	0.00
	Assam	1589	0	28.3	21.6	0.3	125	0.00
	Manipur	200	39	3.0	3.0	0.0	53	0.27
	Meghalaya	325	0	5.7	4.6	-0.1	82	0.00
	Mizoram	145	0	2.1	1.9	-0.1	17	0.00
	Nagaland	159	0	2.4	2.4	-0.1	16	0.00
	Tripura	246	0	4.1	3.7	0.0	34	0.00

D. Transnational Exchanges (MU) - Import(+ve)/Export(-ve)

	Bhutan	Nepal	Bangladesh	Godda -> Bangladesh
Actual (MU)	-7.9	-10.8	-22.7	-16.8
Day Peak (MW)	-476.0	-641.5	-1023.0	-768.4

E. Import/Export by Regions (in MU) - Import(+ve)/Export(-ve); OD(+)/UD(-)

	NR	WR	SR	ER	NER	TOTAL
Schedule(MU)	125.7	-213.8	247.2	-164.4	5.4	0.0
Actual(MU)	108.9	-203.0	258.2	-177.0	4.9	-8.0
O/D/U/D(MU)	-16.8	10.9	11.0	-12.7	-0.5	-8.0

F. Generation Outage(MW)

	NR	WR	SR	ER	NER	TOTAL	% Share
Central Sector	5426	7324	3958	3694	783	21185	45
State Sector	7328	10642	5192	2619	181	25962	55
Total	12754	17966	9150	6313	964	47147	100

G. Sourcewise generation (Gross) (MU)

	NR	WR	SR	ER	NER	All India	% Share
Coal	787	1699	753	721	15	3976	77
Lignite	26	16	59	0	0	101	2
Hydro	96	49	96	26	9	275	5
Nuclear	20	49	71	0	0	140	3
Gas, Naptha & Diesel	12	14	4	0	24	54	1
RES (Wind, Solar, Biomass & Others)	242	178	209	6	1	637	12
Total	1183	2006	1191	754	49	5183	100

Share of RES in total generation (%)	20.49	8.88	17.55	0.83	2.03	12.29
Share of Non-fossil fuel (Hydro,Nuclear and RES) in total generation(%)	30.27	13.79	31.54	4.27	19.40	20.30

H. All India Demand Diversity Factor

Based on Regional Max Demands	1.014
Based on State Max Demands	1.039

I. All India Peak Demand and shortage at Solar and Non-Solar Hour

	Max Demand Met(MW)	Time	Shortage(MW)
Solar hr	229826	9:45	15
Non-Solar hr	205802	18:55	517

Diversity factor = Sum of regional or state maximum demands / All India maximum demand

**Note: All generation MU figures are gross

***Godda (Jharkhand) -> Bangladesh power exchange is through the radial connection (isolated from Indian Grid)

Solar Hours -> 06:00 to 18:00hrs and rest are Non-Solar Hours

*Source: RLDCs for solar connected to ISTS; SLDCs for embedded solar. Limited visibility of embedded solar data.

Executive Director-NLDC

INTER-REGIONAL EXCHANGES							Import=(+ve) /Export =(-ve) for NET (MU)	
							Date of Reporting: 23-Feb-2025	
Sl No	Voltage Level	Line Details	No. of Circuit	Max Import (MW)	Max Export (MW)	Import (MU)	Export (MU)	NET (MU)
Import/Export of ER (With NR)								
1	HVDC	ALIPURDUAR-AGRA	2	0	0	0.0	0.0	0.0
2	HVDC	PUSAULI B/B	-	0	47	0.0	2.4	-2.4
3	765 kV	GAYA-VARANASI	2	0	1030	0.0	15.1	-15.1
4	765 kV	SASARAM-FATEHPUR	1	97	532	0.0	8.2	-8.2
5	765 kV	GAYA-BALIA	1	0	470	0.0	9.8	-9.8
6	400 kV	PUSAULI-VARANASI	1	0	247	0.0	2.1	-2.1
7	400 kV	PUSAULI -ALLAHABAD	1	47	53	0.0	0.3	-0.3
8	400 kV	MUZAFFARPUR-GORAKHPUR	2	444	552	0.0	2.7	-2.7
9	400 kV	PATNA-BALIA	2	0	834	0.0	13.3	-13.3
10	400 kV	NAUBATPUR-BALIA	2	7	444	0.0	4.0	-4.0
11	400 kV	BIHARSHARIFF-BALIA	2	376	175	0.0	0.3	-0.3
12	400 kV	MOTIHARI-GORAKHPUR	2	23	444	0.0	5.9	-5.9
13	400 kV	BIHARSARIFF-SAHUPURI	2	0	0	0.0	4.2	-4.2
14	220 kV	SAHUPURI-KARAMNASA	1	0	36	0.0	0.4	-0.4
15	132 kV	NAGAR UNTARI-RIHAND	1	0	0	0.1	0.0	0.1
16	132 kV	GARWAH-RIHAND	1	30	0	0.5	0.0	0.5
17	132 kV	KARMANASA-SAHUPURI	1	0	0	0.0	0.0	0.0
18	132 kV	KARMANASA-CHANDAULI	1	0	0	0.0	0.0	0.0
ER-NR						0.6	68.7	-68.1
Import/Export of ER (With WR)								
1	765 kV	JHARSUGUDA-DHARAMJAIGARH	4	1310	266	16.9	0.0	16.9
2	765 kV	NEW RANCHI-DHARAMJAIGARH	2	0	1194	0.0	15.7	-15.7
3	765 kV	JHARSUGUDA-DURG	2	0	1041	0.0	19.8	-19.8
4	400 kV	JHARSUGUDA-RAIGARH	4	0	906	0.0	16.4	-16.4
5	400 kV	RANCHI-SIPAT	2	0	374	0.0	5.0	-5.0
6	220 kV	BUDHIPADAR-RAIGARH	1	0	139	0.0	1.9	-1.9
7	220 kV	BUDHIPADAR-KORBA	2	23	153	0.0	1.7	-1.7
ER-WR						16.9	60.3	-43.4
Import/Export of ER (With SR)								
1	HVDC	JEYPORE-GAZUWAKA B/B	2	0	742	0.0	17.6	-17.6
2	HVDC	TALCHER-KOLAR BIPOLE	2	0	1649	0.0	39.8	-39.8
3	765 kV	ANGUL-SRIKAKULAM	2	0	2911	0.0	52.7	-52.7
4	400 kV	TALCHER-I/C	2	0	408	0.0	8.7	-8.7
5	220 kV	BALIMELA-UPPER-SILERRU	1	0	0	0.0	0.0	0.0
ER-SR						0.0	110.1	-110.1
Import/Export of ER (With NER)								
1	400 kV	BINAGURI-BONGAIGAON	2	335	54	3.3	0.1	3.2
2	400 kV	ALIPURDUAR-BONGAIGAON	2	571	22	5.9	0.0	5.9
3	220 kV	ALIPURDUAR-SALAKATI	2	138	0	1.9	0.0	1.9
ER-NER						11.1	0.1	11.0
Import/Export of NER (With NR)								
1	HVDC	BISWANATH CHARIALI-AGRA	2	661	0	16.2	0.0	16.2
NER-NR						16.2	0.0	16.2
Import/Export of WR (With NR)								
1	HVDC	CHAMPA-KURUKSHETRA	2	0	1512	0.0	36.2	-36.2
2	HVDC	VINDHYACHAL B/B	-	824	0	0.6	0.0	0.6
3	HVDC	MUNDRA-MOHINDERGARH	2	0	1172	0.0	29.0	-29.0
4	765 kV	GWALIOR-AGRA	2	1042	1726	4.1	8.4	-4.3
5	765 kV	GWALIOR-PHAGI	2	456	2019	1.1	22.9	-21.8
6	765 kV	JABALPUR-ORAI	2	423	965	0.0	10.1	-10.1
7	765 kV	GWALIOR-ORAI	1	868	0	15.7	0.0	15.7
8	765 kV	SATNA-ORAI	1	0	1045	0.0	17.2	-17.2
9	765 kV	BANASKANTHA-CHITORGARH	2	2136	0	25.4	0.0	25.4
10	765 kV	VINDHYACHAL-VARANASI	2	233	1688	0.0	14.5	-14.5
11	400 kV	ZERDA-KANKROLI	1	366	0	4.6	0.0	4.6
12	400 kV	ZERDA -BHINMAL	1	253	0	3.2	0.0	3.2
13	400 kV	VINDHYACHAL -RIHAND	1	480	0	10.8	0.0	10.8
14	400 kV	RAPP-SHUJALPUR	2	665	337	5.5	0.8	4.7
15	400 kV	NEEMUCH-Chittorgarh	2	768	303	7.0	0.6	6.4
16	220 kV	BHANPURA-RANPUR	1	0	190	0.0	3.1	-3.1
17	220 kV	BHANPURA-MORAK	1	0	30	0.0	2.3	-2.3
18	220 kV	MEHGAON-AURAIYA	1	132	0	2.2	0.0	2.2
19	220 kV	MALANPUR-AURAIYA	1	93	0	1.5	0.0	1.5
20	132 kV	GWALIOR-SAWAI MADHOPUR	1	0	0	0.0	0.0	0.0
21	132 kV	RAJGHAT-LALITPUR	2	0	0	0.0	0.0	0.0
WR-NR						81.6	145.1	-63.5
Import/Export of WR (With SR)								
1	HVDC	BHADRAWATI B/B	-	0	1014	0.0	24.0	-24.0
2	HVDC	RAIGARH-PUGALUR	2	0	4008	0.0	81.1	-81.1
3	765 kV	SOLAPUR-RAICHUR	2	812	1481	1.9	12.2	-10.2
4	765 kV	WARDHA-NIZAMABAD	2	77	2841	0.0	42.0	-42.0
5	765 kV	WARORA-WARANGAL(NEW)	2	0	3139	0.0	48.6	-48.6
6	400 kV	KOLHAPUR-KUDGI	2	1512	0	20.9	0.0	20.9
7	220 kV	KOLHAPUR-CHIKODI	2	0	0	0.0	0.0	0.0
8	220 kV	PONDA-AMBEWADI	1	0	0	0.0	0.0	0.0
9	220 kV	XELDEM-AMBEWADI	1	0	128	2.4	0.0	2.4
WR-SR						25.3	207.9	-182.6
INTERNATIONAL EXCHANGES								
State	Region	Line Name	Max (MW)	Min (MW)	Avg (MW)	Import(+ve)/Export(-ve) Energy Exchange (MU)		
BHUTAN	ER	400kV MANGDECHHU-ALIPURDUAR 1,2&3 I.e. ALIPURDUAR RECEIPT (from MANGDECHU HEP 4*180MW)	273	71	143	3.43		
	ER	400kV TALA-BINAGURI 1,2,4 (& 400kV MALBASE - BINAGURI) i.e. BINAGURI RECEIPT (from TALA HEP 6*170MW)	-291	77	-150	-3.61		
	ER	220kV CHUKHA-BIRPARA 1&2 (& 220kV MALBASE - BIRPARA) i.e. BIRPARA RECEIPT (from CHUKHA HEP 4*84MW)	-370	-237	-319	-7.67		
	NER	132kV GELEPHU-SALAKATI	-15	1	-6	-0.15		
	NER	132kV MOTANGA-RANGIA	10	-2	5	0.11		
NEPAL	NR	NEPAL IMPORT (FROM UP)	-59	0	0	0.00		
	NR	132kV MAHENDRANAGAR-TANAKPUR(NHPC)	-59	0	-39	-0.93		
	ER	NEPAL IMPORT (FROM BIHAR)	-194	-33	-148	-3.56		
	ER	400kV DHALKEBAR-MUZAFFARPUR 1&2	-448	-4	-263	-6.30		
BANGLADESH	ER	BHERAMARA B/B HVDC (B'DESH)	-949	-760	-888	-21.32		
	ER (Isolated from Indian Grid)	400kV GODDA_TPS-RAHANPUR (B'DESH) D/C	-768	-600	-698	-16.75		
	NER	132kV COMILLA-SURAJMANI NAGAR 1&2	-74	0	-57	-1.36		

Export From India (in MU)

Country	GNA (ISGS/PPA)	T-GNA							TOTAL	
		BILATERAL TOTAL	COLLECTIVE							
			IDAM			RTM				
			IEX	PXIL	HPX	IEX	PXIL	HPX		
Bhutan	0.00	0.35	9.15	0.00	0.00	0.00	0.00	0.00	9.50	
Nepal	3.53	0.00	4.47	0.00	0.00	0.00	2.51	0.00	0.00	10.51
Bangladesh	22.11	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	22.11
Myanmar	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total Export	25.64	0.35	13.62	0.00	0.00	0.00	2.51	0.00	0.00	42.12

Import by India(in MU)

Country	GNA (ISGA/PPA)	T-GNA							TOTAL
		BILATERAL TOTAL	COLLECTIVE						
			IDAM			RTM			
			IEX	PXIL	HPX	IEX	PXIL	HPX	
Bhutan	1.50	0.00	0.00	0.00	0.00	0.00	0.00	0.00	1.50
Nepal	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Bangladesh	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Myanmar	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total Import	1.50	0.00	0.00	0.00	0.00	0.00	0.00	0.00	1.50

Net from India(in MU)

-ve : Export / +ve : Import

Country	GNA (ISGS/PPA)	T-GNA							TOTAL
		BILATERAL TOTAL	COLLECTIVE						
			IDAM			RTM			
			IEX	PXIL	HPX	IEX	PXIL	HPX	
Bhutan	1.50	-0.35	-9.15	0.00	0.00	0.00	0.00	0.00	-8.00
Nepal	-3.53	0.00	-4.47	0.00	0.00	-2.51	0.00	0.00	-10.51
Bangladesh	-22.11	0.00	0.00	0.00	0.00	0.00	0.00	0.00	-22.11
Myanmar	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total Net	-24.14	-0.35	-13.62	0.00	0.00	-2.51	0.00	0.00	-40.62

