



National Load Despatch Centre
राष्ट्रीय भार प्रेषण केंद्र
GRID CONTROLLER OF INDIA LIMITED
ग्रिड कंट्रोलर ऑफ इंडिया लिमिटेड

(Government of India Enterprise/ भारत सरकार का उद्यम)
B-9, QUTUB INSTITUTIONAL AREA, KATWARIA SARAI, NEW DELHI -110016
बी-9, कुतुब इन्स्टीट्यूशनल एरिया, कटवारिया सराये, न्यू दिल्ली-110016

Ref: GRID-INDIA/NLDC/SO/Daily PSP Report

दिनांक: 10.02.2026

To,

- कार्यकारी निदेशक, पू.क्षे.भा.प्रे.के., 14, गोल्फ क्लब रोड, कोलकाता - 700033
Executive Director, ERLDC, 14 Golf Club Road, Tollygunge, Kolkata, 700033
- कार्यकारी निदेशक, ऊ.क्षे.भा.प्रे.के., 18/ए, शाहीद जीत सिंह सनसनवाल मार्ग, नई दिल्ली - 110016
Executive Director, NRLDC, 18-A, Shaheed Jeet Singh Marg, Katwaria Sarai, New Delhi - 110016
- कार्यकारी निदेशक, प.क्षे.भा.प्रे.के., एफ3, एम आई डी सी क्षेत्र, अंधेरी, मुंबई - 400093
Executive Director, WRLDC, F-3, M.I.D.C. Area, Marol, Andheri (East), Mumbai-400093
- कार्यकारी निदेशक, ऊ.पू.क्षे.भा.प्रे.के., डोंगतेह, लोअर नोंग्रह, लापालंग, शिलोंग - 793006
Executive Director, NERLDC, Dongteih, Lower Nongrah, Lapalang, Shillong - 793006, Meghalaya
- कार्यकारी निदेशक, द.क्षे.भा.प्रे.के., 29, रेस कोर्स क्रॉस रोड, बंगलुरु - 560009
Executive Director, SRLDC, 29, Race Course Cross Road, Bangalore-560009

Sub: Daily PSP Report for the date 09.02.2026.

महोदय/Sir,

आईईजीसी-2023 की धारा स.-38(1) के प्रावधान के अनुसार, दिनांक 9-फ़रवरी-2026 की अखिल भारतीय प्रणाली की दैनिक ग्रिड निष्पादन रिपोर्ट रांभांप्रेके की वेबसाइट पर उपलब्ध है।

As per article 38(1) of the Indian Electricity Grid Code, the daily report pertaining power supply position of All India Power System for the date 09.02.2026, is available at the NLDC website.

धन्यवाद,
Thanks

Report for previous day

Date of Reporting: 10-Feb-2026

A. Power Supply Position at All India and Regional level

	NR	WR	SR	ER	NER	TOTAL
Demand Met during Evening Peak hrs(MW) (at 19:00 hrs; from RLDCs)	58587	68723	53190	24502	2853	207855
Peak Shortage (MW)	0	0	0	0	0	0
Energy Met (MU)	1242	1619	1303	503	50	4717
Hydro Gen (MU)	112	37	86	25	11	272
Wind Gen (MU)	12	62	49	-	-	123
Solar Gen (MU)*	199.15	188.79	162.17	4.50	1.15	556
Energy Shortage (MU)	0.00	0.00	0.00	0.00	0.00	0.00
Maximum Demand Met During the Day (MW) (From NLDC SCADA)	67645	82015	65436	25532	2949	238975
Time Of Maximum Demand Met	10:31	10:24	09:29	18:14	18:04	10:28

B. Frequency Profile (%)

Region	FVI	< 49.7	49.7 - 49.8	49.8 - 49.9	< 49.9	49.9 - 50.05	> 50.05
All India	0.060	0.32	0.79	8.54	9.65	66.87	23.48

C. Power Supply Position in States

Region	States	Max.Demand Met during the day (MW)	Shortage during maximum Demand (MW)	Energy Met (MU)	Drawal Schedule (MU)	OD(+)/UD(-) (MU)	Max OD (MW)	Energy Shortage (MU)
NR	Punjab	9172	0	160.5	72.1	-0.1	509	0.00
	Haryana	8321	0	158.4	108.7	-0.9	227	0.00
	Rajasthan	18654	0	339.4	111.9	-5.3	1592	0.00
	Delhi	4532	0	80.8	71.7	0.5	437	0.00
	UP	19087	0	350.6	47.7	1.5	454	0.00
	Uttarakhand	2532	0	44.8	36.6	0.3	176	0.00
	HP	2111	0	38.2	32.5	-0.4	125	0.00
	J&K(UT) & Ladakh(UT)	2825	0	60.6	54.9	0.2	269	0.00
	Chandigarh	253	0	4.1	4.1	0.0	22	0.00
	Railways_NR ISTS	197	0	4.3	3.9	0.3	44	0.00
WR	Chhattisgarh	6029	0	123.1	59.8	-0.3	342	0.00
	Gujarat	24190	0	455.0	212.7	-3.3	1061	0.00
	MP	18563	0	335.9	209.7	0.0	564	0.00
	Maharashtra	29610	0	620.8	201.0	-7.4	774	0.00
	Goa	746	0	14.4	12.3	2.0	41	0.00
	DNHDDPDCL	1389	0	31.0	30.9	0.1	50	0.00
	AMNSIL	826	0	18.6	14.1	0.7	273	0.00
	BALCO	602	0	14.4	14.5	-0.1	31	0.00
	RIL JAMNAGAR	267	0	6.2	6.3	-0.1	0	0.00
	Andhra Pradesh	12896	0	237.1	76.0	-0.1	464	0.00
SR	Telangana	16199	0	284.6	141.9	-1.2	782	0.00
	Karnataka	17855	0	328.1	120.2	-0.2	893	0.00
	Kerala	4757	0	90.0	68.8	2.2	587	0.00
	Tamil Nadu	18152	0	354.9	209.1	-1.5	1038	0.00
	Puducherry	438	0	8.7	8.5	-0.1	29	0.00
	Bihar	5861	0	106.5	85.9	-1.3	189	0.00
ER	DVC	3155	0	68.8	-30.6	0.5	473	0.00
	Jharkhand	2077	0	39.2	27.7	-0.2	199	0.00
	Odisha	5717	0	114.7	16.6	-2.3	429	0.00
	West Bengal	8280	0	171.6	59.9	-2.0	164	0.00
	Sikkim	119	0	1.9	1.9	0.0	18	0.00
	Railways_ER ISTS	19	0	0.2	0.2	0.0	4	0.00
NER	Arunachal Pradesh	188	0	3.2	3.2	-0.2	102	0.00
	Assam	1664	0	29.2	23.3	0.0	958	0.00
	Manipur	250	0	3.5	3.7	-0.2	159	0.00
	Meghalaya	358	0	6.3	5.8	-0.1	289	0.00
	Mizoram	145	0	2.4	2.1	-0.1	75	0.00
	Nagaland	176	0	2.6	2.6	-0.1	128	0.00
	Tripura	231	0	2.4	4.9	-1.4	239	0.00

D. Transnational Exchanges (MU) - Import(+ve)/Export(-ve)

	Bhutan	Nepal	Bangladesh	Godda -> Bangladesh
Actual (MU)	-18.5	-11.7	-24.8	-27.0
Day Peak (MW)	-1034.7	-791.9	-1056.2	-1460.2

E. Import/Export by Regions (in MU) - Import(+ve)/Export(-ve); OD(+)/UD(-)

	NR	WR	SR	ER	NER	TOTAL
Schedule(MU)	154.6	-199.9	191.9	-162.9	16.4	0.0
Actual(MU)	172.7	-203.0	176.1	-162.8	13.3	-3.8
O/D/U/D(MU)	18.2	-3.1	-15.9	0.1	-3.1	-3.8

F. Generation Outage(MW)

	NR	WR	SR	ER	NER	TOTAL	% Share
Central Sector	6030	9868	3058	2494	969	22418	43
State Sector	8554	10656	6526	3970	205	29911	57
Total	14584	20523	9584	6464	1174	52328	100

G. Sourcewise generation (Gross) (MU)

	NR	WR	SR	ER	NER	All India	% Share
Coal	754	1548	754	743	8	3807	74
Lignite	28	19	46	0	0	93	2
Hydro	112	37	86	25	11	272	5
Nuclear	43	65	71	0	0	179	3
Gas, Naptha & Diesel	10	17	9	0	22	58	1
RES (Wind, Solar, Biomass & Others)	236	255	245	8	1	745	14
Total	1183	1942	1211	775	42	5154	100

Share of RES in total generation (%)	19.95	13.13	20.23	1.00	2.72	14.45
Share of Non-fossil fuel (Hydro,Nuclear and RES) in total generation(%)	33.05	18.39	33.21	4.20	29.84	23.20

H. All India Demand Diversity Factor

Based on Regional Max Demands	1.019
Based on State Max Demands	1.039

I. All India Peak Demand and shortage at Solar and Non-Solar Hour

	Max Demand Met(MW)	Time	Shortage(MW)
Solar hr	238975	10:28	0
Non-Solar hr	213612	18:47	0

Diversity factor = Sum of regional or state maximum demands / All India maximum demand

**Note: All generation MU figures are gross

***Godda (Jharkhand) -> Bangladesh power exchange is through the radial connection (isolated from Indian Grid)

Solar Hours -> 06:00 to 18:00hrs and rest are Non-Solar Hours

*Source: RLDCs for solar connected to ISTS; SLDCs for embedded solar. Limited visibility of embedded solar data.

Executive Director-NLDC

INTER-REGIONAL EXCHANGES

Import=(+ve)/Export =(-ve) for NET (MU)
Date of Reporting: 10-Feb-2026

Sl No	Voltage Level	Line Details	No. of Circuit	Max Import (MW)	Max Export (MW)	Import (MU)	Export (MU)	NET (MU)
Import/Export of ER (With NR)								
1	HVDC	ALIPURDUAR-AGRA	2	0	0	0.0	0.0	0.0
2	HVDC	PUSAULI B/B	-	0	47	0.0	2.5	-2.5
3	765 kV	GAYA-VARANASI	2	490	1424	0.0	16.3	-16.3
4	765 kV	SASARAM-FATEHPUR	1	181	599	0.0	6.5	-6.5
5	765 kV	GAYA-BALIA	1	59	724	0.0	10.5	-10.5
6	400 kV	PUSAULI-VARANASI	1	0	134	0.0	1.4	-1.4
7	400 kV	PUSAULI-ALLAHABAD	1	41	92	0.0	1.0	-1.0
8	400 kV	MUZAFFARPUR-GORAKHPUR	2	766	493	0.0	0.1	-0.1
9	400 kV	PATNA-BALIA	2	227	914	0.0	11.9	-11.9
10	400 kV	NAUBATPUR-BALIA	2	254	187	0.0	3.8	-3.8
11	400 kV	BIHARSHARIFF-BALIA	2	577	161	3.8	0.0	3.8
12	400 kV	MOTIHARI-GORAKHPUR	2	196	520	0.0	5.8	-5.8
13	400 kV	BIHARSARIFF-SAHUPURI	2	187	461	0.0	3.9	-3.9
14	220 kV	SAHUPURI-KARAMNANA	1	60	16	0.0	1.8	-1.8
15	132 kV	NAGAR UNTARI-RIHAND	1	0	0	0.1	0.0	0.1
16	132 kV	GARWAH-RIHAND	1	30	0	0.6	0.0	0.6
17	132 kV	KARMANASA-CHANDAUJI	1	0	0	0.0	0.0	0.0
ER-NR						4.4	65.6	-61.1
Import/Export of ER (With WR)								
1	765 kV	JHARSUGUDA-DHARAMJAIGARH	4	421	809	0.0	6.9	-6.9
2	765 kV	NEW RANCHI-DHARAMJAIGARH	2	970	906	0.0	0.7	-0.7
3	765 kV	JHARSUGUDA-DURG	2	0	1358	0.0	26.4	-26.4
4	400 kV	JHARSUGUDA-RAIGARH	4	98	332	0.0	3.5	-3.5
5	400 kV	RANCHI-SIPAT	2	202	308	0.0	1.2	-1.2
6	400 kV	JEYPORE-JAGDALPUR	2	330	236	0.9	0.0	0.9
7	220 kV	BUDHIPADAR-RAIGARH	1	0	170	0.0	2.8	-2.8
8	220 kV	BUDHIPADAR-KORBA	2	51	126	0.0	0.7	-0.7
ER-WR						0.9	42.3	-41.4
Import/Export of ER (With SR)								
1	HVDC	JEYPORE-GAZUWAKA B/B	2	0	571	0.0	10.9	-10.9
2	HVDC	TALCHER-KOLAR BIPOLE	2	0	1618	0.0	41.6	-41.6
3	765 kV	ANGUL-SRIKAKULAM	2	0	3132	0.0	55.3	-55.3
4	400 kV	TALCHER-I/C	2	717	379	1.0	0.0	1.0
5	220 kV	BALIMELA-UPPER-SILERRU	1	1	2	0.0	0.0	0.0
ER-SR						0.0	107.8	-107.8
Import/Export of ER (With NER)								
1	400 kV	BINAGURI-BONGAIGAOON	2	187	272	0.7	2.6	-1.9
2	400 kV	ALIPURDUAR-BONGAIGAOON	2	484	250	2.3	0.0	2.3
3	220 kV	ALIPURDUAR-SALAKATI	2	78	57	0.0	0.2	-0.2
ER-NER						3.0	2.8	0.3
Import/Export of NER (With NR)								
1	HVDC	BISWANATH CHARIALI-AGRA	2	960	0	16.7	0.0	16.7
NER-NR						16.7	0.0	16.7
Import/Export of WR (With NR)								
1	HVDC	CHAMPA-KURUKSHETRA	2	0	3046	0.0	62.6	-62.6
2	HVDC	VINDHYACHAL B/B	-	0	106	0.0	2.4	-2.4
3	HVDC	MUNDRA-MOHINDERGARH	2	0	1922	0.0	36.4	-36.4
4	765 kV	GWALIOR-AGRA	2	872	1754	2.6	18.0	-15.4
5	765 kV	GWALIOR-PHAGI	2	738	1944	2.2	29.3	-27.1
6	765 kV	JABALPUR-ORAI	2	471	890	0.0	19.3	-19.3
7	765 kV	GWALIOR-ORAI	1	934	0	17.2	0.0	17.2
8	765 kV	SATNA-ORAI	1	0	1088	0.0	18.2	-18.2
9	765 kV	BANASKANTHA-CHITORGARH	2	2767	235	32.3	0.1	32.2
10	765 kV	VINDHYACHAL VARANASI	2	471	1928	0.0	18.8	-18.8
11	400 kV	ZERDA-KANKROLI	1	409	0	6.3	0.0	6.3
12	400 kV	ZERDA BHINMAL	1	282	0	4.3	0.0	4.3
13	400 kV	VINDHYACHAL -RIHAND	1	486	0	10.0	0.0	10.0
14	400 kV	RAPP-SHUJALPUR	2	952	145	6.9	0.3	6.6
15	400 kV	NEEMUCH-Chittorgarh	2	869	283	4.6	1.2	3.5
16	220 kV	BHANPURA-RANPUR	1	0	133	0.0	2.1	-2.1
17	220 kV	BHANPURA-MORAK	1	0	30	0.0	1.5	-1.5
18	220 kV	MEHGAON-AURAIYA	1	123	4	1.2	0.0	1.2
19	220 kV	MALANPUR-AURAIYA	1	91	14	0.8	0.0	0.8
20	132 kV	RAJGHAT-LALITPUR	2	0	0	0.0	0.0	0.0
WR-NR						88.4	210.2	-121.7
Import/Export of WR (With SR)								
1	HVDC	BHADRAWATI B/B	-	0	975	0.0	12.7	-12.7
2	HVDC	RAIGARH-PUGALUR	2	0	5014	0.0	68.2	-68.2
3	765 kV	SOLAPUR-RAICHUR	2	918	1056	7.0	5.0	2.0
4	765 kV	WARDHA-NIZAMABAD	2	0	2808	0.0	34.1	-34.1
5	765 kV	WARORA-WARANGAL(NEW)	2	0	2801	0.0	35.8	-35.8
6	400 kV	KOLHAPUR-KUDGI	2	1543	0	24.1	0.0	24.1
7	220 kV	KOLHAPUR-CHIKODI	2	0	0	0.0	0.0	0.0
8	220 kV	PONDA-AMBEWADI	1	0	0	0.0	0.0	0.0
9	220 kV	XELDEM-AMBEWADI	1	0	119	2.3	0.0	2.3
WR-SR						33.3	155.7	-122.4

INTERNATIONAL EXCHANGES

					Import(+ve)/Export(-ve)		
State	Region	Line Name	Max (MW)	Min (MW)	Avg (MW)	Energy Exchange (MU)	
BHUTAN	ER	400kV MANGDECHHU-ALIPURDUAR 1,2&3 I.e. ALIPURDUAR RECEIPT (from MANGDECHU HEP 4*180MW)	-318	62	-245	-5.87	
	ER	400kV TALA-BINAGURI 1,2,4 (& 400kV MALBASE - BINAGURI) I.e. BINAGURI RECEIPT (from TALA HEP 6*170MW)	-404	102	-161	-3.87	
	ER	220kV CHUKHA-BIRPARA 1&2 (& 220kV MALBASE - BIRPARA) I.e. BIRPARA RECEIPT (from CHUKHA HEP 4*84MW)	-212	-80	-166	-3.98	
	NER	132kV GELEPHU-SALAKATI	-81	-10	-65	-1.57	
	NER	132kV MOTANGA-RANGIA	-55	-15	-28	-0.68	
NEPAL	NR	NEPAL IMPORT (FROM UP)	-68	0	-35	-0.85	
	NR	132kV MAHENDRANAGAR-TANAKPUR(NHPC)	-68	0	-52	-1.25	
	ER	NEPAL IMPORT (FROM BIHAR)	-155	-88	-123	-2.95	
	ER	400kV DHALKEBAR-MUZAFFARPUR 1&2	-534	-98	-277	-6.65	
BANGLADESH	ER	BHERAMARA B/B HVDC (B'DESH)	-922	-917	-918	-22.02	
	ER (Isolated from Indian Grid)	400kV GODDA_TPS-RAHANPUR (B'DESH) D/C	-1460	-586	-1123	-26.96	
	NER	132kV COMILLA-SURAJMANI NAGAR 1&2	-133	0	-117	-2.80	

CROSS BORDER EXCHANGE SCHEDULE

Date of Reporting: 10-Feb-2026

Export From India (in MU)

Country	GNA (ISGS/PPA)	T-GNA							TOTAL
		BILATERAL TOTAL	COLLECTIVE						
			IDAM			RTM			
			IEX	PXIL	HPX	IEX	PXIL	HPX	
Bhutan	0.00	0.36	19.27	0.00	0.00	0.00	0.00	0.00	19.63
Nepal	3.41	1.75	1.52	0.00	0.00	3.40	0.00	0.00	10.08
Bangladesh	22.95	0.00	0.00	0.00	0.00	0.00	0.00	0.00	22.95
Myanmar	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total Export	26.36	2.11	20.79	0.00	0.00	3.40	0.00	0.00	52.66

Import by India(in MU)

Country	GNA (ISGA/PPA)	T-GNA							TOTAL
		BILATERAL TOTAL	COLLECTIVE						
			IDAM			RTM			
			IEX	PXIL	HPX	IEX	PXIL	HPX	
Bhutan	0.34	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.34
Nepal	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Bangladesh	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Myanmar	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total Import	0.34	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.34

Net from India(in MU)

-ve : Export / +ve : Import

Country	GNA (ISGS/PPA)	T-GNA							TOTAL
		BILATERAL TOTAL	COLLECTIVE						
			IDAM			RTM			
			IEX	PXIL	HPX	IEX	PXIL	HPX	
Bhutan	0.34	-0.36	-19.27	0.00	0.00	0.00	0.00	0.00	-19.29
Nepal	-3.41	-1.75	-1.52	0.00	0.00	-3.40	0.00	0.00	-10.08
Bangladesh	-22.95	0.00	0.00	0.00	0.00	0.00	0.00	0.00	-22.95
Myanmar	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total Net	-26.02	-2.11	-20.79	0.00	0.00	-3.40	0.00	0.00	-52.32

15 Min (INSTANTANEOUS) ALL INDIA GRID FREQUENCY, GENERATION & DEMAND MET (SCADA DATA)												
TIME	FREQUENCY (Hz)	DEMAND MET (MW)	NUCLEAR (MW)	WIND (MW)	SOLAR (MW)	HYDRO** (MW)	GAS (MW)	THERMAL (MW)	OTHERS* (MW)	NET DEMAND (MW)	TOTAL GENERATION (MW)	NET TRANSNATIONAL EXCHANGE (MW)
		(A)	(B)	(C)	(D)	(E)	(F)	(G)	(H)	(I=A-(C+D))	(J=B+C+D+E+F+G+H)	(K)
0:00	50.00	156680	6810	4271	0	6265	1929	138948	3848	152409	162071	-2265
0:15	49.97	157809	6801	4380	0	6600	1930	139384	3805	153429	162900	-2207
0:30	49.92	157798	6802	4827	0	6561	1928	139023	3748	152971	162889	-2180
0:45	49.98	158157	6802	4930	0	6349	1930	139307	3773	153227	163091	-2196
1:00	50.04	157485	6790	4878	0	6165	1925	138859	3754	152607	162371	-2159
1:15	49.99	156587	6795	4812	0	6105	1935	138015	3805	151775	161467	-2160
1:30	49.98	156434	6807	4867	0	6182	1952	137721	3816	151567	161345	-2196
1:45	49.98	156173	6795	4945	0	6076	1941	137296	3840	151228	160893	-2197
2:00	50.02	155236	6803	4869	0	6037	1933	136577	3782	150367	160001	-2174
2:15	49.99	155116	6795	4877	0	6117	1938	136486	3783	150239	159996	-2198
2:30	50.03	155159	6815	4946	0	6067	1935	136446	3830	150213	160039	-2194
2:45	50.01	155258	6789	5085	0	6094	1938	136406	3830	150173	160142	-2153
3:00	50.04	155034	6790	5208	0	6074	1938	136041	3847	149826	159898	-2204
3:15	49.97	155625	6804	5346	0	5559	1948	137088	3832	150279	160577	-2204
3:30	50.02	155927	6793	5337	0	5875	1940	136974	3880	150590	160799	-2199
3:45	50.02	156458	6804	5324	0	5941	1946	137542	3849	151134	161406	-2235
4:00	50.06	156817	6800	5267	0	6226	1936	137731	3892	151550	161852	-2262
4:15	50.03	159369	6796	5265	0	6262	1941	140093	3934	154104	164291	-2265
4:30	50.03	160933	6801	5297	0	6303	1936	141922	3804	155636	166063	-2300
4:45	50.00	162717	6797	5277	0	6333	1957	143774	3853	157440	167991	-2323
5:00	50.10	164170	6796	5189	75	6321	2003	145369	3910	158906	169663	-2403
5:15	50.01	167652	6791	5209	77	6888	2037	148463	3826	162366	173291	-2370
5:30	50.06	172340	6792	5104	77	7513	2041	152787	3881	167159	178195	-2398
5:45	50.01	177705	6803	5198	78	8547	2122	156498	4018	172429	183264	-2392
6:00	50.08	181633	6791	5186	79	9642	2127	159772	3889	176368	187486	-2332
6:15	49.96	188290	6789	5197	253	10815	2127	164848	3920	182840	193949	-2361
6:30	49.95	195989	6784	5165	257	12773	2128	170660	3920	190567	201687	-2378
6:45	49.98	202040	6795	5033	268	14314	2160	174585	3930	196739	207085	-1827
7:00	50.07	208155	6792	4833	328	19825	2150	175541	3931	202994	213400	-1434
7:15	49.83	213973	6786	4639	584	22947	2151	177544	4005	208750	218656	-1404
7:30	49.84	217680	6778	4652	1377	23834	2165	178472	3892	211651	221170	-1432
7:45	50.06	220677	6788	4529	7211	24745	2147	176794	3977	208937	226191	-1400
8:00	50.20	222405	6788	4377	11788	23686	2141	174992	3957	206240	227729	-1420
8:15	50.10	224556	6801	4245	17119	21967	2148	173728	4004	203192	230012	-1429
8:30	50.12	226247	6797	4025	24247	20313	2145	170826	3952	197975	232305	-1378
8:45	50.02	228291	6798	3606	30646	18372	2131	168963	3988	194039	234504	-1412
9:00	50.10	230932	6784	3296	37427	16446	2142	166707	3951	190209	236753	-1459
9:15	49.88	235528	6793	3159	43225	15628	2142	167338	4010	189144	242295	-2028
9:30	50.00	237484	6785	2883	48618	13744	2148	166528	3922	185983	244628	-2485
9:45	49.97	238729	6767	2713	52732	11905	2135	165342	3917	183284	245511	-2567
10:00	50.01	238072	6785	2693	56351	10797	2124	162392	3976	179028	245118	-2562
10:15	49.85	238284	6759	2799	58740	10425	2132	160826	3850	176745	245531	-2714
10:30	49.98	238804	6753	2860	63126	9915	2122	157430	3802	172818	246008	-2656
10:45	50.04	237600	6777	2844	65959	9709	2113	153804	3890	168797	245096	-2658
11:00	50.20	237203	6782	2727	70296	9390	2121	149677	3850	164180	244843	-2689
11:15	50.18	234087	6789	2656	72525	9086	2082	144818	3839	158906	241795	-2698
11:30	50.09	232586	6788	2573	73143	9122	1947	142342	3829	156870	239744	-2704
11:45	50.05	230700	6789	2446	75115	9143	1937	139064	3817	153139	238311	-2722
12:00	50.09	227556	6759	2385	74973	9166	1950	135929	3752	150198	234914	-2673
12:15	49.99	225218	6775	2486	75976	9207	1925	132731	3753	146756	232853	-2671
12:30	50.01	224323	6778	2450	75248	9222	1926	132254	3759	146625	231637	-2709
12:45	50.01	222714	6762	2370	76906	9129	1930	129622	3793	143438	230512	-2696
13:00	50.13	218881	6767	2420	76312	8898	1928	126540	3714	140149	226579	-2689
13:15	50.13	214943	6781	2537	76449	8822	1933	122480	3781	135957	222783	-2733
13:30	50.13	214068	6766	2715	76444	9148	1928	121172	3731	134909	221904	-2677
13:45	49.99	214448	6763	2866	75075	9052	1936	122608	3735	136507	222035	-2660
14:00	50.06	214279	6771	2960	74653	9260	1926	122690	3723	136666	221983	-2664
14:15	50.01	215038	6761	2991	73709	9348	1925	124320	3690	138338	222744	-2620
14:30	50.02	215662	6750	3192	71968	9667	1930	127153	3692	140502	224352	-2639
14:45	50.03	218222	6744	3255	70399	9999	1924	130200	3680	144568	226201	-2643
15:00	49.99	218691	6748	3426	68154	10025	1936	132478	3711	147111	226478	-2738
15:15	49.95	218189	6771	3492	65288	10167	2009	134873	3678	149409	226278	-2769
15:30	50.00	218294	6758	3749	61893	10340	2030	137517	3726	152652	226013	-2727
15:45	50.03	217592	6746	3957	57915	10402	1968	140365	3681	155720	225034	-2763
16:00	50.02	216685	6751	4217	53450	11109	1956	142709	3691	159018	223883	-2711
16:15	49.89	213415	6759	4477	48397	10492	1954	144476	3683	160541	220238	-2700
16:30	50.01	213261	6752	4478	42732	9088	1968	149399	3788	166051	218205	-2675
16:45	49.95	212416	6760	4510	36323	12310	1994	153926	3758	171583	219581	-2609
17:00	50.06	211202	6741	4634	29446	11267	1989	159411	3758	177122	217246	-2619
17:15	50.03	209735	6760	4927	22271	13168	2008	161052	3818	182537	214004	-2600
17:30	50.07	209634	6751	5076	15426	15312	2023	165961	3790	189132	214339	-2481
17:45	50.09	211414	6735	5276	9725	18752	2032	169705	3830	196413	216055	-2410
18:00	50.08	210729	6750	5385	5268	20893	2051	170935	3806	200076	215088	-1947
18:15	50.00	209884	6755	5470	2151	20951	2096	171923	3805	202263	213151	-1336
18:30	50.02	211359	6742	5771	891	21474	2107	173906	3840	204697	214731	-1281
18:45	50.00	212868	6736	6099	422	22106	2131	174913	3806	206347	216213	-1269
19:00	50.04	211952	6744	6385	294	21909	2173	174157	3849	205273	215511	-1298
19:15	50.07	210424	6747	6735	276	21022	2204	172637	3860	203413	213481	-1250
19:30	50.06	207237	6767	7093	0	17336	2247	172601	3823	200144	209867	-1293
19:45	50.01	205097	6766	7429	0	15732	2241	171590	3903	197668	207661	-1363
20:00	50.05	201786	6760	7665	0	14509	2201	169624	3785	194121	204544	-1396
20:15	50.03	198052	6768	7776	0	13088	2143	167690	3768	190276	201233	-1371
20:30	50.03	196057	6772	8033	0	12261	2079	166349	3761	188024	199255	-1463
20:45	49.97	193257	6783	8148	0	11712	1981	165081	3708	185109	197413	-1971
21:00	50.00	190156	6788	8176	0	11696	1931	162308	3722	181980	194621	-2320
21:15	49.99	188099	6775	8234	0	11433	1931	160491	3736	179865	192600	-2370
21:30	49.93	185248	6772	8281	0	11183	1974	158292	3743	176967	190245	-2325
21:45	50.02	182473	6786	8262	0	10055	1976	156606	3759	174211	187444	-2256
22:00	50.04	178984	6770	8292	0	9426	1972	153726	3747	170692	183933	-2225
22:15	49.92	179010	6784	8299	0	9568	1942	153906	3735	170711	184234	-2242
22:30	49.94	176766	6755									