



National Load Despatch Centre
राष्ट्रीय भार प्रेषण केंद्र
GRID CONTROLLER OF INDIA LIMITED
ग्रिड कंट्रोलर ऑफ इंडिया लिमिटेड

(Government of India Enterprise/ भारत सरकार का उद्यम)
B-9, QUTUB INSTITUTIONAL AREA, KATWARIA SARAI, NEW DELHI -110016
बी-9, कुतुब इन्स्टीट्यूशनल एरिया, कटवारिया सराये, न्यू दिल्ली-110016

Ref: GRID-INDIA/NLDC/SO/Daily PSP Report

दिनांक: 21.12.2025

To,

- कार्यकारी निदेशक, पू.क्षे.भा.प्रे.के., 14, गोल्फ क्लब रोड, कोलकाता - 700033
Executive Director, ERLDC, 14 Golf Club Road, Tollygunge, Kolkata, 700033
- कार्यकारी निदेशक, ऊ.क्षे.भा.प्रे.के., 18/ए, शाहीद जीत सिंह सनसनवाल मार्ग, नई दिल्ली - 110016
Executive Director, NRLDC, 18-A, Shaheed Jeet Singh Marg, Katwaria Sarai, New Delhi - 110016
- कार्यकारी निदेशक, प.क्षे.भा.प्रे.के., एफ3, एम आई डी सी क्षेत्र, अंधेरी, मुंबई - 400093
Executive Director, WRLDC, F-3, M.I.D.C. Area, Marol, Andheri (East), Mumbai-400093
- कार्यकारी निदेशक, ऊ.पू.क्षे.भा.प्रे.के., डोंगतेह, लोअर नोंग्रह, लापालंग, शिलोंग - 793006
Executive Director, NERLDC, Dongteih, Lower Nongrah, Lapalang, Shillong - 793006, Meghalaya
- कार्यकारी निदेशक, द.क्षे.भा.प्रे.के., 29, रेस कोर्स क्रॉस रोड, बंगलुरु - 560009
Executive Director, SRLDC, 29, Race Course Cross Road, Bangalore-560009

Sub: Daily PSP Report for the date 20.12.2025.

महोदय/Sir,

आईईजीसी-2023 की धारा स.-38(1) के प्रावधान के अनुसार, दिनांक 20-दिसंबर-2025 की अखिल भारतीय प्रणाली की दैनिक ग्रिड निष्पादन रिपोर्ट रांभांप्रेके की वेबसाइट पर उपलब्ध है।

As per article 38(1) of the Indian Electricity Grid Code, the daily report pertaining power supply position of All India Power System for the date 20.12.2025, is available at the NLDC website.

धन्यवाद,
Thanks

Report for previous day

Date of Reporting: 21-Dec-2025

A. Power Supply Position at All India and Regional level

	NR	WR	SR	ER	NER	TOTAL
Demand Met during Evening Peak hrs(MW) (at 19:00 hrs; from RLDCs)	60306	69721	47987	22454	2794	203262
Peak Shortage (MW)	106	0	250	448	0	804
Energy Met (MU)	1294	1552	1158	478	51	4533
Hydro Gen (MU)	134	48	100	19	11	311
Wind Gen (MU)	2	30	49	-	-	81
Solar Gen (MU)*	160.43	160.81	154.96	2.16	0.94	479
Energy Shortage (MU)	0.88	0.00	0.75	1.02	0.00	2.65
Maximum Demand Met During the Day (MW) (From NLDC SCADA)	69389	77991	58256	24314	2717	229251
Time Of Maximum Demand Met	10:27	09:58	09:30	17:47	17:03	09:47

B. Frequency Profile (%)

Region	FVI	< 49.7	49.7 - 49.8	49.8 - 49.9	< 49.9	49.9 - 50.05	> 50.05
All India	0.065	1.42	0.86	6.62	8.90	78.88	12.22

C. Power Supply Position in States

Region	States	Max.Demand Met during the day (MW)	Shortage during maximum Demand (MW)	Energy Met (MU)	Drawal Schedule (MU)	OD(+)/UD(-) (MU)	Max OD (MW)	Energy Shortage (MU)
NR	Punjab	8544	0	159.5	70.5	0.6	382	0.00
	Haryana	8910	0	171.6	117.4	-0.4	550	0.00
	Rajasthan	18215	0	334.7	116.4	2.2	970	0.00
	Delhi	4899	0	84.0	76.0	2.6	457	0.00
	UP	20430	0	384.3	77.8	0.5	500	0.00
	Uttarakhand	2521	0	47.2	35.6	1.0	174	0.41
	HP	2160	0	38.3	31.2	-0.8	137	0.00
	J&K(UT) & Ladakh(UT)	3165	106	66.2	61.0	-0.5	223	0.47
	Chandigarh	238	0	4.3	4.2	0.1	17	0.00
	Railways_NR ISTS	214	0	3.8	3.7	0.1	48	0.00
WR	Chhattisgarh	5244	0	102.8	36.3	-2.3	356	0.00
	Gujarat	23767	0	452.7	199.3	-5.7	444	0.00
	MP	18649	0	347.1	248.0	0.0	713	0.00
	Maharashtra	27097	0	567.7	171.4	-7.0	982	0.00
	Goa	639	0	12.1	9.9	1.7	55	0.00
	DNHDDPDCL	1340	0	30.3	30.2	0.1	46	0.00
	AMNSIL	857	0	19.0	10.8	1.2	334	0.00
	BALCO	587	0	14.0	14.1	-0.1	17	0.00
	RIL JAMNAGAR	265	0	6.1	6.1	0.0	0	0.00
	Andhra Pradesh	10871	0	208.8	45.7	-2.2	688	0.00
SR	Telangana	13990	0	246.0	111.0	0.5	731	0.00
	Karnataka	16431	0	288.1	127.3	1.3	818	0.00
	Kerala	4187	250	76.7	51.9	0.3	667	0.75
	Tamil Nadu	16305	0	329.7	182.0	-0.6	1250	0.00
	Puducherry	411	0	8.7	8.3	-0.2	27	0.00
	Bihar	5796	0	106.9	100.0	0.5	364	0.12
ER	DVC	3325	0	70.2	-38.5	0.2	641	0.00
	Jharkhand	2137	0	40.9	27.1	0.4	614	0.90
	Odisha	5454	0	105.2	21.7	-3.8	312	0.00
	West Bengal	7619	0	153.2	14.7	-1.6	541	0.00
	Sikkim	102	0	1.7	1.8	0.0	18	0.00
	Railways_ER ISTS	15	0	0.2	0.1	0.0	10	0.00
NER	Arunachal Pradesh	185	0	3.3	3.1	0.1	11	0.00
	Assam	1602	0	28.5	24.1	-0.5	33	0.00
	Manipur	255	0	3.8	3.8	0.0	12	0.00
	Meghalaya	349	0	6.3	5.3	0.0	15	0.00
	Mizoram	170	0	2.3	2.1	-0.2	14	0.00
	Nagaland	160	0	2.9	2.7	0.0	21	0.00
	Tripura	236	0	4.1	4.8	0.1	19	0.00

D. Transnational Exchanges (MU) - Import(+ve)/Export(-ve)

	Bhutan	Nepal	Bangladesh	Godda -> Bangladesh
Actual (MU)	-11.6	2.5	-20.2	-24.8
Day Peak (MW)	-951.2	333.7	-1040.8	-1364.0

E. Import/Export by Regions (in MU) - Import(+ve)/Export(-ve); OD(+)/UD(-)

	NR	WR	SR	ER	NER	TOTAL
Schedule(MU)	214.7	-206.1	180.9	-201.2	11.7	0.0
Actual(MU)	222.7	-211.6	171.4	-205.5	9.5	-13.5
O/D/U/D(MU)	8.1	-5.5	-9.5	-4.3	-2.3	-13.5

F. Generation Outage(MW)

	NR	WR	SR	ER	NER	TOTAL	% Share
Central Sector	7287	11285	9888	5620	114	34194	50
State Sector	10049	11251	10934	2747	205	35186	50
Total	17336	22536	20822	8367	319	69380	100

G. Sourcewise generation (Gross) (MU)

	NR	WR	SR	ER	NER	All India	% Share
Coal	785	1560	625	747	14	3731	75
Lignite	25	16	56	0	0	97	2
Hydro	134	48	101	19	11	311	6
Nuclear	32	53	47	0	0	131	3
Gas, Naptha & Diesel	15	24	4	0	21	64	1
RES (Wind, Solar, Biomass & Others)	189	195	233	6	1	623	13
Total	1180	1896	1065	771	48	4959	100

Share of RES in total generation (%)	15.99	10.29	23.09	0.72	2.02	12.71
Share of Non-fossil fuel (Hydro,Nuclear and RES) in total generation(%)	30.02	15.58	37.31	3.13	24.82	21.66

H. All India Demand Diversity Factor

Based on Regional Max Demands	1.014
Based on State Max Demands	1.035

I. All India Peak Demand and shortage at Solar and Non-Solar Hour

	Max Demand Met(MW)	Time	Shortage(MW)
Solar hr	229251	9:47	0
Non-Solar hr	208194	18:15	1076

Diversity factor = Sum of regional or state maximum demands / All India maximum demand

**Note: All generation MU figures are gross

***Godda (Jharkhand) -> Bangladesh power exchange is through the radial connection (isolated from Indian Grid)

Solar Hours -> 06:00 to 18:00hrs and rest are Non-Solar Hours

*Source: RLDCs for solar connected to ISTS; SLDCs for embedded solar. Limited visibility of embedded solar data.

Executive Director-NLDC

INTER-REGIONAL EXCHANGES

Import=(+ve)/Export =(-ve) for NET (MU)
Date of Reporting: 21-Dec-2025

Sl No	Voltage Level	Line Details	No. of Circuit	Max Import (MW)	Max Export (MW)	Import (MU)	Export (MU)	NET (MU)
Import/Export of ER (With NR)								
1	HVDC	ALIPURDUAR-AGRA	2	0	0	0.0	0.0	0.0
2	HVDC	PUSAULI B/B	-	0	47	0.0	2.4	-2.4
3	765 kV	GAYA-VARANASI	2	127	1243	0.0	15.5	-15.5
4	765 kV	SASARAM-FATEHPUR	1	25	651	0.0	9.0	-9.0
5	765 kV	GAYA-BALIA	1	0	705	0.0	13.3	-13.3
6	400 kV	PUSAULI-VARANASI	1	91	55	0.1	0.0	0.1
7	400 kV	PUSAULI-ALLAHABAD	1	0	142	0.0	2.2	-2.2
8	400 kV	MUZAFFARPUR-GORAKHPUR	2	196	706	0.0	7.0	-7.0
9	400 kV	PATNA-BALIA	2	0	1084	0.0	18.0	-18.0
10	400 kV	NAUBATPUR-BALIA	2	0	496	0.0	5.5	-5.5
11	400 kV	BIHARSHARIFE-BALIA	2	295	335	0.0	1.6	-1.6
12	400 kV	MOTIHARI-GORAKHPUR	2	0	611	0.0	9.7	-9.7
13	400 kV	BIHARSARIFE-SAHUPURI	2	126	481	0.0	5.9	-5.9
14	220 kV	SAHUPURI-KARMANASA	1	8	36	0.0	0.8	-0.8
15	132 kV	NAGAR UNTARI-RIHAND	1	0	0	0.0	0.0	0.0
16	132 kV	GARWAH-RIHAND	1	0	0	0.7	0.0	0.7
17	132 kV	KARMANASA-SAHUPURI	1	0	0	0.0	0.0	0.0
18	132 kV	KARMANASA-CHANDAULI	1	0	30	0.0	0.7	-0.7
						ER-NR	0.8	91.7
								-90.9
Import/Export of ER (With WR)								
1	765 kV	JHARSUGUDA-DHARAMJAIGARH	4	330	1265	0.0	10.9	-10.9
2	765 kV	NEW RANCHI-DHARAMJAIGARH	2	814	1189	0.0	8.2	-8.2
3	765 kV	JHARSUGUDA-DURG	2	0	1346	0.0	23.4	-23.4
4	400 kV	JHARSUGUDA-RAIGARH	4	448	78	4.9	0.0	4.9
5	400 kV	RANCHI-SIPAT	2	254	357	0.0	2.2	-2.2
6	400 kV	JEYPORE-JAGDALPUR	2	589	69	9.3	0.0	9.3
7	220 kV	BUDHIPADAR-RAIGARH	1	27	101	0.0	0.7	-0.7
8	220 kV	BUDHIPADAR-KORBA	2	66	45	0.3	0.0	0.3
						ER-WR	14.6	45.3
								-30.7
Import/Export of ER (With SR)								
1	HVDC	JEYPORE-GAZUWAKA B/B	2	0	726	0.0	17.4	-17.4
2	HVDC	TALCHER-KOLAR BIPOLE	2	0	1335	0.0	27.9	-27.9
3	765 kV	ANGUL-SRIKAKULAM	2	0	2744	0.0	40.9	-40.9
4	400 kV	TALCHER-I/C	2	430	1042	0.0	18.0	-18.0
5	220 kV	BALIMELA-UPPER-SILERRU	1	0	0	0.0	0.0	0.0
						ER-SR	0.0	86.2
								-86.2
Import/Export of ER (With NER)								
1	400 kV	BINAGURI-BONGAIGAON	2	123	443	0.3	5.6	-5.3
2	400 kV	ALIPURDUAR-BONGAIGAON	2	262	514	0.0	5.6	-5.6
3	220 kV	ALIPURDUAR-SALAKATI	2	69	72	0.0	0.5	-0.5
						ER-NER	0.3	11.8
								-11.5
Import/Export of <null> (With <null>)								
No Records Found								
						NER-NR	0.0	0.0
								0.0
Import/Export of WR (With NR)								
1	HVDC	CHAMPA-KURUKSHETRA	2	0	3022	0.0	59.4	-59.4
2	HVDC	VINDHYACHAL B/B	-	242	0	6.1	0.0	6.1
3	HVDC	MUNDRA-MOHINDERGARH	2	0	1460	0.0	21.9	-21.9
4	765 kV	GWALIOR-AGRA	2	532	1600	0.0	16.5	-16.5
5	765 kV	GWALIOR-PHAGI	2	117	2108	0.0	31.5	-31.5
6	765 kV	JABALPUR-ORAI	2	0	998	0.0	30.2	-30.2
7	765 kV	GWALIOR-ORAI	1	1148	0	21.1	0.0	21.1
8	765 kV	SATNA-ORAI	1	0	1319	0.0	25.9	-25.9
9	765 kV	BANASKANTHA-CHITORGARH	2	2441	398	28.5	0.0	28.5
10	765 kV	VINDHYACHAL-VARANASI	2	0	2605	0.0	42.7	-42.7
11	400 kV	ZERDA-KANKROLI	1	355	0	4.9	0.0	4.9
12	400 kV	ZERDA-BHINMAL	1	244	0	3.4	0.0	3.4
13	400 kV	VINDHYACHAL -RIHAND	1	974	0	0.0	21.7	-21.7
14	400 kV	RAPP-SHUJALPUR	2	424	343	2.7	1.6	1.2
15	400 kV	NEEMUCH-Chittorgarh	2	540	429	1.3	0.0	1.3
16	220 kV	BHANPURA-RANPUR	1	0	127	0.0	2.1	-2.1
17	220 kV	BHANPURA-MORAK	1	0	30	0.0	1.5	-1.5
18	220 kV	MEHGAON-AURAIYA	1	171	0	1.6	0.0	1.6
19	220 kV	MALANPUR-AURAIYA	1	134	13	1.0	0.0	1.0
20	132 kV	RAJGHAT-LALITPUR	2	0	0	0.0	0.0	0.0
						WR-NR	70.5	254.9
								-184.5
Import/Export of WR (With SR)								
1	HVDC	BHADRAWATI B/B	-	0	1008	0.0	15.5	-15.5
2	HVDC	RAIGARH-PUGALUR	2	0	4009	0.0	62.6	-62.6
3	765 kV	SOLAPUR-RAICHUR	2	1785	1624	7.5	8.0	-0.5
4	765 kV	WARDHA-NIZAMABAD	2	203	2267	0.0	15.8	-15.8
5	765 kV	WARORA-WARANGAL(NEW)	2	0	2547	0.0	29.5	-29.5
6	400 kV	KOLHAPUR-KUDGI	2	1754	0	25.4	0.0	25.4
7	220 kV	KOLHAPUR-CHIKODI	2	0	0	0.0	0.0	0.0
8	220 kV	PONDA-AMBEWADI	1	0	0	0.0	0.0	0.0
9	220 kV	XELDEM-AMBEWADI	1	0	109	2.0	0.0	2.0
						WR-SR	34.8	131.4
								-96.6
INTERNATIONAL EXCHANGES								
State	Region	Line Name	Max (MW)	Min (MW)	Avg (MW)	Energy Exchange (MU)		
BHUTAN	ER	400kV MANGDECHHU-ALIPURDUAR 1,2&3 L.e. ALIPURDUAR RECEIPT (from MANGDECHHU HEP 4*180MW)	-220	6	-119	-2.86		
	ER	400kV TALA-BINAGURI 1,2,4 (& 400kV MALBASE - BINAGURI) L.e. BINAGURI RECEIPT (from TALA HEP 6*170MW)	297	-241	-1	-0.03		
	ER	220kV CHUKHA-BIRPARA 1&2 (& 220kV MALBASE - BIRPARA) L.e. BIRPARA RECEIPT (from CHUKHA HEP 4*84MW)	-338	-254	-299	-7.18		
	NER	132kV GELEPHU-SALAKATI	-56	0	-46	-1.11		
	NER	132kV MOTANGA-RANGIA	-24	0	-19	-0.46		
NEPAL	NR	NEPAL IMPORT (FROM UP)	-63	0	-6	-0.15		
	NR	132kV MAHENDRANAGAR-TANAKPUR(NHPC)	-63	0	-4	-0.10		
	ER	NEPAL IMPORT (FROM BIHAR)	0	0	0	0.00		
	ER	400kV DHALKEBAR-MUZAFFARPUR 1&2	285	0	113	2.70		
BANGLADESH	ER	BHERAMARA B/B HVDC (B'DESH)	-920	-538	-744	-17.85		
	ER (Isolated from Indian Grid)	400kV GODDA_TPS-RAHANPUR (B'DESH) D/C	-1364	-819	-1032	-24.77		
	NER	132kV COMILLA-SURAJMANI NAGAR 1&2	-119	0	-96	-2.30		

CROSS BORDER EXCHANGE SCHEDULE

Date of Reporting: 21-Dec-2025

Export From India (in MU)

Country	GNA (ISGS/PPA)	T-GNA							TOTAL
		BILATERAL TOTAL	COLLECTIVE						
			IDAM			RTM			
			IEX	PXIL	HPX	IEX	PXIL	HPX	
Bhutan	0.00	0.31	12.89	0.00	0.00	0.00	0.00	0.00	13.20
Nepal	0.38	0.00	0.00	0.00	0.00	0.49	0.00	0.00	0.87
Bangladesh	18.59	0.00	0.00	0.00	0.00	0.00	0.00	0.00	18.59
Myanmar	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total Export	18.97	0.31	12.89	0.00	0.00	0.49	0.00	0.00	32.66

Import by India(in MU)

Country	GNA (ISGA/PPA)	T-GNA							TOTAL
		BILATERAL TOTAL	COLLECTIVE						
			IDAM			RTM			
			IEX	PXIL	HPX	IEX	PXIL	HPX	
Bhutan	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Nepal	0.00	0.00	0.00	0.00	0.00	3.48	0.00	0.00	3.48
Bangladesh	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Myanmar	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total Import	0.00	0.00	0.00	0.00	0.00	3.48	0.00	0.00	3.48

Net from India(in MU)

-ve : Export / +ve : Import

Country	GNA (ISGS/PPA)	T-GNA							TOTAL
		BILATERAL TOTAL	COLLECTIVE						
			IDAM			RTM			
			IEX	PXIL	HPX	IEX	PXIL	HPX	
Bhutan	0.00	-0.31	-12.89	0.00	0.00	0.00	0.00	0.00	-13.20
Nepal	-0.38	0.00	0.00	0.00	0.00	2.99	0.00	0.00	2.61
Bangladesh	-18.59	0.00	0.00	0.00	0.00	0.00	0.00	0.00	-18.59
Myanmar	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total Net	-18.97	-0.31	-12.89	0.00	0.00	2.99	0.00	0.00	-29.18

15 Min (INSTANTANEOUS) ALL INDIA GRID FREQUENCY, GENERATION & DEMAND MET (SCADA DATA)												
TIME	FREQUENCY (Hz)	DEMAND MET (MW)	NUCLEAR (MW)	WIND (MW)	SOLAR (MW)	HYDRO** (MW)	GAS (MW)	THERMAL (MW)	OTHERS* (MW)	NET DEMAND (MW)	TOTAL GENERATION (MW)	NET TRANSNATIONAL EXCHANGE (MW)
		(A)	(B)	(C)	(D)	(E)	(F)	(G)	(H)	(I=A-(C+D))	(J=B+C+D+E+F+G+H)	(K)
0:00	50.02	154090	4877	3555	0	6850	1870	138391	3431	150535	158974	-1321
0:15	50.07	153943	4876	3516	0	7442	1851	137869	3454	150427	159008	-1530
0:30	49.97	153158	4878	3538	0	7391	1859	137039	3460	149620	158165	-1508
0:45	49.97	152770	4872	3488	0	7704	1830	136418	3468	149282	157780	-1527
1:00	50.02	151893	4871	3220	0	7826	1840	135766	3450	148673	156973	-1531
1:15	50.02	150815	4884	3141	0	7302	1860	135258	3414	147674	155859	-1420
1:30	50.02	150279	4891	2980	0	7213	1851	135018	3430	147299	155383	-1391
1:45	50.02	149556	4876	2888	0	7336	1859	134451	3412	146668	154822	-1380
2:00	50.07	147837	4888	2762	0	7294	1833	133187	3442	145075	153406	-1364
2:15	49.97	148440	4886	2644	0	7197	1865	133917	3462	145796	153971	-1421
2:30	50.02	148168	4886	2577	0	7297	1854	133621	3423	145591	153658	-1211
2:45	50.02	148335	4878	2445	0	7480	1855	133667	3463	145890	153788	-1210
3:00	50.02	148553	4872	2326	0	7007	1866	134289	3453	146227	153813	-1149
3:15	49.92	149288	4884	2188	0	7050	1854	135261	3417	147100	154654	-1159
3:30	49.97	148906	4876	2064	0	6967	1838	135061	3407	146842	154213	-1160
3:45	49.97	149709	4880	1973	0	7021	1839	136009	3388	147736	155110	-1212
4:00	50.02	149526	4880	1902	0	6878	1811	136181	3347	147624	154999	-1237
4:15	49.97	152607	4879	1859	0	7437	1831	138733	3369	150748	158108	-1242
4:30	50.02	153479	4880	1803	0	7901	1869	139065	3405	151676	158923	-1228
4:45	49.97	155158	4874	1793	0	7895	1838	140787	3432	153365	160619	-1249
5:00	50.02	156404	4891	1733	56	8125	1821	142048	3388	154615	162062	-1245
5:15	49.97	161252	4879	1795	63	8669	1868	145721	3415	159394	166410	-948
5:30	50.07	166521	4882	1809	25	9777	2218	149657	3508	164687	171876	-973
5:45	50.02	171335	4872	1894	149	11311	2604	152415	3462	169292	176707	-889
6:00	50.07	175064	4879	1929	151	13026	3014	153757	3474	172984	180230	-568
6:15	50.02	180398	4886	2070	190	14824	2873	156948	3458	178138	185249	-432
6:30	50.07	187398	4886	2190	215	18580	2961	159916	3528	184993	192276	-382
6:45	49.97	192554	4890	2366	301	21781	3622	161244	3479	189887	197683	-364
7:00	50.02	198000	4885	2487	795	24420	3837	162788	3541	194718	202753	-388
7:15	49.87	201621	4880	2570	1810	26048	3869	163683	3455	197241	206315	-461
7:30	49.82	205337	4877	2715	3612	27035	3974	164445	3495	199010	210153	-463
7:45	50.02	208068	4886	2791	7205	26118	4006	164246	3395	198072	212647	-504
8:00	50.02	211033	4876	2802	12331	23325	3994	164902	3398	195900	215628	-531
8:15	50.02	214222	4884	2854	18045	21447	3955	164026	3371	193323	218582	-555
8:30	49.97	217621	4891	2773	24893	19747	2114	163849	3469	189955	221736	-633
8:45	50.02	219089	4884	2551	31651	16541	1869	162180	3437	184887	223113	-634
9:00	50.07	220416	4894	2367	38646	13869	1799	158977	3465	179403	224017	-627
9:15	50.07	224872	4873	2396	44546	13577	1851	157791	3479	177930	228513	-747
9:30	50.02	225910	4877	2504	49934	11768	1803	155556	3411	173472	229853	-741
9:45	50.02	229081	4844	2705	53899	11378	1805	154531	3411	172477	232573	-872
10:00	50.02	228269	4862	3042	56209	10749	1792	151929	3402	169018	231985	-1296
10:15	50.02	225496	4870	3409	57314	8727	1782	150645	3409	164773	230156	-1845
10:30	49.97	226149	4866	3629	59782	7851	1761	148748	3421	162738	230058	-1879
10:45	49.97	225261	4851	3924	61867	7039	1766	146592	3387	159470	229426	-2028
11:00	50.02	224305	4857	4027	63715	6659	1811	143856	3477	156563	228402	-2050
11:15	49.92	221845	4863	3911	64631	6526	1789	140762	3410	153303	225892	-2148
11:30	49.92	223053	4850	4188	66753	6275	1785	139621	3422	152112	226894	-2123
11:45	49.92	222911	4858	3972	67412	6560	1744	138718	3440	151527	226704	-2177
12:00	49.92	221386	4862	3823	67956	6566	1788	136741	3356	149607	225092	-2153
12:15	49.92	219332	4839	3747	68110	5963	1772	135401	3418	147475	223250	-2131
12:30	49.97	218327	4847	3619	68464	5959	1782	134029	3361	146244	222061	-2111
12:45	50.03	216940	4842	3608	67887	6077	1774	133223	3398	145445	220809	-2088
13:00	50.03	214703	4847	3625	67287	6370	1782	131077	3460	143791	218448	-2140
13:15	49.98	211001	4859	3500	66789	6204	1746	128589	3359	140712	215046	-1985
13:30	49.98	210208	4845	3408	65876	6256	1761	128612	3348	140924	214106	-1862
13:45	49.98	209764	4855	3135	64360	6599	1781	129042	3441	142269	213213	-1800
14:00	50.03	209833	4852	3008	63470	6714	1755	130195	3373	143355	213367	-1860
14:15	49.93	209733	4832	2896	61403	6668	1791	132484	3357	145434	213431	-1793
14:30	49.88	210519	4838	2786	59074	6992	1842	135107	3330	148659	213969	-1768
14:45	49.98	211151	4840	2719	57204	7321	1924	137537	3420	151228	214965	-1747
15:00	50.03	212324	4826	2580	54882	7303	1952	141136	3443	154862	216122	-1721
15:15	50.03	211593	4842	2607	51030	7986	2015	143239	3395	157956	215114	-1584
15:30	50.03	212758	4830	2560	47431	8412	2409	147184	3409	162767	216235	-1565
15:45	50.03	213566	4832	2567	43912	8845	2738	150901	3439	167087	217234	-1663
16:00	50.13	213404	4833	2532	39245	9991	2915	154161	3421	171627	217098	-1553
16:15	50.03	210272	4833	2445	33520	10893	3322	155587	3441	174307	214041	-1310
16:30	50.03	210320	4827	2257	26771	13987	3547	158990	3434	181292	213813	-889
16:45	49.98	208799	4826	2280	20679	15873	4319	161202	3410	185840	212589	-762
17:00	49.98	208056	4819	2302	14005	20370	4574	162259	3389	191749	211718	-789
17:15	49.88	206470	4828	2437	8848	23835	4697	162111	3440	195185	210196	-793
17:30	49.83	206947	4830	2553	4708	27226	4929	163357	3440	199686	211043	-798
17:45	49.58	207474	4841	2673	2104	29297	5075	164176	3425	202697	211591	-799
18:00	49.78	207273	4826	2839	1075	29698	5071	164762	3415	203359	211686	-754
18:15	49.88	208194	4827	3203	778	30579	5147	164355	3495	204213	212384	-857
18:30	49.78	207487	4857	3412	284	30969	5125	163751	3405	203791	211803	-845
18:45	49.93	207320	4843	3604	145	30725	5099	163744	3436	203571	211596	-809
19:00	50.03	205449	4858	3817	140	29784	5119	162793	3448	201492	209959	-967
19:15	50.03	205413	4850	4101	114	29696	4948	162413	3421	201198	209543	-838
19:30	50.03	201627	4840	4231	0	26024	4699	162279	3466	197396	205539	-867
19:45	50.03	198336	4860	4185	0	24344	3747	161927	3484	194151	202547	-905
20:00	50.03	195881	4867	4212	0	21938	3628	161942	3489	191669	200076	-907
20:15	50.03	193093	4863	4292	0	19403	2633	162799	3517	188801	197507	-790
20:30	50.03	190433	4861	4190	0	17053	2578	162672	3471	186243	194825	-745
20:45	50.03	188030	4867	4300	0	14901	2538	162453	3484	183730	192543	-732
21:00	50.08	184562	4864	4476	0	13885	2514	159901	3494	180086	189134	-719
21:15	50.05	180822	4872	4505	0	12843	2469	157059	3483	176317	185231	-700
21:30	50.05	178076	4875	4676	0	12635	2341	154419	3522	173400	182468	-685
21:45	50.00	174288	4866	4696	0	11320	2215	152463	3574	169592	179134	-1176
22:00	50.10	170229	4865	4804	0	10041	2217	150186	3528	165425	175641	-1357
22:15	50.00	170100	4874	4832	0	9021	2172	150846	3525	165268	175270	-1354
22:30	50.00	167735	4860	4793	0	8881	2175	148830	3533	162942	173072	-1347
22:45	49.90	165732	4860	4								