



National Load Despatch Centre
राष्ट्रीय भार प्रेषण केंद्र
GRID CONTROLLER OF INDIA LIMITED
ग्रिड कंट्रोलर ऑफ इंडिया लिमिटेड

(Government of India Enterprise/ भारत सरकार का उद्यम)
B-9, QUTUB INSTITUTIONAL AREA, KATWARIA SARAI, NEW DELHI -110016
बी-9, कुतुब इन्स्टीट्यूशनल एरिया, कटवारिया सराये, न्यू दिल्ली-110016

Ref: GRID-INDIA/NLDC/SO/Daily PSP Report

दिनांक: 19.02.2025

To,

- कार्यकारी निदेशक, पू.क्षे.भा.प्रे.के., 14, गोल्फ क्लब रोड, कोलकाता - 700033
Executive Director, ERLDC, 14 Golf Club Road, Tollygunge, Kolkata, 700033
- कार्यकारी निदेशक, ऊ.क्षे.भा.प्रे.के., 18/ए, शाहीद जीत सिंह सनसनवाल मार्ग, नई दिल्ली - 110016
Executive Director, NRLDC, 18-A, Shaheed Jeet Singh Marg, Katwaria Sarai, New Delhi - 110016
- कार्यकारी निदेशक, प.क्षे.भा.प्रे.के., एफ3, एम आई डी सी क्षेत्र, अंधेरी, मुंबई - 400093
Executive Director, WRLDC, F-3, M.I.D.C. Area, Marol, Andheri (East), Mumbai-400093
- कार्यकारी निदेशक, ऊ.पू.क्षे.भा.प्रे.के., डोंगतेह, लोअर नोंग्रह, लापालंग, शिलोंग - 793006
Executive Director, NERLDC, Dongteih, Lower Nongrah, Lapalang, Shillong - 793006, Meghalaya
- कार्यकारी निदेशक, द.क्षे.भा.प्रे.के., 29, रेस कोर्स क्रॉस रोड, बंगलुरु - 560009
Executive Director, SRLDC, 29, Race Course Cross Road, Bangalore-560009

Sub: Daily PSP Report for the date 18.02.2025.

महोदय/Sir,

आईईजीसी-2023 की धारा स.-38(1) के प्रावधान के अनुसार, दिनांक 18-फ़रवरी-2025 की अखिल भारतीय प्रणाली की दैनिक ग्रिड निष्पादन रिपोर्ट रांभांप्रेके की वेबसाइट पर उपलब्ध है।

As per article 38(1) of the Indian Electricity Grid Code, the daily report pertaining power supply position of All India Power System for the date 18.02.2025, is available at the NLDC website.

धन्यवाद,
Thanks

Report for previous day

Date of Reporting: 19-Feb-2025

A. Power Supply Position at All India and Regional level

	NR	WR	SR	ER	NER	TOTAL
Demand Met during Evening Peak hrs(MW) (at 19:00 hrs; from RLDCs)	55835	69244	50592	23342	2682	201695
Peak Shortage (MW)	160	0	0	288	43	491
Energy Met (MU)	1245	1648	1353	492	50	4787
Hydro Gen (MU)	97	59	97	25	9	288
Wind Gen (MU)	17	67	34	-	-	118
Solar Gen (MU)*	173.87	121.10	148.02	3.28	0.90	447
Energy Shortage (MU)	0.21	0.12	0.00	0.99	0.27	1.59
Maximum Demand Met During the Day (MW) (From NLDC SCADA)	67007	79675	65856	24134	2735	236166
Time Of Maximum Demand Met	10:27	10:37	10:13	18:25	18:02	10:25

B. Frequency Profile (%)

Region	FVI	< 49.7	49.7 - 49.8	49.8 - 49.9	< 49.9	49.9 - 50.05	> 50.05
All India	0.042	0.00	0.73	6.12	6.85	72.72	20.43

C. Power Supply Position in States

Region	States	Max.Demand Met during the day (MW)	Shortage during maximum Demand (MW)	Energy Met (MU)	Drawal Schedule (MU)	OD(+)/UD(-) (MU)	Max OD (MW)	Energy Shortage (MU)
NR	Punjab	8876	0	160.1	79.2	-0.1	643	0.00
	Haryana	8514	0	162.9	102.8	-2.5	170	0.00
	Rajasthan	17934	0	352.2	114.6	-1.6	647	0.00
	Delhi	4124	0	72.9	60.6	-0.5	330	0.00
	UP	19335	0	349.4	103.2	-1.2	403	0.00
	Uttarakhand	2331	0	42.2	33.9	-0.8	117	0.00
	HP	2193	0	38.4	33.0	-0.7	93	0.00
	J&K(UT) & Ladakh(UT)	2883	0	59.6	60.6	-2.8	851	0.21
	Chandigarh	238	0	3.7	3.7	-0.1	33	0.00
WR	Railways_NR ISTS	194	0	4.0	4.0	0.1	26	0.00
	Chhattisgarh	5888	0	133.4	64.0	1.2	257	0.00
	Gujarat	23324	0	448.2	195.6	-5.0	658	0.00
	MP	17777	0	351.5	221.4	-3.3	503	0.12
	Maharashtra	29669	0	635.4	224.1	-0.6	803	0.00
	Goa	730	0	15.2	14.4	0.6	189	0.00
	DNHDDPDCL	1330	0	30.7	30.8	-0.1	31	0.00
	AMNSIL	754	0	16.0	9.7	-0.4	223	0.00
	BALCO	532	0	12.7	12.7	0.0	14	0.00
SR	RIL JAMNAGAR	194	0	4.5	4.5	0.0	0	0.00
	Andhra Pradesh	12623	0	240.9	66.7	0.1	488	0.00
	Telangana	15952	0	306.9	167.2	0.0	895	0.00
	Karnataka	17868	0	330.0	130.0	1.1	1058	0.00
	Kerala	4637	0	92.0	69.8	1.0	359	0.00
	Tamil Nadu	17987	0	373.8	217.2	1.4	801	0.00
	Puducherry	426	0	9.3	8.8	0.0	66	0.00
ER	Bihar	5108	0	100.8	87.3	1.5	161	0.00
	DVC	3306	0	70.1	-40.9	-0.2	342	0.00
	Jharkhand	2052	0	39.7	28.7	0.5	348	0.99
	Odisha	5265	0	105.4	35.1	-0.7	382	0.00
	West Bengal	8224	0	173.5	42.1	-1.5	145	0.00
	Sikkim	123	0	2.0	2.0	0.0	27	0.00
	Railways_ER ISTS	16	0	0.2	0.1	0.1	4	0.00
NER	Arunachal Pradesh	183	0	3.4	3.5	-0.2	10	0.00
	Assam	1554	0	28.8	22.6	0.5	114	0.00
	Manipur	201	0	3.4	3.1	0.3	49	0.27
	Meghalaya	335	0	5.7	4.6	-0.1	76	0.00
	Mizoram	144	0	2.2	1.9	-0.1	23	0.00
	Nagaland	151	0	2.5	2.5	0.0	26	0.00
	Tripura	209	0	4.1	3.8	0.1	33	0.00

D. Transnational Exchanges (MU) - Import(+ve)/Export(-ve)

	Bhutan	Nepal	Bangladesh	Godda -> Bangladesh
Actual (MU)	-7.7	-12.8	-23.3	-17.7
Day Peak (MW)	-700.0	-782.5	-1033.0	-764.0

E. Import/Export by Regions (in MU) - Import(+ve)/Export(-ve); OD(+)/UD(-)

	NR	WR	SR	ER	NER	TOTAL
Schedule(MU)	206.1	-261.5	228.9	-179.8	6.3	0.0
Actual(MU)	196.4	-259.5	236.1	-187.4	5.1	-9.3
O/D/U/D(MU)	-9.8	2.1	7.2	-7.7	-1.2	-9.3

F. Generation Outage(MW)

	NR	WR	SR	ER	NER	TOTAL	% Share
Central Sector	6465	7461	4378	2654	766	21724	45
State Sector	7988	9873	5552	3219	197	26828	55
Total	14453	17334	9930	5873	963	48553	100

G. Sourcewise generation (Gross) (MU)

	NR	WR	SR	ER	NER	All India	% Share
Coal	767	1715	757	742	15	3996	77
Lignite	26	10	46	0	0	82	2
Hydro	97	59	97	25	9	288	6
Nuclear	21	52	61	0	0	134	3
Gas, Naptha & Diesel	16	18	11	0	24	68	1
RES (Wind, Solar, Biomass & Others)	217	191	222	6	1	637	12
Total	1145	2045	1194	773	49	5206	100

Share of RES in total generation (%)	18.98	9.34	18.59	0.78	1.82	12.24
Share of Non-fossil fuel (Hydro,Nuclear and RES) in total generation(%)	29.30	14.78	31.87	4.05	20.70	20.36

H. All India Demand Diversity Factor

Based on Regional Max Demands	1.013
Based on State Max Demands	1.029

I. All India Peak Demand and shortage at Solar and Non-Solar Hour

	Max Demand Met(MW)	Time	Shortage(MW)
Solar hr	236166	10:25	13
Non-Solar hr	207385	18:56	47

Diversity factor = Sum of regional or state maximum demands / All India maximum demand

**Note: All generation MU figures are gross

***Godda (Jharkhand) -> Bangladesh power exchange is through the radial connection (isolated from Indian Grid)

Solar Hours -> 06:00 to 18:00hrs and rest are Non-Solar Hours

*Source: RLDCs for solar connected to ISTS; SLDCs for embedded solar. Limited visibility of embedded solar data.

Executive Director-NLDC

INTER-REGIONAL EXCHANGES

Import=(+ve) /Export =(-ve) for NET (MU)

Date of Reporting: 19-Feb-2025

Sl No	Voltage Level	Line Details	No. of Circuit	Max Import (MW)	Max Export (MW)	Import (MU)	Export (MU)	NET (MU)
Import/Export of ER (With NR)								
1	HVDC	ALIPURDUAR-AGRA	2	0	0	0.0	0.0	0.0
2	HVDC	PUSAULI B/B	-	0	47	0.0	1.1	-1.1
3	765 kV	GAYA-VARANASI	2	64	1061	0.0	16.0	-16.0
4	765 kV	SASARAM-FATEHPUR	1	0	667	0.0	11.9	-11.9
5	765 kV	GAYA-BALIA	1	0	590	0.0	8.4	-8.4
6	400 kV	PUSAULI-VARANASI	1	25	247	0.0	1.0	-1.0
7	400 kV	PUSAULI -ALLAHABAD	1	35	34	0.0	0.1	-0.1
8	400 kV	MUZAFFARPUR-GORAKHPUR	2	216	499	0.0	3.7	-3.7
9	400 kV	PATNA-BALIA	2	0	872	0.0	17.0	-17.0
10	400 kV	NAUBATPUR-BALIA	2	0	297	0.0	5.0	-5.0
11	400 kV	BIHARSHARIFF-BALIA	2	181	217	0.0	1.4	-1.4
12	400 kV	MOTIHARI-GORAKHPUR	2	0	458	0.0	7.3	-7.3
13	400 kV	BIHARSARIFF-SAHUPURI	2	130	413	0.0	5.7	-5.7
14	220 kV	SAHUPURI-KAMANASA	1	0	55	0.0	1.1	-1.1
15	132 kV	NAGAR UNTARI-RIHAND	1	0	0	0.1	0.0	0.1
16	132 kV	GARWAH-RIHAND	1	30	0	0.6	0.0	0.6
17	132 kV	KARMANASA-SAHUPURI	1	0	0	0.0	0.0	0.0
18	132 kV	KARMANASA-CHANDAULI	1	0	0	0.0	0.0	0.0
ER-NR						0.7	79.7	-79.0
Import/Export of ER (With WR)								
1	765 kV	JHARSUGUDA-DHARAMJAIGARH	4	440	459	1.7	0.0	1.7
2	765 kV	NEW RANCHI-DHARAMJAIGARH	2	302	1178	0.0	12.4	-12.4
3	765 kV	JHARSUGUDA-DURG	2	0	1201	0.0	24.0	-24.0
4	400 kV	JHARSUGUDA-RAIGARH	4	0	662	0.0	10.5	-10.5
5	400 kV	RANCHI-SIPAT	2	30	323	0.0	4.0	-4.0
6	220 kV	BUDHIPADAR-RAIGARH	1	0	138	0.0	1.7	-1.7
7	220 kV	BUDHIPADAR-KORBA	2	98	67	0.7	0.0	0.7
ER-WR						2.4	52.6	-50.2
Import/Export of ER (With SR)								
1	HVDC	JEYPORE-GAZUWAKA B/B	2	0	370	0.0	8.7	-8.7
2	HVDC	TALCHER-KOLAR BIPOLE	2	0	1649	0.0	39.8	-39.8
3	765 kV	ANGUL-SRIKAKULAM	2	0	2952	0.0	53.6	-53.6
4	400 kV	TALCHER-I/C	2	0	388	0.0	7.5	-7.5
5	220 kV	BALIMELA-UPPER-SILERRU	1	0	0	0.0	0.0	0.0
ER-SR						0.0	102.0	-102.0
Import/Export of ER (With NER)								
1	400 kV	BINAGURI-BONGAIGAON	2	321	53	3.0	0.1	2.9
2	400 kV	ALIPURDUAR-BONGAIGAON	2	546	0	5.5	0.0	5.5
3	220 kV	ALIPURDUAR-SALAKATI	2	112	0	1.8	0.0	1.8
ER-NER						10.3	0.1	10.2
Import/Export of NER (With NR)								
1	HVDC	BISWANATH CHARIALI-AGRA	2	662	0	15.7	0.0	15.7
NER-NR						15.7	0.0	15.7
Import/Export of WR (With NR)								
1	HVDC	CHAMPA-KURUKSHETRA	2	0	3025	0.0	73.2	-73.2
2	HVDC	VINDHYACHAL B/B	-	537	0	6.1	0.0	6.1
3	HVDC	MUNDRA-MOHINDERGARH	2	0	1453	0.0	36.3	-36.3
4	765 kV	GWALIOR-AGRA	2	351	1690	0.5	12.9	-12.4
5	765 kV	GWALIOR-PHAGI	2	292	1651	0.4	21.3	-20.8
6	765 kV	JABALPUR-ORAI	2	44	900	0.0	16.0	-16.0
7	765 kV	GWALIOR-ORAI	1	783	0	14.7	0.0	14.7
8	765 kV	SATNA-ORAI	1	0	1023	0.0	18.6	-18.6
9	765 kV	BANASKANTHA-CHITORGARH	2	1454	0	16.6	0.0	16.6
10	765 kV	VINDHYACHAL-VARANASI	2	0	1932	0.0	21.8	-21.8
11	400 kV	ZERDA-KANKROLI	1	258	0	3.3	0.0	3.3
12	400 kV	ZERDA -BHINMAL	1	178	0	2.3	0.0	2.3
13	400 kV	VINDHYACHAL -RIHAND	1	492	0	10.6	0.0	10.6
14	400 kV	RAPP-SHUJALPUR	2	528	270	4.4	0.7	3.7
15	400 kV	NEEMUCH-Chittorgarh	2	667	259	5.7	0.6	5.0
16	220 kV	BHANPURA-RANPUR	1	0	154	0.0	3.3	-3.3
17	220 kV	BHANPURA-MORAK	1	0	30	0.0	2.2	-2.2
18	220 kV	MEHGAON-AURAIYA	1	134	0	2.0	0.0	2.0
19	220 kV	MALANPUR-AURAIYA	1	104	0	1.3	0.0	1.3
20	132 kV	GWALIOR-SAWAI MADHOPUR	1	0	0	0.0	0.0	0.0
21	132 kV	RAJGHAT-LALITPUR	2	0	0	0.0	0.0	0.0
WR-NR						67.9	206.8	-138.9
Import/Export of WR (With SR)								
1	HVDC	BHADRAWATI B/B	-	0	1013	0.0	24.0	-24.0
2	HVDC	RAIGARH-PUGALUR	2	0	4008	0.0	80.7	-80.7
3	765 kV	SOLAPUR-RAICHUR	2	960	1530	3.5	10.5	-7.0
4	765 kV	WARDHA-NIZAMABAD	2	0	2772	0.0	39.3	-39.3
5	765 kV	WARORA-WARANGAL(NEW)	2	0	2777	0.0	42.5	-42.5
6	400 kV	KOLHAPUR-KUDGI	2	1505	0	21.2	0.0	21.2
7	220 kV	KOLHAPUR-CHIKODI	2	0	0	0.0	0.0	0.0
8	220 kV	PONDA-AMBEWADI	1	0	81	0.0	0.5	-0.5
9	220 kV	XELDEM-AMBEWADI	1	0	120	2.2	0.0	2.2
WR-SR						26.9	197.5	-170.6

INTERNATIONAL EXCHANGES							Import(+ve)/Export(-ve)
State	Region	Line Name	Max (MW)	Min (MW)	Avg (MW)	Energy Exchange (MU)	
BHUTAN	ER	400kV MANGDECHHU-ALIPURDUAR 1,2&3 I.e. ALIPURDUAR RECEIPT (from MANGDECHU HEP 4*180MW)	427	-29	158	3.79	
	ER	400kV TALA-BINAGURI 1,2,4 (& 400kV MALBASE - BINAGURI) I.e. BINAGURI RECEIPT (from TALA HEP 6*170MW)	-309	122	-130	-3.12	
	ER	220kV CHUKHA-BIRPARA 1&2 (& 220kV MALBASE - BIRPARA) I.e. BIRPARA RECEIPT (from CHUKHA HEP 4*84MW)	-421	-223	-341	-8.17	
	NER	132kV GELEPHU-SALAKATI	-20	3	-7	-0.17	
	NER	132kV MOTANGA-RANGIA	-13	3	-3	-0.07	
NEPAL	NR	NEPAL IMPORT (FROM UP)	0	0	0	-1.04	
	NR	132kV MAHENDRANAGAR-TANAKPUR(NHPC)	0	0	0	-1.08	
	ER	NEPAL IMPORT (FROM BIHAR)	-213	-17	-155	-3.72	
	ER	400kV DHALKEBAR-MUZAFFARPUR 1&2	-504	7	-291	-6.98	
BANGLADESH	ER	BHERAMARA B/B HVDC (B'DESH)	-951	-759	-901	-21.63	
	ER (Isolated from Indian Grid)	400kV GODDA_TPS-RAHANPUR (B'DESH) D/C	-764	-602	-737	-17.69	
	NER	132kV COMILLA-SURAJMANI NAGAR 1&2	-82	0	-69	-1.65	

Export From India (in MU)

Country	GNA (ISGS/PPA)	T-GNA							TOTAL
		BILATERAL TOTAL	COLLECTIVE						
			IDAM			RTM			
			IEX	PXIL	HPX	IEX	PXIL	HPX	
Bhutan	0.00	0.35	9.33	0.00	0.00	0.19	0.00	0.00	9.87
Nepal	3.76	0.00	4.98	0.00	0.00	2.45	0.00	0.00	11.19
Bangladesh	22.37	0.00	0.00	0.00	0.00	0.00	0.00	0.00	22.37
Myanmar	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total Export	26.13	0.35	14.31	0.00	0.00	2.64	0.00	0.00	43.43

Import by India(in MU)

Country	GNA (ISGA/PPA)	T-GNA							TOTAL
		BILATERAL TOTAL	COLLECTIVE						
			IDAM			RTM			
			IEX	PXIL	HPX	IEX	PXIL	HPX	
Bhutan	1.42	0.00	0.00	0.00	0.00	0.00	0.00	0.00	1.42
Nepal	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Bangladesh	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Myanmar	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total Import	1.42	0.00	0.00	0.00	0.00	0.00	0.00	0.00	1.42

Net from India(in MU)

-ve : Export / +ve : Import

Country	GNA (ISGS/PPA)	T-GNA							TOTAL
		BILATERAL TOTAL	COLLECTIVE						
			IDAM			RTM			
			IEX	PXIL	HPX	IEX	PXIL	HPX	
Bhutan	1.42	-0.35	-9.33	0.00	0.00	-0.19	0.00	0.00	-8.45
Nepal	-3.76	0.00	-4.98	0.00	0.00	-2.45	0.00	0.00	-11.19
Bangladesh	-22.37	0.00	0.00	0.00	0.00	0.00	0.00	0.00	-22.37
Myanmar	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total Net	-24.71	-0.35	-14.31	0.00	0.00	-2.64	0.00	0.00	-42.01

Date of Reporting: 19-Feb-2025												
15 Min (INSTANTANEOUS) ALL INDIA GRID FREQUENCY, GENERATION & DEMAND MET (SCADA DATA)												
TIME	FREQUENCY (Hz)	DEMAND MET (MW)	NUCLEAR (MW)	WIND (MW)	SOLAR (MW)	HYDRO** (MW)	GAS (MW)	THERMAL (MW)	OTHERS* (MW)	NET DEMAND MET (MW)	TOTAL GENERATION (MW)	NET TRANSNATIONAL EXCHANGE (MW)
		(A)	(B)	(C)	(D)	(E)	(F)	(G)	(H)	(I=A-(C+D))	(J=B+C+D+E+F+G+H)	(K) (+ve) Import, (-ve) Export
0:00	50.02	172821	5211	6521	994	7803	2406	152269	3129	165306	178333	-1942
0:15	49.92	173527	5222	6441	997	7496	2293	153307	3145	166089	178901	-1830
0:30	49.97	173412	5244	6176	998	7953	2314	153188	3129	166238	179002	-1824
0:45	49.81	172628	5220	5944	1001	8036	2314	152399	3127	165683	178041	-1776
1:00	49.91	171827	5210	5669	1005	7991	2316	152050	3167	165153	177408	-1774
1:15	49.96	171386	5235	5493	1014	7538	2312	151973	3197	164879	176762	-1661
1:30	50.01	170676	5236	5504	1019	7318	2260	151504	3157	164153	175998	-1607
1:45	49.96	170148	5228	5179	1016	6927	2255	151706	3149	163953	175460	-1605
2:00	50.01	168987	5218	4967	1017	6660	2249	151154	3123	163003	174388	-1589
2:15	50.01	168514	5217	4846	1009	6282	2249	151094	3111	162659	173808	-1548
2:30	50.01	167815	5216	4586	1007	6357	2221	150750	3104	162222	173241	-1546
2:45	49.96	167763	5225	4423	1039	6115	2239	150928	3189	162301	173158	-1548
3:00	49.96	167032	5211	4247	1040	6027	2264	150579	3137	161745	172505	-1528
3:15	49.91	166926	5224	4154	1047	5870	2240	150708	3141	161725	172384	-1548
3:30	49.96	166717	5220	4099	1047	6142	2243	150329	3112	161571	172192	-1477
3:45	49.97	167021	5224	3992	1042	6157	2230	150552	3086	161987	172283	-1306
4:00	50.02	167284	5237	3930	1038	6250	2250	150736	3110	162316	172551	-1333
4:15	49.96	169351	5213	3768	1035	6434	2216	152775	3129	164548	174570	-1364
4:30	50.01	170748	5213	3762	1038	6414	2190	154403	3129	165948	176149	-1380
4:45	50.01	172265	5223	4019	1038	6407	2190	155658	3130	167208	177665	-1389
5:00	50.06	174003	5251	4111	1039	6413	2158	157090	3132	168853	179194	-1438
5:15	50.01	177729	5284	4199	1040	6691	2211	160606	3152	172490	183183	-1546
5:30	50.06	180575	5293	4084	1037	7302	2215	162956	3147	175454	186034	-1527
5:45	50.01	184106	5299	4217	1032	7804	2311	165799	3165	178857	189627	-1674
6:00	50.06	187051	5310	4125	1026	9055	2344	167410	3174	181900	192444	-1599
6:15	49.96	191402	5318	4175	1245	11170	2748	169202	3191	185982	197049	-1653
6:30	49.96	197406	5298	4225	1231	14577	3157	171493	3162	191950	203143	-1532
6:45	50.07	202936	5319	4338	1274	18968	3835	171643	3198	197324	208575	-1490
7:00	50.02	206358	5340	4578	1651	21008	4074	171435	3309	200129	211395	-1298
7:15	49.91	209588	5366	4821	2549	22203	4355	171987	3245	202218	214526	-1297
7:30	50.02	212488	5400	5051	4455	22465	4535	172096	3220	202982	217222	-1208
7:45	50.07	214409	5393	5212	7332	22393	4537	170736	3223	201865	218826	-1127
8:00	50.12	214280	5414	5027	10808	21274	4079	168608	3316	198445	218526	-1132
8:15	50.07	218602	5386	4713	15281	21387	4013	168585	3409	198608	222774	-1419
8:30	50.07	219353	5425	4287	19901	18858	3991	167436	3377	195165	223275	-1550
8:45	50.12	221535	5401	3942	25430	17021	3984	165785	3423	192163	224986	-1585
9:00	50.07	224002	5408	3637	29465	16187	4009	165622	3438	190900	227766	-1674
9:15	49.97	229219	5426	3143	33498	15953	4060	167447	3458	192578	232985	-1729
9:30	50.02	231105	5439	2689	37252	14823	4026	167585	3513	191164	235327	-1603
9:45	50.02	233333	5416	2355	41619	13018	3919	167125	3466	189359	236918	-1604
10:00	50.02	233378	5431	2180	43983	12455	2981	166676	3492	187215	237198	-1593
10:15	50.02	235215	5434	2268	48150	10531	2819	166847	3467	184797	239516	-1618
10:30	50.02	236106	5448	2309	50871	10851	2815	164414	3391	182926	240099	-1988
10:45	49.97	235247	5451	2467	53009	10034	2713	162227	3430	179771	239331	-2185
11:00	50.07	234674	5424	2571	55128	9156	2627	160545	3405	176975	238856	-2148
11:15	50.07	233844	5419	2750	57759	8870	2587	157832	3440	173335	238657	-2279
11:30	50.07	232388	5433	2979	58541	8190	2555	156049	3426	170868	237173	-2284
11:45	50.02	231276	5450	3204	58962	8222	2517	153154	3453	169110	234962	-2293
12:00	50.12	229263	5404	3209	60534	8177	2459	150371	3420	165520	233574	-2313
12:15	49.97	228041	5433	3435	59812	7805	2349	149802	3454	164794	232090	-2255
12:30	50.07	227627	5419	3646	60568	7882	2330	148464	3439	163413	231748	-2263
12:45	50.07	226610	5440	3653	61227	7749	2359	146806	3462	161730	230696	-2263
13:00	50.12	223199	5433	3895	60588	7821	2352	143545	3396	158716	227030	-2300
13:15	50.07	219632	5240	3961	60699	7314	2377	140266	3292	154972	223149	-2316
13:30	50.07	218852	5257	4269	60491	6988	2368	139804	3371	154092	222548	-2318
13:45	50.07	218322	5259	4458	59613	7162	2355	139877	3442	154251	222166	-2329
14:00	50.07	218419	5267	4361	58899	7337	2336	140389	3417	155159	222006	-2343
14:15	49.97	218163	5278	4344	57825	7479	2341	141588	3430	155994	222285	-2395
14:30	49.97	219380	5270	4346	56251	7956	2368	143558	3366	158783	223115	-2398
14:45	49.97	219192	5283	4361	54099	8320	2364	145732	3379	160732	223538	-2415
15:00	49.97	219495	5300	4262	51825	8623	2344	147989	3361	163408	223704	-2403
15:15	50.02	218600	5292	4104	49478	8812	2355	149496	3299	165018	222836	-2425
15:30	50.02	217568	5300	3826	45936	9215	2420	152118	3321	167806	222136	-2383
15:45	50.02	218060	5319	3733	43741	10099	2501	153730	3282	170586	222405	-2430
16:00	50.02	216350	5296	3475	40170	10046	2540	156515	3281	172705	221323	-2378
16:15	50.02	213348	5335	3417	36524	9782	2499	158025	3246	173407	218828	-2390
16:30	49.92	213105	5325	3337	32816	10510	2518	160478	3189	176952	218173	-2294
16:45	49.97	214228	5336	3337	28375	12211	2508	163959	3208	182516	218934	-1865
17:00	49.97	212232	5366	3379	23850	13419	2503	165025	3220	185003	216762	-1639
17:15	50.02	209517	5391	3228	18873	14747	2547	166458	3204	187416	214448	-1147
17:30	50.02	208401	5384	3150	13935	17485	2566	166952	3265	191316	212737	-1095
17:45	50.02	207014	5414	3134	9189	20176	2615	167805	3224	194691	211557	-1104
18:00	50.02	205448	5433	3074	5419	21550	2665	168592	3250	196955	209983	-1028
18:15	49.92	202984	5451	3213	2860	21875	2697	169418	3122	196911	208636	-1026
18:30	49.87	204948	5467	3379	1427	22665	2856	171567	3114	200142	210475	-954
18:45	49.87	206948	5477	3555	962	23525	2923	171852	3142	202431	211436	-964
19:00	49.97	207143	5480	3874	956	23200	2853	171853	3171	202313	211387	-946
19:15	50.02	206663	5497	4136	883	22217	2865	172229	3160	201644	210987	-968
19:30	50.02	205269	5489	4542	893	20880	2864	171366	3155	199834	209189	-933
19:45	50.07	202287	5489	4856	710	19835	2799	169690	3171	196721	206550	-949
20:00	50.02	198241	5458	5010	677	17881	2661	167504	3184	192554	202375	-984
20:15	49.97	194795	5444	5285	391	14784	2631	167027	3290	189119	198852	-1115
20:30	50.02	192549	5430	5587	375	13174	2589	166230	3242	186587	196627	-1081
20:45	50.02	190889	5425	5946	406	11372	2552	166042	3341	184537	195084	-1114
21:00	50.07	187624	5424	6127	412	11193	2561	163082	3270	181085	192069	-1354
21:15	50.02	186238	5396	6103	410	11153	2552	162167	3289	179725	191070	-1851
21:30	50.07	184884	5399	6104	426	10663	2582	161143	3243	178354	189560	-1912
21:45	50.02	183856	5412	5970	401	10313	2428	161066	3259	177485	188849	-2133
22:00	50.07	181384	5428	5826	356	9763	2404	159286	3254	175202	186317	-2162
22:15	49.97	182694	5419	5788	357	10451	2418	160148	3270	176549	187851	-2193
22:30	49.97</											