



National Load Despatch Centre
राष्ट्रीय भार प्रेषण केंद्र
GRID CONTROLLER OF INDIA LIMITED
ग्रिड कंट्रोलर ऑफ इंडिया लिमिटेड
(Government of India Enterprise/ भारत सरकार का उद्यम)
B-9, QUTUB INSTITUTIONAL AREA, KATWARIA SARAI, NEW DELHI -110016
बी-9, कुतुब इन्स्टीट्यूशनल एरिया, कटवारिया सराये, न्यू दिल्ली-110016

Ref: POSOCO/NLDC/SO/Daily PSP Report

दिनांक: 19.09.2024

To,

- कार्यकारी निदेशक, पू.क्षे.भा.प्रे.के., 14, गोल्फ क्लब रोड, कोलकाता - 700033
Executive Director, ERLDC, 14 Golf Club Road, Tollygunge, Kolkata, 700033
- कार्यकारी निदेशक, ऊ.क्षे.भा.प्रे.के., 18/ए, शाहीद जीत सिंह सनसनवाल मार्ग, नई दिल्ली - 110016
Executive Director, NRLDC, 18-A, Shaheed Jeet Singh Marg, Katwaria Sarai, New Delhi - 110016
- कार्यकारी निदेशक, प.क्षे.भा.प्रे.के., एफ3, एम आई डी सी क्षेत्र, अंधेरी, मुंबई - 400093
Executive Director, WRLDC, F-3, M.I.D.C. Area, Marol, Andheri (East), Mumbai-400093
- कार्यकारी निदेशक, ऊ.पू.क्षे.भा.प्रे.के., डोंगतेह, लोअर नोंग्रह, लापालंग, शिलोंग - 793006
Executive Director, NERLDC, Dongteih, Lower Nongrah, Lapalang, Shillong - 793006, Meghalaya
- कार्यकारी निदेशक, द.क्षे.भा.प्रे.के., 29, रेस कोर्स क्रॉस रोड, बंगलुरु - 560009
Executive Director, SRLDC, 29, Race Course Cross Road, Bangalore-560009

Sub: Daily PSP Report for the date 18.09.2024.

महोदय/Dear Sir,

आईईजीसी-2023 की धारा स.-5.5.1 के प्रावधान के अनुसार, दिनांक 18-सितंबर-2024 की अखिल भारतीय प्रणाली की दैनिक ग्रिड निष्पादन रिपोर्ट रांभांप्रेके की वेबसाइट पर उपलब्ध है।

As per article 5.5.1 of the Indian Electricity Grid Code, the daily report pertaining power supply position of All India Power System for the date 18.09.2024, is available at the NLDC website.

धन्यवाद,
Thanks

Report for previous day

Date of Reporting: 19-Sep-2024

A. Power Supply Position at All India and Regional level

	NR	WR	SR	ER	NER	TOTAL
Demand Met during Evening Peak hrs(MW) (at 20:00 hrs; from RLDCs)	61801	59061	50733	27006	3668	202269
Peak Shortage (MW)	623	94	0	587	33	1337
Energy Met (MU)	1440	1363	1312	561	75	4751
Hydro Gen (MU)	338	120	176	94	28	755
Wind Gen (MU)	11	68	147	-	-	226
Solar Gen (MU)*	160.35	86.15	141.67	3.22	1.13	393
Energy Shortage (MU)	3.49	3.80	0.24	2.09	0.12	9.74
Maximum Demand Met During the Day (MW) (From NLDC SCADA)	64983	61388	62899	27405	3853	213926
Time Of Maximum Demand Met	11:50	16:48	10:56	22:29	18:18	10:56

B. Frequency Profile (%)

Region	FVI	< 49.7	49.7 - 49.8	49.8 - 49.9	< 49.9	49.9 - 50.05	> 50.05
All India	0.093	2.44	2.63	10.61	15.68	78.12	6.20

C. Power Supply Position in States

Region	States	Max.Demand Met during the day (MW)	Shortage during maximum Demand (MW)	Energy Met (MU)	Drawal Schedule (MU)	OD(+)/UD(-) (MU)	Max OD (MW)	Energy Shortage (MU)
NR	Punjab	14800	0	296.8	161.0	-0.3	940	0.00
	Haryana	9703	0	209.7	153.4	-2.3	254	0.01
	Rajasthan	13715	0	300.5	92.3	1.2	816	1.96
	Delhi	5170	0	107.8	105.4	-0.1	246	0.00
	UP	19806	0	377.9	160.8	0.3	454	0.69
	Uttarakhand	2090	0	45.4	19.0	0.4	154	0.00
	HP	1768	0	37.0	5.1	-0.4	121	0.00
	J&K(UT) & Ladakh(UT)	2691	0	55.5	34.2	3.4	380	0.83
	Chandigarh	292	0	6.0	6.0	0.0	45	0.00
WR	Railways_NR ISTS	201	0	4.0	3.9	0.1	54	0.00
	Chhattisgarh	5025	89	109.8	53.5	0.1	347	0.42
	Gujarat	21437	0	444.0	189.6	-0.9	1156	0.00
	MP	10344	0	199.6	65.0	-0.6	613	0.00
	Maharashtra	25883	2079	535.2	166.8	3.4	1374	3.38
	Goa	673	0	14.0	11.4	2.3	59	0.00
	DNHDDPDCL	1328	0	30.1	29.9	0.2	48	0.00
	AMNSIL	802	0	17.6	7.4	0.9	281	0.00
	BALCO	527	0	12.6	12.7	-0.1	518	0.00
SR	Andhra Pradesh	12710	0	245.0	92.2	-0.6	419	0.00
	Telangana	14856	0	296.5	153.8	0.1	958	0.00
	Karnataka	15288	0	269.1	109.8	0.1	927	0.00
	Kerala	4158	0	84.8	52.0	0.5	478	0.24
	Tamil Nadu	18576	0	406.1	179.4	1.0	929	0.00
	Puducherry	519	0	11.0	10.4	-0.1	43	0.00
ER	Bihar	7309	277	138.3	128.8	-2.3	317	1.53
	DVC	3326	0	66.7	-45.8	-1.7	270	0.00
	Jharkhand	2043	0	38.3	29.2	-0.9	198	0.56
	Odisha	6167	0	121.2	24.4	-2.1	338	0.00
	West Bengal	9894	0	195.0	68.8	-1.2	870	0.00
	Sikkim	84	0	1.3	1.5	-0.2	9	0.00
	Railways_ER ISTS	21	0	0.1	0.1	-0.1	3	0.00
NER	Arunachal Pradesh	182	0	4.6	3.1	1.1	26	0.00
	Assam	2607	0	51.3	42.0	1.7	218	0.04
	Manipur	217	0	2.0	2.9	-1.0	31	0.08
	Meghalaya	260	0	4.5	1.8	-0.2	115	0.00
	Mizoram	122	0	2.3	0.6	-0.2	12	0.00
	Nagaland	171	0	3.5	2.8	0.3	13	0.00
	Tripura	330	0	6.5	6.0	0.4	66	0.00

D. Transnational Exchanges (MU) - Import(+ve)/Export(-ve)

	Bhutan	Nepal	Bangladesh	Godda -> Bangladesh
Actual (MU)	39.2	19.0	-22.8	-24.9
Day Peak (MW)	1953.0	919.1	-1007.0	-1137.0

E. Import/Export by Regions (in MU) - Import(+ve)/Export(-ve); OD(+)/UD(-)

	NR	WR	SR	ER	NER	TOTAL
Schedule(MU)	218.3	-231.7	155.8	-154.1	11.6	0.0
Actual(MU)	213.6	-220.9	153.9	-163.6	11.7	-5.3
O/D/U/D(MU)	-4.7	10.8	-2.0	-9.5	0.1	-5.3

F. Generation Outage(MW)

	NR	WR	SR	ER	NER	TOTAL	% Share
Central Sector	4449	18374	3648	5036	280	31787	51
State Sector	7086	10894	9952	2429	176	30536	49
Total	11535	29268	13600	7465	456	62323	100

G. Sourcewise generation (Gross) (MU)

	NR	WR	SR	ER	NER	All India	% Share
Coal	743	1318	603	681	16	3362	66
Lignite	23	16	65	0	0	104	2
Hydro	338	120	176	94	28	755	15
Nuclear	30	53	71	0	0	154	3
Gas, Naptha & Diesel	2	38	5	0	23	67	1
RES (Wind, Solar, Biomass & Others)	177	157	317	6	1	657	13
Total	1312	1702	1236	780	68	5099	100
Share of RES in total generation (%)	13.45	9.23	25.62	0.72	1.65	12.89	
Share of Non-fossil fuel (Hydro,Nuclear and RES) in total generation(%)	41.45	19.41	45.57	12.74	42.88	30.72	

H. All India Demand Diversity Factor

Based on Regional Max Demands	1.030
Based on State Max Demands	1.098

I. All India Peak Demand and shortage at Solar and Non-Solar Hour

	Max Demand Met(MW)	Time	Shortage(MW)
Solar hr	213926	10:56	0
Non-Solar hr	203976	19:43	3652

Diversity factor = Sum of regional or state maximum demands / All India maximum demand

**Note: All generation MU figures are gross

***Godda (Jharkhand) -> Bangladesh power exchange is through the radial connection (isolated from Indian Grid)

Solar Hours -> 06:00 to 18:00hrs and rest are Non-Solar Hours

*Source: RLDCs for solar connected to ISTS; SLDCs for embedded solar. Limited visibility of embedded solar data.

Executive Director-NLDC

INTER-REGIONAL EXCHANGES

Import=(+ve) /Export =(-ve) for NET (MU)

Date of Reporting: 19-Sep-2024

Sl No	Voltage Level	Line Details	No. of Circuit	Max Import (MW)	Max Export (MW)	Import (MU)	Export (MU)	NET (MU)
Import/Export of ER (With NR)								
1	HVDC	ALIPURDUAR-AGRA	2	0	351	0.0	8.4	-8.4
2	HVDC	PUSAULI B/B	-	0	112	0.0	2.8	-2.8
3	765 kV	GAYA-VARANASI	2	139	927	0.0	9.6	-9.6
4	765 kV	SASARAM-FATEHPUR	1	0	404	0.0	4.6	-4.6
5	765 kV	GAYA-BALIA	1	0	583	0.0	9.2	-9.2
6	400 kV	PUSAULI-VARANASI	1	0	155	0.0	2.9	-2.9
7	400 kV	PUSAULI -ALLAHABAD	1	40	30	0.2	0.0	0.2
8	400 kV	MUZAFFARPUR-GORAKHPUR	2	0	608	0.0	8.7	-8.7
9	400 kV	PATNA-BALIA	2	0	649	0.0	10.8	-10.8
10	400 kV	NAUBATPUR-BALIA	2	0	228	0.0	3.0	-3.0
11	400 kV	BIHARSHARIFF-BALIA	2	112	133	0.0	0.7	-0.7
12	400 kV	MOTIHARI-GORAKHPUR	2	0	349	0.0	5.5	-5.5
13	400 kV	BIHARSHARIFF-VARANASI	2	0	0	0.0	0.0	0.0
14	220 kV	SAHUPURI-KARAMNASA	1	0	66	0.0	0.8	-0.8
15	132 kV	NAGAR UNTARI-RIHAND	1	0	0	0.0	0.0	0.0
16	132 kV	GARWAH-RIHAND	1	30	0	0.4	0.0	0.4
17	132 kV	KARMANASA-SAHUPURI	1	0	0	0.0	0.0	0.0
18	132 kV	KARMANASA-CHANDAULI	1	0	0	0.0	0.0	0.0
ER-NR						0.6	66.8	-66.3
Import/Export of ER (With WR)								
1	765 kV	JHARSUGUDA-DHARAMJAIGARH	4	0	1029	0.0	14.6	-14.6
2	765 kV	NEW RANCHI-DHARAMJAIGARH	2	1214	659	7.7	0.0	7.7
3	765 kV	JHARSUGUDA-DURG	2	0	634	0.0	11.6	-11.6
4	400 kV	JHARSUGUDA-RAIGARH	4	0	583	0.0	9.0	-9.0
5	400 kV	RANCHI-SIPAT	2	190	294	0.0	0.7	-0.7
6	220 kV	BUDHIPADAR-RAIGARH	1	0	167	0.0	2.9	-2.9
7	220 kV	BUDHIPADAR-KORBA	2	23	134	0.0	1.5	-1.5
ER-WR						7.7	40.4	-32.6
Import/Export of ER (With SR)								
1	HVDC	JEYPORE-GAZUWAKA B/B	2	0	729	0.0	17.4	-17.4
2	HVDC	TALCHER-KOLAR BIPOLE	2	0	0	0.0	0.0	0.0
3	765 kV	ANGUL-SRIKAKULAM	2	0	2914	0.0	54.4	-54.4
4	400 kV	TALCHER-I/C	2	1872	0	40.2	0.0	40.2
5	220 kV	BALIMELA-UPPER-SILERRU	1	0	0	0.0	0.0	0.0
ER-SR						0.0	71.9	-71.9
Import/Export of ER (With NER)								
1	400 kV	BINAGURI-BONGAIGAON	2	0	616	0.0	9.9	-9.9
2	400 kV	ALIPURDUAR-BONGAIGAON	2	0	993	0.0	16.9	-16.9
3	220 kV	ALIPURDUAR-SALAKATI	2	0	194	0.0	3.5	-3.5
ER-NER						0.0	30.3	-30.3
Import/Export of NER (With NR)								
1	HVDC	BISWANATH CHARIALI-AGRA	2	0	852	0.0	20.4	-20.4
NER-NR						0.0	20.4	-20.4
Import/Export of WR (With NR)								
1	HVDC	CHAMPA-KURUKSHETRA	2	0	2016	0.0	35.2	-35.2
2	HVDC	VINDHYACHAL B/B	-	0	201	0.0	3.0	-3.0
3	HVDC	MUNDRA-MOHINDERGARH	2	0	978	0.0	24.2	-24.2
4	765 kV	GWALIOR-AGRA	2	0	1206	0.1	14.3	-14.2
5	765 kV	GWALIOR-PHAGI	2	516	1739	1.3	22.9	-21.6
6	765 kV	JABALPUR-ORAI	2	0	919	0.0	23.2	-23.2
7	765 kV	GWALIOR-ORAI	1	596	48	7.8	0.0	7.8
8	765 kV	SATNA-ORAI	1	0	826	0.0	14.3	-14.3
9	765 kV	BANASKANTHA-CHITORGARH	2	2117	0	29.5	0.0	29.5
10	765 kV	VINDHYACHAL-VARANASI	2	203	2183	0.0	25.7	-25.7
11	400 kV	ZERDA-KANKROLI	1	427	0	5.3	0.0	5.3
12	400 kV	ZERDA -BHINMAL	1	461	112	0.3	0.9	-0.7
13	400 kV	VINDHYACHAL -RIHAND	1	0	1	0.0	0.0	0.0
14	400 kV	RAPP-SHUJALPUR	2	405	489	2.1	4.0	-1.8
15	400 kV	NEEMUCH-Chittorgarh	2	273	571	1.1	5.4	-4.3
16	220 kV	BHANPURA-RANPUR	1	0	72	0.0	0.9	-0.9
17	220 kV	BHANPURA-MORAK	1	0	30	0.0	1.7	-1.7
18	220 kV	MEHGAON-AURAIYA	1	49	18	0.2	0.1	0.2
19	220 kV	MALANPUR-AURAIYA	1	43	26	0.2	0.0	0.2
20	132 kV	GWALIOR-SAWAI MADHOPUR	1	0	0	0.0	0.0	0.0
21	132 kV	RAJGHAT-LALITPUR	2	0	0	0.0	0.0	0.0
WR-NR						47.9	175.9	-128.0
Import/Export of WR (With SR)								
1	HVDC	BHADRAWATI B/B	-	0	1003	0.0	21.3	-21.3
2	HVDC	RAIGARH-PUGALUR	2	0	2499	0.0	34.3	-34.3
3	765 kV	SOLAPUR-RAICHUR	2	535	1113	0.5	7.9	-7.4
4	765 kV	WARDHA-NIZAMABAD	2	0	2679	0.0	44.5	-44.5
5	765 kV	WARORA-WARANGAL(NEW)	2	0	2536	0.0	41.2	-41.2
6	400 kV	KOLHAPUR-KUDGI	2	1276	0	20.6	0.0	20.6
7	220 kV	KOLHAPUR-CHIKODI	2	0	0	0.0	0.0	0.0
8	220 kV	PONDA-AMBEWADI	1	99	0	1.5	0.0	1.5
9	220 kV	XELDEM-AMBEWADI	1	1	114	2.1	0.0	2.1
WR-SR						24.8	149.2	-124.5

INTERNATIONAL EXCHANGES					Import(+ve)/Export(-ve)		
State	Region	Line Name	Max (MW)	Min (MW)	Avg (MW)	Energy Exchange (MU)	
BHUTAN	ER	400kV MANGDECHHU-ALIPURDUAR 1,2&3 i.e. ALIPURDUAR RECEIPT (from MANGDECHU HEP 4*180MW)	760	516	563	13.50	
	ER	400kV TALA-BINAGURI 1,2,4 (& 400kV MALBASE - BINAGURI) i.e. BINAGURI RECEIPT (from TALA HEP 6*170MW)	893	677	850	20.40	
	ER	220kV CHUKHA-BIRPARA 1&2 (& 220kV MALBASE - BIRPARA) i.e. BIRPARA RECEIPT (from CHUKHA HEP 4*84MW)	154	91	135	3.24	
	NER	132kV GELEPHU-SALAKATI	36	-19	27	0.64	
	NER	132kV MOTANGA-RANGIA	83	35	60	1.43	
NEPAL	NR	NEPAL IMPORT (FROM UP)	0	0	0	0.00	
	NR	132kV MAHENDRANAGAR-TANAKPUR(NHPC)	64	0	53	1.27	
	ER	NEPAL IMPORT (FROM BIHAR)	62	9	53	1.28	
	ER	400kV DHALKEBAR-MUZAFFARPUR 1&2	793	606	685	16.45	
BANGLADESH	ER	BHERAMARA B/B HVDC (B'DESH)	-904	-759	-874	-20.99	
	ER (Isolated from Indian Grid)	400kV GODDA_TPS-RAHANPUR (B'DESH) D/C	-1137	-982	-1038	-24.91	
	NER	132kV COMILLA-SURAJMANI NAGAR 1&2	-103	0	-76	-1.82	

Export From India (in MU)

Country	GNA (ISGS/PPA)	T-GNA							TOTAL
		BILATERAL TOTAL	COLLECTIVE						
			IDAM			RTM			
			IEX	PXIL	HPX	IEX	PXIL	HPX	
Bhutan	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Nepal	0.07	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.07
Bangladesh	21.63	0.00	0.00	0.00	0.00	0.00	0.00	0.00	21.63
Myanmar	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total Export	21.70	0.00	0.00	0.00	0.00	0.00	0.00	0.00	21.70

Import by India(in MU)

Country	GNA (ISGA/PPA)	T-GNA							TOTAL
		BILATERAL TOTAL	COLLECTIVE						
			IDAM			RTM			
			IEX	PXIL	HPX	IEX	PXIL	HPX	
Bhutan	38.84	0.00	1.77	0.00	0.00	0.00	0.00	0.00	40.61
Nepal	7.08	0.00	11.31	0.00	0.00	0.00	0.00	0.00	18.39
Bangladesh	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Myanmar	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total Import	45.92	0.00	13.08	0.00	0.00	0.00	0.00	0.00	59.00

Net from India(in MU)

-ve : Export / +ve : Import

Country	GNA (ISGS/PPA)	T-GNA							TOTAL
		BILATERAL TOTAL	COLLECTIVE						
			IDAM			RTM			
			IEX	PXIL	HPX	IEX	PXIL	HPX	
Bhutan	38.84	0.00	1.77	0.00	0.00	0.00	0.00	0.00	40.61
Nepal	7.01	0.00	11.31	0.00	0.00	0.00	0.00	0.00	18.32
Bangladesh	-21.63	0.00	0.00	0.00	0.00	0.00	0.00	0.00	-21.63
Myanmar	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total Net	24.22	0.00	13.08	0.00	0.00	0.00	0.00	0.00	37.30