



National Load Despatch Centre
राष्ट्रीय भार प्रेषण केंद्र
GRID CONTROLLER OF INDIA LIMITED
ग्रिड कंट्रोलर ऑफ इंडिया लिमिटेड

(Government of India Enterprise/ भारत सरकार का उद्यम)
B-9, QUTUB INSTITUTIONAL AREA, KATWARIA SARAI, NEW DELHI -110016
बी-9, कुतुब इन्स्टीट्यूशनल एरिया, कटवारिया सराये, न्यू दिल्ली-110016

Ref: GRID-INDIA/NLDC/SO/Daily PSP Report

दिनांक: 06.01.2026

To,

- कार्यकारी निदेशक, पू.क्षे.भा.प्रे.के., 14, गोल्फ क्लब रोड, कोलकाता - 700033
Executive Director, ERLDC, 14 Golf Club Road, Tollygunge, Kolkata, 700033
- कार्यकारी निदेशक, ऊ.क्षे.भा.प्रे.के., 18/ए, शाहीद जीत सिंह सनसनवाल मार्ग, नई दिल्ली - 110016
Executive Director, NRLDC, 18-A, Shaheed Jeet Singh Marg, Katwaria Sarai, New Delhi - 110016
- कार्यकारी निदेशक, प.क्षे.भा.प्रे.के., एफ3, एम आई डी सी क्षेत्र, अंधेरी, मुंबई -400093
Executive Director, WRLDC, F-3, M.I.D.C. Area, Marol, Andheri (East), Mumbai-400093
- कार्यकारी निदेशक, ऊ.पू.क्षे.भा.प्रे.के., डोंगतेह, लोअर नोंग्रह, लापालंग, शिलोंग - 793006
Executive Director, NERLDC, Dongteih, Lower Nongrah, Lapalang, Shillong - 793006, Meghalaya
- कार्यकारी निदेशक, द.क्षे.भा.प्रे.के., 29, रेस कोर्स क्रॉस रोड, बंगलुरु -560009
Executive Director, SRLDC, 29, Race Course Cross Road, Bangalore-560009

Sub: Daily PSP Report for the date 05.01.2026.

महोदय/Sir,

आईईजीसी-2023 की धारा स.-38(1) के प्रावधान के अनुसार, दिनांक 5-जनवरी-2026 की अखिल भारतीय प्रणाली की दैनिक ग्रिड निष्पादन रिपोर्ट रांभांप्रेके की वेबसाइट पर उपलब्ध है।

As per article 38(1) of the Indian Electricity Grid Code, the daily report pertaining power supply position of All India Power System for the date 05.01.2026, is available at the NLDC website.

धन्यवाद,
Thanks

Report for previous day

Date of Reporting: 06-Jan-2026

A. Power Supply Position at All India and Regional level

	NR	WR	SR	ER	NER	TOTAL
Demand Met during Evening Peak hrs(MW) (at 19:00 hrs; from RLDCs)	63613	70248	49716	24037	2926	210540
Peak Shortage (MW)	0	0	0	129	0	129
Energy Met (MU)	1329	1549	1190	484	53	4605
Hydro Gen (MU)	113	36	80	21	15	263
Wind Gen (MU)	16	96	115	-	-	227
Solar Gen (MU)*	155.56	158.66	145.02	2.33	0.68	462
Energy Shortage (MU)	0.21	0.00	0.00	0.24	0.00	0.45
Maximum Demand Met During the Day (MW) (From NLDC SCADA)	72530	79037	60978	24695	2977	236715
Time Of Maximum Demand Met	10:29	09:59	09:27	17:52	17:11	09:59

B. Frequency Profile (%)

Region	FVI	< 49.7	49.7 - 49.8	49.8 - 49.9	< 49.9	49.9 - 50.05	> 50.05
All India	0.034	0.00	0.43	3.93	4.36	73.28	22.36

C. Power Supply Position in States

Region	States	Max.Demand Met during the day (MW)	Shortage during maximum Demand (MW)	Energy Met (MU)	Drawal Schedule (MU)	OD(+)/UD(-) (MU)	Max OD (MW)	Energy Shortage (MU)
NR	Punjab	9456	0	167.6	82.0	0.4	683	0.00
	Haryana	9107	0	168.4	111.1	0.0	572	0.00
	Rajasthan	17798	0	331.3	114.9	-6.9	816	0.00
	Delhi	5450	0	90.7	84.1	0.5	526	0.00
	UP	21923	0	408.3	91.1	-1.1	475	0.00
	Uttarakhand	2625	0	47.6	38.1	-0.3	77	0.21
	HP	2147	0	39.1	32.3	-0.9	172	0.00
	J&K(UT) & Ladakh(UT)	3271	0	67.0	63.8	-1.4	106	0.00
	Chandigarh	280	0	4.7	4.7	-0.1	17	0.00
	Railways_NR ISTS	200	0	4.3	3.6	0.8	61	0.00
WR	Chhattisgarh	5390	0	108.1	51.1	-0.2	326	0.00
	Gujarat	23743	0	436.5	181.8	-4.2	778	0.00
	MP	18335	0	332.0	205.4	0.0	613	0.00
	Maharashtra	29540	0	589.9	176.0	-6.7	742	0.00
	Goa	718	0	14.0	11.7	1.9	67	0.00
	DNHDDPDCL	1347	0	30.4	30.0	0.4	150	0.00
	AMNSIL	838	0	18.4	11.5	-0.1	253	0.00
	BALCO	604	0	14.3	14.5	-0.2	13	0.00
	RIL JAMNAGAR	245	0	5.3	5.4	-0.1	0	0.00
	Andhra Pradesh	11442	0	214.8	53.2	-0.7	599	0.00
SR	Telangana	14814	0	257.3	101.3	-0.6	484	0.00
	Karnataka	16109	0	286.5	95.6	-1.7	769	0.00
	Kerala	4503	0	81.8	64.9	1.2	393	0.00
	Tamil Nadu	17371	0	340.7	191.1	-1.8	875	0.00
	Puducherry	409	0	8.7	8.1	0.0	59	0.00
	Bihar	6675	129	118.7	106.3	0.8	638	0.24
ER	DVC	3250	0	67.2	-38.5	0.5	389	0.00
	Jharkhand	2399	0	42.2	31.0	-1.9	141	0.00
	Odisha	5128	0	96.7	4.4	-0.9	390	0.00
	West Bengal	7873	0	157.5	26.3	-1.8	281	0.00
	Sikkim	114	0	1.9	1.8	0.0	13	0.00
	Railways_ER ISTS	11	0	0.1	0.1	0.0	4	0.00
NER	Arunachal Pradesh	193	0	3.5	3.2	0.2	119	0.00
	Assam	1615	0	29.4	23.4	0.2	999	0.00
	Manipur	272	0	4.0	4.1	-0.1	200	0.00
	Meghalaya	379	0	6.6	5.7	-0.1	330	0.00
	Mizoram	168	0	2.3	2.2	-0.3	113	0.00
	Nagaland	170	0	2.8	2.7	0.0	120	0.00
	Tripura	241	0	4.3	5.1	0.2	275	0.00

D. Transnational Exchanges (MU) - Import(+ve)/Export(-ve)

	Bhutan	Nepal	Bangladesh	Godda -> Bangladesh
Actual (MU)	-11.8	-5.5	-13.3	-26.2
Day Peak (MW)	-845.8	-618.0	-908.9	-1463.0

E. Import/Export by Regions (in MU) - Import(+ve)/Export(-ve); OD(+)/UD(-)

	NR	WR	SR	ER	NER	TOTAL
Schedule(MU)	253.8	-169.2	108.5	-202.7	9.5	0.0
Actual(MU)	244.4	-175.9	100.2	-190.4	8.8	-13.0
O/D/U/D(MU)	-9.4	-6.7	-8.3	12.3	-0.7	-12.9

F. Generation Outage(MW)

	NR	WR	SR	ER	NER	TOTAL	% Share
Central Sector	5890	12209	7328	3715	160	29301	49
State Sector	8354	11403	8310	2359	205	30630	51
Total	14244	23611	15638	6074	365	59931	100

G. Sourcewise generation (Gross) (MU)

	NR	WR	SR	ER	NER	All India	% Share
Coal	795	1457	681	737	13	3683	73
Lignite	29	18	48	0	0	94	2
Hydro	113	36	80	21	15	263	5
Nuclear	53	52	47	0	0	152	3
Gas, Naptha & Diesel	9	21	10	0	22	61	1
RES (Wind, Solar, Biomass & Others)	197	257	309	6	1	770	15
Total	1194	1841	1175	764	50	5024	100

Share of RES in total generation (%)	16.47	13.97	26.33	0.76	1.35	15.32
Share of Non-fossil fuel (Hydro,Nuclear and RES) in total generation(%)	30.34	18.74	37.09	3.49	30.14	23.59

H. All India Demand Diversity Factor

Based on Regional Max Demands	1.014
Based on State Max Demands	1.039

I. All India Peak Demand and shortage at Solar and Non-Solar Hour

	Max Demand Met(MW)	Time	Shortage(MW)
Solar hr	236715	9:59	0
Non-Solar hr	215274	18:00	462

Diversity factor = Sum of regional or state maximum demands / All India maximum demand

**Note: All generation MU figures are gross

***Godda (Jharkhand) -> Bangladesh power exchange is through the radial connection (isolated from Indian Grid)

Solar Hours -> 06:00 to 18:00hrs and rest are Non-Solar Hours

*Source: RLDCs for solar connected to ISTS; SLDCs for embedded solar. Limited visibility of embedded solar data.

Executive Director-NLDC

INTER-REGIONAL EXCHANGES

Import=(+ve) /Export =(-ve) for NET (MU)
Date of Reporting: 06-Jan-2026

Sl No	Voltage Level	Line Details	No. of Circuit	Max Import (MW)	Max Export (MW)	Import (MU)	Export (MU)	NET (MU)
Import/Export of ER (With NR)								
1	HVDC	ALIPURDUAR-AGRA	2	0	0	0.0	0.0	0.0
2	HVDC	PUSAULI B/B	-	0	47	0.0	2.5	-2.5
3	765 kV	GAYA-VARANASI	2	0	1323	0.0	20.5	-20.5
4	765 kV	SASARAM-FATEHPUR	1	0	518	0.0	7.7	-7.7
5	765 kV	GAYA-BALIA	1	0	273	0.0	13.1	-13.1
6	400 kV	PUSAULI-VARANASI	1	21	51	0.0	0.0	0.0
7	400 kV	PUSAULI-ALLAHABAD	1	0	115	0.0	1.9	-1.9
8	400 kV	MUZAFFARPUR-GORAKHPUR	2	222	597	0.0	6.0	-6.0
9	400 kV	PATNA-BALIA	2	0	906	0.0	13.9	-13.9
10	400 kV	NAUBATPUR-BALIA	2	0	451	0.0	3.7	-3.7
11	400 kV	BIHARSHARIFF-BALIA	2	366	248	0.1	0.0	0.1
12	400 kV	MOTIHARI-GORAKHPUR	2	0	505	0.0	8.1	-8.1
13	400 kV	BIHARSARIFF-SAHUPURI	2	31	401	0.0	5.4	-5.4
14	220 kV	SAHUPURI-KARMANASA	1	16	27	0.0	0.7	-0.7
15	132 kV	NAGAR UNTARI-RIHAND	1	0	0	0.1	0.0	0.1
16	132 kV	GARWAH-RIHAND	1	30	0	0.0	0.0	0.0
17	132 kV	KARMANASA-SAHUPURI	1	0	30	0.0	0.0	0.0
18	132 kV	KARMANASA-CHANDAULI	1	0	31	0.0	0.8	-0.8
ER-NR						0.1	84.2	-84.1
Import/Export of ER (With WR)								
1	765 kV	JHARSUGUDA-DHARAMJAIGARH	4	0	2424	0.0	30.5	-30.5
2	765 kV	NEW RANCHI-DHARAMJAIGARH	2	580	1268	0.0	9.3	-9.3
3	765 kV	JHARSUGUDA-DURG	2	0	1446	0.0	24.9	-24.9
4	400 kV	JHARSUGUDA-RAIGARH	4	0	888	0.0	13.8	-13.8
5	400 kV	RANCHI-SIPAT	2	109	408	0.0	2.9	-2.9
6	400 kV	JEYPORE-JACDALPUR	2	369	362	0.0	1.2	1.2
7	220 kV	BUDHIPADAR-RAIGARH	1	0	187	0.0	3.2	-3.2
8	220 kV	BUDHIPADAR-KORBA	2	22	148	0.0	1.1	-1.1
ER-WR						1.2	85.6	-84.4
Import/Export of ER (With SR)								
1	HVDC	JEYPORE-GAZUWAKA B/B	2	0	737	0.0	12.3	-12.3
2	HVDC	TALCHER-KOLAR BIPOLE	2	0	1175	0.0	12.0	-12.0
3	765 kV	ANGUL-SRIKAKULAM	2	0	2809	0.0	45.8	-45.8
4	400 kV	TALCHER-I/C	2	1894	0	31.6	0.0	31.6
5	220 kV	BALIMELA-UPPER-SILERRU	1	3	2	0.0	0.0	0.0
ER-SR						0.0	70.1	-70.1
Import/Export of ER (With NER)								
1	400 kV	BINAGURI-BONGAIGAON	2	147	191	1.1	1.4	-0.3
2	400 kV	ALIPURDUAR-BONGAIGAON	2	602	347	3.3	0.0	3.3
3	220 kV	ALIPURDUAR-SALAKATI	2	15	228	0.0	2.1	-2.1
ER-NER						4.3	3.4	0.9
Import/Export of NER (With NR)								
1	HVDC	BISWANATH CHARIALI-AGRA	2	656	0	10.9	0.0	10.9
NER-NR						10.9	0.0	10.9
Import/Export of WR (With NR)								
1	HVDC	CHAMPA-KURUKSHETRA	2	0	3396	0.0	57.4	-57.4
2	HVDC	VINDHYACHAL B/B	-	0	107	0.0	2.4	-2.4
3	HVDC	MUNDRA-MOHINDERGARH	2	0	1176	0.0	29.1	-29.1
4	765 kV	GWALIOR-AGRA	2	0	2339	0.0	34.6	-34.6
5	765 kV	GWALIOR-PHAGI	2	283	1294	0.0	20.2	-20.2
6	765 kV	JABALPUR-ORAI	2	0	1006	0.0	32.1	-32.1
7	765 kV	GWALIOR-ORAI	1	840	0	14.4	0.0	14.4
8	765 kV	SATNA-ORAI	1	0	1235	0.0	24.4	-24.4
9	765 kV	BANASKANTHA-CHITORGARH	2	2098	857	16.7	2.4	14.3
10	765 kV	VINDHYACHAL-VARANASI	2	0	2180	0.0	32.4	-32.4
11	400 kV	ZERDA-KANKROLI	1	359	36	3.8	0.0	3.8
12	400 kV	ZERDA -BHINMAL	1	248	27	2.6	0.0	2.6
13	400 kV	VINDHYACHAL -RIHAND	1	961	0	19.4	0.0	19.4
14	400 kV	RAPP-SHUJALPUR	2	594	256	3.5	0.7	2.8
15	400 kV	NEEMUCH-Chittorgarh	2	441	536	2.1	2.7	-0.6
16	220 kV	BHANPURA-RANPUR	1	0	119	0.0	2.0	-2.0
17	220 kV	BHANPURA-MORAK	1	0	30	0.0	1.5	-1.5
18	220 kV	MEHGAON-AURAIYA	1	100	25	0.9	0.1	0.8
19	220 kV	MALANPUR-AURAIYA	1	70	36	0.4	0.2	0.3
20	132 kV	RAIGHAT-LALITPUR	2	0	0	0.0	0.0	0.0
WR-NR						63.8	242.3	-178.5
Import/Export of WR (With SR)								
1	HVDC	BHADRAWATI B/B	-	0	1009	0.0	24.0	-24.0
2	HVDC	RAIGARH-PUGALUR	2	0	4512	0.0	60.6	-60.6
3	765 kV	SOLAPUR-RAICHUR	2	1553	807	11.7	3.2	8.5
4	765 kV	WARDHA-NIZAMABAD	2	976	1785	2.9	15.9	-13.0
5	765 kV	WARORA-WARANGAL(NEW)	2	291	2365	0.3	25.9	-25.7
6	400 kV	KOLHAPUR-KUDGI	2	1838	0	32.0	0.0	32.0
7	220 kV	KOLHAPUR-CHIKODI	2	0	0	0.0	0.0	0.0
8	220 kV	PONDA-AMBEWADI	1	0	0	0.0	0.0	0.0
9	220 kV	XELDEM-AMBEWADI	1	0	106	1.9	0.0	1.9
WR-SR						48.8	129.6	-80.8

INTERNATIONAL EXCHANGES					Import(+ve)/Export(-ve)		
State	Region	Line Name	Max (MW)	Min (MW)	Avg (MW)	Energy Exchange (MU)	
BHUTAN	ER	400kV MANGDECHHU-ALIPURDUAR 1,2&3 I.e. ALIPURDUAR RECEIPT (from MANGDECHU HEP 4*180MW)	-316	38	-172	-4.13	
	ER	400kV TALA-BINAGURI 1,2,4 (& 400kV MALBASE - BINAGURI) I.e. BINAGURI RECEIPT (from TALA HEP 6*170MW)	-245	169	-55	-1.31	
	ER	220kV CHUKHA-BIRPARA 1&2 (& 220kV MALBASE - BIRPARA) I.e. BIRPARA RECEIPT (from CHUKHA HEP 4*84MW)	-270	-134	-213	-5.12	
	NER	132kV GELEPHU-SALAKATI	-60	0	-38	-0.91	
	NER	132kV MOTANGA-RANGIA	-27	0	-12	-0.29	
NEPAL	NR	NEPAL IMPORT (FROM UP)	-68	0	0	0.00	
	NR	132kV MAHENDRANAGAR-TANAKPUR(NHPC)	-68	0	-42	-1.01	
	ER	NEPAL IMPORT (FROM BIHAR)	-150	0	-95	-2.29	
	ER	400kV DHALKEBAR-MUZAFFARPUR 1&2	-351	-80	-92	-2.20	
BANGLADESH	ER	BHERAMARA B/B HVDC (B'DESH)	-817	-249	-452	-10.85	
	ER (Isolated from Indian Grid)	400kV GODDA_TPS-RAHANPUR (B'DESH) D/C	-1463	-816	-1093	-26.22	
	NER	132kV COMILLA-SURAJMANI NAGAR 1&2	-120	0	-103	-2.46	

CROSS BORDER EXCHANGE SCHEDULE

Date of Reporting: 06-Jan-2026

Export From India (in MU)

Country	GNA (ISGS/PPA)	T-GNA							TOTAL
		BILATERAL TOTAL	COLLECTIVE						
			IDAM			RTM			
			IEX	PXIL	HPX	IEX	PXIL	HPX	
Bhutan	0.00	0.31	13.52	0.00	0.00	0.18	0.00	0.00	14.01
Nepal	2.45	0.00	0.35	0.00	0.00	2.26	0.00	0.00	5.06
Bangladesh	11.39	0.00	0.00	0.00	0.00	0.00	0.00	0.00	11.39
Myanmar	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total Export	13.84	0.31	13.87	0.00	0.00	2.44	0.00	0.00	30.46

Import by India(in MU)

Country	GNA (ISGA/PPA)	T-GNA							TOTAL
		BILATERAL TOTAL	COLLECTIVE						
			IDAM			RTM			
			IEX	PXIL	HPX	IEX	PXIL	HPX	
Bhutan	0.25	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.25
Nepal	0.00	0.00	0.00	0.00	0.00	0.32	0.00	0.00	0.32
Bangladesh	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Myanmar	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total Import	0.25	0.00	0.00	0.00	0.00	0.32	0.00	0.00	0.57

Net from India(in MU)

-ve : Export / +ve : Import

Country	GNA (ISGS/PPA)	T-GNA							TOTAL
		BILATERAL TOTAL	COLLECTIVE						
			IDAM			RTM			
			IEX	PXIL	HPX	IEX	PXIL	HPX	
Bhutan	0.25	-0.31	-13.52	0.00	0.00	-0.18	0.00	0.00	-13.76
Nepal	-2.45	0.00	-0.35	0.00	0.00	-1.95	0.00	0.00	-4.75
Bangladesh	-11.39	0.00	0.00	0.00	0.00	0.00	0.00	0.00	-11.39
Myanmar	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total Net	-13.59	-0.31	-13.87	0.00	0.00	-2.13	0.00	0.00	-29.90

15 Min (INSTANTANEOUS) ALL INDIA GRID FREQUENCY, GENERATION & DEMAND MET (SCADA DATA)													Date of Reporting: 06-Jan-2026
TIME	FREQUENCY (Hz)	DEMAND MET (MW)	NUCLEAR (MW)	WIND (MW)	SOLAR (MW)	HYDRO** (MW)	GAS (MW)	THERMAL (MW)	OTHERS* (MW)	NET DEMAND MET (MW)	TOTAL GENERATION (MW)	NET TRANSNATIONAL EXCHANGE (MW) (+(ve) Import, -(ve) Export)	
		(A)	(B)	(C)	(D)	(E)	(F)	(G)	(H)	(I=A-(C+D))	(J=I+B+C+D+E)	(K)	
0:00	50.05	149344	5687	11074	0	5528	1947	125645	3615	138270	153496	-1687	
0:15	50.00	148389	5701	11142	0	5639	2010	124724	3636	137247	152852	-1756	
0:30	49.95	148522	5710	11092	0	5916	1945	124214	3638	137430	152515	-1708	
0:45	50.00	147686	5700	10987	0	5966	1945	123438	3642	136699	151678	-1667	
1:00	50.00	146954	5692	11072	0	5902	1941	122785	3622	135882	151014	-1657	
1:15	50.00	145540	5691	10987	0	5722	2025	121707	3657	134553	149789	-1627	
1:30	49.95	145156	5703	10957	0	5566	1951	121418	3641	134199	149236	-1621	
1:45	50.00	144575	5690	10767	0	5425	1947	121104	3674	133808	148607	-1537	
2:00	50.05	143347	5704	10628	0	5410	1894	120019	3664	132719	147319	-1403	
2:15	50.00	143559	5688	10566	0	5452	1951	120140	3637	132993	147434	-1401	
2:30	50.00	143309	5693	10311	0	5423	1950	120195	3637	132998	147209	-1325	
2:45	49.95	143277	5695	9785	0	5492	1941	120418	3677	133492	147008	-1211	
3:00	50.05	143160	5694	9627	0	5478	2034	120548	3466	133533	146847	-1117	
3:15	49.95	143090	5700	9606	0	5361	1938	120731	3461	133484	146797	-1122	
3:30	50.00	143311	5700	9441	0	5389	1937	121032	3490	133870	146989	-1064	
3:45	49.95	143890	5687	9231	0	5608	1943	121380	3583	134659	147432	-1115	
4:00	50.05	144209	5689	9101	0	5823	1934	121711	3568	135108	147826	-1130	
4:15	50.00	146820	5694	9003	0	6227	1949	123948	3600	137817	150421	-1137	
4:30	50.00	148603	5701	8919	0	6675	1948	125214	3596	139684	152053	-1041	
4:45	50.00	150876	5700	8676	0	6763	1968	127421	3594	142200	154122	-1065	
5:00	50.05	152845	5696	8694	83	6950	2013	129448	3612	144068	156496	-1112	
5:15	50.00	157973	5690	8625	84	6942	2045	134329	3659	149264	161374	-1180	
5:30	50.00	161964	5694	8461	82	7069	2219	138307	3618	153421	165450	-1296	
5:45	50.00	166125	5705	8341	78	7301	2597	142274	3645	157706	169941	-1347	
6:00	50.05	170137	5706	8314	66	8381	2917	145404	3603	161757	174391	-1536	
6:15	49.94	176287	5680	8319	103	9172	3183	150644	3652	167865	180753	-1579	
6:30	50.04	183794	5688	8118	105	11094	3417	155908	3658	175571	187988	-1126	
6:45	49.94	190606	5682	7960	190	12401	3278	161130	3628	182456	194269	-688	
7:00	50.04	196444	5692	7899	509	14951	3264	164055	3658	188036	200028	-763	
7:15	50.05	203359	5697	8041	1175	18714	3350	166224	3660	194143	206861	-797	
7:30	50.05	208212	5701	8064	2428	20452	3771	167423	3653	197720	211492	-861	
7:45	50.05	211357	5688	7912	4312	21692	3833	167221	3673	199133	214331	-845	
8:00	50.10	213637	5693	7704	7120	21533	3525	166336	3706	198813	215617	-864	
8:15	50.10	218288	5697	7412	10632	21613	3675	166502	3660	200244	219191	-847	
8:30	50.05	220878	5684	7123	14427	21079	2501	166457	3775	199328	221046	-827	
8:45	50.05	224187	5684	6888	18971	19870	2343	165526	3758	198328	223040	-824	
9:00	50.15	226918	5688	6643	23469	16945	2400	164916	3758	198806	223819	-758	
9:15	50.04	232410	5690	6541	27273	15606	2442	166053	3737	198596	227342	-750	
9:30	50.04	233858	5685	6540	31448	13402	2252	164869	3778	195870	227974	-785	
9:45	50.05	235721	5669	6581	34802	11173	2216	165105	3672	194338	229218	-1030	
10:00	50.05	236267	5655	6833	37170	10173	2197	162324	3680	192264	228032	-1026	
10:15	50.05	235846	5616	7085	40267	8472	2195	159584	3694	188494	226913	-1120	
10:30	50.10	235783	5663	7146	42451	7717	2198	157378	3641	186186	226194	-1408	
10:45	50.10	234874	5676	7385	44829	6994	2133	155002	3652	182660	225671	-1800	
11:00	50.10	233475	5607	7552	46961	6436	2205	150896	3737	178962	223394	-1778	
11:15	50.00	230462	5651	7626	48815	5678	2104	147014	3641	174021	220529	-1790	
11:30	50.05	229750	5662	7668	50095	5204	2149	143386	3614	171987	217778	-1756	
11:45	49.95	227754	5655	7682	50555	5118	2208	141227	3688	169517	216133	-1715	
12:00	50.00	226262	5644	7453	51297	5258	2157	138842	3669	167512	214320	-1703	
12:15	49.95	223304	5649	7237	51448	5108	2096	135649	3717	164619	210904	-1591	
12:30	50.00	222703	5656	7120	51932	5196	2073	133810	3702	163651	209489	-1518	
12:45	49.95	221351	5645	6910	51121	5261	2069	132288	3686	163320	206980	-1527	
13:00	49.95	218163	5649	6813	51034	5251	2019	130469	3727	160316	204962	-1574	
13:15	49.90	213022	5605	6739	50185	5040	2031	127724	3702	156098	201026	-1546	
13:30	49.89	212453	5655	6543	50269	5345	2028	127258	3743	155641	200841	-1560	
13:45	49.94	213132	5651	6416	48924	5375	2008	128543	3682	157792	200599	-1525	
14:00	50.04	213563	5649	6346	48300	5660	2025	128323	3720	158917	200023	-1527	
14:15	49.94	213046	5638	6177	46424	5663	2016	130632	3689	160445	200239	-1658	
14:30	49.94	214344	5631	6006	45230	5930	2047	134028	3670	163108	202542	-1694	
14:45	49.99	215442	5631	5959	43546	6379	2073	136586	3645	165937	203819	-1738	
15:00	50.04	215127	5636	5909	41245	6239	2120	138709	3723	167973	203581	-1769	
15:15	50.09	213464	5647	5949	38791	6077	2028	139409	3609	168724	201510	-1625	
15:30	50.04	213924	5637	5894	49464	6307	2100	142888	3690	158566	215980	-1636	
15:45	49.94	214073	5637	5916	44665	6824	2107	147059	3711	163492	215919	-1647	
16:00	50.04	212700	5622	5942	39995	7538	2104	149901	3643	166763	214745	-1655	
16:15	49.99	209496	5634	6039	35386	7801	2130	151186	3702	168071	211878	-1602	
16:30	49.94	209857	5616	6228	28715	8795	2185	156897	3621	174914	212057	-1628	
16:45	49.89	210247	5634	6434	22708	11148	2224	160463	3726	181105	212337	-1554	
17:00	49.99	210879	5619	6590	16162	14153	2275	164282	3635	188127	212716	-1399	
17:15	49.94	208344	5622	6745	10749	16865	2324	164837	3623	190850	210765	-1425	
17:30	50.04	210803	5638	6918	6270	20258	2521	167310	3650	197615	212565	-695	
17:45	49.89	213729	5641	7168	3122	24415	2610	168883	3687	203439	215526	-726	
18:00	49.89	215274	5624	7560	1205	25825	2859	170365	3711	206509	217149	-723	
18:15	49.99	214112	5633	7134	562	26620	2806	169590	3643	206416	215988	-703	
18:30	50.04	214650	5648	7622	307	26870	2831	169230	3704	206721	216212	-705	
18:45	50.04	214222	5643	8631	274	26414	2626	168609	3763	205317	215960	-682	
19:00	50.04	212215	5644	9288	243	25249	2320	167332	3768	202684	213844	-713	
19:15	50.09	209305	5662	9896	239	22144	2286	167052	3757	199170	211036	-695	
19:30	50.09	206258	5663	10379	0	20300	2291	165154	3791	195879	207578	-707	
19:45	50.09	204561	5653	10850	0	18486	2284	164192	3780	193711	205245	-731	
20:00	50.09	200528	5644	11465	0	15918	2225	162337	3786	189063	201375	-739	
20:15	50.04	197951	5668	11888	0	13469	2182	162153	3797	186063	199157	-834	
20:30	50.04	194596	5669	12307	0	11951	2136	161461	3774	182289	197298	-794	
20:45	49.99	192576	5682	12634	0	11208	2109	159989	3773	179942	195395	-775	
21:00	50.04	189452	5676	12970	0	10354	2164	157509	3831	176482	192504	-810	
21:15	50.05	185940	5668	13315	0	9993	2109	154048	3832	172625	188965	-721	
21:30	50.05	182717	5682	13635	0	9674	2136	151013	3767	169082	185907	-668	
21:45	50.05	179326	5682	13887	0	8404	2108	148658	3716	165439	182455	-742	
22:00	50.05	175098	5686	14106	0	7453	2144	146032	3666	160992	179087	-1468	
22:15	49.95	174875	5674	14141	0	7949	2127	144597	3693	160734	178181	-1433	
22:30	50.00	173072	5679	14183	0	8131	2127	142441	3729	158889	176290	-1391	
22:45													