



National Load Despatch Centre
राष्ट्रीय भार प्रेषण केंद्र
GRID CONTROLLER OF INDIA LIMITED
ग्रिड कंट्रोलर ऑफ इंडिया लिमिटेड

(Government of India Enterprise/ भारत सरकार का उद्यम)
B-9, QUTUB INSTITUTIONAL AREA, KATWARIA SARAI, NEW DELHI -110016
बी-9, कुतुब इन्स्टीट्यूशनल एरिया, कटवारिया सराये, न्यू दिल्ली-110016

Ref: GRID-INDIA/NLDC/SO/Daily PSP Report

दिनांक: 09.05.2025

To,

- कार्यकारी निदेशक, पू.क्षे.भा.प्रे.के., 14, गोल्फ क्लब रोड, कोलकाता - 700033
Executive Director, ERLDC, 14 Golf Club Road, Tollygunge, Kolkata, 700033
- कार्यकारी निदेशक, ऊ.क्षे.भा.प्रे.के., 18/ए, शाहीद जीत सिंह सनसनवाल मार्ग, नई दिल्ली - 110016
Executive Director, NRLDC, 18-A, Shaheed Jeet Singh Marg, Katwaria Sarai, New Delhi - 110016
- कार्यकारी निदेशक, प.क्षे.भा.प्रे.के., एफ3, एम आई डी सी क्षेत्र, अंधेरी, मुंबई - 400093
Executive Director, WRLDC, F-3, M.I.D.C. Area, Marol, Andheri (East), Mumbai-400093
- कार्यकारी निदेशक, ऊ.पू.क्षे.भा.प्रे.के., डोंगतेह, लोअर नोंग्रह, लापालंग, शिलोंग - 793006
Executive Director, NERLDC, Dongteih, Lower Nongrah, Lapalang, Shillong - 793006, Meghalaya
- कार्यकारी निदेशक, द.क्षे.भा.प्रे.के., 29, रेस कोर्स क्रॉस रोड, बंगलुरु - 560009
Executive Director, SRLDC, 29, Race Course Cross Road, Bangalore-560009

Sub: Daily PSP Report for the date 08.05.2025.

महोदय/Sir,

आईईजीसी-2023 की धारा स.-38(1) के प्रावधान के अनुसार, दिनांक 8-मई-2025 की अखिल भारतीय प्रणाली की दैनिक ग्रिड निष्पादन रिपोर्ट रांभांप्रेके की वेबसाइट पर उपलब्ध है।

As per article 38(1) of the Indian Electricity Grid Code, the daily report pertaining power supply position of All India Power System for the date 08.05.2025, is available at the NLDC website.

धन्यवाद,
Thanks

Report for previous day

Date of Reporting: 09-May-2025

A. Power Supply Position at All India and Regional level

	NR	WR	SR	ER	NER	TOTAL
Demand Met during Evening Peak hrs(MW) (at 20:00 hrs; from RLDCs)	63101	61919	50825	28988	3254	208087
Peak Shortage (MW)	0	0	0	0	0	0
Energy Met (MU)	1336	1429	1221	632	59	4678
Hydro Gen (MU)	244	17	81	28	15	385
Wind Gen (MU)	20	80	77	-	-	176
Solar Gen (MU)*	198.49	132.31	142.87	4.02	0.78	478
Energy Shortage (MU)	0.00	0.00	0.00	0.05	0.00	0.05
Maximum Demand Met During the Day (MW) (From NLDC SCADA)	63451	62162	57115	30579	3362	208590
Time Of Maximum Demand Met	19:55	19:41	15:20	23:25	19:06	19:43

B. Frequency Profile (%)

Region	FVI	< 49.7	49.7 - 49.8	49.8 - 49.9	< 49.9	49.9 - 50.05	> 50.05
All India	0.041	0.38	0.93	4.66	5.97	76.00	18.03

C. Power Supply Position in States

Region	States	Max.Demand Met during the day (MW)	Shortage during maximum Demand (MW)	Energy Met (MU)	Drawal Schedule (MU)	OD(+)/UD(-) (MU)	Max OD (MW)	Energy Shortage (MU)
NR	Punjab	8307	0	171.7	93.2	-8.9	194	0.00
	Haryana	8858	0	186.9	134.1	-0.3	244	0.00
	Rajasthan	13043	0	253.9	84.5	-9.0	449	0.00
	Delhi	5460	0	113.0	102.8	-2.2	113	0.00
	UP	25281	0	474.0	174.3	2.0	368	0.00
	Uttarakhand	2203	0	48.3	32.8	0.1	193	0.00
	HP	1822	0	36.1	10.2	-0.7	471	0.00
	J&K(UT) & Ladakh(UT)	2371	0	43.4	26.4	-1.0	633	0.00
	Chandigarh	269	0	4.8	5.3	-0.5	20	0.00
	Railways_NR ISTS	202	0	4.3	4.0	0.3	34	0.00
WR	Chhattisgarh	5422	0	121.5	61.6	-0.5	343	0.00
	Gujarat	18137	0	373.9	146.7	-9.0	834	0.00
	MP	11968	0	263.9	158.4	-2.9	555	0.00
	Maharashtra	26196	0	586.2	194.6	0.2	1067	0.00
	Goa	824	0	17.7	17.7	-0.1	77	0.00
	DNHDDPDCL	1341	0	30.4	30.2	0.2	184	0.00
	AMNSIL	893	0	20.2	9.6	0.3	250	0.00
	BALCO	533	0	12.7	12.7	0.0	9	0.00
	RIL JAMNAGAR	198	0	2.9	2.9	0.0	0	0.00
SR	Andhra Pradesh	10761	0	224.9	67.9	-1.2	710	0.00
	Telangana	10166	0	208.3	84.9	-1.3	592	0.00
	Karnataka	15392	0	299.1	111.2	-0.9	483	0.00
	Kerala	5065	0	99.4	68.6	0.4	631	0.00
	Tamil Nadu	17544	0	379.1	231.2	-4.9	807	0.00
	Puducherry	526	0	10.5	10.8	-0.4	66	0.00
ER	Bihar	7107	0	142.7	132.5	-1.1	395	0.05
	DVC	3129	0	69.3	-35.3	0.3	277	0.00
	Jharkhand	2110	0	46.0	37.1	0.1	149	0.00
	Odisha	6729	0	135.7	64.8	-0.5	519	0.00
	West Bengal	11682	0	237.5	102.2	-1.9	237	0.00
	Sikkim	62	0	0.8	1.3	-0.5	10	0.00
	Railways_ER ISTS	28	0	0.2	0.2	0.0	3	0.00
NER	Arunachal Pradesh	184	0	3.2	3.1	0.0	55	0.00
	Assam	2023	0	35.5	28.1	0.7	203	0.00
	Manipur	231	0	3.3	3.1	0.2	56	0.00
	Meghalaya	325	0	5.4	2.6	-0.1	176	0.00
	Mizoram	132	0	2.1	1.9	-0.1	21	0.00
	Nagaland	165	0	2.8	2.8	0.0	9	0.00
	Tripura	353	0	6.6	5.4	0.4	91	0.00

D. Transnational Exchanges (MU) - Import(+ve)/Export(-ve)

	Bhutan	Nepal	Bangladesh	Godda -> Bangladesh
Actual (MU)	3.7	-13.0	-23.5	-31.4
Day Peak (MW)	315.0	-792.6	-992.0	-1387.0

E. Import/Export by Regions (in MU) - Import(+ve)/Export(-ve); OD(+)/UD(-)

	NR	WR	SR	ER	NER	TOTAL
Schedule(MU)	154.5	-328.3	166.9	-6.0	12.9	0.0
Actual(MU)	128.9	-316.3	164.3	2.4	13.3	-7.4
O/D/U/D(MU)	-25.6	12.0	-2.6	8.4	0.5	-7.4

F. Generation Outage(MW)

	NR	WR	SR	ER	NER	TOTAL	% Share
Central Sector	4094	6657	4478	2255	386	17870	42
State Sector	7144	10210	5516	1994	179	25043	58
Total	11238	16867	9994	4249	565	42913	100

G. Sourcewise generation (Gross) (MU)

	NR	WR	SR	ER	NER	All India	% Share
Coal	751	1510	686	688	12	3647	72
Lignite	27	15	40	0	0	82	2
Hydro	244	17	81	28	15	385	8
Nuclear	28	65	71	0	0	165	3
Gas, Naptha & Diesel	17	53	4	0	22	96	2
RES (Wind, Solar, Biomass & Others)	229	214	248	6	1	698	14
Total	1296	1875	1130	722	49	5072	100

Share of RES in total generation (%)	17.66	11.42	21.97	0.84	1.62	13.76
Share of Non-fossil fuel (Hydro,Nuclear and RES) in total generation(%)	38.68	15.82	35.44	4.72	31.24	24.60

H. All India Demand Diversity Factor

Based on Regional Max Demands	1.038
Based on State Max Demands	1.088

I. All India Peak Demand and shortage at Solar and Non-Solar Hour

	Max Demand Met(MW)	Time	Shortage(MW)
Solar hr	205479	14:58	0
Non-Solar hr	208590	19:43	0

Diversity factor = Sum of regional or state maximum demands / All India maximum demand

**Note: All generation MU figures are gross

***Godda (Jharkhand) -> Bangladesh power exchange is through the radial connection (isolated from Indian Grid)

Solar Hours -> 06:00 to 18:00hrs and rest are Non-Solar Hours

*Source: RLDCs for solar connected to ISTS; SLDCs for embedded solar. Limited visibility of embedded solar data.

Executive Director-NLDC

INTER-REGIONAL EXCHANGES								
Import=(+ve) /Export =(-ve) for NET (MU)								
Date of Reporting: 09-May-2025								
Sl No	Voltage Level	Line Details	No. of Circuit	Max Import (MW)	Max Export (MW)	Import (MU)	Export (MU)	NET (MU)
Import/Export of ER (With NR)								
1	HVDC	ALIPURDUAR-AGRA	2	0	0	0.0	0.0	0.0
2	HVDC	PUSAULI B/B	-	0	47	0.0	2.5	-2.5
3	765 kV	GAYA-VARANASI	2	1281	412	7.5	0.0	7.5
4	765 kV	SASARAM-FATEHPUR	1	555	261	2.4	0.0	2.4
5	765 kV	GAYA-BALIA	1	32	428	0.0	4.0	-4.0
6	400 kV	PUSAULI-VARANASI	1	0	161	0.0	2.1	-2.1
7	400 kV	PUSAULI -ALLAHABAD	1	64	59	0.0	0.3	-0.3
8	400 kV	MUZAFFARPUR-GORAKHPUR	2	826	196	4.7	0.0	4.7
9	400 kV	PATNA-BALIA	2	612	453	0.0	0.8	-0.8
10	400 kV	NAUBATPUR-BALIA	2	263	276	0.7	0.0	0.7
11	400 kV	BIHARSHARIEF-BALIA	2	774	0	9.5	0.0	9.5
12	400 kV	MOTIHARI-GORAKHPUR	2	317	276	0.0	0.9	-0.9
13	400 kV	BIHARSARIEF-SAHUPURI	2	254	59	2.8	0.0	2.8
14	220 kV	SAHUPURI-KARAMNASA	1	6	82	0.2	0.0	0.2
15	132 kV	NAGAR UNTARI-RIHAND	1	0	0	0.0	0.0	0.0
16	132 kV	GARWAH-RIHAND	1	30	0	0.6	0.0	0.6
17	132 kV	KARMANASA-SAHUPURI	1	0	0	0.0	0.0	0.0
18	132 kV	KARMANASA-CHANDAULI	1	0	0	0.0	0.0	0.0
ER-NR						28.4	10.6	17.8
Import/Export of ER (With WR)								
1	765 kV	JHARSUGUDA-DHARAMJAIGARH	4	1064	517	4.9	0.0	4.9
2	765 kV	NEW RANCHI-DHARAMJAIGARH	2	2088	0	27.0	0.0	27.0
3	765 kV	JHARSUGUDA-DURG	2	94	507	0.0	6.7	-6.7
4	400 kV	JHARSUGUDA-RAIGARH	4	390	278	0.2	0.0	0.2
5	400 kV	RANCHI-SIPAT	2	544	0	6.3	0.0	6.3
6	220 kV	BUDHIPADAR-RAIGARH	1	87	38	0.4	0.0	0.4
7	220 kV	BUDHIPADAR-KORBA	2	221	0	2.5	0.0	2.5
ER-WR						41.3	6.7	34.6
Import/Export of ER (With SR)								
1	HVDC	JEYPORE-GAZUWAKA B/B	2	0	312	0.0	7.4	-7.4
2	HVDC	TALCHER-KOLAR BIPOLE	2	0	1761	0.0	39.9	-39.9
3	765 kV	ANGUL-SRIKAKULAM	2	0	2486	0.0	42.7	-42.7
4	400 kV	TALCHER-I/C	2	631	573	0.0	0.6	-0.6
5	220 kV	BALIMELA-UPPER-SILERRU	1	0	0	0.0	0.0	0.0
ER-SR						0.0	90.0	-90.0
Import/Export of ER (With NER)								
1	400 kV	BINAGURI-BONGAIGAON	2	190	277	0.8	1.3	-0.5
2	400 kV	ALIPURDUAR-BONGAIGAON	2	207	411	0.0	1.5	-1.5
3	220 kV	ALIPURDUAR-SALAKATI	2	45	55	0.3	0.0	0.3
ER-NER						1.1	2.7	-1.7
Import/Export of NER (With NR)								
1	HVDC	BISWANATH CHARIALI-AGRA	2	471	0	11.6	0.0	11.6
NER-NR						11.6	0.0	11.6
Import/Export of WR (With NR)								
1	HVDC	CHAMPA-KURUKSHETRA	2	0	3016	0.0	58.9	-58.9
2	HVDC	VINDHYACHAL B/B	-	0	105	0.0	2.4	-2.4
3	HVDC	MUNDRA-MOHINDERGARH	2	0	1172	0.0	29.1	-29.1
4	765 kV	GWALIOR-AGRA	2	0	1681	0.0	22.3	-22.3
5	765 kV	GWALIOR-PHAGI	2	1248	1265	7.7	10.8	-3.1
6	765 kV	JABALPUR-ORAI	2	90	809	0.0	16.3	-16.3
7	765 kV	GWALIOR-ORAI	1	634	0	8.7	0.0	8.7
8	765 kV	SATNA-ORAI	1	0	915	0.0	15.9	-15.9
9	765 kV	BANASKANTHA-CHITORGARH	2	684	1090	4.8	5.8	-1.1
10	765 kV	VINDHYACHAL-VARANASI	2	0	2729	0.0	52.7	-52.7
11	400 kV	ZERDA-KANKROLI	1	210	36	2.0	0.0	1.9
12	400 kV	ZERDA -BHINMAL	1	120	159	0.4	1.1	-0.7
13	400 kV	VINDHYACHAL -RIHAND	1	972	0	19.9	0.0	19.9
14	400 kV	RAPP-SHUJALPUR	2	584	166	5.8	0.4	5.4
15	400 kV	NEEMUCH-Chittorgarh	2	722	244	5.7	0.8	4.9
16	220 kV	BHANPURA-RANPUR	1	0	139	0.0	2.5	-2.5
17	220 kV	BHANPURA-MORAK	1	0	30	0.0	1.6	-1.6
18	220 kV	MEHGAON-AURAIYA	1	66	6	0.8	0.0	0.8
19	220 kV	MALANPUR-AURAIYA	1	45	16	0.4	0.0	0.4
20	132 kV	GWALIOR-SAWAI MADHOPUR	1	0	0	0.0	0.0	0.0
21	132 kV	RAJGHAT-LALITPUR	2	0	0	0.0	0.0	0.0
WR-NR						56.1	220.6	-164.5
Import/Export of WR (With SR)								
1	HVDC	BHADRAWATI B/B	-	0	309	0.0	7.2	-7.2
2	HVDC	RAIGARH-PUGALUR	2	0	4006	0.0	67.7	-67.7
3	765 kV	SOLAPUR-RAICHUR	2	919	1562	3.5	11.5	-8.0
4	765 kV	WARDHA-NIZAMABAD	2	0	2154	0.0	26.3	-26.3
5	765 kV	WARORA-WARANGAL(NEW)	2	0	2420	0.0	32.8	-32.8
6	400 kV	KOLHAPUR-KUDGI	2	1502	0	22.7	0.0	22.7
7	220 kV	KOLHAPUR-CHIKODI	2	0	0	0.0	0.0	0.0
8	220 kV	PONDA-AMBEWADI	1	0	0	0.0	0.0	0.0
9	220 kV	XELDEM-AMBEWADI	1	0	124	2.6	0.0	2.6
WR-SR						28.8	145.6	-116.8
INTERNATIONAL EXCHANGES								
State	Region	Line Name	Max (MW)	Min (MW)	Avg (MW)	Import(+ve)/Export(-ve) Energy Exchange (MU)		
BHUTAN	ER	400kV MANGDECHHU-ALIPURDUAR 1,2&3 i.e. ALIPURDUAR RECEIPT (from MANGDECHU HEP 4*180MW)	439	141	296	7.10		
	ER	400kV TALA-BINAGURI 1,2,4 (& 400kV MALBASE - BINAGURI) i.e. BINAGURI RECEIPT (from TALA HEP 6*170MW)	-85	39	-20	-0.48		
	ER	220kV CHUKHA-BIRPARA 1&2 (& 220kV MALBASE - BIRPARA) i.e. BIRPARA RECEIPT (from CHUKHA HEP 4*84MW)	-182	-88	-127	-3.06		
	NER	132kV GELEPHU-SALAKATI	-16	3	-5	-0.13		
	NER	132kV MOTANGA-RANGIA	20	-3	10	0.25		
NEPAL	NR	NEPAL IMPORT (FROM UP)	-73	0	-45	-1.07		
	NR	132kV MAHENDRANAGAR-TANAKPUR(NHPC)	-73	0	-55	-1.33		
	ER	NEPAL IMPORT (FROM BIHAR)	-201	0	-116	-2.78		
	ER	400kV DHALKEBAR-MUZAFFARPUR 1&2	-592	16	-325	-7.79		
BANGLADESH	ER	BHERAMARA B/B HVDC (B'DESH)	-946	-897	-938	-22.51		
	ER (Isolated from Indian Grid)	400kV GODDA_TPS-RAHANPUR (B'DESH) D/C	-1387	-1152	-1310	-31.44		
	NER	132kV COMILLA-SURAJMANI NAGAR 1&2	-46	0	-41	-0.98		

Export From India (in MU)

Country	GNA (ISGS/PPA)	T-GNA							TOTAL
		BILATERAL TOTAL	COLLECTIVE						
			IDAM			RTM			
			IEX	PXIL	HPX	IEX	PXIL	HPX	
Bhutan	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Nepal	2.80	0.00	3.75	0.00	0.00	3.88	0.00	0.00	10.43
Bangladesh	23.27	0.00	0.00	0.00	0.00	0.00	0.00	0.00	23.27
Myanmar	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total Export	26.07	0.00	3.75	0.00	0.00	3.88	0.00	0.00	33.70

Import by India(in MU)

Country	GNA (ISGA/PPA)	T-GNA							TOTAL
		BILATERAL TOTAL	COLLECTIVE						
			IDAM			RTM			
			IEX	PXIL	HPX	IEX	PXIL	HPX	
Bhutan	4.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	4.00
Nepal	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Bangladesh	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Myanmar	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total Import	4.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	4.00

Net from India(in MU)

-ve : Export / +ve : Import

Country	GNA (ISGS/PPA)	T-GNA							TOTAL
		BILATERAL TOTAL	COLLECTIVE						
			IDAM			RTM			
			IEX	PXIL	HPX	IEX	PXIL	HPX	
Bhutan	4.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	4.00
Nepal	-2.80	0.00	-3.75	0.00	0.00	-3.88	0.00	0.00	-10.43
Bangladesh	-23.27	0.00	0.00	0.00	0.00	0.00	0.00	0.00	-23.27
Myanmar	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total Net	-22.07	0.00	-3.75	0.00	0.00	-3.88	0.00	0.00	-29.70

