



National Load Despatch Centre
राष्ट्रीय भार प्रेषण केंद्र
GRID CONTROLLER OF INDIA LIMITED
ग्रिड कंट्रोलर ऑफ इंडिया लिमिटेड

(Government of India Enterprise/ भारत सरकार का उद्यम)
B-9, QUTUB INSTITUTIONAL AREA, KATWARIA SARAI, NEW DELHI -110016
बी-9, कुतुब इन्स्टीट्यूशनल एरिया, कटवारिया सराये, न्यू दिल्ली-110016

Ref: GRID-INDIA/NLDC/SO/Daily PSP Report

दिनांक: 11.11.2025

To,

- कार्यकारी निदेशक, पू.क्षे.भा.प्रे.के., 14, गोल्फ क्लब रोड, कोलकाता - 700033
Executive Director, ERLDC, 14 Golf Club Road, Tollygunge, Kolkata, 700033
- कार्यकारी निदेशक, ऊ.क्षे.भा.प्रे.के., 18/ए, शाहीद जीत सिंह सनसनवाल मार्ग, नई दिल्ली - 110016
Executive Director, NRLDC, 18-A, Shaheed Jeet Singh Marg, Katwaria Sarai, New Delhi - 110016
- कार्यकारी निदेशक, प.क्षे.भा.प्रे.के., एफ3, एम आई डी सी क्षेत्र, अंधेरी, मुंबई - 400093
Executive Director, WRLDC, F-3, M.I.D.C. Area, Marol, Andheri (East), Mumbai-400093
- कार्यकारी निदेशक, ऊ.पू.क्षे.भा.प्रे.के., डोंगतेह, लोअर नोंग्रह, लापलंग, शिलोंग - 793006
Executive Director, NERLDC, Dongteih, Lower Nongrah, Lapalang, Shillong - 793006, Meghalaya
- कार्यकारी निदेशक, द.क्षे.भा.प्रे.के., 29, रेस कोर्स क्रॉस रोड, बंगलुरु - 560009
Executive Director, SRLDC, 29, Race Course Cross Road, Bangalore-560009

Sub: Daily PSP Report for the date 10.11.2025.

महोदय/Sir,

आईईजीसी-2023 की धारा स.-38(1) के प्रावधान के अनुसार, दिनांक 10-नवंबर-2025 की अखिल भारतीय प्रणाली की दैनिक ग्रिड निष्पादन रिपोर्ट रांभांप्रेके की वेबसाइट पर उपलब्ध है।

As per article 38(1) of the Indian Electricity Grid Code, the daily report pertaining power supply position of All India Power System for the date 10.11.2025, is available at the NLDC website.

धन्यवाद,
Thanks

Report for previous day

Date of Reporting: 11-Nov-2025

A. Power Supply Position at All India and Regional level

	NR	WR	SR	ER	NER	TOTAL
Demand Met during Evening Peak hrs(MW) (at 19:00 hrs: from RLDCs)	52918	59165	49368	21957	2823	186231
Peak Shortage (MW)	0	0	0	0	0	0
Energy Met (MU)	1080	1316	1096	446	53	3991
Hydro Gen (MU)	141	43	166	43	18	411
Wind Gen (MU)	2	22	11	-	-	35
Solar Gen (MU)*	184.95	163.99	133.42	3.82	1.06	487
Energy Shortage (MU)	0.15	0.00	0.00	0.00	0.00	0.15
Maximum Demand Met During the Day (MW) (From NLDC SCADA)	54764	62728	52793	22515	2989	192252
Time Of Maximum Demand Met	18:19	17:35	15:56	18:36	17:21	18:23

B. Frequency Profile (%)

Region	FV1	< 49.7	49.7 - 49.8	49.8 - 49.9	< 49.9	49.9 - 50.05	> 50.05
All India	0.064	0.32	1.20	9.05	10.58	68.52	20.90

C. Power Supply Position in States

Region	States	Max.Demand Met during the day (MW)	Shortage during maximum Demand (MW)	Energy Met (MU)	Drawal Schedule (MU)	OD(+)/UD(-) (MU)	Max OD (MW)	Energy Shortage (MU)
NR	Punjab	7277	0	137.3	64.1	-0.7	728	0.00
	Haryana	7339	0	143.4	116.5	1.0	254	0.01
	Rajasthan	14531	0	279.9	81.8	2.2	1301	0.00
	Delhi	3923	0	73.5	71.1	-0.2	301	0.00
	UP	16377	0	307.3	84.0	0.4	269	0.00
	Uttarakhand	2086	0	38.8	26.8	0.3	173	0.14
	HP	2022	0	35.2	20.8	-0.2	302	0.00
	J&K(UT) & Ladakh(UT)	2978	0	56.9	50.6	0.3	154	0.00
	Chandigarh	199	0	3.5	3.4	0.1	15	0.00
	Railways NR ISTS	200	0	4.3	3.8	0.5	70	0.00
WR	Chhattisgarh	4593	0	89.3	31.2	-0.2	406	0.00
	Gujarat	18910	0	384.0	230.8	0.0	926	0.00
	MP	14345	0	256.4	167.9	0.0	980	0.00
	Maharashtra	25105	0	507.4	176.1	-0.3	496	0.00
	Goa	701	0	14.1	11.9	2.0	49	0.00
	DNHDDPDCL	1332	0	29.7	29.6	0.1	38	0.00
	AMNSIL	801	0	16.4	9.8	-0.4	270	0.00
	BALCO	538	0	12.8	12.8	0.0	33	0.00
	RIL JAMNAGAR	255	0	5.8	5.9	-0.1	0	0.00
	Andhra Pradesh	9393	0	204.9	74.8	0.3	654	0.00
SR	Telangana	9605	0	178.8	62.5	-1.0	363	0.00
	Karnataka	14005	0	265.2	104.2	2.0	885	0.00
	Kerala	4401	0	84.0	55.0	-0.5	296	0.00
	Tamil Nadu	17525	0	354.1	212.0	0.1	740	0.00
	Puducherry	427	0	9.1	8.7	-0.3	21	0.00
	Bihar	4915	0	90.3	72.9	-1.3	340	0.00
ER	DVC	3121	0	62.9	-22.0	0.1	317	0.00
	Jharkhand	1980	0	37.4	25.6	-2.1	148	0.00
	Odisha	5365	0	103.0	26.8	-2.8	477	0.00
	West Bengal	7790	0	151.3	35.0	-0.9	381	0.00
	Sikkim	81	0	1.3	1.4	-0.2	21	0.00
	Railways ER ISTS	10	0	0.1	0.2	-0.1	4	0.00
NER	Arunachal Pradesh	161	0	2.7	2.7	-0.2	22	0.00
	Assam	1831	0	32.1	24.5	0.5	126	0.00
	Manipur	225	0	3.3	3.1	0.2	36	0.00
	Meghalaya	329	0	5.4	4.0	-0.1	34	0.00
	Mizoram	131	0	2.0	0.9	-0.3	11	0.00
	Nagaland	160	0	2.6	2.3	-0.1	17	0.00
	Tripura	269	0	4.8	3.5	-0.1	21	0.00

D. Transnational Exchanges (MU) - Import(+ve)/Export(-ve)

	Bhutan	Nepal	Bangladesh	Godda -> Bangladesh
Actual (MU)	12.6	21.2	-24.4	-24.0
Day Peak (MW)	800.2	961.8	-1041.2	-1241.2

E. Import/Export by Regions (in MU) - Import(+ve)/Export(-ve); OD(+)/UD(-)

	NR	WR	SR	ER	NER	TOTAL
Schedule(MU)	146.9	-150.2	170.5	-174.5	7.2	0.0
Actual(MU)	145.7	-137.6	166.7	-196.4	4.7	-16.9
O/D/U/D(MU)	-1.3	12.7	-3.9	-21.9	-2.5	-16.9

F. Generation Outage(MW)

	NR	WR	SR	ER	NER	TOTAL	% Share
Central Sector	6543	12917	7048	3060	598	30167	40
State Sector	13379	19269	9508	2219	205	44580	60
Total	19922	32186	16556	5279	803	74746	100

G. Sourcewise generation (Gross) (MU)

	NR	WR	SR	ER	NER	All India	% Share
Coal	604	1238	595	657	12	3106	72
Lignite	26	13	43	0	0	82	2
Hydro	141	43	166	43	18	411	9
Nuclear	37	53	41	0	0	131	3
Gas, Naptha & Diesel	6	23	5	0	21	55	1
RES (Wind, Solar, Biomass & Others)	199	189	162	6	1	557	13
Total	1012	1559	1013	706	52	4342	100

Share of RES in total generation (%)	19.62	12.14	16.03	0.88	2.07	12.84
Share of Non-fossil fuel (Hydro,Nuclear and RES) in total generation(%)	37.20	18.27	36.52	6.95	36.72	25.32

H. All India Demand Diversity Factor

Based on Regional Max Demands	1.018
Based on State Max Demands	1.078

Diversity factor = Sum of regional or state maximum demands / All India maximum demand

**Note: All generation MU figures are gross

***Godda (Jharkhand) -> Bangladesh power exchange is through the radial connection (isolated from Indian Grid)

Solar Hours -> 06:00 to 18:00hrs and rest are Non-Solar Hours

*Source: RLDCs for solar connected to ISTS; SLDCs for embedded solar. Limited visibility of embedded solar data.

I. All India Peak Demand and shortage at Solar and Non-Solar Hour

	Max Demand Met(MW)	Time	Shortage(MW)
Solar hr	188330	9:55	0
Non-Solar hr	192252	18:23	0

INTER-REGIONAL EXCHANGES

Import=(+ve)/Export=(-ve) for NET (MU)
Date of Reporting: 11-Nov-2025

Sl No	Voltage Level	Line Details	No. of Circuit	Max Import (MW)	Max Export (MW)	Import (MU)	Export (MU)	NET (MU)
Import/Export of ER (With NR)								
1	HVDC	ALIPURDUAR-AGRA	2	0	312	0.0	7.6	-7.6
2	HVDC	PUSAULI B/B	-	0	47	0.0	2.5	-2.5
3	765 kV	GAYANARANASI	2	202	1273	0.0	15.9	-15.9
4	765 kV	SASARAM-FATEHPUR	1	15	644	0.0	8.5	-8.5
5	765 kV	GAYA-BALIA	1	0	602	0.0	8.4	-8.4
6	400 kV	PUSAULI-VARANASI	1	0	97	0.0	1.4	-1.4
7	400 kV	PUSAULI-ALLAHABAD	1	5	75	0.0	0.9	-0.9
8	400 kV	MUZAFFARPUR-GORAKHPUR	2	85	632	0.0	8.1	-8.1
9	400 kV	PATNA-BALIA	2	0	884	0.0	12.5	-12.5
10	400 kV	NAUBATPUR-BALIA	2	130	225	0.0	4.3	-4.3
11	400 kV	BIHARSHARIFF-BALIA	2	282	180	0.3	0.0	0.3
12	400 kV	MOTIHARI-GORAKHPUR	2	0	521	0.0	7.5	-7.5
13	400 kV	BIHARSARIFF-SAHUPURI	2	130	463	0.0	5.1	-5.1
14	220 kV	SAHUPURI-KARMANASA	1	27	3	0.0	1.6	-1.6
15	132 kV	NAGAR UNTARI-RIHAND	1	0	0	0.0	0.0	0.0
16	132 kV	GARWAH-RIHAND	1	30	0	0.4	0.0	0.4
17	132 kV	KARMANASA-SAHUPURI	1	0	0	0.0	0.0	0.0
18	132 kV	KARMANASA-CHANDAULI	1	0	0	0.0	0.0	0.0
ER-NR						0.8	84.3	-83.5
Import/Export of ER (With WR)								
1	765 kV	JHARSUGUDA-DHARAMJAIGARH	4	948	755	0.0	1.6	-1.6
2	765 kV	NEW RANCHI-DHARAMJAIGARH	2	530	681	0.0	3.5	-3.5
3	765 kV	JHARSUGUDA-DURG	2	0	1296	0.0	22.8	-22.8
4	400 kV	JHARSUGUDA-RAIGARH	4	305	309	0.0	1.0	-1.0
5	400 kV	RANCHI-SIPAT	2	179	324	0.0	1.2	-1.2
6	400 kV	JEYPORE-JACDALPUR	2	569	397	0.1	0.0	0.1
7	220 kV	BUDHIPADAR-RAIGARH	1	51	133	0.0	1.6	-1.6
8	220 kV	BUDHIPADAR-KORBA	2	157	100	0.2	0.0	0.2
ER-WR						0.3	31.7	-31.4
Import/Export of ER (With SR)								
1	HVDC	JEYPORE-GAZUWAKA B/B	2	0	734	0.0	4.8	-4.8
2	HVDC	TALCHER-KOLAR BIPOLE	2	0	1619	0.0	44.7	-44.7
3	765 kV	ANGUL-SRIKAKULAM	2	0	3011	0.0	53.0	-53.0
4	400 kV	TALCHER-I/C	2	69	950	0.0	4.5	-4.5
5	220 kV	BALIMELA-UPPER-SILERRU	1	24	0	0.4	0.0	0.4
ER-SR						0.4	102.5	-102.0
Import/Export of ER (With NER)								
1	400 kV	BINAGURI-BONGAIGAON	2	0	538	0.0	10.9	-10.9
2	400 kV	ALIPURDUAR-BONGAIGAON	2	0	800	0.0	10.9	-10.9
3	220 kV	ALIPURDUAR-SALAKATI	2	0	113	0.0	1.8	-1.8
ER-NER						0.0	23.6	-23.6
Import/Export of NER (With NR)								
1	HVDC	BISWANATH CHARIAL-AGRA	2	0	604	0.0	14.5	-14.5
NER-NR						0.0	14.5	-14.5
Import/Export of WR (With NR)								
1	HVDC	CHAMPA-KURUKSHETRA	2	0	1975	0.0	36.8	-36.8
2	HVDC	VINDHYACHAL B/B	-	194	0	4.9	0.0	4.9
3	HVDC	MUNDRA-MOHINDERGARH	2	0	300	0.0	7.4	-7.4
4	765 kV	GWALIOR-AGRA	2	86	1262	0.0	13.2	-13.2
5	765 kV	GWALIOR-PHAGI	2	614	2203	1.8	30.3	-28.5
6	765 kV	JABALPUR-ORAI	2	99	668	0.0	18.5	-18.5
7	765 kV	GWALIOR-ORAI	1	1087	0	16.4	0.0	16.4
8	765 kV	SATNA-ORAI	1	0	862	0.0	15.5	-15.5
9	765 kV	BANASKANTHA-CHITORGARH	2	2945	0	40.0	0.0	40.0
10	765 kV	VINDHYACHAL-VARANASI	2	17	1298	0.0	17.9	-17.9
11	400 kV	ZERDA-KANKROLI	1	476	0	8.0	0.0	8.0
12	400 kV	ZERDA -BHNMAL	1	329	0	5.5	0.0	5.5
13	400 kV	VINDHYACHAL -RIHAND	1	0	2	0.0	0.0	0.0
14	400 kV	RAPP-SHUJALPUR	2	718	173	5.7	0.3	5.3
15	400 kV	NEEMUCH-Chittorgarh	2	743	253	5.0	1.4	3.7
16	220 kV	BHANPURA-RANPUR	1	0	100	0.0	1.7	-1.7
17	220 kV	BHANPURA-MORAK	1	0	30	0.0	1.2	-1.2
18	220 kV	MEHGAON-AURAIYA	1	116	0	0.8	0.0	0.8
19	220 kV	MALANPUR-AURAIYA	1	92	4	0.5	0.0	0.5
20	132 kV	RAIGHAT-LALITPUR	2	0	0	0.0	0.0	0.0
WR-NR						88.8	144.3	-55.5
Import/Export of WR (With SR)								
1	HVDC	BHADRAWATI B/B	-	0	992	0.0	21.5	-21.5
2	HVDC	RAIGARH-PUGALUR	2	0	2503	0.0	41.1	-41.1
3	765 kV	SOLAPUR-RAICHUR	2	473	1839	0.4	10.0	-9.6
4	765 kV	WARDHA-NIZAMABAD	2	0	2208	0.0	25.3	-25.3
5	765 kV	WARORA-WARANGAL(NEW)	2	0	2633	0.0	34.8	-34.8
6	400 kV	KOLHAPUR-KUDGI	2	1156	0	17.1	0.0	17.1
7	220 kV	KOLHAPUR-CHIKODI	2	0	0	0.0	0.0	0.0
8	220 kV	PONDA-AMBEWADI	1	0	0	0.0	0.0	0.0
9	220 kV	XELDEM-AMBEWADI	1	0	97	2.0	0.0	2.0
WR-SR						19.5	132.8	-113.3

INTERNATIONAL EXCHANGES					Import(+ve)/Export(-ve)	
State	Region	Line Name	Max (MW)	Min (MW)	Avg (MW)	Energy Exchange (MU)
BHUTAN	ER	400kV MANGDECHHU-ALIPURDUAR 1,2&3 I.e. ALIPURDUAR RECEIPT (from MANGDECHU HEP 4*180MW)	580	182	235	5.65
	ER	400kV TALA-BINAGURI 1,2,4 (& 400kV MALBASE - BINAGURI) I.e. BINAGURI RECEIPT (from TALA HEP 6*170MW)	417	286	349	8.38
	ER	220kV CHUKHA-BIRPARA 1&2 (& 220kV MALBASE - BIRPARA) I.e. BIRPARA RECEIPT (from CHUKHA HEP 4*84MW)	-156	0	0	0.00
	NER	132kV GELEPHU-SALAKATI	-56	0	-48	-1.15
	NER	132kV MOTANGA-RANGIA	-25	0	-13	-0.31
NEPAL	NR	NEPAL IMPORT (FROM UP)	0	0	0	0.00
	NR	132kV MAHENDRANAGAR-TANAKPUR(NHPC)	69	0	63	1.52
	ER	NEPAL IMPORT (FROM BIHAR)	0	0	0	0.00
	ER	400kV DHALKEBAR-MUZAFFARPUR 1&2	838	556	821	19.70
BANGLADESH	ER	BHERAMARA B/B HVDC (B'DESH)	-977	0	-960	-23.03
	ER (Isolated from Indian Grid)	400kV GODDA_TPS-RAHANPUR (B'DESH) D/C	-1241	-829	-1001	-24.02
	NER	132kV COMILLA-SURAJMANI NAGAR 1&2	-70	0	-56	-1.34

CROSS BORDER EXCHANGE SCHEDULE

Date of Reporting: 11-Nov-2025

Export From India (in MU)

Country	GNA (ISGS/PPA)	T-GNA							TOTAL
		BILATERAL TOTAL	COLLECTIVE						
			IDAM			RTM			
			IEX	PXIL	HPX	IEX	PXIL	HPX	
Bhutan	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Nepal	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Bangladesh	24.17	0.00	0.00	0.00	0.00	0.00	0.00	0.00	24.17
Myanmar	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total Export	24.17	0.00	0.00	0.00	0.00	0.00	0.00	0.00	24.17

Import by India(in MU)

Country	GNA (ISGA/PPA)	T-GNA							TOTAL
		BILATERAL TOTAL	COLLECTIVE						
			IDAM			RTM			
			IEX	PXIL	HPX	IEX	PXIL	HPX	
Bhutan	0.94	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.94
Nepal	0.92	0.00	12.69	0.00	0.00	3.96	0.00	0.00	17.57
Bangladesh	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Myanmar	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total Import	1.86	0.00	12.69	0.00	0.00	3.96	0.00	0.00	18.51

Net from India(in MU)

-ve : Export / +ve : Import

Country	GNA (ISGS/PPA)	T-GNA							TOTAL
		BILATERAL TOTAL	COLLECTIVE						
			IDAM			RTM			
			IEX	PXIL	HPX	IEX	PXIL	HPX	
Bhutan	0.94	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.94
Nepal	0.92	0.00	12.69	0.00	0.00	3.96	0.00	0.00	17.57
Bangladesh	-24.17	0.00	0.00	0.00	0.00	0.00	0.00	0.00	-24.17
Myanmar	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total Net	-22.31	0.00	12.69	0.00	0.00	3.96	0.00	0.00	-5.66

