



National Load Despatch Centre
राष्ट्रीय भार प्रेषण केंद्र
GRID CONTROLLER OF INDIA LIMITED
ग्रिड कंट्रोलर ऑफ इंडिया लिमिटेड

(Government of India Enterprise/ भारत सरकार का उद्यम)
B-9, QUTUB INSTITUTIONAL AREA, KATWARIA SARAI, NEW DELHI -110016
बी-9, कुतुब इन्स्टीट्यूशनल एरिया, कटवारिया सराये, न्यू दिल्ली-110016

Ref: GRID-INDIA/NLDC/SO/Daily PSP Report

दिनांक: 06.11.2025

To,

- कार्यकारी निदेशक, पू.क्षे.भा.प्रे.के., 14, गोल्फ क्लब रोड, कोलकाता - 700033
Executive Director, ERLDC, 14 Golf Club Road, Tollygunge, Kolkata, 700033
- कार्यकारी निदेशक, ऊ.क्षे.भा.प्रे.के., 18/ए, शाहीद जीत सिंह सनसनवाल मार्ग, नई दिल्ली - 110016
Executive Director, NRLDC, 18-A, Shaheed Jeet Singh Marg, Katwaria Sarai, New Delhi - 110016
- कार्यकारी निदेशक, प.क्षे.भा.प्रे.के., एफ3, एम आई डी सी क्षेत्र, अंधेरी, मुंबई - 400093
Executive Director, WRLDC, F-3, M.I.D.C. Area, Marol, Andheri (East), Mumbai-400093
- कार्यकारी निदेशक, ऊ.पू.क्षे.भा.प्रे.के., डोंगतेह, लोअर नोंग्रह, लापलंग, शिलोंग - 793006
Executive Director, NERLDC, Dongteih, Lower Nongrah, Lapalang, Shillong - 793006, Meghalaya
- कार्यकारी निदेशक, द.क्षे.भा.प्रे.के., 29, रेस कोर्स क्रॉस रोड, बंगलुरु - 560009
Executive Director, SRLDC, 29, Race Course Cross Road, Bangalore-560009

Sub: Daily PSP Report for the date 05.11.2025.

महोदय/Sir,

आईईजीसी-2023 की धारा स.-38(1) के प्रावधान के अनुसार, दिनांक 5-नवंबर-2025 की अखिल भारतीय प्रणाली की दैनिक ग्रिड निष्पादन रिपोर्ट रांभांप्रेके की वेबसाइट पर उपलब्ध है।

As per article 38(1) of the Indian Electricity Grid Code, the daily report pertaining power supply position of All India Power System for the date 05.11.2025, is available at the NLDC website.

धन्यवाद,
Thanks

Report for previous day

Date of Reporting: 06-Nov-2025

A. Power Supply Position at All India and Regional level

	NR	WR	SR	ER	NER	TOTAL
Demand Met during Evening Peak hrs(MW) (at 19:00 hrs; from RLDCs)	51989	58728	49474	22978	2957	186126
Peak Shortage (MW)	0	0	0	0	0	0
Energy Met (MU)	1102	1293	1120	478	56	4048
Hydro Gen (MU)	156	58	179	59	21	474
Wind Gen (MU)	6	32	47	-	-	85
Solar Gen (MU)*	162.15	139.03	112.42	3.54	0.57	418
Energy Shortage (MU)	0.00	0.00	0.00	0.00	0.00	0.00
Maximum Demand Met During the Day (MW) (From NLDC SCADA)	56355	62553	51848	23898	3170	196314
Time Of Maximum Demand Met	18:23	18:29	09:39	18:09	17:24	18:26

B. Frequency Profile (%)

Region	FV1	< 49.7	49.7 - 49.8	49.8 - 49.9	< 49.9	49.9 - 50.05	> 50.05
All India	0.026	0.00	0.00	3.24	3.24	88.90	7.86

C. Power Supply Position in States

Region	States	Max.Demand Met during the day (MW)	Shortage during maximum Demand (MW)	Energy Met (MU)	Drawal Schedule (MU)	OD(+)/UD(-) (MU)	Max OD (MW)	Energy Shortage (MU)
NR	Punjab	6878	0	130.2	60.9	-1.4	497	0.00
	Haryana	7722	0	155.6	130.0	-0.7	200	0.00
	Rajasthan	13423	0	270.1	69.6	-1.0	679	0.00
	Delhi	4150	0	81.5	78.9	0.4	317	0.00
	UP	17892	0	332.8	105.3	-0.9	537	0.00
	Uttarakhand	2100	0	40.3	27.7	0.2	163	0.00
	HP	1860	0	34.2	19.5	-0.5	373	0.00
	J&K(UT) & Ladakh(UT)	2726	0	49.7	41.4	-0.5	248	0.00
	Chandigarh	197	0	3.5	3.5	0.0	10	0.00
	Railways_NR ISTS	231	0	4.3	4.0	0.3	61	0.00
WR	Chhattisgarh	4669	0	95.5	42.5	-1.1	239	0.00
	Gujarat	17799	0	365.6	219.0	1.3	922	0.00
	MP	11951	0	230.8	139.0	0.0	344	0.00
	Maharashtra	25719	0	518.9	180.0	-1.2	704	0.00
	Goa	730	0	15.0	12.3	2.2	65	0.00
	DNHDDPDCL	1270	0	29.5	29.4	0.1	70	0.00
	AMNSIL	818	0	18.9	11.6	0.3	300	0.00
	BALCO	537	0	12.8	12.9	-0.1	3	0.00
	RIL JAMNAGAR	255	0	5.6	5.7	-0.1	0	0.00
	Andhra Pradesh	9357	0	206.7	79.0	-0.4	637	0.00
SR	Telangana	8807	0	183.9	65.7	-1.5	355	0.00
	Karnataka	13782	0	258.9	94.5	-0.2	1538	0.00
	Kerala	4505	0	85.3	53.9	-2.0	286	0.00
	Tamil Nadu	17657	0	375.2	205.4	-2.6	595	0.00
	Puducherry	454	0	10.2	9.7	-0.1	66	0.00
	Bihar	5519	0	103.6	82.5	-2.5	185	0.00
ER	DVC	3046	0	65.6	-24.8	0.1	287	0.00
	Jharkhand	2019	0	38.4	28.1	-1.6	231	0.00
	Odisha	5127	0	100.7	27.8	-2.0	386	0.00
	West Bengal	8500	0	167.9	48.7	-2.3	221	0.00
	Sikkim	87	0	1.3	1.4	-0.1	6	0.00
	Railways_ER ISTS	16	0	0.2	0.1	0.0	4	0.00
NER	Arunachal Pradesh	161	0	2.8	2.8	-0.3	18	0.00
	Assam	1884	0	34.7	27.9	0.1	63	0.00
	Manipur	213	0	3.0	3.1	-0.1	26	0.00
	Meghalaya	318	0	5.6	4.0	-0.1	84	0.00
	Mizoram	134	0	2.1	0.9	-0.2	8	0.00
	Nagaland	166	0	2.6	2.3	-0.1	27	0.00
	Tripura	272	0	5.2	3.8	-0.1	63	0.00

D. Transnational Exchanges (MU) - Import(+ve)/Export(-ve)

	Bhutan	Nepal	Bangladesh	Godda -> Bangladesh
Actual (MU)	23.1	20.8	-24.5	-29.1
Day Peak (MW)	1138.2	947.2	-1041.1	-1467.1

E. Import/Export by Regions (in MU) - Import(+ve)/Export(-ve); OD(+)/UD(-)

	NR	WR	SR	ER	NER	TOTAL
Schedule(MU)	159.6	-176.4	167.2	-159.4	8.9	0.0
Actual(MU)	179.8	-166.6	159.1	-191.3	7.2	-11.9
O/D/U/D(MU)	20.2	9.7	-8.1	-31.9	-1.8	-11.9

F. Generation Outage(MW)

	NR	WR	SR	ER	NER	TOTAL	% Share
Central Sector	7302	12142	6428	3370	573	29815	41
State Sector	11149	18787	10098	2287	205	42525	59
Total	18451	30929	16526	5657	778	72340	100

G. Sourcewise generation (Gross) (MU)

	NR	WR	SR	ER	NER	All India	% Share
Coal	607	1236	600	664	11	3118	71
Lignite	30	10	48	0	0	88	2
Hydro	156	58	179	59	21	474	11
Nuclear	36	53	41	0	0	130	3
Gas, Naptha & Diesel	5	31	5	0	21	62	1
RES (Wind, Solar, Biomass & Others)	177	172	185	6	1	540	12
Total	1011	1560	1058	728	54	4411	100

Share of RES in total generation (%)	17.53	10.99	17.51	0.79	1.07	12.25
Share of Non-fossil fuel (Hydro,Nuclear and RES) in total generation(%)	36.51	18.10	38.36	8.88	39.93	25.92

H. All India Demand Diversity Factor

Based on Regional Max Demands	1.007
Based on State Max Demands	1.033

I. All India Peak Demand and shortage at Solar and Non-Solar Hour

	Max Demand Met(MW)	Time	Shortage(MW)
Solar hr	181452	9:56	0
Non-Solar hr	196314	18:26	0

Diversity factor = Sum of regional or state maximum demands / All India maximum demand

**Note: All generation MU figures are gross

***Godda (Jharkhand) -> Bangladesh power exchange is through the radial connection (isolated from Indian Grid)

Solar Hours -> 06:00 to 18:00hrs and rest are Non-Solar Hours

*Source: RLDCs for solar connected to ISTS; SLDCs for embedded solar. Limited visibility of embedded solar data.

Executive Director-NLDC

INTER-REGIONAL EXCHANGES

Import=(+ve)/Export =(-ve) for NET (MU)
Date of Reporting: 06-Nov-2025

Sl No	Voltage Level	Line Details	No. of Circuit	Max Import (MW)	Max Export (MW)	Import (MU)	Export (MU)	NET (MU)
Import/Export of ER (With NR)								
1	HVDC	ALIPURDUAR-AGRA	2	0	313	0.0	7.6	-7.6
2	HVDC	PUSAULI B/B	-	0	47	0.0	2.5	-2.5
3	765 kV	GAYA-VARANASI	2	324	1003	0.0	11.1	-11.1
4	765 kV	SASARAM-FATEHPUR	1	14	567	0.0	6.9	-6.9
5	765 kV	GAYA-BALIA	1	0	562	0.0	8.1	-8.1
6	400 kV	PUSAULI-VARANASI	1	0	99	0.0	1.6	-1.6
7	400 kV	PUSAULI-ALLAHABAD	1	6	66	0.0	0.8	-0.8
8	400 kV	MUZAFFARPUR-GORAKHPUR	2	100	576	0.0	6.8	-6.8
9	400 kV	PATNA-BALIA	2	0	917	0.0	13.4	-13.4
10	400 kV	NAUBATPUR-BALIA	2	284	82	0.0	5.1	-5.1
11	400 kV	BIHARSHARIFF-BALIA	2	274	161	1.0	0.0	1.0
12	400 kV	MOTIHARI-GORAKHPUR	2	0	502	0.0	6.8	-6.8
13	400 kV	BIHARSARIFF-SAHUPURI	2	171	389	0.0	3.3	-3.3
14	220 kV	SAHUPURI-KARMANASA	1	36	0	0.0	1.5	-1.5
15	132 kV	NAGAR UNTARI-RIHAND	1	0	0	0.0	0.0	0.0
16	132 kV	GARWAH-RIHAND	1	30	0	0.4	0.0	0.4
17	132 kV	KARMANASA-SAHUPURI	1	0	0	0.0	0.0	0.0
18	132 kV	KARMANASA-CHANDAULI	1	0	0	0.0	0.6	-0.6
ER-NR						1.4	75.9	-74.5
Import/Export of ER (With WR)								
1	765 kV	JHARSUGUDA-DHARAMJAIGARH	4	312	1392	0.0	15.0	-15.0
2	765 kV	NEW RANCHI-DHARAMJAIGARH	2	407	515	0.0	1.6	-1.6
3	765 kV	JHARSUGUDA-DURG	2	0	853	0.0	14.4	-14.4
4	400 kV	JHARSUGUDA-RAIGARH	4	308	300	0.0	0.9	-0.9
5	400 kV	RANCHI-SIPAT	2	151	280	0.0	1.7	-1.7
6	400 kV	JEYPORE-JACDALPUR	2	394	235	2.7	0.0	2.7
7	220 kV	BUDHIPADAR-RAIGARH	1	29	137	0.0	1.6	-1.6
8	220 kV	BUDHIPADAR-KORBA	2	139	99	0.0	0.2	-0.2
ER-WR						2.7	35.4	-32.7
Import/Export of ER (With SR)								
1	HVDC	JEYPORE-GAZUWAKA B/B	2	0	414	0.0	9.8	-9.8
2	HVDC	TALCHER-KOLAR BIPOLE	2	0	1617	0.0	29.1	-29.1
3	765 kV	ANGUL-SRIKAKULAM	2	0	2848	0.0	51.1	-51.1
4	400 kV	TALCHER I/C	2	769	772	0.0	1.9	-1.9
5	220 kV	BALIMELA-UPPER-SILERRU	1	28	0	0.5	0.0	0.5
ER-SR						0.5	90.0	-89.5
Import/Export of ER (With NER)								
1	400 kV	BINAGURI-BONGAIGAON	2	0	532	0.0	8.7	-8.7
2	400 kV	ALIPURDUAR-BONGAIGAON	2	0	797	0.0	13.2	-13.2
3	220 kV	ALIPURDUAR-SALAKATI	2	0	168	0.0	3.0	-3.0
ER-NER						0.0	24.9	-24.9
Import/Export of NER (With NR)								
1	HVDC	BISWANATH CHARIALI-AGRA	2	0	704	0.0	16.9	-16.9
NER-NR						0.0	16.9	-16.9
Import/Export of WR (With NR)								
1	HVDC	CHAMPA-KURUKSHETRA	2	0	3019	0.0	72.4	-72.4
2	HVDC	VINDHYACHAL B/B	-	194	0	4.9	0.0	4.9
3	HVDC	MUNDRA-MOHINDERGARH	2	0	495	0.0	12.2	-12.2
4	765 kV	GWALIOR-AGRA	2	355	1007	0.6	11.6	-11.0
5	765 kV	GWALIOR-PHAGI	2	828	1861	3.3	24.1	-20.8
6	765 kV	JABALPUR-ORAI	2	283	686	0.0	16.6	-16.6
7	765 kV	GWALIOR-ORAI	1	845	0	12.6	0.0	12.6
8	765 kV	SATNA-ORAI	1	0	924	0.0	15.8	-15.8
9	765 kV	BANASKANTHA-CHITORGARH	2	2729	56	37.5	0.0	37.5
10	765 kV	VINDHYACHAL-VARANASI	2	0	1383	0.0	19.5	-19.5
11	400 kV	ZERDA-KANKROLI	1	549	0	8.2	0.0	8.2
12	400 kV	ZERDA -BHINMAL	1	379	0	5.6	0.0	5.6
13	400 kV	VINDHYACHAL -RIHAND	1	0	1	0.0	0.0	0.0
14	400 kV	RAPP-SHUJALPUR	2	728	183	4.9	0.7	4.2
15	400 kV	NEEMUCH-Chittorgarh	2	620	283	3.8	2.1	1.7
16	220 kV	BHANPURA-RANPUR	1	0	99	0.0	1.6	-1.6
17	220 kV	BHANPURA-MORAK	1	0	30	0.0	1.4	-1.4
18	220 kV	MEHGAON-AURAIYA	1	99	0	0.9	0.0	0.9
19	220 kV	MALANPUR-AURAIYA	1	77	0	0.6	0.0	0.6
20	132 kV	RAIGHAT-LALITPUR	2	0	0	0.0	0.0	0.0
WR-NR						82.6	177.7	-95.1
Import/Export of WR (With SR)								
1	HVDC	BHADRAWATI B/B	-	0	495	0.0	12.0	-12.0
2	HVDC	RAIGARH-PUGALUR	2	0	3003	0.0	51.0	-51.0
3	765 kV	SOLAPUR-RAICHUR	2	739	1284	3.5	6.2	-2.7
4	765 kV	WARDHA-NIZAMABAD	2	0	2017	0.0	27.3	-27.3
5	765 kV	WARORA-WARANGAL(NEW)	2	0	2147	0.0	32.1	-32.1
6	400 kV	KOLHAPUR-KUDGI	2	1084	0	18.9	0.0	18.9
7	220 kV	KOLHAPUR-CHIKODI	2	0	0	0.0	0.0	0.0
8	220 kV	PONDA-AMBEWADI	1	0	0	0.0	0.0	0.0
9	220 kV	XELDEM-AMBEWADI	1	0	116	0.0	2.2	2.2
WR-SR						24.6	128.6	-104.0

INTERNATIONAL EXCHANGES					Import(+ve)/Export(-ve)		
State	Region	Line Name	Max (MW)	Min (MW)	Avg (MW)	Energy Exchange (MU)	
BHUTAN	ER	400kV MANGDECHHU-ALIPURDUAR 1,2&3 I.e. ALIPURDUAR RECEIPT (from MANGDECHU HEP 4*180MW)	646	337	413	9.91	
	ER	400kV TALA-BINAGURI 1,2,4 (& 400kV MALBASE - BINAGURI) I.e. BINAGURI RECEIPT (from TALA HEP 6*170MW)	701	424	595	14.28	
	ER	220kV CHUKHA-BIRPARA 1&2 (& 220kV MALBASE - BIRPARA) I.e. BIRPARA RECEIPT (from CHUKHA HEP 4*84MW)	-59	11	-19	-0.45	
	NER	132kV GELEPHU-SALAKATI	-43	0	-30	-0.73	
	NER	132kV MOTANGA-RANGIA	12	-6	4	0.10	
NEPAL	NR	NEPAL IMPORT (FROM UP)	0	0	0	0.00	
	NR	132kV MAHENDRANAGAR-TANAKPUR(NHPC)	69	0	63	1.51	
	ER	NEPAL IMPORT (FROM BIHAR)	0	0	0	0.00	
	ER	400kV DHALKEBAR-MUZAFFARPUR 1&2	851	691	804	19.30	
BANGLADESH	ER	BHERAMARA B/B HVDC (B'DESH)	-966	-959	-964	-23.14	
	ER (Isolated from Indian Grid)	400kV GODDA_TPS-RAHANPUR (B'DESH) D/C	-1467	-898	-1214	-29.13	
	NER	132kV COMILLA-SURAJMANI NAGAR 1&2	-71	0	-56	-1.34	

CROSS BORDER EXCHANGE SCHEDULE

Date of Reporting: 06-Nov-2025

Export From India (in MU)

Country	GNA (ISGS/PPA)	T-GNA							TOTAL
		BILATERAL TOTAL	COLLECTIVE						
			IDAM			RTM			
			IEX	PXIL	HPX	IEX	PXIL	HPX	
Bhutan	0.00	0.33	0.00	0.00	0.00	0.00	0.00	0.00	0.33
Nepal	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Bangladesh	23.76	0.17	0.00	0.00	0.00	0.00	0.00	0.00	23.93
Myanmar	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total Export	23.76	0.50	0.00	0.00	0.00	0.00	0.00	0.00	24.26

Import by India(in MU)

Country	GNA (ISGA/PPA)	T-GNA							TOTAL
		BILATERAL TOTAL	COLLECTIVE						
			IDAM			RTM			
			IEX	PXIL	HPX	IEX	PXIL	HPX	
Bhutan	12.50	0.00	0.00	0.00	0.00	0.00	0.00	0.00	12.50
Nepal	0.76	0.16	11.27	0.00	0.00	5.30	0.00	0.00	17.49
Bangladesh	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Myanmar	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total Import	13.26	0.16	11.27	0.00	0.00	5.30	0.00	0.00	29.99

Net from India(in MU)

-ve : Export / +ve : Import

Country	GNA (ISGS/PPA)	T-GNA							TOTAL	
		BILATERAL TOTAL	COLLECTIVE							
			IDAM			RTM				
			IEX	PXIL	HPX	IEX	PXIL	HPX		
Bhutan	12.50	-0.33	0.00	0.00	0.00	0.00	0.00	0.00	12.17	
Nepal	0.76	0.16	11.27	0.00	0.00	0.00	5.30	0.00	0.00	17.49
Bangladesh	-23.76	-0.17	0.00	0.00	0.00	0.00	0.00	0.00	0.00	-23.93
Myanmar	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total Net	-10.50	-0.34	11.27	0.00	0.00	0.00	5.30	0.00	0.00	5.73

15 Min (INSTANTANEOUS) ALL INDIA GRID FREQUENCY, GENERATION & DEMAND MET (SCADA DATA)												
TIME	FREQUENCY (Hz)	DEMAND MET (MW)	NUCLEAR (MW)	WIND (MW)	SOLAR (MW)	HYDRO** (MW)	GAS (MW)	THERMAL (MW)	OTHERS* (MW)	NET DEMAND MET (MW)	TOTAL GENERATION N (MW)	NET TRANSNATIONAL EXCHANGE (MW)
		(A)	(B)	(C)	(D)	(E)	(F)	(G)	(H)	(I=A-C+D)	(J=B+C+D+E+H)	(K) (+ve) Import, (-ve) Export
0:00	50.04	156151	4742	5307	0	17361	2207	126496	1883	150844	157996	986
0:15	49.94	155341	4755	5197	0	16420	2215	126509	1845	150144	156941	968
0:30	49.94	154418	4735	5170	0	17160	2210	125074	1769	149248	156118	979
0:45	49.94	153544	4703	5025	0	17363	2216	123951	1801	148519	155059	988
1:00	49.94	152600	4720	4848	0	16405	2220	123980	1781	147752	153954	1012
1:15	49.94	151008	4748	4698	0	16253	2224	123258	1798	146310	152979	993
1:30	49.99	150281	4757	4545	0	16131	2223	122575	1845	145736	152076	1034
1:45	49.99	149227	4745	4440	0	15578	2209	122385	1825	144787	151182	1013
2:00	49.99	148221	4716	4321	0	15611	2207	121557	1841	143900	150253	984
2:15	49.99	147400	4762	4366	0	15488	2219	120764	1779	143034	149378	978
2:30	49.99	146980	4763	4340	0	15329	2220	120267	1847	142640	148766	961
2:45	49.94	146554	4741	4194	0	14957	2220	120403	1849	142360	148364	979
3:00	49.94	146198	4726	4069	0	15043	2220	120101	1781	142129	147940	967
3:15	49.99	146003	4740	3952	0	15283	2215	120091	1873	142051	148154	902
3:30	49.99	145777	4749	3901	0	15242	2225	119928	1819	141876	147864	894
3:45	49.99	146716	4735	3860	0	15336	2221	120590	1778	142856	148520	864
4:00	49.99	146791	4755	3713	0	15398	2226	120642	1813	143078	148547	853
4:15	49.94	148384	4752	3645	0	15441	2209	122384	1797	144739	150228	858
4:30	49.99	148988	4740	3535	0	15456	2226	123913	1770	146363	151640	843
4:45	49.99	151322	4753	3368	0	15665	2223	125414	1807	147954	153230	794
5:00	50.04	153143	4750	3283	2	15937	2218	127158	1794	149858	155142	816
5:15	49.99	155999	4765	3237	-3	16446	2195	129525	1822	152765	157987	776
5:30	50.04	158161	4758	3115	-3	16809	2227	131633	1775	155049	160314	744
5:45	50.04	160369	4763	3063	4	18166	2193	132742	1789	157302	162720	764
6:00	50.09	162359	4767	2896	4	20300	2146	132776	1864	159459	164753	719
6:15	50.09	163740	4777	2827	70	22569	2152	132011	1798	160843	166204	726
6:30	50.04	167143	4767	2717	297	24046	2181	134330	1788	164129	170126	789
6:45	49.94	169580	4774	2574	914	24556	2183	135728	1802	166092	172531	794
7:00	49.94	171667	4766	2464	2237	24990	2184	135956	1830	166966	174427	764
7:15	49.94	172549	4788	2329	4669	24945	2189	134730	1811	165551	175461	794
7:30	50.04	174072	4791	2227	8120	24782	2170	132798	1880	163725	176768	804
7:45	50.04	173714	4790	2069	12655	22147	2170	130259	1876	158990	175966	840
8:00	50.09	173166	4801	1996	17681	21194	2155	125120	1894	153489	174841	870
8:15	50.04	174785	4785	2045	23386	19486	2182	122489	1953	149354	176326	890
8:30	49.99	175697	4785	2138	28394	17638	2192	119381	1937	145165	176465	919
8:45	49.94	176313	4791	1922	33067	17256	2194	115699	1969	141324	176898	1006
9:00	50.04	176301	4804	1833	37674	16725	2235	111792	1963	136794	177026	1002
9:15	49.89	179640	4795	1804	43365	15471	2193	110432	2038	134471	180098	1021
9:30	50.04	180424	4787	1736	47795	15387	2186	106586	2153	130893	180630	1010
9:45	49.94	181094	4795	1603	50603	14838	2196	104883	2089	128888	181007	988
10:00	49.99	180943	4791	1552	53211	14389	2199	102537	2091	126180	180770	959
10:15	49.99	180737	4778	1549	55909	13301	2220	101650	2115	123279	181522	1010
10:30	49.99	179829	4770	1449	56081	13489	2188	100657	2088	122299	180722	980
10:45	50.04	179415	4782	1407	56305	13487	2168	100871	2119	121703	181139	977
11:00	50.04	178624	4774	1337	55941	13229	2184	100085	2128	121346	179678	994
11:15	50.04	176843	4783	1276	55468	12289	2153	99802	2116	120099	177887	963
11:30	50.04	176308	4791	1234	54910	12346	2140	99582	2110	120164	177113	953
11:45	50.04	175948	4791	1238	54738	12428	2142	99201	2176	119972	176714	994
12:00	50.04	174518	4768	1304	53947	12236	2155	99194	2145	119267	175749	863
12:15	49.99	173720	4790	1346	53568	12263	2158	98397	2126	118806	174648	980
12:30	50.04	173692	4777	1309	54052	12147	2154	98051	2093	118331	174583	958
12:45	49.99	171953	4775	1299	51936	11536	2178	98613	2089	118718	172426	928
13:00	50.09	168766	4764	1329	50259	11054	2144	97760	2102	117178	169412	929
13:15	49.98	166198	4775	1346	47989	11012	2163	97438	2181	116863	166904	892
13:30	49.98	168115	4771	1491	49199	11046	2176	98098	2080	117425	168861	896
13:45	49.93	169183	4780	1599	49569	11113	2246	98180	2065	118015	169552	947
14:00	49.98	169005	4781	1750	49211	11747	2209	97441	2123	118044	169262	956
14:15	49.93	170345	4780	1830	48656	12198	2239	98657	2107	119859	170467	986
14:30	49.93	172029	4765	1928	50025	12610	2246	98611	2059	120076	172244	929
14:45	49.93	172271	4773	2135	49154	13227	2251	98883	2039	120982	172462	859
15:00	49.98	173894	4773	2362	48473	13544	2225	100478	2067	123059	173922	858
15:15	49.98	174466	4799	2681	45702	13774	2257	103600	2026	126083	174839	858
15:30	49.98	176413	4785	2698	41875	14522	2380	108402	2012	131840	176674	793
15:45	49.93	176751	4807	2855	37993	15106	2541	111584	2041	135903	176927	817
16:00	49.98	177793	4795	3115	33491	15722	2937	115958	2011	141187	178029	814
16:15	49.93	177301	4801	3391	27971	16448	3286	120052	2046	145939	177995	701
16:30	49.98	178321	4811	3610	22162	16909	3573	126064	2011	152549	179140	762
16:45	49.93	178648	4829	3593	16816	17731	3654	131092	1919	158239	179634	718
17:00	49.98	181133	4852	3848	11726	19000	3666	136926	1919	165559	181937	692
17:15	50.04	183152	4824	3819	7202	19841	3897	142380	1931	172131	183894	595
17:30	50.09	186393	4846	3749	3808	22348	4558	145989	1920	178836	187218	547
17:45	50.04	190735	4856	3664	1604	25197	4806	149674	1939	185467	191740	610
18:00	50.04	193801	4864	3746	684	26973	4872	151740	1927	189371	194806	641
18:15	50.04	195879	4858	3926	395	28953	4901	151567	2003	191558	196603	727
18:30	50.04	196004	4852	4169	295	28435	4880	152004	1981	191540	196616	687
18:45	49.99	194238	4851	4307	133	28677	3710	151072	1949	189798	194699	734
19:00	50.04	191102	4837	4591	101	27496	3215	149623	1918	186410	191781	760
19:15	49.99	188966	4823	4836	103	26766	2772	148208	1928	184027	189436	744
19:30	50.04	185802	4826	4945	0	26367	2658	145690	1882	180857	186368	768
19:45	49.99	183614	4827	4899	0	25649	2586	144029	1869	178715	183859	736
20:00	50.04	180406	4823	4904	0	23740	2450	142562	1914	175502	180393	764
20:15	50.04	178211	4836	5065	0	22994	2278	140889	2003	173146	178065	797
20:30	49.99	176426	4829	5214	0	22635	2177	139937	1898	171212	176690	751
20:45	50.04	174741	4832	5328	0	21168	2199	139688	1907	169413	175122	742
21:00	50.04	173086	4823	5525	0	20198	2190	138588	1943	167561	173267	769
21:15	49.99	171166	4835	5488	0	19994	2188	137395	1955	165678	171255	788
21:30	49.99	169722	4840	5404	0	18910	2213	136543	1946	164318	169856	773
21:45	49.99	168812	4831	5241	0	18554	2234	136099	1948	163571	168907	751
22:00	50.04	166097	4838	5118	0	18378	2214	133953	1977	160979	166478	780
22:15	49.94	166477	4848	5030	0	18827	2231	133772	1970	161447	166678	801
22:30	49.99	165627	4838	5116	0	18905	2207	132688	1944	160511	165698	834
22:45	49.99											